

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Milngavie M2

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	49	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	49	4	NTU	0	< 0.30	0.31	1
Odour	49	0	Dilution number	0	0	0	0
Taste	49	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	49	9.5	pH units	0	7.50	7.83	8.50
Aluminium	49	200	µgAl/l	0	12	24.04	39
Iron	49	200	µgFe/l	0	< 6	10.22	49
Manganese	49	50	µgMn/l	0	< 2	2.12	4
Lead	49	10	µgPb/l	0	< 0.30	0.63	8.30
Coliform Bacteria (Total coliforms)	191	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	191	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	49	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	49	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	191		CFU/ml	0	0	0.09	8
Residual Disinfectant - Free	192		mg/l	0	0.22	0.54	0.97
Residual Disinfectant - Total	191		mg/l	0	0.30	0.63	1.02
Conductivity	49	2500	µS/cm	0	50	58.16	174
Chloride	49	250	mgCl/l	0	5	5.98	12
Chlorate	49	0.25	mg/l	0	0.01	0.04	0.08
HAA5 Total	4	60	µg/l	0	18.40	23.20	30.40

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Milngavie M2

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Microcystin LR	4	1	µg/l	0	< 0.05	< 0.05	< 0.05
Sulphate	4	250	mgSO4/l	0	7.30	7.45	7.50
Sodium	4	200	mgNa/l	0	3.80	3.93	4
Nitrate	3	50	mgNO3/l	0	< 0.50	0.71	1.13
Nitrite	4	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	3		Unitless	0	0	0.01	0.02
Ammonium (total)	4	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Copper	4	2	mgCu/l	0	< 0.00	0.00	0.01
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	4	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	4	50	µgCN/l	0	< 1	1	1
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorite	4	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	4	10	µgBrO3/l	0	< 0.90	1.15	1.50

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Milngavie M2

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Total organic carbon	4		mgC/l	0	1	1.13	1.40
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Tetrachloro methane	4	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	4	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	4	100	µg/l	0	24.40	34.08	39.70
1_2 Dichloroethane	4	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	4	1	µg/l	0	< 0.08	< 0.08	< 0.08
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Pesticides - Total Substances	4	0.5	µg/l	0	0	0	0
	2			0	< 0.01	< 0.01	< 0.01
	2			0	< 0.01	< 0.01	< 0.01