

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Milngavie M3

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	40	20	mg/l Pt/Co	0	< 2	2	2
Turbidity	40	4	NTU	0	< 0.30	0.30	0.30
Odour	40	0	Dilution number	0	0	0	0
Taste	40	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	40	9.5	pH units	2.50	7.50	7.90	9.70
Sulphate	4	250	mgSO4/l	0	8.20	8.30	8.50
Sodium	4	200	mgNa/l	0	3.80	4	4.10
Aluminium	40	200	µgAl/l	2.50	10	27.58	239
Iron	40	200	µgFe/l	0	< 6	16.43	125
Manganese	40	50	µgMn/l	0	< 2	2.28	7
Cyanide	4	50	µgCN/l	0	< 1	1	1
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Lead	40	10	µgPb/l	0	< 0.30	0.35	1.20
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Coliform Bacteria (Total coliforms)	156	0	CFU/100ml	0.64	0	0.01	2
E. coli (Faecal coliforms)	156	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	40	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	40	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	155		CFU/ml	0	0	0.90	57

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Milngavie M3

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Residual Disinfectant - Free	156		mg/l	0	< 0.04	0.56	1.20
Residual Disinfectant - Total	156		mg/l	0	0.12	0.64	1.31
Conductivity	40	2500	µS/cm	0	51	54.95	64
Chloride	40	250	mgCl/l	0	5	5.80	7
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorate	40	0.25	mg/l	0	0.02	0.05	0.10
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	4	1	µg/l	0	< 0.05	< 0.05	< 0.05
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Nitrate	4	50	mgNO3/l	0	< 0.50	0.65	0.85
Nitrite	4	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	4		Unitless	0	0	0.01	0.02
Ammonium (total)	4	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Copper	4	2	mgCu/l	0	0.00	0.01	0.01
Arsenic	4	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	4	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Milngavie M3

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
HAA5 Total	4	60	µg/l	0	18.40	21.95	24.90
Total organic carbon	4		mgC/l	0	1	1.15	1.20
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Tetrachloro methane	4	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	4	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	4	100	µg/l	0	21.30	30.58	36.70
Chlorite	4	0.25	mg/l	0	< 0.02	0.02	0.02
1_2 Dichloroethane	4	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	4	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	4	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Pesticides - Total Substances	4	0.5	µg/l	0	0	0	0
	2			0	< 0.01	< 0.01	< 0.01
	2			0	< 0.01	< 0.01	< 0.01