

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Milngavie M4c

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	31	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	31	4	NTU	0	< 0.30	0.30	0.30
Odour	31	0	Dilution number	0	0	0	0
Taste	31	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	31	9.5	pH units	0	7.30	7.75	8.10
Sulphate	3	250	mgSO ₄ /l	0	7.70	8.23	8.60
Sodium	3	200	mgNa/l	0	3.90	4.10	4.30
Aluminium	30	200	µgAl/l	0	10	22.23	39
Iron	30	200	µgFe/l	0	< 6	12.83	50
Manganese	30	50	µgMn/l	0	< 2	2	2
Copper	3	2	mgCu/l	0	< 0.00	< 0.00	< 0.00
Arsenic	3	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	3	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	3	50	µgCN/l	0	< 1	1	1
Chromium	3	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	3	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	3	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Lead	31	10	µgPb/l	0	< 0.30	0.37	1.30
Antimony	3	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	3	10	µgSe/l	0	< 1.20	< 1.20	< 1.20

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Milngavie M4c

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Coliform Bacteria (Total coliforms)	120	0	CFU/100ml	0.83	0	0.01	1
E. coli (Faecal coliforms)	120	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	31	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	31	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	120		CFU/ml	0	0	1.69	159
Residual Disinfectant - Free	121		mg/l	0	0.15	0.59	0.87
Residual Disinfectant - Total	121		mg/l	0	0.32	0.67	1.07
Conductivity	31	2500	µS/cm	0	51	55.32	66
Chloride	31	250	mgCl/l	0	5	5.90	7
Boron	3	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorate	31	0.25	mg/l	0	0.02	0.05	0.11
Gross Alpha Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	3	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Fluoride	3	1.5	mgF/l	0	< 0.12	0.24	0.48
Pesticides - Total Substances	6	0.5	µg/l	0	0	0	0
Chlorite	3	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	3	60	µg/l	0	17.30	20.43	22.50
Bromate	3	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Dicamba	4	0.1	µg/l	0	< 0.01	< 0.01	< 0.01

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Milngavie M4c

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Nitrate	3	50	mgNO3/l	0	< 0.50	0.67	0.79
Nitrite	3	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	3		Unitless	0	0	0.01	0.02
Ammonium (total)	3	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
BISPHENOL A	3	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Total organic carbon	3		mgC/l	0	1.20	1.20	1.20
PAH - Sum Of 4 Substances	3	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	3	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Tetrachloro methane	3	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	3	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	3	100	µg/l	0	27.90	31.07	33.90
1_2 Dichloroethane	3	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	3	1	µg/l	0	< 0.08	< 0.08	< 0.08
Microcystin LR	3	1	µg/l	0	< 0.05	< 0.05	< 0.05
	2			0	< 0.01	< 0.01	< 0.01
	2			0	< 0.01	< 0.01	< 0.01