

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Milngavie M4d

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	31	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	31	4	NTU	0	< 0.30	0.30	0.40
Odour	31	0	Dilution number	0	0	0	0
Taste	31	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	31	9.5	pH units	0	7.40	7.76	8.30
Sulphate	3	250	mgSO ₄ /l	0	7.80	7.93	8
Sodium	3	200	mgNa/l	0	3.70	3.93	4.10
Aluminium	31	200	µgAl/l	0	13	23	38
Iron	31	200	µgFe/l	0	< 6	8.65	30
Manganese	31	50	µgMn/l	0	< 2	2.32	12
Copper	3	2	mgCu/l	0	< 0.00	0.02	0.05
Fluoride	3	1.5	mgF/l	0	< 0.12	0.12	0.13
Arsenic	3	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	3	5	µgCd/l	0	< 0.02	0.02	0.02
Cyanide	3	50	µgCN/l	0	< 1	1	1
Chromium	3	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	3	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	3	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Lead	3	10	µgPb/l	0	< 0.30	< 0.30	< 0.30
Antimony	3	5	µgSb/l	0	< 0.40	< 0.40	< 0.40

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Milngavie M4d

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Selenium	3	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Coliform Bacteria (Total coliforms)	120	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	120	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	31	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	31	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	119		CFU/ml	0	0	0.28	9
Residual Disinfectant - Free	120		mg/l	0	< 0.04	0.60	0.85
Residual Disinfectant - Total	120		mg/l	0	0.05	0.67	0.93
Conductivity	31	2500	µS/cm	0	51	54.71	63
Chloride	31	250	mgCl/l	0	5	5.90	7
Boron	3	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorate	3	0.25	mg/l	0	0.02	0.04	0.07
Chlorite	3	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	3	10	µgBrO3/l	0	< 0.90	1.30	1.90
Gross Alpha Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	3	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Total organic carbon	3		mgC/l	0	1.10	1.17	1.20
PAH - Sum Of 4 Substances	3	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	3	0.01	µg/l	0	< 0.00	< 0.00	< 0.00

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Milngavie M4d

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Tetrachloro methane	3	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	3	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	3	100	µg/l	0	26	31.27	38.60
HAA5 Total	3	60	µg/l	0	16	19	22.80
1_2 Dichloroethane	3	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	3	1	µg/l	0	< 0.08	< 0.08	< 0.08
Nitrate	3	50	mgNO3/l	0	< 0.50	0.86	1.15
Nitrite	3	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	3		Unitless	0	0	0.01	0.02
Ammonium (total)	3	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Microcystin LR	3	1	µg/l	0	< 0.05	< 0.05	< 0.05
BISPHENOL A	3	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Pesticides - Total Substances	3	0.5	µg/l	0	0	0	0
	2			0	< 0.01	< 0.01	< 0.01
	2			0	< 0.01	< 0.01	< 0.01