

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Milngavie M5 Drumchapel South

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	37	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	37	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	37	0	Dilution number	0	0	0	0
Taste	37	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	37	9.5	pH units	0	7.30	7.77	8.40
Aluminium	36	200	µgAl/l	0	11	23.92	42
Iron	36	200	µgFe/l	0	< 6	8.58	36
Manganese	36	50	µgMn/l	0	< 2	2	2
Coliform Bacteria (Total coliforms)	144	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	144	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	37	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	37	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	143		CFU/ml	0	0	0.19	6
Residual Disinfectant - Free	145		mg/l	0	< 0.04	0.59	0.95
Residual Disinfectant - Total	145		mg/l	0	0.08	0.67	1.12
Conductivity	37	2500	µS/cm	0	50	53.32	59
Chloride	37	250	mgCl/l	0	5	5.86	6
HAA5 Total	4	60	µg/l	0	15.90	18.53	21.50
Microcystin LR	4	1	µg/l	0	< 0.05	< 0.05	< 0.05
BISPHENO L A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Milngavie M5 Drumchapel South

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Sulphate	4	250	mgSO4/l	0	7.40	7.68	8.10
Sodium	4	200	mgNa/l	0	3.80	3.98	4.10
Nitrate	4	50	mgNO3/l	0	< 0.50	0.67	1
Nitrite	4	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	4		Unitless	0	0	0.01	0.02
Ammonium (total)	4	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Total organic carbon	4		mgC/l	0	1.10	1.20	1.30
Copper	4	2	mgCu/l	0	< 0.00	0.00	0.00
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	4	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	4	50	µgCN/l	0	< 1	1	1
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Lead	4	10	µgPb/l	0	< 0.30	< 0.30	< 0.30
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Tetrachloro methane	4	3	µg/l	0	< 0.08	< 0.08	< 0.08

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Milngavie M5 Drumchapel South

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	4	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	4	100	µg/l	0	23.90	33.13	40.90
Chlorate	4	0.25	mg/l	0	0.02	0.04	0.05
Chlorite	4	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
1_2 Dichloroethane	4	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	4	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	4	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Pesticides - Total Substances	4	0.5	µg/l	0	0	0	0
	2			0	< 0.01	< 0.01	< 0.01
	2			0	< 0.01	< 0.01	< 0.01