

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Muirdykes

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	76	20	mg/l Pt/Co	0	< 2	2	2
Turbidity	76	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	76	0	Dilution number	0	0	0	0
Taste	76	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	76	9.5	pH units	0	7.80	8.32	8.80
Total organic carbon	76		mgC/l	0	1.40	1.75	2.20
Aluminium	76	200	µgAl/l	0	< 8	18.32	62
Iron	76	200	µgFe/l	0	< 6	9.05	40
Manganese	76	50	µgMn/l	0	< 2	2.04	3
Cyanide	76	50	µgCN/l	0	< 1	1.01	2
Lead	76	10	µgPb/l	0	< 0.30	0.49	3.90
PAH - Sum Of 4 Substances	5	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Coliform Bacteria (Total coliforms)	204	0	CFU/100ml	0.49	0	0.02	5
E. coli (Faecal coliforms)	204	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	76	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	76	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	203		CFU/ml	0	0	1.41	76
Residual Disinfectant - Free	205		mg/l	0	< 0.04	0.57	1.05
Residual Disinfectant - Total	205		mg/l	0	0.04	0.66	1.24
Conductivity	76	2500	µS/cm	0	126	140.97	151

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Muirdykes

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Chloride	76	250	mgCl/l	0	11	13.95	16
Benzo 3_4 Pyrene	5	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Tetrachloro methane	75	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Tric hloroethene - Sum Of 2 Substances	75	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalometh anes	75	100	µg/l	0	29.80	52.06	79.70
HAA5 Total	76	60	µg/l	0	10.10	23.24	35.30
1_2 Dichloroeth ane	75	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	75	1	µg/l	0	< 0.08	< 0.08	< 0.08
Microcystin LR	76	1	µg/l	0	< 0.05	< 0.05	< 0.05
BISPHENO L A	5	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Sulphate	5	250	mgSO4/l	0	18.60	19.78	20.90
Sodium	5	200	mgNa/l	0	16	17.84	18.60
Nitrate	5	50	mgNO3/l	0	< 0.50	1.07	1.66
Nitrite	5	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrat e formula	5		Unitless	0	0	0.02	0.03
Ammonium (total)	5	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Copper	5	2	mgCu/l	0	< 0.00	0.01	0.02
Fluoride	5	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	5	10	µgAs/l	0	< 0.20	0.20	0.20
Cadmium	5	5	µgCd/l	0	< 0.02	< 0.02	< 0.02

Scottish Water**Water Register****Date range of sample: 01/01/2025 to 31/12/2025****Regulation Zone = Muirdykes**

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Chromium	5	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	5	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	5	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	5	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	5	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	5	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorate	5	0.25	mg/l	0	0.04	0.09	0.13
Chlorite	5	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	5	10	µgBrO3/l	0	< 0.90	0.96	1.20
Gross Alpha Activity	5		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	5		Bq/l	0	< 0.04	0.04	0.05
Uranium	5	30	µgU/l	0	< 0.04	< 0.04	< 0.04