

**Scottish Water**

**Water Register**

**Date range of sample: 01/01/2025 to 31/12/2025**

**Regulation Zone = Newmore**

Page 1 of 3

| Parameter Name                                         | No. of Results | PCV  | Units of Measure        | Results Failing PCV (%) | Min    | Mean   | Max    |
|--------------------------------------------------------|----------------|------|-------------------------|-------------------------|--------|--------|--------|
| Colour                                                 | 10             | 20   | mg/l Pt/Co              | 0                       | < 2    | 2      | 2      |
| Turbidity                                              | 10             | 4    | NTU                     | 0                       | < 0.30 | 0.30   | 0.30   |
| Odour                                                  | 10             | 0    | Dilution number         | 0                       | 0      | 0      | 0      |
| Taste                                                  | 10             | 0    | Dilution number         | 0                       | 0      | 0      | 0      |
| Hydrogen ion (pH)                                      | 10             | 9.5  | pH units                | 0                       | 7.20   | 7.72   | 8.20   |
| Nitrite                                                | 10             | 0.5  | mgNO <sub>2</sub> /l    | 0                       | < 0.02 | < 0.02 | < 0.02 |
| Ammonium (total)                                       | 10             | 0.5  | mg/l as NH <sub>4</sub> | 0                       | 0.18   | 0.27   | 0.34   |
| Total organic carbon                                   | 2              |      | mgC/l                   | 0                       | 1.20   | 1.35   | 1.50   |
| Aluminium                                              | 10             | 200  | µgAl/l                  | 0                       | 24     | 42.60  | 60     |
| Iron                                                   | 10             | 200  | µgFe/l                  | 0                       | < 6    | 11.30  | 23     |
| Manganese                                              | 10             | 50   | µgMn/l                  | 0                       | < 2    | < 2    | < 2    |
| Lead                                                   | 10             | 10   | µgPb/l                  | 0                       | < 0.30 | 0.50   | 2.30   |
| Coliform Bacteria (Total coliforms)                    | 36             | 0    | CFU/100ml               | 0                       | 0      | 0      | 0      |
| E. coli (Faecal coliforms)                             | 36             | 0    | CFU/100ml               | 0                       | 0      | 0      | 0      |
| Enterococci (Faecal streptococci)                      | 10             | 0    | CFU/100ml               | 0                       | 0      | 0      | 0      |
| Clostridium perfringens (Sulphite Reducing Clostridia) | 10             | 0    | CFU/100ml               | 0                       | 0      | 0      | 0      |
| Colony Counts After 3 Days At 22°C                     | 36             |      | CFU/ml                  | 0                       | 0      | 0.25   | 7      |
| Residual Disinfectant - Free                           | 36             |      | mg/l                    | 0                       | < 0.04 | 0.06   | 0.10   |
| Residual Disinfectant - Total                          | 36             |      | mg/l                    | 0                       | 0.66   | 0.95   | 1.25   |
| Conductivity                                           | 10             | 2500 | µS/cm                   | 0                       | 85     | 105.20 | 172    |

**Scottish Water**

**Water Register**

**Date range of sample: 01/01/2025 to 31/12/2025**

**Regulation Zone = Newmore**

Page 2 of 3

| Parameter Name                                           | No. of Results | PCV  | Units of Measure | Results Failing PCV (%) | Min    | Mean   | Max    |
|----------------------------------------------------------|----------------|------|------------------|-------------------------|--------|--------|--------|
| Chloride                                                 | 10             | 250  | mgCl/l           | 0                       | 7      | 8.60   | 10     |
| Tetrachloro methane                                      | 2              | 3    | µg/l             | 0                       | < 0.08 | < 0.08 | < 0.08 |
| Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances | 2              | 10   | µg/l             | 0                       | < 0.52 | < 0.52 | < 0.52 |
| Total Trihalomethanes                                    | 2              | 100  | µg/l             | 0                       | 14.90  | 15.30  | 15.70  |
| Chlorite                                                 | 10             | 0.25 | mg/l             | 0                       | < 0.02 | < 0.02 | < 0.02 |
| HAA5 Total                                               | 2              | 60   | µg/l             | 0                       | 10.70  | 12.30  | 13.90  |
| 1_2 Dichloroethane                                       | 2              | 3    | µg/l             | 0                       | < 0.09 | < 0.09 | < 0.09 |
| Benzene                                                  | 2              | 1    | µg/l             | 0                       | < 0.08 | < 0.08 | < 0.08 |
| Bromate                                                  | 10             | 10   | µgBrO3/l         | 0                       | < 0.90 | < 0.90 | < 0.90 |
| Microcystin LR                                           | 2              | 1    | µg/l             | 0                       | < 0.05 | < 0.05 | < 0.05 |
| BISPHENOL A                                              | 2              | 2.5  | µg/l             | 0                       | < 0.13 | < 0.13 | < 0.13 |
| Sulphate                                                 | 2              | 250  | mgSO4/l          | 0                       | 22     | 24.15  | 26.30  |
| Sodium                                                   | 2              | 200  | mgNa/l           | 0                       | 16.90  | 17.80  | 18.70  |
| Nitrate                                                  | 2              | 50   | mgNO3/l          | 0                       | 0.71   | 0.81   | 0.91   |
| Nitrite/Nitrate formula                                  | 2              |      | Unitless         | 0                       | 0.01   | 0.02   | 0.02   |
| Copper                                                   | 2              | 2    | mgCu/l           | 0                       | 0.01   | 0.01   | 0.02   |
| Fluoride                                                 | 2              | 1.5  | mgF/l            | 0                       | < 0.12 | < 0.12 | < 0.12 |
| Arsenic                                                  | 2              | 10   | µgAs/l           | 0                       | < 0.20 | < 0.20 | < 0.20 |
| Cadmium                                                  | 2              | 5    | µgCd/l           | 0                       | < 0.02 | < 0.02 | < 0.02 |
| Cyanide                                                  | 2              | 50   | µgCN/l           | 0                       | 2      | 2.50   | 3      |

**Scottish Water****Water Register****Date range of sample: 01/01/2025 to 31/12/2025****Regulation Zone = Newmore**

Page 3 of 3

| <b>Parameter Name</b>     | <b>No. of Results</b> | <b>PCV</b> | <b>Units of Measure</b> | <b>Results Failing PCV (%)</b> | <b>Min</b> | <b>Mean</b> | <b>Max</b> |
|---------------------------|-----------------------|------------|-------------------------|--------------------------------|------------|-------------|------------|
| Chromium                  | 2                     | 50         | µgCr/l                  | 0                              | < 0.60     | < 0.60      | < 0.60     |
| Mercury                   | 2                     | 1          | µgHg/l                  | 0                              | < 0.02     | < 0.02      | < 0.02     |
| Nickel                    | 2                     | 20         | µgNi/l                  | 0                              | < 0.80     | < 0.80      | < 0.80     |
| Antimony                  | 2                     | 5          | µgSb/l                  | 0                              | < 0.40     | < 0.40      | < 0.40     |
| Selenium                  | 2                     | 10         | µgSe/l                  | 0                              | < 1.20     | < 1.20      | < 1.20     |
| Boron                     | 2                     | 1          | mgB/l                   | 0                              | < 0.02     | < 0.02      | < 0.02     |
| Chlorate                  | 2                     | 0.25       | mg/l                    | 0                              | 0.08       | 0.10        | 0.13       |
| Gross Alpha Activity      | 2                     |            | Bq/l                    | 0                              | < 0.04     | < 0.04      | < 0.04     |
| Gross Beta Activity       | 2                     |            | Bq/l                    | 0                              | < 0.04     | < 0.04      | < 0.04     |
| Uranium                   | 2                     | 30         | µgU/l                   | 0                              | < 0.04     | < 0.04      | < 0.04     |
| PAH - Sum Of 4 Substances | 2                     | 0.1        | µg/l                    | 0                              | < 0.02     | < 0.02      | < 0.02     |
| Benzo 3_4 Pyrene          | 2                     | 0.01       | µg/l                    | 0                              | < 0.00     | < 0.00      | < 0.00     |