

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Pateshill

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	37	20	mg/l Pt/Co	0	< 2	3.14	6
Turbidity	37	4	NTU	0	< 0.30	0.31	0.50
Odour	37	0	Dilution number	0	0	0	0
Taste	37	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	37	9.5	pH units	0	7.30	8.05	8.30
Nitrite	37	0.5	mgNO ₂ /l	0	< 0.02	0.03	0.14
Ammonium (total)	37	0.5	mg/l as NH ₄	0	0.21	0.28	0.36
Total organic carbon	4		mgC/l	0	2.20	2.60	3.10
Aluminium	36	200	µgAl/l	0	8	26.72	83
Iron	36	200	µgFe/l	0	< 6	11.36	49
Manganese	36	50	µgMn/l	0	< 2	2.69	7
Lead	37	10	µgPb/l	0	< 0.30	0.49	3.10
Coliform Bacteria (Total coliforms)	120	0	CFU/100ml	0.83	0	0.01	1
E. coli (Faecal coliforms)	120	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	37	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	37	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	119		CFU/ml	0	0	7.68	300
Residual Disinfectant - Free	120		mg/l	0	< 0.04	0.05	0.50
Residual Disinfectant - Total	120		mg/l	0	0.35	0.90	1.07
Conductivity	37	2500	µS/cm	0	58	141.89	176

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Pateshill

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Chloride	37	250	mgCl/l	0	6	21.81	28
Tetrachloro methane	4	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	4	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	4	100	µg/l	0	21.20	25.18	34.80
Chlorate	37	0.25	mg/l	10.81	0.03	0.11	0.36
HAA5 Total	4	60	µg/l	0	15.30	20.83	27
1_2 Dichloroethane	4	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	4	1	µg/l	0	< 0.08	< 0.08	< 0.08
Microcystin LR	4	1	µg/l	0	< 0.05	< 0.05	< 0.05
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Sulphate	4	250	mgSO4/l	0	3.20	6.20	13.30
Sodium	4	200	mgNa/l	0	4.90	11.58	14.70
Nitrate	4	50	mgNO3/l	0	1.06	2.44	4.50
Nitrite/Nitrate formula	4		Unitless	0	0.02	0.06	0.09
Copper	4	2	mgCu/l	0	< 0.00	0.00	0.01
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	4	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	4	50	µgCN/l	0	< 1	2	3
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60

Scottish Water**Water Register****Date range of sample: 01/01/2025 to 31/12/2025****Regulation Zone = Pateshill**

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorite	4	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	4	10	µgBrO3/l	0	< 0.90	1.05	1.50
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00