

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Penwhapple

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	16	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	16	4	NTU	0	< 0.30	0.30	0.30
Odour	16	0	Dilution number	0	0	0	0
Taste	16	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	16	9.5	pH units	0	7.80	8.06	8.50
Aluminium	16	200	µgAl/l	0	< 8	8.88	12
Iron	16	200	µgFe/l	0	< 6	10.19	59
Manganese	16	50	µgMn/l	0	< 2	2.50	7
Coliform Bacteria (Total coliforms)	24	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	24	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	16	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	16	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	24		CFU/ml	0	0	0	0
Residual Disinfectant - Free	24		mg/l	0	0.26	0.51	0.78
Residual Disinfectant - Total	24		mg/l	0	0.32	0.59	0.84
Conductivity	16	2500	µS/cm	0	159	172.25	186
Chloride	16	250	mgCl/l	0	13	15.06	17
Sulphate	2	250	mgSO4/l	0	36.10	36.40	36.70
Sodium	2	200	mgNa/l	0	7.20	7.45	7.70
Total organic carbon	16		mgC/l	0	1.60	2.03	2.70

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Penwhapple

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Copper	2	2	mgCu/l	0	0.01	0.01	0.01
Arsenic	2	10	µgAs/l	0	< 0.20	0.20	0.20
Cadmium	2	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	16	50	µgCN/l	0	< 1	1	1
Chromium	2	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	2	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	2	20	µgNi/l	0	< 0.80	0.90	1
Lead	16	10	µgPb/l	0	< 0.30	0.31	0.40
Antimony	2	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	2	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	2	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Tetrachloro methane	16	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	16	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	16	100	µg/l	0	35.80	49.59	79.50
HAA5 Total	15	60	µg/l	0	18.70	26.23	38.80
1_2 Dichloroethane	16	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	16	1	µg/l	0	< 0.08	< 0.08	< 0.08
Gross Alpha Activity	2		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	2		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	2	30	µgU/l	0	< 0.04	< 0.04	< 0.04

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Penwhapple

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
BISPHENOL A	2	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
PAH - Sum Of 4 Substances	2	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	2	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Fluoride	2	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Chlorate	2	0.25	mg/l	0	< 0.01	< 0.01	< 0.01
Chlorite	2	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	2	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Microcystin LR	2	1	µg/l	0	< 0.05	< 0.05	< 0.05
Nitrate	2	50	mgNO3/l	0	< 0.50	< 0.50	< 0.50
Nitrite	2	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	2		Unitless	0	0	0	0
Ammonium (total)	2	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04