

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Rosebery B

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	25	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	25	4	NTU	0	< 0.30	0.30	0.30
Odour	25	0	Dilution number	0	0	0	0
Taste	25	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	25	9.5	pH units	0	7.80	8.34	8.70
Total organic carbon	25		mgC/l	0	1	1.23	1.40
Aluminium	25	200	µgAl/l	0	< 8	10.84	15
Iron	25	200	µgFe/l	0	< 6	16.56	194
Manganese	25	50	µgMn/l	0	< 2	2.40	7
Cyanide	25	50	µgCN/l	0	< 1	1	1
Lead	25	10	µgPb/l	0	< 0.30	0.34	0.80
Coliform Bacteria (Total coliforms)	95	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	95	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	25	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	25	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	95		CFU/ml	0	0	0.03	1
Residual Disinfectant - Free	96		mg/l	0	0.06	0.46	0.66
Residual Disinfectant - Total	96		mg/l	0	0.23	0.54	0.97
Conductivity	25	2500	µS/cm	0	74	80	88
Chloride	25	250	mgCl/l	0	11	11.92	13

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Rosebery B

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Tetrachloro methane	25	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	25	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	25	100	µg/l	0	7.50	29.82	42
Chlorite	24	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	25	60	µg/l	0	5.80	13.52	22.40
1_2 Dichloroethane	25	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	25	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	24	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Microcystin LR	25	1	µg/l	0	< 0.05	< 0.05	< 0.05
PAH - Sum Of 4 Substances	3	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	3	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Sulphate	3	250	mgSO4/l	0	2.30	2.37	2.40
Sodium	3	200	mgNa/l	0	8.60	9.17	9.60
Nitrate	3	50	mgNO3/l	0	< 0.50	0.81	0.98
Nitrite	3	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	3		Unitless	0	0	0.01	0.02
Ammonium (total)	3	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Copper	3	2	mgCu/l	0	< 0.00	0.00	0.00
Fluoride	3	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	3	10	µgAs/l	0	< 0.20	< 0.20	< 0.20

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Rosebery B

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Cadmium	3	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Chromium	3	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	3	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	3	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	3	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	3	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	3	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorate	3	0.25	mg/l	0	< 0.01	< 0.01	< 0.01
Gross Alpha Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	3	30	µgU/l	0	< 0.04	< 0.04	< 0.04
BISPHENO L A	3	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Pesticides - Total Substances	3	0.5	µg/l	0	0	0.01	0.03
	2			0	< 0.01	0.02	0.03
	2			0	< 0.01	< 0.01	< 0.01