

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Rosebery Castle Moffat

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	16	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	16	4	NTU	0	< 0.30	0.31	0.40
Odour	16	0	Dilution number	0	0	0	0
Taste	16	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	16	9.5	pH units	0	7.70	7.91	8.50
Sulphate	2	250	mgSO4/l	0	27.20	27.70	28.20
Sodium	2	200	mgNa/l	0	7.30	7.85	8.40
Total organic carbon	16		mgC/l	0	1	1.42	2
Aluminium	16	200	µgAl/l	0	12	18.81	31
Iron	16	200	µgFe/l	0	< 6	29.06	128
Manganese	16	50	µgMn/l	0	< 2	4.19	14
Cyanide	16	50	µgCN/l	0	< 1	1	1
Mercury	2	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	2	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Lead	16	10	µgPb/l	0	< 0.30	0.45	1.70
PAH - Sum Of 4 Substances	2	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Coliform Bacteria (Total coliforms)	59	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	59	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	16	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	16	0	CFU/100ml	0	0	0	0

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Rosebery Castle Moffat

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colony Counts After 3 Days At 22øc	60		CFU/ml	0	0	3.15	189
Residual Disinfectant - Free	60		mg/l	0	0.09	0.54	0.91
Residual Disinfectant - Total	60		mg/l	0	0.17	0.61	0.97
Conductivity	16	2500	µS/cm	0	163	185.44	206
Chloride	16	250	mgCl/l	0	12	12.81	13
Boron	2	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	2	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Tetrachloro methane	16	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Tric hloroethene - Sum Of 2 Substances	16	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalometh anes	16	100	µg/l	0	32	41.23	53.90
HAA5 Total	16	60	µg/l	0	15.40	26.17	44.70
1_2 Dichloroeth ane	16	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	16	1	µg/l	0	< 0.08	< 0.08	< 0.08
Gross Alpha Activity	2		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	2		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	2	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	16	1	µg/l	0	< 0.05	< 0.05	< 0.05
BISPHENO L A	2	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Copper	2	2	mgCu/l	0	0.00	0.00	0.00
Fluoride	2	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Rosebery Castle Moffat

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Arsenic	2	10	µgAs/l	0	< 0.20	0.25	0.30
Cadmium	2	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Chromium	2	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Antimony	2	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	2	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Chlorate	2	0.25	mg/l	0	< 0.01	< 0.01	< 0.01
Chlorite	2	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	2	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Nitrate	2	50	mgNO3/l	0	0.92	1.13	1.34
Nitrite	2	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	2		Unitless	0	0.02	0.03	0.03
Ammonium (total)	2	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Pesticides - Total Substances	2	0.5	µg/l	0	0	0	0
	1			0	< 0.01	< 0.01	< 0.01
	1			0	< 0.01	< 0.01	< 0.01