

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Spynie

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	25	20	mg/l Pt/Co	0	< 2	2.36	4
Turbidity	25	4	NTU	0	< 0.30	0.36	0.80
Odour	25	0	Dilution number	0	0	0	0
Taste	25	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	25	9.5	pH units	0	7.80	7.99	8.10
Nitrite	25	0.5	mgNO ₂ /l	0	< 0.02	0.08	0.29
Ammonium (total)	25	0.5	mg/l as NH ₄	0	0.14	0.27	0.34
Total organic carbon	25		mgC/l	0	1.40	1.90	2.50
Aluminium	25	200	µgAl/l	0	< 8	11.56	23
Iron	25	200	µgFe/l	0	22	58.60	184
Manganese	25	50	µgMn/l	0	3	5.16	14
Cyanide	25	50	µgCN/l	0	< 1	2.84	6
Lead	25	10	µgPb/l	0	< 0.30	0.66	8.20
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	0.03
Coliform Bacteria (Total coliforms)	96	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	96	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	25	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	25	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	97		CFU/ml	0	0	0.47	14
Residual Disinfectant - Free	97		mg/l	0	< 0.04	0.05	0.10

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Spynie

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Residual Disinfectant - Total	97		mg/l	0	0.39	1.05	1.43
Conductivity	25	2500	µS/cm	0	199	242.96	276
Chloride	25	250	mgCl/l	0	12	15.12	17
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	0.00
Tetrachloro methane	25	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	25	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	25	100	µg/l	0	22.50	32.24	45.70
Chlorate	25	0.25	mg/l	4	0.02	0.10	0.31
HAA5 Total	25	60	µg/l	0	18	24.62	37.20
1_2 Dichloroethane	25	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	25	1	µg/l	0	< 0.08	< 0.08	< 0.08
Microcystin LR	25	1	µg/l	0	< 0.05	< 0.05	< 0.05
BISPHENOL A	3	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Sulphate	3	250	mgSO4/l	0	37.10	51.90	65.30
Sodium	3	200	mgNa/l	0	8.60	9.77	11.10
Nitrate	3	50	mgNO3/l	0	2.65	4.20	5.62
Nitrite/Nitrate formula	3		Unitless	0	0.05	0.10	0.13
Copper	3	2	mgCu/l	0	< 0.00	0.00	0.00
Fluoride	3	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	3	10	µgAs/l	0	< 0.20	0.20	0.20

Scottish Water**Water Register****Date range of sample: 01/01/2025 to 31/12/2025****Regulation Zone = Spynie**

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Cadmium	3	5	µgCd/l	0	0.02	0.02	0.02
Chromium	3	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	3	1	µgHg/l	0	< 0.02	0.05	0.12
Nickel	3	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	3	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	3	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	3	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorite	3	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	3	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	3		Bq/l	0	< 0.04	0.04	0.04
Uranium	3	30	µgU/l	0	0.04	0.05	0.06