

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Stornoway Western Isles

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	13	20	mg/l Pt/Co	0	< 2	2.46	4
Turbidity	13	4	NTU	0	< 0.30	0.30	0.30
Odour	13	0	Dilution number	0	0	0	0
Taste	13	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	13	9.5	pH units	0	7.80	8.26	8.50
Nitrite	13	0.5	mgNO ₂ /l	0	< 0.02	< 0.02	< 0.02
Ammonium (total)	13	0.5	mg/l as NH ₄	0	0.22	0.29	0.34
Total organic carbon	13		mgC/l	0	1	1.84	2.60
Aluminium	13	200	µgAl/l	0	11	17.23	28
Iron	13	200	µgFe/l	0	7	15.15	61
Manganese	13	50	µgMn/l	0	< 2	2.31	4
Cyanide	13	50	µgCN/l	0	< 1	3.15	6
Lead	13	10	µgPb/l	0	< 0.30	0.54	3.40
Coliform Bacteria (Total coliforms)	35	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	35	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	13	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	13	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22°C	36		CFU/ml	0	0	0	0
Residual Disinfectant - Free	36		mg/l	0	< 0.04	0.08	0.17
Residual Disinfectant - Total	36		mg/l	0	0.75	1.13	1.32

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Stornoway Western Isles

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Conductivity	13	2500	µS/cm	0	145	176.85	207
Chloride	13	250	mgCl/l	0	27	29.46	32
Tetrachloro methane	14	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	14	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	13	100	µg/l	0	20.90	37.85	58
Chlorite	13	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	12	60	µg/l	0	12.50	22.31	33.30
1_2 Dichloroethane	14	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	14	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	13	10	µgBrO3/l	0	< 0.90	0.92	1.20
Microcystin LR	2	1	µg/l	0	< 0.05	< 0.05	< 0.05
BISPHENOL A	2	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Nitrate	2	50	mgNO3/l	0	< 0.50	0.63	0.75
Nitrite/Nitrate formula	2		Unitless	0	0	0.01	0.02
Sulphate	2	250	mgSO4/l	0	16.40	21.15	25.90
Sodium	2	200	mgNa/l	0	30.20	34.55	38.90
Copper	2	2	mgCu/l	0	< 0.00	0.01	0.02
Fluoride	2	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	2	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	2	5	µgCd/l	0	< 0.02	< 0.02	< 0.02

Scottish Water**Water Register****Date range of sample: 01/01/2025 to 31/12/2025****Regulation Zone = Stornoway Western Isles**

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Chromium	2	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	2	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	2	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	2	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	2	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
PAH - Sum Of 4 Substances	2	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Boron	2	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	2	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Chlorate	3	0.25	mg/l	0	0.06	0.11	0.14
Gross Alpha Activity	2		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	2		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	2	30	µgU/l	0	< 0.04	< 0.04	< 0.04