

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Tullich

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	22	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	22	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	22	0	Dilution number	0	0	0	0
Taste	22	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	22	9.5	pH units	0	7.70	8.37	8.90
Sulphate	3	250	mgSO ₄ /l	0	28	30.33	33.20
Sodium	3	200	mgNa/l	0	21.80	23	24.20
Nitrate	3	50	mgNO ₃ /l	0	< 0.50	0.57	0.71
Nitrite	3	0.5	mgNO ₂ /l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	3		Unitless	0	0	0.00	0.01
Ammonium (total)	3	0.5	mg/l as NH ₄	0	< 0.04	< 0.04	< 0.04
Total organic carbon	22		mgC/l	0	0.70	1.02	1.40
Aluminium	22	200	µgAl/l	0	< 8	8	8
Iron	22	200	µgFe/l	0	< 6	11.23	57
Manganese	22	50	µgMn/l	0	< 2	2	2
Copper	2	2	mgCu/l	0	0.00	0.01	0.01
Arsenic	2	10	µgAs/l	0	< 0.20	< 0.20	< 0.20
Cadmium	2	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	21	50	µgCN/l	0	< 1	1	1
Chromium	2	50	µgCr/l	0	< 0.60	< 0.60	< 0.60

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Tullich

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Mercury	3	1	µgHg/l	0	< 0.02	< 0.02	< 0.02
Nickel	2	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Lead	20	10	µgPb/l	0	< 0.30	0.36	1.50
Antimony	2	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	2	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Coliform Bacteria (Total coliforms)	37	0	CFU/100ml	2.70	0	0.03	1
E. coli (Faecal coliforms)	37	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	22	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	22	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	37		CFU/ml	0	0	1.68	19
Residual Disinfectant - Free	37		mg/l	0	0.47	0.62	0.84
Residual Disinfectant - Total	37		mg/l	0	0.50	0.68	0.90
Conductivity	22	2500	µS/cm	0	165	173.45	183
Chloride	22	250	mgCl/l	0	15	17.14	18
Boron	3	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Tetrachloro methane	22	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Tric hloroethene - Sum Of 2 Substances	22	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalometh anes	22	100	µg/l	0	14.10	28.62	45.10
Chlorate	22	0.25	mg/l	0	0.03	0.06	0.12
HAA5 Total	22	60	µg/l	0	4.80	9.08	13.40

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Tullich

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
1_2 Dichloroethane	22	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	22	1	µg/l	0	< 0.08	< 0.08	< 0.08
Gross Alpha Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	2	30	µgU/l	0	< 0.04	< 0.04	< 0.04
BISPHENOL A	3	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Microcystin LR	3	1	µg/l	0	< 0.05	< 0.05	< 0.05
Fluoride	3	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
PAH - Sum Of 4 Substances	3	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	3	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
Chlorite	3	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	3	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Pesticides - Total Substances	3	0.5	µg/l	0	0	0	0
	2			0	< 0.01	< 0.01	< 0.01
	2			0	< 0.01	< 0.01	< 0.01