

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Turret A

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	52	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	52	4	NTU	0	< 0.30	< 0.30	< 0.30
Odour	52	0	Dilution number	0	0	0	0
Taste	52	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	52	9.5	pH units	0	7.50	7.86	8.50
Total organic carbon	52		mgC/l	0	0.90	1.10	1.40
Aluminium	51	200	µgAl/l	0	< 8	19.96	43
Iron	51	200	µgFe/l	0	< 6	12.67	107
Manganese	51	50	µgMn/l	0	< 2	5.35	50
Cyanide	51	50	µgCN/l	0	< 1	1	1
Lead	52	10	µgPb/l	0	< 0.30	0.36	1.10
Coliform Bacteria (Total coliforms)	204	0	CFU/100ml	0.49	0	0.00	1
E. coli (Faecal coliforms)	204	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	52	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	52	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	203		CFU/ml	0	0	0.05	5
Residual Disinfectant - Free	205		mg/l	0	< 0.04	0.62	0.95
Residual Disinfectant - Total	205		mg/l	0	0.05	0.70	1
Conductivity	52	2500	µS/cm	0	61	65.12	73
Chloride	52	250	mgCl/l	0	10	11.38	13

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Turret A

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Tetrachloro methane	52	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	52	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	52	100	µg/l	0	17.50	28.59	43.30
Chlorate	52	0.25	mg/l	0	0.02	0.07	0.14
HAA5 Total	53	60	µg/l	0	7.80	21.00	31.20
1_2 Dichloroethane	52	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	52	1	µg/l	0	< 0.08	< 0.08	< 0.08
Microcystin LR	52	1	µg/l	0	< 0.05	< 0.05	< 0.05
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Sulphate	4	250	mgSO4/l	0	1.50	1.60	1.70
Sodium	4	200	mgNa/l	0	4.90	6.15	7.30
Nitrate	3	50	mgNO3/l	0	< 0.50	0.61	0.71
Nitrite	4	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	3		Unitless	0	0	0.01	0.01
Ammonium (total)	4	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Copper	4	2	mgCu/l	0	< 0.00	0.00	0.01
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	< 0.20	0.23	0.30
Cadmium	4	5	µgCd/l	0	< 0.02	0.02	0.02
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60

Scottish Water**Water Register****Date range of sample: 01/01/2025 to 31/12/2025****Regulation Zone = Turret A**

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Mercury	4	1	µgHg/l	0	< 0.02	0.02	0.02
Nickel	4	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorite	4	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	4	10	µgBrO3/l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
PAH - Sum Of 4 Substances	2	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	2	0.01	µg/l	0	< 0.00	< 0.00	< 0.00