

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Turret B

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	25	20	mg/l Pt/Co	0	< 2	< 2	< 2
Turbidity	25	4	NTU	0	< 0.30	0.30	0.30
Odour	25	0	Dilution number	0	0	0	0
Taste	25	0	Dilution number	0	0	0	0
Hydrogen ion (pH)	25	9.5	pH units	0	7.50	7.77	8.10
Total organic carbon	25		mgC/l	0	0.90	1.16	1.90
Aluminium	25	200	µgAl/l	0	10	22.36	63
Iron	25	200	µgFe/l	0	< 6	9.12	57
Manganese	25	50	µgMn/l	0	< 2	5.76	32
Cyanide	25	50	µgCN/l	0	< 1	1	1
Lead	25	10	µgPb/l	0	< 0.30	0.32	0.70
Coliform Bacteria (Total coliforms)	96	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	96	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	25	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	25	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	96		CFU/ml	0	0	3.22	300
Residual Disinfectant - Free	95		mg/l	0	0.41	0.71	1
Residual Disinfectant - Total	95		mg/l	0	0.49	0.78	1.13
Conductivity	25	2500	µS/cm	0	62	68.08	109
Chloride	25	250	mgCl/l	0	8	11.28	13

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Turret B

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Tetrachloro methane	25	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	25	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	25	100	µg/l	0	17.60	28.49	38.50
Chlorate	25	0.25	mg/l	0	0.03	0.07	0.14
HAA5 Total	25	60	µg/l	0	15.50	22.51	31.50
1_2 Dichloroethane	25	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	24	1	µg/l	0	< 0.08	< 0.08	< 0.08
Microcystin LR	25	1	µg/l	0	< 0.05	< 0.05	< 0.05
Sulphate	3	250	mgSO4/l	0	1.50	1.60	1.80
Sodium	3	200	mgNa/l	0	5.40	6.30	7.50
Nitrate	3	50	mgNO3/l	0	< 0.50	0.69	1.08
Nitrite	3	0.5	mgNO2/l	0	< 0.02	< 0.02	< 0.02
Nitrite/Nitrate formula	3		Unitless	0	0	0.01	0.02
Ammonium (total)	3	0.5	mg/l as NH4	0	< 0.04	< 0.04	< 0.04
Copper	3	2	mgCu/l	0	0.00	0.01	0.03
Fluoride	3	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	3	10	µgAs/l	0	< 0.20	0.23	0.30
Cadmium	3	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Chromium	3	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	3	1	µgHg/l	0	< 0.02	< 0.02	< 0.02

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Turret B

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Nickel	3	20	µgNi/l	0	< 0.80	< 0.80	< 0.80
Antimony	3	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	3	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Boron	3	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Chlorite	3	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
Bromate	3	10	µgBrO3/l	0	< 0.90	1.07	1.40
Gross Alpha Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	3		Bq/l	0	< 0.04	< 0.04	< 0.04
Uranium	3	30	µgU/l	0	< 0.04	< 0.04	< 0.04
PAH - Sum Of 4 Substances	3	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	3	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
BISPHENOL A	3	2.5	µg/l	0	< 0.13	< 0.13	< 0.13