

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Turriff

Page 1 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Colour	46	20	mg/l Pt/Co	0	< 2	2.13	4
Turbidity	46	4	NTU	0	< 0.30	0.31	0.60
Odour	46	0	Dilution number	4.35	0	0.07	2
Taste	46	0	Dilution number	2.17	0	0.04	2
Hydrogen ion (pH)	46	9.5	pH units	0	8	8.50	8.80
Sulphate	4	250	mgSO ₄ /l	0	26	33.38	38.20
Sodium	4	200	mgNa/l	0	25.90	28.55	31.50
Nitrite	46	0.5	mgNO ₂ /l	0	< 0.02	0.04	0.25
Ammonium (total)	46	0.5	mg/l as NH ₄	0	0.19	0.33	0.38
Total organic carbon	45		mgC/l	0	1	1.75	13.60
Aluminium	46	200	µgAl/l	0	< 8	15.26	66
Iron	46	200	µgFe/l	0	< 6	13.93	61
Manganese	47	50	µgMn/l	0	< 2	8.34	24
Copper	4	2	mgCu/l	0	< 0.00	0.00	0.01
Fluoride	4	1.5	mgF/l	0	< 0.12	< 0.12	< 0.12
Arsenic	4	10	µgAs/l	0	< 0.20	0.20	0.20
Cadmium	4	5	µgCd/l	0	< 0.02	< 0.02	< 0.02
Cyanide	46	50	µgCN/l	0	< 1	2.98	5
Chromium	4	50	µgCr/l	0	< 0.60	< 0.60	< 0.60
Mercury	4	1	µgHg/l	0	< 0.02	< 0.02	< 0.02

Scottish Water
Water Register
Date range of sample: 01/01/2025 to 31/12/2025
Regulation Zone = Turriff

Page 2 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
Nickel	4	20	µgNi/l	0	0.80	1.15	1.60
Lead	4	10	µgPb/l	0	< 0.30	< 0.30	< 0.30
Antimony	4	5	µgSb/l	0	< 0.40	< 0.40	< 0.40
Selenium	4	10	µgSe/l	0	< 1.20	< 1.20	< 1.20
Coliform Bacteria (Total coliforms)	180	0	CFU/100ml	0	0	0	0
E. coli (Faecal coliforms)	180	0	CFU/100ml	0	0	0	0
Enterococci (Faecal streptococci)	46	0	CFU/100ml	0	0	0	0
Clostridium perfringens (Sulphite Reducing Clostridia)	46	0	CFU/100ml	0	0	0	0
Colony Counts After 3 Days At 22øc	180		CFU/ml	0	0	4.06	300
Residual Disinfectant - Free	180		mg/l	0	< 0.04	0.05	0.40
Residual Disinfectant - Total	180		mg/l	0	0.51	1.22	1.41
Conductivity	46	2500	µS/cm	0	124	260.48	322
Chloride	46	250	mgCl/l	0	23	26	43
Boron	4	1	mgB/l	0	< 0.02	< 0.02	< 0.02
Tetrachloro methane	46	3	µg/l	0	< 0.08	< 0.08	< 0.08
Tetrachloro ethene/Trichloroethene - Sum Of 2 Substances	46	10	µg/l	0	< 0.52	< 0.52	< 0.52
Total Trihalomethanes	46	100	µg/l	0	12.40	18.03	26.70
Chlorate	46	0.25	mg/l	0	0.03	0.11	0.20
Chlorite	4	0.25	mg/l	0	< 0.02	< 0.02	< 0.02
HAA5 Total	46	60	µg/l	0	< 1.90	10.28	30.60

Scottish Water

Water Register

Date range of sample: 01/01/2025 to 31/12/2025

Regulation Zone = Turriff

Page 3 of 3

Parameter Name	No. of Results	PCV	Units of Measure	Results Failing PCV (%)	Min	Mean	Max
1_2 Dichloroethane	46	3	µg/l	0	< 0.09	< 0.09	< 0.09
Benzene	46	1	µg/l	0	< 0.08	< 0.08	< 0.08
Bromate	4	10	µgBrO ₃ /l	0	< 0.90	< 0.90	< 0.90
Gross Alpha Activity	4		Bq/l	0	< 0.04	< 0.04	< 0.04
Gross Beta Activity	4		Bq/l	0	0.04	0.05	0.06
Uranium	4	30	µgU/l	0	< 0.04	< 0.04	< 0.04
Microcystin LR	46	1	µg/l	0	< 0.05	< 0.05	< 0.05
Nitrate	4	50	mgNO ₃ /l	0	4.69	8.66	14.51
Nitrite/Nitrate formula	4		Unitless	0	0.09	0.18	0.30
PAH - Sum Of 4 Substances	4	0.1	µg/l	0	< 0.02	< 0.02	< 0.02
Benzo 3_4 Pyrene	4	0.01	µg/l	0	< 0.00	< 0.00	< 0.00
BISPHENOL A	4	2.5	µg/l	0	< 0.13	< 0.13	< 0.13
Pesticides - Total Substances	4	0.5	µg/l	0	0	0	0
	2			0	< 0.01	< 0.01	< 0.01
	2			0	< 0.01	< 0.01	< 0.01