Result Summary

Jess Reynolds
California Rural Water Association
1234 North Market Blvd.
Sacramento, CA 95834

Lab Job #: 569165
Location: Fulton Community School & Farm
Date Received: 10/02/26

Sample ID: 493009877 A **Lab ID: 569165-001** **Collected: 10/02/26 06:59**
Matrix: Drinking Water

A - Water Dispenser_Near Entry

569165-001 Analyte	Result	Qual	Units	RL	DF	Chemist
Method: EPA 200.8 Prep Method: 200.8 DirectAnalysis						
Lead	ND		ug/L	1.0	1	EPL

Sample ID: 493009877 B **Lab ID: 569165-002** **Collected: 10/02/26 07:03**
Matrix: Drinking Water

B - Sink Faucet_Near Entry (L)

569165-002 Analyte	Result	Qual	Units	RL	DF	Chemist
Method: EPA 200.8 Prep Method: 200.8 DirectAnalysis						
Lead	ND		ug/L	1.0	1	EPL

Sample ID: 493009877 C **Lab ID: 569165-003** **Collected: 10/02/26 07:05**
Matrix: Drinking Water

C - Sink Faucet_Near Entry (R)

569165-003 Analyte	Result	Qual	Units	RL	DF	Chemist
Method: EPA 200.8 Prep Method: 200.8 DirectAnalysis						
Lead	ND		ug/L	1.0	1	EPL

Sample ID: 493009877 D **Lab ID: 569165-004** **Collected: 10/02/26 07:17**
Matrix: Drinking Water

D - Sink Faucet_Kitchen

569165-004 Analyte	Result	Qual	Units	RL	DF	Chemist
Method: EPA 200.8 Prep Method: 200.8 DirectAnalysis						
Lead	ND		ug/L	1.0	1	EPL

Results for any subcontracted analyses are not included in this summary. Data qualifiers and additional information necessary for the interpretation of the test results are contained in the PDF file and may not be included in this summary.

Result Summary

Sample ID: 493009877 D30	Lab ID: 569165-005	Collected: 10/02/26 07:20
	Matrix: Drinking Water	

D30 - Sink Faucet_Kitchen FLUSHED

569165-005 Analyte	Result	Qual	Units	RL	DF	Chemist
Method: EPA 200.8 Prep Method: 200.8 DirectAnalysis						
Lead	ND		ug/L	1.0	1	EPL

Sample ID: 493009877 E	Lab ID: 569165-006	Collected: 10/02/26 07:09
	Matrix: Drinking Water	

E - Sink Faucet_Classroom 113 (R)

569165-006 Analyte	Result	Qual	Units	RL	DF	Chemist
Method: EPA 200.8 Prep Method: 200.8 DirectAnalysis						
Lead	ND		ug/L	1.0	1	EPL

Sample ID: 493009877 F	Lab ID: 569165-007	Collected: 10/02/26 07:11
	Matrix: Drinking Water	

F - Sink Faucet_Classroom113 (L)

569165-007 Analyte	Result	Qual	Units	RL	DF	Chemist
Method: EPA 200.8 Prep Method: 200.8 DirectAnalysis						
Lead	ND		ug/L	1.0	1	EPL

Sample ID: 493009877 G	Lab ID: 569165-008	Collected: 10/02/26 07:14
	Matrix: Drinking Water	

G - Sink Faucet_Classroom 113 (Far Left)

569165-008 Analyte	Result	Qual	Units	RL	DF	Chemist
Method: EPA 200.8 Prep Method: 200.8 DirectAnalysis						
Lead	ND		ug/L	1.0	1	EPL

ND Not Detected

Results for any subcontracted analyses are not included in this summary. Data qualifiers and additional information necessary for the interpretation of the test results are contained in the PDF file and may not be included in this summary.