C.No:196/DFO/VIJAYANAGAR/FAC/2026

Office of the District Fire Officer
Karnataka State Fire and Emergency Servic
Vijayanagara District Hosapete
Date: 18/09/2026

ANNEXURE-1

(Up to 14.99 mtrs in height)

Group B, Educational Buildings

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

To,

The President
Wisdom Wings English Medium School,
Itagi Road Kotturu,
Kotturu Taluk, Vijayanagara Dist.

Sub: Issue of **"Fire Advise certificate"** to **"Wisdom Wings English Medium School"** Under the ages of Taata Education Trust (R) Bannigola Located at Itagi Road Kotturu, Kotturu Taluk, Vijayanagara Dist.

Ref: 01) No.94/FSO/Kotturu/2026 Date:17/09/2026 . Inspection Report by Fire Station Officer, Kotturu.

02) Applicant Request Letter Dated: 16/09/2026.

******

With reference to the subject above cited, the premises of **"Wisdom Wings English Medium School"** Under the ages of Taata Education Trust(R) Bannigola Located at Itagi Road Kotturu, Kotturu Taluk, Vijayanagara Dist. was inspected by me on Dated:17/09/2026 ith respect to fire prevention, fire fighting and evacuation measures to be complied premises and Submitted building details as under.

A. Details of the Building/Premises:-

01.	Name and Address of the applicant.	:	The President Wisdom Wings English Medium School, Itagi Road Kotturu, Kotturu Taluk, Vijayanagara Dist.
02.	Name and Address of the premises.	:	Wisdom Wings English Medium School, Itagi Road Kotturu, Kotturu Taluk, Vijayanagara Dist
03.	Name and Address of the Building owner.	:	The President Wisdom Wings English Medium School, #779, 3rd Ward, Vidyanagara Kotturu, Kotturu Taluk, Vijayanagara Dist.
04.	School Code:	:	**47452 (CBSCE)**
05.	Number of Buildings	:	01 No Building
06.	Number of floors	:	Ground + 03 Upper floor.
07.	Floor-wise details of occupancy :- (As per Physical Inspection)		
	Ground Floor:	:	Class Room - 05 No's. Principal Room-01 No. Office Room- 01 No. Staff Room- 01 No. Toilet Room- 02 No's.

DISTRICT FIRE OFFICER Vijayanagara Dist. Hosapete Karnataka State Fire and Emergency Services

	First Floor	:	Class Room -04 No's. Library Room - 01 No. Loboratory Room-01 No.
	Second Floor	:	Class Room :05 No's. Toilet Room- 02 No's.
	Third Floor		Class Room - 05 No's.
08.	Height of the building	:	14.70 Mtrs.
09.	Site area	:	3793.00 Sq Mtrs.
10.	Built-up area of each floor :-		
	Ground Floor:	:	388.58 Sq Mtrs.
	First Floor	:	388.58 Sq Mtrs.
	Second Floor	:	388.58 Sq Mtrs.
	Third Floor	:	388.58 Sq Mtrs.
11.	Total built-up area	:	**1554.32 Sq Mtrs.**
12.	Surrounding properties:-		
	East(Front)	:	SY No 90 Agriculture Land.
	West(Rear)	:	SY No 92 Agriculture Land.
	North(Side)	:	09 Mtrs Wide Kotturu to Huvinahadagali Road.
	South(Side)	:	SY No 93 Agriculture Land.
13.	Set back area available around the Building:-		
	East	:	14.00 Mtrs.
	West	:	04.09 Mtrs.
	North	:	15.00 Mtrs.
	South	:	15.00 Mtrs.

B. On inspection of this Educational premises, the following fire prevention, fire fighting and evacuation measures are recommended & are considered absolutely essential from fire safety point of view:-

Sl. No. [01]	Details [02]	Existing [03]			Recommendations [04]
01.	Accessibility to Premises.	The premises is accessible 09 Mtrs wide Kotturu to Huvinahadagali Road at Northern side.			Adequate.
02.	No of entrances.	01 No.			Adequate
03.	Width of entry/exit	Entrence cum exit 05.50 mtrs wide have been Provided from 09 mtr Wide road located on the Northern side. Connected to Kotturu to Huvinahadagali Road.			Adequate.
04.	No. of staircases available.	No of staircase	:	02 No	Adequate.
		Width of staircase	:	01.50 Mtrs. 01.50 Mtrs.	
		Width of treads	:	30.00 Cms. 30.00 Cms.	

DISTRICT FIRE OFFICER ★ Vijayanagara Dist. Hosapete ★ Karnataka State Fire and Emergency Services

		Height of risers	:	15.00 Cms.	15.00 Cms.	
		No of riser per flight	:	11 riser per Flight.	11 riser per flight	
		Height of handrail	:	00.90 Mtrs.	00.90 Mtrs.	
05.	Fire extinguisher	03 No's of ABC extinguishers of kg capacity Provided				The following extinguishers should be provided. 01) 16 No's ABC FE each of 6 kg capacity Each floor, to be installed For Every 100 Sq Mtrs 02) 01 No of CO2 extinguisher of 4.5 kg capacity near the Electrical Switch board. [All the extinguishers suggested above should be with B.I.S. markings and should be located at an easily accessible position without obstructing the normal passage and maintained periodically].
06.	Hose reel hose system.	Provided				01 No of Hose reel hose Required For every 1000 m2 of Built up area and G I Pipe of minimum 63 mm shall be provided.Hose reel hose of minimum 19 mm size of adequate length to reach the farthest point should be provided near the staircase at each floor with a shut off branch having a nozzle of 5 mm size.
07.	At the terrace tank level with minimum pressure of 3.5 kg/cm2	Not Provided.				To Provide 01 No booster pump with minimum pressure of 450 LPM.
08.	Diesel generators	Not Provided.				Recommended to provide

DISTRICT FIRE OFFICER ★ Vijayanagara Dist. Hosapete ★ Karnataka State Fire and Emergency Services

			One Adequate capacity of Diesel Generator and it should be connected to alternate power supply.
09.	Terrace tank.	Not Provided.	To Provide (RCC or FRP) Underground Tank of 10,000 Ltrs capacity required with 450 LPM booster pump .
10.	Escape routes	Not Marked.	Signage board is required with illuminated points for in which direction to go outside from the building for staff & students and also separate light arrangement to the illumination board by doing from battery operated
11.	Fire order (Fire Safety Plans)	Not Displayed.	The Notice board have been indicted the action should be taken by the employees in case of any emergency should be displayed with the telephone number of Kottur Fire Station i.e-08391-226777 & 101, 112 and the telephone number of nearest Ambulance services and Police Station.
12.	No Smoking Board	Not Displayed.	COTPA Sec-4 Direction No Smoking area Smoking hear is an offence Board Should be written in English & Kannada both language Shall be Prominently displayed at inside the Entry/Exist of Each Floor.
13.	Fire Siren	Not Installed.	A fire Siren shall be installed in the premises to inform the inmates in case of a fire emergency/evacuate the area
14.	Nominate one fire Nodal officer	--	A fire nodal officer shall be nominated either from teaching or no teaching staff.
15.	Fire fighting training.	Trained 01. Nagaraja T No:2025073610. 01. Prakash U M No. 2025073609	At-least 40% of School Staff should be got trained in basic fire fighting at R.A.Mundkur fire & Emergency Services Academy, Bannerughatta road, Bangalore within 3

DISTRICT FIRE OFFICER
Vijayanagara Dist. Hosapete
Karnataka State Fire and Emergency Services

capacity of ator and it connected to er supply

		months or at an early date.

16) Fire Precautionary Measures:-

1) Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical cum panel premises.
2) Accumulation of combustible waste in and around the premises should be avoided.
3) The exit ways shall be always kept clear without any Obstruction.
4) Liquefied petroleum gas should not be stored in the building.
5) The doors shall not be kept locked / latched during working hours and shall be free from obstruction.
6) During the class hours the class room doors shall not be locked from inside to outside.
7) As per Honorable supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the fire safety day on 14thaprilof every year by conducting fire safety drills with co-ordinate with fire service department.

Hence, here with recommended to issue **"Fire Advise certificate"** for Preprimary/Primary/High School Building of **"Wisdom Wings English Medium School"** Under the ages of Taata Education Trust(R) Bannigola Located at Itagi Road Kotturu, Kotturu Taluk, Vijayanagara Dist. Subject To Condition And Compliance Of The Above Recommendations In Within 3 Months And Compliance To The Undersigned.

Note:

01 This is only the **"Fire Advise certificate"** issued by the Fire & Emergency Services Department from fire safety view of the low-rise building. This shall not be considered as No Objection Certificate or Fire Advisory Compliance Certificate for the Building.

2. After completion of all the firefighting installations as advised in Fire Advisory Certificate, 'Fire Advisory Compliance Certificate' shall be obtained from the Fire and Emergency department.

This **"Fire Advise certificate"** *is valid for only* ***One Year*** *from the date of issue.*

Yours faithfully,

Date- 18-09-2026.
Place- Hosapete.

District Fire Officer
Karnataka State Fire and Emergency Services
Vijayanagara District Hosapete 583201

Copy: Fire Station Officer, Kotturu.