# GENERAL INSPECTION & SAMPLING CO.

IMPARTIALLY ACCURATE

● Analysts ● Quality Controllers ● Surveyors ● Handling Agent
[an ISO : 9001-2015 Certified Company]
H.O. : Plot No. R-11 : Industrial Estate, Dam Road, Hospet - 583 203.
Ph : 08394 - (O) : 232190. Cell : 9448130803, E-mail : giscohospet@yahoo.com


## TEST CERTIFICATE

| | | | |
|---|---|---|---|
| Test Report Number | **GISCO/WWEMS:G-1386/25-26.** | | |
| Date of sample Received | **02.08.2025.** | Report Date | **05.08.2025.** |
| Name and Address of the Customer | **WISDOM WINGS ENGLISH MEDIUM SCHOOL** | | |
| | **19th Ward SIDDAGANGA NAGARA ITAGI ROAD, KOTTURU-583134.** | | |
| Sample Description | **Water Sample.** | Sample code | **GISCO/08/25/1165.** |
| Sample Mode | **Submitted.** | Package condition/ Any other details | **Received in bottle.Qty: 02 Litre.** |
| Sample Mark | **Filter Water.** | Date of Performance | **02.08.2025 TO 04.08.2025.** |
| Condition of the sample | **Satisfactory.** | | |
| Customer Provided Information | **Customer Name, Address, Sample Description, Sample Mark, Sample Quantity,Test Protocol.** | | |

| SL.NO | PARAMETER | UNITS | RESULTS | STANDARD: IS 10500 2012. | |
|---|---|---|---|---|---|
| | | | | DL | PL |
| 1. | pH | --- | **06.58** | 6.5 to 8.5 | NR |
| 2. | Odour | --- | **Unobjectionable** | --- | --- |
| 3. | Turbidity | NTU | **0.1** | 1 | 5 |
| 4. | E . Conductivity | µ Mhos | **150** | --- | --- |
| 5. | Total Dissolved Solids | mg/l | **90** | 500 | 2000 |
| 6. | Total Hardness | mg/l | **34.2** | 200 | 600 |
| 7. | Total Alkalinity | mg/l | **24** | 200 | 600 |
| 8. | Chlorides (Cl) | mg/l | **20.12** | 250 | 1000 |
| 9. | Sulphates ($SO_4$) | mg/l | **3.24** | 200 | 400 |
| 10. | Calcium (Ca) | mg/l | **5.32** | 75 | 200 |
| 11. | Magnesium (Mg) | mg/l | **5.07** | 30 | 100 |
| 12. | Total Iron (Fe) | mg/l | **0.08** | 0.30 | NR |
| 13. | Flourides (F) | mg/l | **0.24** | 1.0 | 1.5 |
| 14. | Nitrates ($NO_3$) | mg/l | **2.86** | 45 | NR |

For GENERAL INSPECTION & SAMPLING CO.,

AUTHORISED SIGNATORY.

*Note: 1. BDL – Below Desirable Limit, PL – Permissible Limit, NR – No Relaxation.*

***2. Sample not drawn by us.***




1.Sample (s) not drawn by us unless otherwise specified.
2.The remaining portion of the tested samples (Except perishable samples & water) are destroyed after 30 days from the issue of Test Certificate unless otherwise specified
3.This test certificate refer to only applicable parameters of the sample (s) tested and does not opine about the quality of the tested material
4.Without our permission in writing this report shall not be reproduced wholly or in part and shall not be used as an evidence in the court of law or used in any advertising media
5.The liability of our laboratory is limited to the invoiced amount any dispute concerned with this report is subject to the Hospet Jurisdiction only.