Office of the District Fire Officer
Karnataka State Fire and Emergency Service
Vijayanagara District Hosapete 583201

C.NO:202/DFO/VIJAYANAGARA/FACC/2026

Date: 24-09-2026.

**To,**

The President
Wisdom Wings English Medium School,
Itagi Road Kotturu,
Kotturu Taluk, Vijayanagara Dist

**Sub**:- Issue of **"Fire Advise *Compliance Certificate*"** to **"Wisdom Wings English Medium School"** Under the ages of Taata Education Trust (R) Bannigola Located at Itagi Road Kotturu, Kotturu Taluk, Vijayanagara Dist. (**School Code: 47452 CBSCE.**)

**Ref**:-1) C.No:196/DFO/VIJAYANAGARA/FAC/2026 Dated:18/09/2026 Issue by "Fire Advise Certificate" from District Fire Officer Vijayanagara District Hosapete.

2) Ref. No:96/FSO/Kotturu/2026 Dated:24/09/2026 Inspection report By Fire Station Officer Kotturu.

3) Applicant Letter Dated On: 18/09/2026.

**********

With reference to the subject cited above, As per reference (1) of to **"Wisdom Wings English Medium School"** Under the ages of Taata Education Trust (R) Bannigola Located at Itagi Road Kotturu, Kotturu Taluk, Vijayanagara Dist. (**School Code: 47452 CBSCE.**) Fire Safety was inspected by Fire Station Officer Kotturu had from the fire prevention, firefighting system to be installed within 03 Months including training part.

As per reference (2) TheFire Station Officer Kotturu was Inspected the School Building on Dated:22-09-2026 & Submit the Report that the applicant has fulfilled all the Recommendation made in the Recommendation, Fire Station Officer Kotturu checked and found the fire fighting systems are working in good condition during inspection & recommended to issue of "Fire Advise Compliance Certificate" for the same. Subject to Condition That at-least 40% of employees should be trained in basic fire fighting at our R.A. Mundkur Fire & Emergency Academy, Bannerghatta Road, Bengaluru.

Hence here with a issuing ***"Fire Advise Compliance Certificate"*** for your Above said educational building having a height of 14.70 Mtrs. with a Ground + 03 Upper floor, from fire prevention, firefighting and evacuation point of view & Recommended to It is also advised that if at any time the fire protection and fire extinguishing equipment installed as per the recommendations of the department is found to be not in good condition or the safety measures are not strictly followed or any additional structures are constructed in the open area left by law around the said building, or any kind of permanent/temporary obstruction is caused, this Fire Advise Compliance Certificate will be void and further action will be taken within the framework of the law.This

*This "**Fire Advise Compliance Certificate**" is valid for **One year** only. it is renewable*

**Date** :24/09/2026
**Place**: Hosapete.

**Copy**: Fire Station Officer,Kotturu.

Your's faithfully

District Fire Officer
Karnataka State Fire and Emergency Services
Vijayanagara District Hosapete 583201