Monthly Summary Report

Institution: NKSP

Memorandum

Date: 11/01/2024

To: Statewide Heat Plan Coordinator

Subject: Heat Plan Activity - October

The following is a summary of the heat related activity for the month of October

at NKSP (Institution)

1. Were outside temperatures 90 degrees or above (Stage I Alerts)?: Yes

   Number of days Stage I Alert initiated: 9

2. Were cooling and/or hydration measures instituted in housing units reaching 90 degrees or more (Stage II Alert)? No

   Number of days Stage II Alert initiated: 0

3. Were medical rounds performed in housing units reaching 95 degrees or more (Stage III Alert)? No

   Number of days Stage III Alert initiated: 0

4. Weekly list of heat risk patients archived?: Yes

5. Number of patients with heat related illness. 0 List these patients on the Heat Incident Log and include the patients name, CDCR #, list of heat risk medications, Mental Health Services Delivery System designation, description of the symptoms diagnosis at the time of the heat related illness, a brief summary of the medical treatment rendered, where the incident occurred, and the ultimate disposition of the patient. The Heat Incident log shall be submitted each month with the Monthly Summary Report if heat related illnesses have occurred.

Weekly list of Heat-Risk Patients is generated automatically. A hard copy is distributed to the Facility Lieutenants, Classifications and Parole Representative, Food Manager, Outpatient Housing Unit and Mental Health Department. An e-mail copy is distributed to the Litigation Coordinator, Associate Warden, Facility Captains, Prison Industry Authority, Education Staff and Medical Staff.

Inside and Outside Temperature Logs, Medical Rounds Logs, Heat Incident Logs and Weekly lists of Heat-Risk Patients have been collected and are on file and easily accessible in the office of the institution's Heat Plan Coordinator.

Kevin Hixon
Warden Name

Warden Signature

Celia Bell
Chief Executive Officer Name

DocuSigned by:
Celia Bell
3D2A9C88E19B409...
Chief Executive Officer Signature

Unauthorized collection, creation, use, disclosure, modification, or destruction of personally identifiable information and/or protected health information may subject individuals to civil liability under applicable federal and state laws.

DISTRIBUTION: Litigation Coordinator, Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB- I Temp. Reading Location: 2ND TIER A-SECTION
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-14-24	0300	69	D. Hill
	0600	71	Anaya
	0900	73	Anaya
	1200	73	Anaya
	1500	72	B. Wright
	1800	70	B. Wright
	2100	70	B. Wright
	2400	69	D. Hill

Tuesday

Date	Time	Temp.	Name (Print)
10-15-24	0300	68	D. Hill
	0600	68	E. Andrade
	0900	71	E. Andrade
	1200	73	E. Andrade
	1500	72	B. CORRAL
	1800	70	B. CORRAL
	2100	70	B. CORRAL
	2400	69	D. Hill

Wednesday

Date	Time	Temp.	Name (Print)
10-16-24	0300	68	D. Hill
	0600	69	E. Andrade
	0900	71	E. Andrade
	1200	73	E. Andrade
	1500	73	J. Castrejon
	1800	73	J. Castrejon
	2100	73	J. Castrejon
	2400	71	D. Hill

Thursday

Date	Time	Temp.	Name (Print)
10-17-24	0300	69	D. Hill
	0600	70	E. Andrade
	0900	71	E. Andrade
	1200	73	E. Andrade
	1500	74	J. Castrejon
	1800	74	J. Castrejon
	2100	72	J. Castrejon
	2400	69	D. Hill

Friday

Date	Time	Temp.	Name (Print)
10-18-24	0300	67	D. Hill
	0600	69	E. Andrade
	0900	70	E. Andrade
	1200	70	E. Andrade
	1500	66	E. Mendez
	1800	66	E. Mendez
	2100	60	E. Mendez
	2400	61	G. Rios

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	60	G. Rios
	0600	60	M. Pompa
	0900	60	Pompa
	1200	60	Pompa
	1500	62	Mendez
	1800	64	Mendez
	2100	62	Mendez
	2400	60	G. Rios

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	60	G. Rios
	0600	60	Pompa
	0900	60	Pompa
	1200	60	Pompa
	1500	64	N. Rodriguez
	1800	62	N. Rodriguez
	2100	62	N. Rodriguez
	2400	60	G. Rios

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: A-1 (B) Temp. Reading Location: 2nd TIER: ABOVE C/ PEPSI
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-14-24	0300	69	D. Hill
	0600	71	A Anaya
	0900	73	A Anaya
	1200	76	A Anaya
	1500	72	B. Knight
	1800	72	B. Knight
	2100	70	B. Knight
	2400	69	D Hill

Tuesday

Date	Time	Temp.	Name (Print)
10-15-24	0300	68	D Hill
	0600	68	E. Andrade
	0900	71	E. Andrade
	1200	73	E. Andrade
	1500	72	B. CORRAL
	1800	70	B. CORRAL
	2100	70	B. CORRAL
	2400	69	D Hill

Wednesday

Date	Time	Temp.	Name (Print)
10-16-24	0300	68	D Hill
	0600	69	E. Andrade
	0900	71	E. Andrade
	1200	73	E. Andrade
	1500	73	D. Castrejon
	1800	73	D. Castrejon
	2100	73	D. Castrejon
	2400	71	D Hill

Thursday

Date	Time	Temp.	Name (Print)
10-17-24	0300	69	D Hill
	0600	70	E. Andrade
	0900	71	E. Andrade
	1200	73	E. Andrade
	1500	74	D Castrejon
	1800	74	D Castrejon
	2100	72	D Castrejon
	2400	69	D. Hill

Friday

Date	Time	Temp.	Name (Print)
10-18-24	0300	67	D Hill
	0600	69	M. Mena
	0900	70	M. Mena
	1200	69	R Rivas
	1500	66	E MENDEZ
	1800	66	E MENDEZ
	2100	66	E MENDEZ
	2400	69	G Rios

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	60	G Rios
	0600	60	Pompa
	0900	60	Pompa
	1200	60	Pompa
	1500	62	E MENDEZ
	1800	64	E MENDEZ
	2100	62	E MENDEZ
	2400	69	G. Rios

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	60	G Rios
	0600	60	Pompa
	0900	60	Pompa
	1200	60	Pompa
	1500	64	N. Rodriguez
	1800	62	N. Rodriguez
	2100	62	N. Rodriguez
	2400	62	D Hill

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB -2 Temp. Reading Location: 2nd Tier - A Section
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/14	0300	72	J Blanco
	0600	71	[illegible]
	0900	72	[illegible]
	1200	73	R-Lima
	1500	75	O Rubio
	1800	74	O Rubio
	2100	72	O Rubio
	2400	72	J Blanco

Tuesday

Date	Time	Temp.	Name (Print)
10/15	0300	71	J Blanco
	0600	71	R-Lima
	0900	72	R-Lima
	1200	74	R-Lima
	1500	75	O Rubio
	1800	76	O Rubio
	2100	73	O Rubio
	2400	72	J Blanco

Wednesday

Date	Time	Temp.	Name (Print)
10/16	0300	71	J Blanco
	0600	72	R-Lima
	0900	73	R-Lima
	1200	73	R-Lima
	1500	74	O Rubio
	1800	75	O Rubio
	2100	72	O Rubio
	2400	70	Gill

Thursday

Date	Time	Temp.	Name (Print)
10/17	0300	70	Gill
	0600	70	R-Lima
	0900	71	R-Lima
	1200	73	R-Lima
	1500	73	Josan
	1800	72	Josan
	2100	72	Josan
	2400	70	Gill

Friday

Date	Time	Temp.	Name (Print)
10/18	0300	70	Gill
	0600	70	Chan
	0900	70	Chan
	1200	72	Chan
	1500	71	[illegible]
	1800	70	[illegible]
	2100	70	[illegible]
	2400	70	[illegible]

Saturday

Date	Time	Temp.	Name (Print)
10/19	0300	68	J Blanco
	0600	68	Chan
	0900	68	Chan
	1200	70	Chan
	1500	70	R. Knight
	1800	70	R. Knight
	2100	69	R. Knight
	2400	68	J Blanco

Sunday

Date	Time	Temp.	Name (Print)
10/20	0300	66	J Blanco
	0600	64	R-Lima
	0900	65	R-Lima
	1200	67	R-Lima
	1500	69	O Rubio
	1800	69	O Rubio
	2100	67	O Rubio
	2400	67	[illegible]

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: A3 Temp. Reading Location: 2nd Tier A Section
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-14-24	0300	65	Saldana
	0600	65	Saldana
	0900	65	Saldana
	1200	69	Saldana
	1500	72	HINOJOSA
	1800	72	HINOJOSA
	2100	71	HINOJOSA
	2400	76	Reveles

Tuesday

Date	Time	Temp.	Name (Print)
10-15-2024	0300	70	Reveles
	0600	64	CHAN
	0900	64	CHAN
	1200	68	CHAN
	1500	70	R. Borquez
	1800	68	R. Borquez
	2100	68	R. Borquez
	2400	65	LANE

Wednesday

Date	Time	Temp.	Name (Print)
10-16-24	0300	65°	LANE
	0600	65	Pompa
	0900	65	Pompa
	1200	65	Pompa
	1500	70	GRAYSON
	1800	70	GRAYSON
	2100	70	GRAYSON
	2400	67°	LANE

Thursday

Date	Time	Temp.	Name (Print)
10-17-24	0300	66°	LANE
	0600	64	Saldana
	0900	65	Saldana
	1200	68	Saldana
	1500	68	R. Knight
	1800	66	R. Knight
	2100	65	R. Knight
	2400	69°	LANE

Friday

Date	Time	Temp.	Name (Print)
10-18-24	0300	64°	LANE
	0600	60	Saldana
	0900	60	Saldana
	1200	62	Saldana
	1500	63	HINOJOSA
	1800	63	HINOJOSA
	2100	62	HINOJOSA
	2400	65°	LANE

Saturday

Date	Time	Temp.	Name (Print)
10-19-24	0300	60°	LANE
	0600	58	Saldana
	0900	59	Saldana
	1200	60	Saldana
	1500	60	HINOJOSA
	1800	60	HINOJOSA
	2100	60	HINOJOSA
	2400	62°	LANE

Sunday

Date	Time	Temp.	Name (Print)
10-20-24	0300	60°	LANE
	0600	55	Saldana
	0900	59	Saldana
	1200	60	Saldana
	1500	61	HINOJOSA
	1800	61	HINOJOSA
	2100	60	HINOJOSA
	2400	60°	LANE

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: A3 Temp. Reading Location: 2nd Tier B Section
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-14-24	0300	65	Saldaña
	0600	65	Saldaña
	0900	65	Saldaña
	1200	69	Saldaña
	1500	70	HINOJOSA
	1800	70	HINOJOSA
	2100	69	HINOJOSA
	2400	70	Reveles

Tuesday

Date	Time	Temp.	Name (Print)
10.15.24	0300	70	Reveles
	0600	64	CHAN
	0900	64	CHAN
	1200	68	CHAN
	1500	70	R. Borquez
	1800	68	R. Borquez
	2100	68	R. Borquez
	2400	65	LANE

Wednesday

Date	Time	Temp.	Name (Print)
10.16.24	0300	65°	LANE
	0600	65	Pompa
	0900	65	Pompa
	1200	65	Pompa
	1500	70	GRAYSON
	1800	70	GRAYSON
	2100	70	GRAYSON
	2400	67°	LANE

Thursday

Date	Time	Temp.	Name (Print)
10.17.24	0300	66°	LANE
	0600	64	Saldaña
	0900	65	Saldaña
	1200	68	Saldaña
	1500	68	R. Knight
	1800	66	R. Knight
	2100	65	R. Knight
	2400	69°	LANE

Friday

Date	Time	Temp.	Name (Print)
10.18.24	0300	64°	LANE
	0600	60	Saldaña
	0900	60	Saldaña
	1200	61	HINOJOSA
	1500	61	HINOJOSA
	1800	61	HINOJOSA
	2100	61	HINOJOSA
	2400	65°	LANE

Saturday

Date	Time	Temp.	Name (Print)
10.19.24	0300	60°	LANE
	0600	58	Saldaña
	0900	59	Saldaña
	1200	60	Saldaña
	1500	60	HINOJOSA
	1800	60	HINOJOSA
	2100	60	HINOJOSA
	2400	61°	LANE

Sunday

Date	Time	Temp.	Name (Print)
10.20.24	0300	60°	LANE
	0600	55	Saldaña
	0900	59	Saldaña
	1200	60	Saldaña
	1500	60	HINOJOSA
	1800	60	HINOJOSA
	2100	60	HINOJOSA
	2400	60°	LANE

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: A4-A Temp. Reading Location: Dayroom (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-14-2024	0300	75	Reveles
	0600	72	CHAN
	0900	72	CHAN
	1200	74	CHAN
	1500	77	Barza
	1800	74	Barza
	2100	75	Barza
	2400	70	PRICE

Tuesday

Date	Time	Temp.	Name (Print)
10/15/24	0300	70	PRICE
	0600	70	O.Montoya
	0900	70	O.Montoya
	1200	70	O.Montoya
	1500	73	Barza
	1800	73	Barza
	2100	71	Barza
	2400	70	PRICE

Wednesday

Date	Time	Temp.	Name (Print)
10/16/24	0300	70	PRICE
	0600	70	O.Montoya
	0900	70	O.Montoya
	1200	70	O.Montoya
	1500	73	Barza
	1800	73	Barza
	2100	71	Barza
	2400	70	PRICE

Thursday

Date	Time	Temp.	Name (Print)
10/17/24	0300	70	PRICE
	0600	70	O.Montoya
	0900	70	O.Montoya
	1200	70	O.Montoya
	1500	70	Barza
	1800	69	Barza
	2100	69	Barza
	2400	70	PRICE

Friday

Date	Time	Temp.	Name (Print)
10/18/24	0300	70	PRICE
	0600	70	L.Gonzalez
	0900	70	L.Gonzalez
	1200	70	L.Gonzalez
	1500	70	Hinojosa
	1800	70	Hinojosa
	2100	70	Hinojosa
	2400	68	PRICE

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	68	PRICE
	0600	62	U. VALENCIA
	0900	62	U. VALENCIA
	1200	62	U. VALENCIA
	1500	65	A. TAPIA
	1800	65	A. TAPIA
	2100	65	A. TAPIA
	2400	65	Reveles

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	65	Reveles
	0600	62	CHAN
	0900	62	CHAN
	1200	64	CHAN
	1500	65	GRAYSON
	1800	65	GRAYSON
	2100	65	GRAYSON
	2400	64	Reveles

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: SYNASP Housing Unit: A4-B Temp. Reading Location: dayroom (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-14-2024	0300	75	Rewles
	0600	72	CHAN
	0900	72	CHAN
	1200	74	CHAN
	1500	77	Barza
	1800	76	Barza
	2100	75	Barza
	2400	70	PRICE

Tuesday

Date	Time	Temp.	Name (Print)
10/15/24	0300	70	PRICE
	0600	70	O.Montoya
	0900	70	O.Montoya
	1200	70	O.Montoya
	1500	73	Barza
	1800	73	Barza
	2100	71	Barza
	2400	70	PRICE

Wednesday

Date	Time	Temp.	Name (Print)
10/16/24	0300	70	PRICE
	0600	70	O.Montoya
	0900	70	O.Montoya
	1200	70	O.Montoya
	1500	73	Barza
	1800	73	Barza
	2100	71	Barza
	2400	70	PRICE

Thursday

Date	Time	Temp.	Name (Print)
10/17/24	0300	70	PRICE
	0600	70	O.Montoya
	0900	70	O.Montoya
	1200	70	O.Montoya
	1500	70	Barza
	1800	69	Barza
	2100	69	Barza
	2400	70	PRICE

Friday

Date	Time	Temp.	Name (Print)
10/18/24	0300	70	PRICE
	0600	70	L. Gonzale
	0900	70	L. Gonzale
	1200	70	L. Gonzale
	1500	70	HAWKSH
	1800	70	HAWKSH
	2100	70	HAWKSH
	2400	68	PRICE

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	68	PRICE
	0600	62	U. VALENCIA
	0900	64	U. VALENCIA
	1200	64	U. VALENCIA
	1500	65	A. TAPIA
	1800	65	A. TAPIA
	2100	65	A. TAPIA
	2400	65	Rewles

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	65	Rewles
	0600	62	CHAN
	0900	62	CHAN
	1200	64	CHAN
	1500	65	GRAYSON
	1800	65	GRAYSON
	2100	65	GRAYSON
	2400	64	Rewles

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB- 5 Temp. Reading Location: 2ND TIER A-SECTION
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-14-24	0300	70	Ramirez
	0600	70	M. Pompa
	0900	70	M. Pompa
	1200	70	M. Pompa
	1500	72	GRAYSON
	1800	72	GRAYSON
	2100	72	GRAYSON
	2400	72	D. Gallo

Tuesday

Date	Time	Temp.	Name (Print)
10-15-24	0300	70	D. Gallo
	0600	70	Pompa
	0900	70	Pompa
	1200	70	Pompa
	1500	72	GRAYSON
	1800	72	GRAYSON
	2100	72	GRAYSON
	2400	72	D. Gallo

Wednesday

Date	Time	Temp.	Name (Print)
10-16-24	0300	70	D. Gallo
	0600	70	Bruce
	0900	70	Bruce
	1200	72	Bruce
	1500	75	Gill
	1800	75	Gill
	2100	72	Gill
	2400	72	Gill

Thursday

Date	Time	Temp.	Name (Print)
10-17-24	0300	70	D. Gallo
	0600	70	Bruce
	0900	70	Bruce
	1200	71	Bruce
	1500	72	Gill
	1800	70	Gill
	2100	70	Gill
	2400	70	Gill

Friday

Date	Time	Temp.	Name (Print)
10-18-2024	0300	69	Rivelos
	0600	70	Bruce
	0900	70	Bruce
	1200	70	Bruce
	1500	70	G. Rios
	1800	70	G. Rios
	2100	68	G. Rios
	2400	66	C. Ramirez

Saturday

Date	Time	Temp.	Name (Print)
10-19-24	0300	66	C. Ramirez
	0600	64	Bruce
	0900	65	Bruce
	1200	70	Bruce
	1500	68	G. Rios
	1800	68	G. Rios
	2100	68	G. Rios
	2400	66°	M. Gonzalez

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	64°	M. Gonzalez
	0600	65	Bruce
	0900	67	Bruce
	1200	68	Bruce
	1500	68	A. TAPIA
	1800	68	A. TAPIA
	2100	65	A. TAPIA
	2400	67	M. Gonzalez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB- 5 Temp. Reading Location: 2ND TIER B-SECTION
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-14-24	0300	70	RAMIREZ
	0600	70	Pompa
	0900	70	Pompa
	1200	70	Pompa
	1500	72	GRAYSON
	1800	72	GRAYSON
	2100	72	GRAYSON
	2400	72	D. PENSON

Tuesday

Date	Time	Temp.	Name (Print)
10-15-24	0300	70	D. PENSON
	0600	70	M. Pompa
	0900	70	M. Pompa
	1200	70	M. Pompa
	1500	72	GRAYSON
	1800	72	GRAYSON
	2100	72	GRAYSON
	2400	72	D. PENSON

Wednesday

Date	Time	Temp.	Name (Print)
10-16-24	0300	70	D. PENSON
	0600	70	BRUCE
	0900	70	BRUCE
	1200	72	BRUCE
	1500	74	Gill
	1800	74	Gill
	2100	72	Gill
	2400	72	Gill

Thursday

Date	Time	Temp.	Name (Print)
10-17-24	0300	70	D. PENSON
	0600	70	BRUCE
	0900	70	BRUCE
	1200	71	BRUCE
	1500	72	Gill
	1800	70	Gill
	2100	70	Gill
	2400	70	Reveles

Friday

Date	Time	Temp.	Name (Print)
10-18 2024	0300	69	Reveles
	0600	70	BRUCE
	0900	70	BRUCE
	1200	70	BRUCE
	1500	70	G. Rios
	1800	70	G. Rios
	2100	68	G. Rios
	2400	66	C. Ramirez

Saturday

Date	Time	Temp.	Name (Print)
10-19-24	0300	66	C. Ramirez
	0600	64	BRUCE
	0900	65	BRUCE
	1200	70	BRUCE
	1500	68	G. Rios
	1800	68	G. Rios
	2100	68	G. Rios
	2400	66	M. Gonzalez

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	64°	M. Gonzalez
	0600	65	BRUCE
	0900	67	BRUCE
	1200	68	BRUCE
	1500	68	A. TAPIA
	1800	68	A. TAPIA
	2100	65	A. TAPIA
	2400	67	M. Gonzalez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATI

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 1 (A) or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday 10/14/24

Date	Time	Temp.	Name (Print)
10/14/24	0300	75	J. MAYORGA
	0600	73	R Ramirez
	0900	75	R Ramirez
	1200	78	R Ramirez
	1500	78	J Soto
	1800	78	J Soto
	2100	77	J Soto
	2400	75	J. MAYORGA

Tuesday

Date	Time	Temp.	Name (Print)
10/15/24	0300	75	J. MAYORGA
	0600	75	R. Ramirez
	0900	75	R. Ramirez
	1200	78	R. Ramirez
	1500	78	J Soto
	1800	77	J Soto
	2100	77	J Soto
	2400	77	J. MAYORGA

Wednesday

Date	Time	Temp.	Name (Print)
10/16/24	0300	~~75~~ 75	J. MAYORGA
	0600	73	J. Youngblood
	0900	74	J. Youngblood
	1200	78	J. Youngblood
	1500	78	J Soto
	1800	77	J Soto
	2100	77	J Soto
	2400	75	J. MAYORGA

Thursday

Date	Time	Temp.	Name (Print)
10/17/24	0300	74	J. MAYORGA
	0600	75	R Ramirez
	0900	75	R Ramirez
	1200	78	R Ramirez
	1500	78	J Soto
	1800	78	J Soto
	2100	76	J Soto
	2400	77	A. Ramos

Friday

Date	Time	Temp.	Name (Print)
10/18/24	0300	77	A. Ramos
	0600	75	R Ramirez
	0900	75	R Ramirez
	1200	76	R Ramirez
	1500	78	J Soto
	1800	78	J Soto
	2100	78	J Soto
	2400	77	A. Ramos

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	77	A. Ramos
	0600	68	T. Smith
	0900	70	T Smith
	1200	70	T Smith
	1500	70	G Campos
	1800	70	G Campos
	2100	70	G Campos
	2400	70	D. Hu

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	70	D. Hu
	0600	68	T Smith
	0900	70	T Smith
	1200	70	T Smith
	1500	70	G Campos
	1800	72	G Campos
	2100	70	G Campos
	2400	70	S Mejia

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATI

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # A or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/14/24	0300	75	J. MAYORGA
	0600	75	R Ramirez
	0900	78	R Ramirez
	1200	78	R Ramirez
	1500	78	J Soto
	1800	78	J Soto
	2100	77	J Soto
	2400	75	J. MAYORGA

Tuesday

Date	Time	Temp.	Name (Print)
10/15/24	0300	75	J. MAYORGA
	0600	75	R Ramirez
	0900	77	R Ramirez
	1200	78	R Ramirez
	1500	78	J Soto
	1800	77	J Soto
	2100	77	J Soto
	2400	77	J. MAYORGA

Wednesday

Date	Time	Temp.	Name (Print)
10/16/24	0300	75	J. MAYORGA
	0600	73	J. Younger
	0900	75	J. Younger
	1200	75	R Ramirez
	1500	78	J Soto
	1800	77	J Soto
	2100	77	J Soto
	2400	75	J. MAYORGA

Thursday

Date	Time	Temp.	Name (Print)
10/17/24	0300	74	J. MAYORGA
	0600	74	R Ramirez
	0900	74	R Ramirez
	1200	75	R Ramirez
	1500	78	R Ramirez
	1800	78	J Soto
	2100	76	J Soto
	2400	77	A. Tamos

Friday

Date	Time	Temp.	Name (Print)
10/18/24	0300	77	A. Tamos
	0600	75	R Ramirez
	0900	75	R Ramirez
	1200	75	R Ramirez
	1500	78	J Soto
	1800	77	J Soto
	2100	77	J Soto
	2400	77	A. Tamos

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	77	A. Tamos
	0600	68	T Smal
	0900	70	T Smal
	1200	70	T Smal
	1500	70	G Campos
	1800	70	G Campos
	2100	70	G Campos
	2400	70	D Hu

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	70	D Hu
	0600	68	T Smal
	0900	70	T Smal
	1200	70	T Smal
	1500	70	G Campos
	1800	70	G Campos
	2100	70	G Campos
	2400	70	S. Mejia

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATI

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 2 A or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/14/24	0300	77	D CRUZ
	0600	76	D CRUZ
	0900	76	Ortiz
	1200	76	Ortiz
	1500	77	R. SALAZAR
	1800	78	R. SALAZAR
	2100	77	R. SALAZAR
	2400	77	D. CRUZ

Tuesday

Date	Time	Temp.	Name (Print)
10-15-24	0300	77	D. CRUZ
	0600	77	D. CRUZ
	0900	76	Ortiz
	1200	76	Ortiz
	1500	77	R. SALAZAR
	1800	78	R. SALAZAR
	2100	77	R. SALAZAR
	2400	76	Earnest

Wednesday

Date	Time	Temp.	Name (Print)
10-16-24	0300	76	Earnest
	0600	76	Ortiz
	0900	76	Ortiz
	1200	76	Ortiz
	1500	77	R. SALAZAR
	1800	78	R. SALAZAR
	2100	77	R. SALAZAR
	2400	76	Earnest

Thursday

Date	Time	Temp.	Name (Print)
10-17-24	0300	75	Earnest
	0600	75	King
	0900	75	King
	1200	75	King
	1500	77	R. SALAZAR
	1800	78	R. SALAZAR
	2100	79	R. SALAZAR
	2400	77	Earnest

Friday

Date	Time	Temp.	Name (Print)
10-18-24	0300	75	Earnest
	0600	75	N CRUZ
	0900	75	N CRUZ
	1200	77	N CRUZ
	1500	77	PASUMBAL
	1800	76	PASUMBAL
	2100	75	PASUMBAL
	2400	75	Ortiz

Saturday

Date	Time	Temp.	Name (Print)
10-19-24	0300	75	Ortiz
	0600	75	Ortiz
	0900	75	Ortiz
	1200	75	Ortiz
	1500	75	PASUMBAL
	1800	75	PASUMBAL
	2100	75	PASUMBAL
	2400	75	MARSCAL

Sunday

Date	Time	Temp.	Name (Print)
10-20-24	0300	75	MARSCAL
	0600	75	Ortiz
	0900	75	Ortiz
	1200	75.	Ortiz
	1500	75	M. Zamora
	1800	74	M. Zamora
	2100	74	M. Zamora
	2400	74	N. Rodriguez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATI

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 2 A or (B) Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-14-24	0300	77	D Cruz
	0600	76	D Cruz
	0900	76	Ortiz
	1200	76	Ortiz
	1500	77	R. SALAZAR
	1800	78	R. SALAZAR
	2100	77	R. SALAZAR
	2400	77	D. CRUZ

Tuesday

Date	Time	Temp.	Name (Print)
10-15-24	0300	77	D. CRUZ
	0600	77	D. CRUZ
	0900	76	Ortiz
	1200	76.	Ortiz
	1500	77	R. SALAZAR
	1800	78	R. SALAZAR
	2100	77	R. SALAZAR
	2400	76	Earnest

Wednesday

Date	Time	Temp.	Name (Print)
10-16-24	0300	75	Earnest
	0600	75	Ortiz
	0900	75	Ortiz
	1200	75	Ortiz
	1500	77	R. SALAZAR
	1800	78	R. SALAZAR
	2100	77	R. SALAZAR
	2400	75	Earnest

Thursday

Date	Time	Temp.	Name (Print)
10-17-24	0300	75	Earnest
	0600	75	King
	0900	75	King
	1200	75	King
	1500	77	R. SALAZAR
	1800	78	R. SALAZAR
	2100	77	R. SALAZAR
	2400	76	Earnest

Friday

Date	Time	Temp.	Name (Print)
10-18-24	0300	75	Earnest
	0600	75	N CRUZ
	0900	75	N CRUZ
	1200	77	N CRUZ
	1500	77	PASUMBAL
	1800	76	PASUMBAL
	2100	75	PASUMBAL
	2400	75	OR the

Saturday

Date	Time	Temp.	Name (Print)
10-19-24	0300	75	Ortiz
	0600	75	Ortiz
	0900	75	Ortiz
	1200	76.	Ortiz
	1500	75	PASUMBAL
	1800	75	PASUMBAL
	2100	75	PASUMBAL
	2400	75	MARIYCAL

Sunday

Date	Time	Temp.	Name (Print)
10-20-24	0300	75	MARISCAL
	0600	75	Ortiz
	0900	75	Ortiz
	1200	75	Ortiz
	1500	75	M. Zamora
	1800	74	M. Zamora
	2100	74	M. Zamora
	2400	74	N. Rodriguez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD #3A Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-14-24	0300	72	P. Cerda
	0600	72	J. Hernandez
	0900	72	J. Hernandez
	1200	72	J. Hernandez
	1500	73	PASUMBAL
	1800	73	PASUMBAL
	2100	72	PASUMBAL
	2400	72	LOGAN

Tuesday

Date	Time	Temp.	Name (Print)
10-15-24	0300	70	LOGAN
	0600	70	J. Hernandez
	0900	70	J. Hernandez
	1200	70	J. Hernandez
	1500	72	SOLORIO
	1800	72	SOLORIO
	2100	72	SOLORIO
	2400	71	D. CRUZ

Wednesday

Date	Time	Temp.	Name (Print)
10-16-24	0300	76	D. CRUZ
	0600	78	D. CRUZ
	0900	70	J. Hernandez
	1200	71	J. Hernandez
	1500	72	SOLORIO
	1800	72	SOLORIO
	2100	72	SOLORIO
	2400	72	P. Cerda

Thursday

Date	Time	Temp.	Name (Print)
10-17-24	0300	70	P. Cerda
	0600	70	J. Hernandez
	0900	70	J. Hernandez
	1200	70	J. Hernandez
	1500	70	SOLORIO
	1800	70	SOLORIO
	2100	70	SOLORIO
	2400	70	P. Cerda

Friday

Date	Time	Temp.	Name (Print)
10-18-24	0300	70	P. Cerda
	0600	70	King
	0900	70	King
	1200	70	King
	1500	70	SOLORIO
	1800	70	SOLORIO
	2100	70	SOLORIO
	2400	72	P. Cerda

Saturday

Date	Time	Temp.	Name (Print)
10-19-24	0300	72	P. Cerda
	0600	72	King
	0900	72	King
	1200	72	King
	1500	72	S. Peng
	1800	70	S. Peng
	2100	70	S. Peng
	2400	70	P. Cerda

Sunday

Date	Time	Temp.	Name (Print)
10-20-24	0300	70	P. Cerda
	0600	70	J. Hernandez
	0900	70	J. Hernandez
	1200	70	J. Hernandez
	1500	70	PASUMBAL
	1800	70	PASUMBAL
	2100	70	PASUMBAL
	2400	70	P. Cerda

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD #3B Temp. Reading Location: T I E R 2
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-14-24	0300	72	P. Cerda
	0600	72	J. Hernandez
	0900	72	J. Hernandez
	1200	72	J. Hernandez
	1500	73	PASUMBAL
	1800	73	PASUMBAL
	2100	72	PASUMBAL
	2400	72	LOGAN

Tuesday

Date	Time	Temp.	Name (Print)
10-15-24	0300	70	LOGAN
	0600	70	J. Hernandez
	0900	70	J. Hernandez
	1200	70	J. Hernandez
	1500	75	SOLORIO
	1800	75	SOLORIO
	2100	75	SOLORIO
	2400	71	D. Cruz

Wednesday

Date	Time	Temp.	Name (Print)
10-16-24	0300	71	D. CRUZ
	0600	70	D. CRUZ
	0900	70	J. Hernandez
	1200	71	J. Hernandez
	1500	72	SOLORIO
	1800	75	SOLORIO
	2100	75	SOLORIO
	2400	72	P. Cerda

Thursday

Date	Time	Temp.	Name (Print)
10-17-24	0300	70	P. Cerda
	0600	70	J. Hernandez
	0900	70	J. Hernandez
	1200	70	J. Hernandez
	1500	72	SOLORIO
	1800	72	SOLORIO
	2100	72	SOLORIO
	2400	71	P. Cerda

Friday

Date	Time	Temp.	Name (Print)
10-18-24	0300	70	P. Cerda
	0600	70	King
	0900	70	King
	1200	70	King
	1500	72	SOLORIO
	1800	75	SOLORIO
	2100	75	SOLORIO
	2400	72	P. Cerda

Saturday

Date	Time	Temp.	Name (Print)
10-19-24	0300	72	P. Cerda
	0600	72	King
	0900	72	King
	1200	72	King
	1500	72	J. Pena
	1800	70	J. Pena
	2100	70	J. Pena
	2400	70	P. Cerda

Sunday

Date	Time	Temp.	Name (Print)
10-20-24	0300	70	P. Cerda
	0600	70	J. Hernandez
	0900	70	J. Hernandez
	1200	70	J. Hernandez
	1500	70	PASUMBAL
	1800	70	PASUMBAL
	2100	70	PASUMBAL
	2400	70	P. Cerda

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATI

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 4 (A) or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10.14.24	0300	72	RAGNIDO
	0600	72	King
	0900	72	King
	1200	72	King
	1500	73	H. Martinez
	1800	73	H. Martinez
	2100	72	H. Martinez
	2400	70	Z. Green

Tuesday

Date	Time	Temp.	Name (Print)
10.15.24	0300	70	Z. Green
	0600	70	APEREZ
	0900	70	APEREZ
	1200	70	APEREZ
	1500	75	PASUMBAL
	1800	75	PASUMBAL
	2100	72	PASUMBAL
	2400	72	Z. Green

Wednesday

Date	Time	Temp.	Name (Print)
10.16.24	0300	71	Z. Green
	0600	71	APEREZ
	0900	71	APEREZ
	1200	71	APEREZ
	1500	70	CAMPOS
	1800	70	CAMPOS
	2100	70	CAMPOS
	2400	70	R. Cisneros

Thursday

Date	Time	Temp.	Name (Print)
10.17.24	0300	70	R. Cisneros
	0600	70	APEREZ
	0900	70	APEREZ
	1200	70	APEREZ
	1500	71	H. Martinez
	1800	70	H. Martinez
	2100	70	H. Martinez
	2400	70	R. Cisneros

Friday

Date	Time	Temp.	Name (Print)
10.18.24	0300	69	R. Cisneros
	0600	70	APEREZ
	0900	70	APEREZ
	1200	70	APEREZ
	1500	69	H. Martinez
	1800	69	H. Martinez
	2100	69	H. Martinez
	2400	69	R. Cisneros

Saturday

Date	Time	Temp.	Name (Print)
10.19.24	0300	68	R. Cisneros
	0600	66	APEREZ
	0900	66	APEREZ
	1200	66	APEREZ
	1500	67	H. Martinez
	1800	68	H. Martinez
	2100	68	H. Martinez
	2400	67	LOGAN

Sunday

Date	Time	Temp.	Name (Print)
10.20.24	0300	67	LOGAN
	0600	67	King
	0900	70	King
	1200	70	King
	1500	70	H. Franklin
	1800	70	H. Franklin
	2100	69	H. Franklin
	2400	68	LOGAN

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITAT

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 4 A or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10.14.24	0300	72	RAGUDO
	0600	72	King
	0900	72	King
	1200	72	King
	1500	73	H. Martinez
	1800	72	H. Martinez
	2100	72	H. Martinez
	2400	70	Z. Green

Tuesday

Date	Time	Temp.	Name (Print)
10.15.24	0300	70	Z. Green
	0600	70	A. Perez
	0900	70	A. Perez
	1200	70	A. Perez
	1500	75	Pasumbal
	1800	73	Pasumbal
	2100	72	Pasumbal
	2400	72	Z. Green

Wednesday

Date	Time	Temp.	Name (Print)
10.16.24	0300	70	Z. Green
	0600	70	A. Perez
	0900	70	A. Perez
	1200	70	A. Perez
	1500	70	G. Campos
	1800	70	G. Campos
	2100	70	G. Campos
	2400	70	R. Cisneros

Thursday

Date	Time	Temp.	Name (Print)
10.17.24	0300	70	R. Cisneros
	0600	70	A. Perez
	0900	70	A. Perez
	1200	70	A. Perez
	1500	71	H. Martinez
	1800	71	H. Martinez
	2100	70	H. Martinez
	2400	70	R. Cisneros

Friday

Date	Time	Temp.	Name (Print)
10.18.24	0300	69	R. Cisneros
	0600	70	A. Perez
	0900	70	A. Perez
	1200	70	A. Perez
	1500	69	H. Martinez
	1800	69	H. Martinez
	2100	69	H. Martinez
	2400	69	R. Cisneros

Saturday

Date	Time	Temp.	Name (Print)
10.19.24	0300	68	R. Cisneros
	0600	66	A. Perez
	0900	66	A. Perez
	1200	66	A. Perez
	1500	67	H. Martinez
	1800	67	H. Martinez
	2100	68	H. Martinez
	2400	67	Logan

Sunday

Date	Time	Temp.	Name (Print)
10.20.24	0300	67	Logan
	0600	67	King
	0900	70	King
	1200	70	King
	1500	70	Franklin
	1800	70	H. Franklin
	2100	69	H. Franklin
	2400	68	Logan

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATI

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 5 (A) or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-19-24	0300	75	[illegible]
	0600	75	[illegible]
	0900	X	[illegible]
	1200	75	[illegible]
	1500	77	J. ortega
	1800	77	J. ortega
	2100	76	J. ortega
	2400	75	[illegible]

Tuesday

Date	Time	Temp.	Name (Print)
10/15/29	0300	75	[illegible]
	0600	75	Smal
	0900	75	Smal
	1200	76	Smal
	1500	76	O.Vegar
	1800	76	O.Vegar
	2100	76	O.Vegar
	2400	75	[illegible]

Wednesday

Date	Time	Temp.	Name (Print)
10-16-23	0300	76	[illegible]
	0600	75	E. CRUZ
	0900	77	E CRUZ
	1200	77	E CRUZ
	1500	77	O.Vegar
	1800	77	O.Vegar
	2100	76	O.Vegar
	2400	75	[illegible]

Thursday

Date	Time	Temp.	Name (Print)
10-17-24	0300	72	[illegible]
	0600	75	E Cruz
	0900	76	E CRUZ
	1200	76	E CRUZ
	1500	72	G.CAMPOS
	1800	72	G.CAMPOS
	2100	72	G.CAMPOS
	2400	74	LOGAN

Friday

Date	Time	Temp.	Name (Print)
10/18/24	0300	74	LOGAN
	0600	74	E CRUZ
	0900	74	E.CRUZ
	1200	74	E CRUZ
	1500	74	G.CAMPOS
	1800	73	G.CAMPOS
	2100	73	G.CAMPOS
	2400	72	LOGAN

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	72	LOGAN
	0600	73	E CRUZ
	0900	75	E.CRUZ
	1200	75	E.CRUZ
	1500	75	J.ortega
	1800	74	J.ortega
	2100	73	J.ortega
	2400	71	[illegible]

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	69	[illegible]
	0600	70	E.CRUZ
	0900	74	E.CRUZ
	1200	74	E.CRUZ
	1500	75	J.ortega
	1800	74	J.ortega
	2100	74	J.ortega
	2400	71	[illegible]

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITATI

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 5 A or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-14-24	0300	75	[illegible]
	0600	76	[illegible]
	0900	75	[illegible]
	1200	75	[illegible]
	1500	77	J.ortega
	1800	77	J.ortega
	2100	76	J.ortega
	2400	75	[illegible]

Tuesday

Date	Time	Temp.	Name (Print)
10/15/24	0300	75	[illegible]
	0600	75	Smar
	0900	75	Smar
	1200	76	Smar
	1500	76	O.Vegar
	1800	76	O.Vegar
	2100	76	O.Vegar
	2400	75	[illegible]

Wednesday

Date	Time	Temp.	Name (Print)
10-16-24	0300	74	[illegible]
	0600	74	E.Cruz
	0900	76	E.Cruz
	1200	76	E.Cruz
	1500	77	O.Vegar
	1800	77	O.Vegar
	2100	75	O.Vegar
	2400	71	[illegible]

Thursday

Date	Time	Temp.	Name (Print)
10-17-24	0300	76	[illegible]
	0600	74	E.Cruz
	0900	76	E.Cruz
	1200	76	E.Cruz
	1500	72	Lecamos
	1800	72	Lecamos
	2100	72	Lecamos
	2400	74	Logan

Friday

Date	Time	Temp.	Name (Print)
10/18/24	0300	74	Logan
	0600	74	E.Cruz
	0900	76	E.Cruz
	1200	76	E.Cruz
	1500	74	Lecamos
	1800	73	Lecamos
	2100	73	Lecamos
	2400	72	Logan

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	72	Logan
	0600	72	Logan
	0900	75	E.Cruz
	1200	75	E.Cruz
	1500	75	J.ortega
	1800	74	J.ortega
	2100	73	J.ortega
	2400	75	[illegible]

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	71	[illegible]
	0600	71	E.Cruz
	0900	75	E.Cruz
	1200	75	E.Cruz
	1500	75	J.ortega
	1800	74	J.ortega
	2100	77	J.ortega
	2400	77	[illegible]

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Blue A Side Temp. Reading Location: dayroom (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10.14.24	0300	74	B ROSS
	0600	75	Lyner
	0900	75	Lyner
	1200	75	Lyner
	1500	76	M. Yang
	1800	75	M. Yang
	2100	75	M. Yang
	2400	74	D SLS

Tuesday

Date	Time	Temp.	Name (Print)
10.15.24	0300	74	D SLS
	0600	74	Lyner
	0900	75	Lyner
	1200	75	Lyner
	1500	76	M. Yang
	1800	73	M. Yang
	2100	73	M. Yang
	2400	73	D SLS

Wednesday

Date	Time	Temp.	Name (Print)
10.16.24	0300	73	D SLS
	0600	74	Lyner
	0900	74	Lyner
	1200	74	Lyner
	1500	75	Y. Lorenzo
	1800	75	Y. Lorenzo
	2100	74	Y. Lorenzo
	2400	74	B. ROSS

Thursday

Date	Time	Temp.	Name (Print)
10.17.24	0300	73	B. ROSS
	0600	74	Lyner
	0900	74	Lyner
	1200	74	Lyner
	1500	75	Y. Lorenzo
	1800	75	Y. Lorenzo
	2100	74	Y. Lorenzo
	2400	74	M. Romero

Friday

Date	Time	Temp.	Name (Print)
10.18.24	0300	74	M. Romero
	0600	74	Lyner
	0900	75	Lyner
	1200	75	Lyner
	1500	75	Y. Lorenzo
	1800	74	Y. Lorenzo
	2100	74	Y. Lorenzo
	2400	72	M. Romero

Saturday

Date	Time	Temp.	Name (Print)
10.19.24	0300	72	M. Romero
	0600	72	V. [illegible]
	0900	73	V. [illegible]
	1200	73	V. [illegible]
	1500	74	Y. Lorenzo
	1800	73	Y. Lorenzo
	2100	73	Y. Lorenzo
	2400	71	M. Romero

Sunday

Date	Time	Temp.	Name (Print)
10.20.24	0300	70	M. Romero
	0600	69	[illegible]
	0900	70	Jacoflive
	1200	72	Lacoflive
	1500	73	E. Serrato
	1800	70	E. Serrato
	2100	70	E. Serrato
	2400	70	M. Romero

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B/B B-Side Temp. Reading Location: dayroom
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/14/24	0300	74	B. ROSS
	0600	75	Lopez
	0900	75	Lopez
	1200	75	Lopez
	1500	76	M Yang
	1800	75	M Yang
	2100	75	M Yang
	2400	74	D SIS

Tuesday

Date	Time	Temp.	Name (Print)
10-15-24	0300	74	D SIS
	0600	74	Lopez
	0900	75	Lopez
	1200	75	Lopez
	1500	73	M Yang
	1800	73	M Yang
	2100	73	M Yang
	2400	73	D SIS

Wednesday

Date	Time	Temp.	Name (Print)
10.16.24	0300	73	D SIS
	0600	74	Lopez
	0900	74	Lopez
	1200	74	Lopez
	1500	75	Y. Lorenzo
	1800	74	Y. Lorenzo
	2100	74	Y. Lorenzo
	2400	74	B. ROSS

Thursday

Date	Time	Temp.	Name (Print)
10.17.24	0300	73	B. ROSS
	0600	74	Lopez
	0900	74	Lopez
	1200	74	Lopez
	1500	75	Y. Lorenzo
	1800	75	Y. Lorenzo
	2100	75	Y. Lorenzo
	2400	74	M. Romero

Friday

Date	Time	Temp.	Name (Print)
10.18.24	0300	74	M. Romero
	0600	74	Lopez
	0900	75	Lopez
	1200	75	Lopez
	1500	75	Y. Lorenzo
	1800	75	Y. Lorenzo
	2100	75	Y. Lorenzo
	2400	72	M. Romero

Saturday

Date	Time	Temp.	Name (Print)
10.19.24	0300	72	M. Romero
	0600	72	V. [illegible]
	0900	73	V. [illegible]
	1200	73	V. [illegible]
	1500	72	Y. Lorenzo
	1800	72	Y. Lorenzo
	2100	72	Y. Lorenzo
	2400	71	M. Romero

Sunday

Date	Time	Temp.	Name (Print)
10-20-24	0300	70	M. Romero
	0600	70	Lacofieva
	0900	71	Lacofieva
	1200	72	Lacofieva
	1500	73	E. Serrato
	1800	70	E. Serrato
	2100	70	E. Serrato
	2400	70	M. Romero

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NILSP Housing Unit: C2A Temp. Reading Location: Day Room Above T.V.
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/14/24	0300	78	Penal
	0600	78	Lopez
	0900	78	Lopez
	1200	78	Lopez
	1500	78	M-Serrato
	1800	78	M-Serrato
	2100	77	M-Serrato
	2400	77	L. Mauro

Tuesday

Date	Time	Temp.	Name (Print)
10/15/24	0300	77	L. Mauro
	0600	77	McIntosh
	0900	78	McIntosh
	1200	80	McIntosh
	1500	78	M. Serrato
	1800	77	M-Serrato
	2100	75	M. Serrato
	2400	75	M-Serrato

Wednesday

Date	Time	Temp.	Name (Print)
10/16/24	0300	75°	M-Serrato
	0600	76	McIntosh
	0900	77	McIntosh
	1200	78	McIntosh
	1500	76	Ellison
	1800	76	Ellison
	2100	76	Ellison
	2400	75	Ellison

Thursday

Date	Time	Temp.	Name (Print)
10/17/24	0300	74	Ellison
	0600	74	McIntosh
	0900	75	McIntosh
	1200	77	McIntosh
	1500	76	Ellison
	1800	74	Ellison
	2100	72	Ellison
	2400	72	Ellison

Friday

Date	Time	Temp.	Name (Print)
10/18/24	0300	72	Ellison
	0600	72	McIntosh
	0900	73	McIntosh
	1200	74	J Ferrer
	1500	74	J Ferrer
	1800	73	J Ferrer
	2100	71	J Ferrer
	2400	70	Ellison

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	70	Ellison
	0600	70	T. Deras Santos
	0900	72	T. Deras Santos
	1200	73	T. Deras Santos
	1500	72	G. Contreras
	1800	72	G. Contreras
	2100	72	G. Contreras
	2400	72	D. Alvarado

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	71	D. Alvarado
	0600	71	M-Serrato
	0900	72	M-Serrato
	1200	72	M. Serrato
	1500	73	Lule
	1800	73	Lule
	2100	73	Lule
	2400	72	Penal

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATIO

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C2 BSIDE Temp. Reading Location: TOP TIER
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-14-24	0300	77	L. Mones
	0600	77	A CASILLAS
	0900	77	A CASILLAS
	1200	78	A CASILLAS
	1500	78	D. Alvarado
	1800	78	D. Alvarado
	2100	77	D. Alvarado
	2400	77	A. walter

Tuesday

Date	Time	Temp.	Name (Print)
10/15/24	0300	77	A. walter
	0600	77	A CASILLAS
	0900	77	A CASILLAS
	1200	78	A CASILLAS
	1500	78	A walter
	1800	78	A. walter
	2100	77	A walter
	2400	77	A. walter

Wednesday

Date	Time	Temp.	Name (Print)
10/16/24	0300	76	A walter
	0600	76	R. ANAYA
	0900	77	R. ANAYA
	1200	77	R. ANAYA
	1500	77	COTTON
	1800	77	COTTON
	2100	77	COTTON
	2400	77	A walter

Thursday

Date	Time	Temp.	Name (Print)
10/17/24	0300	77	A walter
	0600	77	R. ANAYA
	0900	77	R. ANAYA
	1200	77	R. ANAYA
	1500	77	COTTON
	1800	77	COTTON
	2100	75	COTTON
	2400	75	COTTON

Friday

Date	Time	Temp.	Name (Print)
10/18/24	0300	75	COTTON
	0600	75	A CASILLAS
	0900	75	A CASILLAS
	1200	76	A CASILLAS
	1500	76	COTTON
	1800	76	COTTON
	2100	75	COTTON
	2400	75	Walter

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	75	walter
	0600	75	A. CASILLAS
	0900	75	A CASILLAS
	1200	75	A CASILLAS
	1500	75	COTTON
	1800	75	COTTON
	2100	73	COTTON
	2400	73	COTTON

Sunday

Date	Time	Temp.	Name (Print)
10-20-24	0300	73	Montes
	0600	75	V. Rodriguez
	0900	75	[illegible]
	1200	75	[illegible]
	1500	75	D. Alvarado
	1800	75	D. Alvarado
	2100	75	D. Alvarado
	2400	75	L. MONTES

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C3A Temp. Reading Location: TIER 2
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/14/24	0300	76	MONTES
	0600	75	MONTES
	0900	75	MONTES
	1200	75	MONTES
	1500	75	MONTES
	1800	77	MONTES
	2100	78	MONTES
	2400	78	MONTES

Tuesday

Date	Time	Temp.	Name (Print)
10/15/24	0300	76	TORRES
	0600	76	TORRES
	0900	76	TORRES
	1200	75	TORRES
	1500	75	Camacho
	1800	75	Camacho
	2100	76	Camacho
	2400	76	Camacho

Wednesday

Date	Time	Temp.	Name (Print)
10/16/24	0300	74	Camacho
	0600	74	Camacho
	0900	75	Camacho
	1200	75	Montes
	1500	74	Montes
	1800	74	Montes
	2100	75	Camacho
	2400	74	Camacho

Thursday

Date	Time	Temp.	Name (Print)
10/17/24	0300	74	Reyes
	0600	75	Reyes
	0900	75	Reyes
	1200	75	Martinez
	1500	77	Martinez
	1800	74	Martinez
	2100	74	[illegible]
	2400	74	[illegible]

Friday

Date	Time	Temp.	Name (Print)
10/18/24	0300	74	[illegible]
	0600	74	[illegible]
	0900	76	[illegible]
	1200	76	[illegible]
	1500	75	[illegible]
	1800	75	[illegible]
	2100	74	[illegible]
	2400	74	[illegible]

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	74	Camacho
	0600	74	[illegible]
	0900	75	Camacho
	1200	75	Camacho
	1500	74	[illegible]
	1800	74	[illegible]
	2100	73	[illegible]
	2400	73	[illegible]

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	73	[illegible]
	0600	73	[illegible]
	0900	74	[illegible]
	1200	75	Camacho
	1500	75	[illegible]
	1800	75	[illegible]
	2100	74	[illegible]
	2400	73	[illegible]

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C3B Temp. Reading Location: Above T.V
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/14/24	0300	78	A. Martinez
	0600	75	D. Valencia
	0900	75	D. Valencia
	1200	75	D. Valencia
	1500	75	J. Acosta
	1800	77	J. Acosta
	2100	78	J. Acosta
	2400	78	A. Martinez

Tuesday

Date	Time	Temp.	Name (Print)
10/15/24	0300	76°	E. Torres
	0600	76	D. Valencia
	0900	76	D. Valencia
	1200	76	D. Valencia
	1500	76	J. Acosta
	1800	75	J. Acosta
	2100	75	J. Acosta
	2400	74	E. Torres

Wednesday

Date	Time	Temp.	Name (Print)
10/16/24	0300	74	E. Torres
	0600	75	D. Valencia
	0900	75	D. Valencia
	1200	75	D. Valencia
	1500	75	J. Acosta
	1800	75	J. Acosta
	2100	75	J. Acosta
	2400	78	E. Torres

Thursday

Date	Time	Temp.	Name (Print)
10/17/24	0300	74	E. Torres
	0600	75	J. Jones
	0900	75	J. Jones
	1200	75	J. Jones
	1500	74	R. Aguilar
	1800	74	R. Aguilar
	2100	74	R. Aguilar
	2400	74	E. Torres

Friday

Date	Time	Temp.	Name (Print)
10/18/24	0300	74	E. Torres
	0600	75	J. Jones
	0900	75	J. Jones
	1200	75	J. Jones
	1500	75	R. Aguilar
	1800	74	R. Aguilar
	2100	74	R. Aguilar
	2400	74	Witcher

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	74	Witcher
	0600	75	D. Valencia
	0900	75	D. Valencia
	1200	75	D. Valencia
	1500	75	J. Acosta
	1800	73	J. Acosta
	2100	70	J. Acosta
	2400	70	Witcher

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	73	Witcher
	0600	73	D. Valencia
	0900	73	D. Valencia
	1200	73	D. Valencia
	1500	73	J. Acosta
	1800	73	J. Acosta
	2100	72	J. Acosta
	2400	72	E. Torres

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C4-A Temp. Reading Location: ABOVE T.V IN DAYROOM
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/13/24	0300	75°	S.RAU
	0600	72	Vielmas
	0900	73	Vielmas
	1200	75	Vielmas
	1500	79	Vielmas
	1800	80	Vielmas
	2100	78	Vielmas
	2400	75°	S.RALL

Tuesday

Date	Time	Temp.	Name (Print)
10/14/24	0300	74°	S.RALL
	0600	74°	J.Padilla
	0900	74°	J.Padilla
	1200	80	Vielmas
	1500	78	Vielmas
	1800	77	Vielmas
	2100	77	Vielmas
	2400	76	D.Marcus

Wednesday

Date	Time	Temp.	Name (Print)
10/15/24	0300	76	D.Marcus
	0600	75°	Z. Jones
	0900	75°	Z. Jones
	1200	75°	Z. Jones
	1500	76	Vielmas
	1800	76	Vielmas
	2100	74	Vielmas
	2400	76	C.WITCHER

Thursday

Date	Time	Temp.	Name (Print)
10/16/24	0300	76	C.WITCHER
	0600	76	Torres, E
	0900	77	Torres, E
	1200	78	Torres, E
	1500	80	Vielmas
	1800	79	Vielmas
	2100	78	Vielmas
	2400	75	C.WITCHERS

Friday

Date	Time	Temp.	Name (Print)
10/17/24	0300	75	C.WITCHER
	0600	73	E.Torres
	0900	75	E.Torres
	1200	75	Torres
	1500	74	Torres
	1800	73	Torres
	2100	72	Torres
	2400	70°	S.Rau

Saturday

Date	Time	Temp.	Name (Print)
10/18/24	0300	70°	S.Rau
	0600	72	E.Torres
	0900	72	E.Torres
	1200	73	E.Torres
	1500	73	R. Aguilar
	1800	73	R. Aguilar
	2100	72	R. Aguilar
	2400	72°	S.Rau

Sunday

Date	Time	Temp.	Name (Print)
10/19/24	0300	70°	S.Rau
	0600	70	E.Torres
	0900	71	E.Torres
	1200	71	E Torres
	1500	72	R. Aguilar
	1800	72	R. Aguilar
	2100	71	R. Aguilar
	2400	70°	S.Rau

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C4 - B Temp. Reading Location: left side of T.V.
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/14/2024	0300	71	Witcher
	0600	72	J. Padilla
	0900	72	J. Padilla
	1200	72	J. Padilla
	1500	72	Tovar
	1800	73	Tovar
	2100	73	Tovar
	2400	73	H. Gall

Tuesday

Date	Time	Temp.	Name (Print)
10/15/2024	0300	73	H. Gall
	0600	73	A. Herrera
	0900	73	A. Herrera
	1200	75	A. Herrera
	1500	75	Z. Green
	1800	73	Z. Green
	2100	73	Z. Green
	2400	73	P. Rosales

Wednesday

Date	Time	Temp.	Name (Print)
10/16/2024	0300	71	P. Rosales
	0600	71	A. Herrera
	0900	72	A. Herrera
	1200	72	A. Herrera
	1500	75	R. Aguilar
	1800	75	R. Aguilar
	2100	72	R. Aguilar
	2400	72	[illegible]

Thursday

Date	Time	Temp.	Name (Print)
10/17/2024	0300	70	Herrera
	0600	70	A. Herrera
	0900	70	A. Herrera
	1200	71	A. Herrera
	1500	71°	K. MADRIGAL
	1800	71°	K. MADRIGAL
	2100	70	K. Madrigal
	2400	70°	G. ZAMORA

Friday

Date	Time	Temp.	Name (Print)
10/18/2024	0300	70°	G. ZAMORA
	0600	70°	A. Herrera
	0900	70	A. Herrera
	1200	70	A. Herrera
	1500	70°	H. Tran
	1800	70°	H. Tran
	2100	70°	H. Tran
	2400	70	J. Jacques

Saturday

Date	Time	Temp.	Name (Print)
10/19/2024	0300	70	J. Jacques
	0600	70	R. Sing
	0900	70	R. Sing
	1200	69°	H. Tran
	1500	70°	H. Tran
	1800	70°	H. Tran
	2100	69°	H. Tran
	2400	70	J. Jacques

Sunday

Date	Time	Temp.	Name (Print)
10/20/2024	0300	70	J. Jacques
	0600	69	J. Padilla
	0900	69	J. Padilla
	1200	69°	H. Tran
	1500	69°	H. Tran
	1800	69°	H. Tran
	2100	69°	H. Tran
	2400	68	Witcher

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. D - 1 (A) Side Temp. Reading Location: Tier 2 - Above Dayroom TV (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/14/24	0300	74	W. COLBERT
	0600	74	B. COVERT
	0900	74	B. COVERT
	1200	75	B. COVERT
	1500	75	S. MORENO
	1800	75	S. MORENO
	2100	70	S. MORENO
	2400	74	W. COLBERT

Tuesday

Date	Time	Temp.	Name (Print)
10/15/24	0300	75	W. COLBERT
	0600	75	B. COVERT
	0900	75	B. COVERT
	1200	76	B. COVERT
	1500	76	J. NIETO
	1800	75	J. NIETO
	2100	75	J. NIETO
	2400	74	W. COLBERT

Wednesday

Date	Time	Temp.	Name (Print)
10/16/24	0300	74	W. Colbert
	0600	74	B. COVERT
	0900	75	B. COVERT
	1200	75	B. COVERT
	1500	76	J. NIETO
	1800	75	J. NIETO
	2100	75	J. NIETO
	2400	74	A. MALDONADO

Thursday

Date	Time	Temp.	Name (Print)
10/17/24	0300	74	A. MALDONADO
	0600	74	B. COVERT
	0900	75	B. COVERT
	1200	75	B. COVERT
	1500	75	J. NIETO
	1800	75	J. NIETO
	2100	75	J. NIETO
	2400	74	DENOTO

Friday

Date	Time	Temp.	Name (Print)
10/18/24	0300	74	DENOTO
	0600	74	B. COVERT
	0900	74	B. COVERT
	1200	75	B. COVERT
	1500	75	J. NIETO
	1800	74	J. NIETO
	2100	74	J. NIETO
	2400	74	V. Nduku

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	72	V. Nduku
	0600	72	E. MENDOZA
	0900	72	E. MENDOZA
	1200	72	E. MENDOZA
	1500	72	[illegible]
	1800	72	[illegible]
	2100	72	[illegible]
	2400	72	W. COLBERT

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	72	W. COLBERT
	0600	72	[illegible]
	0900	72	M. [illegible]
	1200	72	M. [illegible]
	1500	72	S. MORENO
	1800	72	S. MORENO
	2100	70	S. MORENO
	2400	70	W. Colbert

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D1 (B-SIDE) Temp. Reading Location: 2ND TIER ABOVE DAYROOM TV (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/14/21	0300	74	W. COLBERT
	0600	74	B. COVERT
	0900	75	B. COVERT
	1200	75	B. COVERT
	1500	75	S. MORENO
	1800	75	S. MORENO
	2100	72	S. MORENO
	2400	74	W. COLBERT

Tuesday

Date	Time	Temp.	Name (Print)
10/15/21	0300	75	W. Colbert
	0600	75	B. COVERT
	0900	76	B. COVERT
	1200	76	B. COVERT
	1500	76	J. NIETO
	1800	75	J. NIETO
	2100	75	J. NIETO
	2400	74	W. COLBERT

Wednesday

Date	Time	Temp.	Name (Print)
10/16/21	0300	74	W. COLBERT
	0600	74	B. COVERT
	0900	75	B. COVERT
	1200	76	B. COVERT
	1500	76	J. NIETO
	1800	75	J. NIETO
	2100	75	J. NIETO
	2400	74	A. MALDONADO

Thursday

Date	Time	Temp.	Name (Print)
10/17/21	0300	74	A. MALDONADO
	0600	74	B. COVERT
	0900	75	B. COVERT
	1200	76	B. COVERT
	1500	76	J. NIETO
	1800	75	J. NIETO
	2100	75	J. NIETO
	2400	74	Devoto

Friday

Date	Time	Temp.	Name (Print)
10/18/21	0300	74	Devoto
	0600	74	B. COVERT
	0900	75	B. COVERT
	1200	75	B. COVERT
	1500	75	J. NIETO
	1800	75	J. NIETO
	2100	74	J. NIETO
	2400	74	V. Ndukwu

Saturday

Date	Time	Temp.	Name (Print)
10/19/21	0300	72	V. Ndukwu
	0600	72	E MENDOZ
	0900	72	E MENDOZ
	1200	72	E MENDOZ
	1500	72	[illegible]
	1800	72	[illegible]
	2100	72	[illegible]
	2400	72	W. COLBERT

Sunday

Date	Time	Temp.	Name (Print)
10/20/21	0300	72	W. COLBERT
	0600	72	[illegible]
	0900	72	M. Y[illegible]
	1200	72	M. Y[illegible]
	1500	72	S. MORENO
	1800	72	S. MORENO
	2100	70	S. MORENO
	2400	70	W. COLBERT

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D2 (A) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/14/24	0300	74	A. MALDONADO
	0600	74	M. CERDA
	0900	76	M. CERDA
	1200	76	M. CERDA
	1500	76	A. Meza
	1800	76	A Meza
	2100	76	A Meza
	2400	75	Villareal

Tuesday

Date	Time	Temp.	Name (Print)
10/15/24	0300	75	Villareal
	0600	74	Bolton
	0900	74	Bolton
	1200	76	Bolton
	1500	76	J. ESQUIVEL
	1800	76	J. ESQUIVEL
	2100	74	J. ESQUIVEL
	2400	74	R Roberts

Wednesday

Date	Time	Temp.	Name (Print)
10/16/24	0300	74	R Roberts
	0600	74	Bolton
	0900	74	Bolton
	1200	75	Bolton
	1500	75	Aguirre
	1800	75	Aguirre
	2100	75	Aguirre
	2400	74	R Roberts

Thursday

Date	Time	Temp.	Name (Print)
10/17/24	0300	74	R Roberts
	0600	74	Bolton
	0900	74	Bolton
	1200	75	Bolton
	1500	76	J Ferrer
	1800	77	J Ferrer
	2100	77	J Ferrer
	2400	74	R Roberts

Friday

Date	Time	Temp.	Name (Print)
10/18/24	0300	74	R Roberts
	0600	73	G. Contreras
	0900	74	G. Contreras
	1200	75	G. Contreras
	1500	75	A-MEZA
	1800	75	A. MEZA
	2100	74	A. MEZA
	2400	70	R Roberts

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	70	R Roberts
	0600	70	G. Contreras
	0900	70	G. Contreras
	1200	~~70~~	~~A-MEZA~~ AMW
	1500	71	A-MEZA
	1800	71	A Meza
	2100	71	Meza
	2400	70	R Roberts

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	70	R Roberts
	0600	70	Rodriguez
	0900	71	Rodriguez
	1200	72	Rodriguez
	1500	72	Meza
	1800	71	Meza
	2100	71	Meza
	2400	71	Villareal

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D2 (B) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/14/24	0300	74	A-MALDONADO
	0600	74	M. CERDA
	0900	76	M. CERDA
	1200	76	M. CERDA
	1500	76	A-MEZA
	1800	76	A Meza
	2100	76	A-MEZA
	2400	75	Villareal

Tuesday

Date	Time	Temp.	Name (Print)
10/15/24	0300	75	Villareal
	0600	74	Bethea
	0900	74	Bethea
	1200	76	Bethea
	1500	76	J. ESQUIVEL
	1800	77	J. ESQUIVEL
	2100	74	J. ESQUIVEL
	2400	79	R Roberts

Wednesday

Date	Time	Temp.	Name (Print)
10/16/24	0300	79	R Roberts
	0600	75	Bethea
	0900	75	Bethea
	1200	76	Bethea
	1500	77	Hamah
	1800	77	Hamah
	2100	77	Hamah
	2400	77	R Roberts

Thursday

Date	Time	Temp.	Name (Print)
10/17/24	0300	78	R Roberts
	0600	76	Bethea
	0900	76	Bethea
	1200	76	Bethea
	1500	74	J Perry
	1800	77	J Perry
	2100	77	J Perry
	2400	78	R Roberts

Friday

Date	Time	Temp.	Name (Print)
10/18/24	0300	78	R Roberts
	0600	74	G. Contreras
	0900	74	G. Contreras
	1200	75	G. Contreras
	1500	75	A-MEZA
	1800	75	A. MEZA
	2100	74	A MEZA
	2400	72	R Roberts

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	72	R Roberts
	0600	71	G. Contreras
	0900	71	G. Contreras
	1200	71	G. Contreras
	1500	71	A-MEZA
	1800	71	A Meza
	2100	71	A Meza
	2400	70	R Roberts

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	70	R Roberts
	0600	70	Rodriguez
	0900	71	Rodriguez
	1200	72	Rodriguez
	1500	71	MEZA
	1800	71	MEZA
	2100	71	MEZA
	2400	71	Villareal

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D3 (A) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/14/24	0300	68	D. MANCIAS
	0600	70	J. ESQUIVEL
	0900	70	J. ESQUIVEL
	1200	73	J. ESQUIVEL
	1500	75	A. MARIN
	1800	73	A. MARIN
	2100	74	A. MARIN
	2400	72	M. GRANT

Tuesday

Date	Time	Temp.	Name (Print)
10/15/24	0300	72	M. GRANT
	0600	72	J. ESQUIVEL
	0900	72	J. ESQUIVEL
	1200	74	J. ESQUIVEL
	1500	71	M. GRANT
	1800	71	M. GRANT
	2100	71	M. GRANT
	2400	71	M. GRANT

Wednesday

Date	Time	Temp.	Name (Print)
10/16/24	0300	71	M. GRANT
	0600	70	D. CASTREJON
	0900	71	D. CASTREJON
	1200	72	D. CASTREJON
	1500	75	A. MARIN
	1800	75	A. MARIN
	2100	75	A. MARIN
	2400	71	M. GRANT

Thursday

Date	Time	Temp.	Name (Print)
10/17/24	0300	71	M. GRANT
	0600	70	N. TOVAR
	0900	70	N. TOVAR
	1200	70	N. TOVAR
	1500	72	R. CISNEROS
	1800	72	R. CISNEROS
	2100	70	R. CISNEROS
	2400	70	M. GRANT

Friday

Date	Time	Temp.	Name (Print)
10/18/24	0300	70	M. GRANT
	0600	71	J. ESQUIVEL
	0900	73	J. ESQUIVEL
	1200	74	J. ESQUIVEL
	1500	74	S. MORENO
	1800	74	S. MORENO
	2100	71	S. MORENO
	2400	70	A. Dominguez

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	70	A. Dominguez
	0600	70	J. ESQUIVEL
	0900	71	J. ESQUIVEL
	1200	74	J. ESQUIVEL
	1500	74	V. Fernandez
	1800	73	V. Fernandez
	2100	71	V. Fernandez
	2400	71	G. Lincepes

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	70	G. Lincepes
	0600	70	S. MORENO
	0900	70	S. MORENO
	1200	70	S. MORENO
	1500	70	M. Yang
	1800	69	M. Yang
	2100	68	M. Yang
	2400	68	C. VALENCIA

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D3 (B) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/14/24	0300	68	D. Mancias
	0600	70	J. ESQUIVEL
	0900	72	J. ESQUIVEL
	1200	74	J. ESQUIVEL
	1500	75	A. Martinez
	1800	75	A. Martinez
	2100	75	A. Martinez
	2400	75	M. Garrett

Tuesday

Date	Time	Temp.	Name (Print)
10/15/24	0300	75	M Garrett
	0600	74	J. ESQUIVEL
	0900	74	J. ESQUIVEL
	1200	75	J. ESQUIVEL
	1500	75	M Garrett
	1800	75	M. Garrett
	2100	75	M. Garrett
	2400	75	M. Garrett

Wednesday

Date	Time	Temp.	Name (Print)
10/16/24	0300	75	M. Garrett
	0600	70	D. Castrejon
	0900	71	D. Castrejon
	1200	74	D. Castrejon
	1500	77	A. Martinez
	1800	76	A. Martinez
	2100	76	A. Martinez
	2400	74	M Garrett

Thursday

Date	Time	Temp.	Name (Print)
10/17/24	0300	74	M Garrett
	0600	70	N. Tovar
	0900	70	N. Tovar
	1200	70	N Tovar
	1500	72	R. Cisneros
	1800	72	R. Cisneros
	2100	70	R. Cisneros
	2400	72	M Garrett

Friday

Date	Time	Temp.	Name (Print)
10/18/24	0300	72	M Garrett
	0600	72	J. ESQUIVEL
	0900	74	J. ESQUIVEL
	1200	75	J. ESQUIVEL
	1500	75	S. Moreno
	1800	75	S. Moreno
	2100	71	S. Moreno
	2400	70	A. Dominguez

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	70	A Dominguez
	0600	70	J. ESQUIVEL
	0900	71	J. ESQUIVEL
	1200	73	J. ESQUIVEL
	1500	74	V. Fernandez
	1800	73	V. Fernandez
	2100	71	V. Fernandez
	2400	71	G. Linares

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	71	G. Linares
	0600	70	S. Moreno
	0900	70	S. Moreno
	1200	70	S. Moreno
	1500	70	M. Yang
	1800	69	M. Yang
	2100	68	M. Yang
	2400	68	C. VALENCIA

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. D - 4 (A) Side Temp. Reading Location: Tier 2 - Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-14-24	0300	74	S.Bacz
	0600	74	A Lopez
	0900	74	A Lopez
	1200	75	A. Lopez
	1500	74	Ayeola
	1800	74	Ayeola
	2100	74	Ayeola
	2400	74	S.Bacz

Tuesday

Date	Time	Temp.	Name (Print)
10-15-24	0300	74	S. Bacz
	0600	74	A Lopez
	0900	74	A Lopez
	1200	75	A Lopez
	1500	75	Ayeola
	1800	75	Ayeola
	2100	75	Ayeola
	2400	74	SBacz

Wednesday

Date	Time	Temp.	Name (Print)
10-16-24	0300	74	S.Bacz
	0600	74	A Lopez
	0900	74	A Lopez
	1200	75	A Lopez
	1500	74	R. PASCUA
	1800	74	R. PASCUA
	2100	74	R. PASCUA
	2400	74	[illegible]

Thursday

Date	Time	Temp.	Name (Print)
10-17-24	0300	74	[illegible]
	0600	74	D. Castrejon
	0900	74	D. Castrejon
	1200	75	D. Castrejon
	1500	75	R. PASCUA
	1800	75	R. PASCUA
	2100	75	R. PASCUA
	2400	75	J. Villareal

Friday

Date	Time	Temp.	Name (Print)
10-18-24	0300	75	J. Villareal
	0600	74	E MENDEZ
	0900	74	E MENDEZ
	1200	74	E MENDEZ
	1500	73	R. PASCUA
	1800	72	R. PASCUA
	2100	72	R. PASCUA
	2400	75	J. Villareal

Saturday

Date	Time	Temp.	Name (Print)
10-19-24	0300	72	J. Villareal
	0600	72	N. CRUZ
	0900	73	N. CRUZ
	1200	75	N. CRUZ
	1500	76	H. Gill
	1800	75	H. Gill
	2100	74	H. Gill
	2400	73	Drake

Sunday

Date	Time	Temp.	Name (Print)
10-20-24	0300	75	Drake
	0600	68	A Lopez
	0900	[illegible]	A Lopez
	1200	70	A. Lopez
	1500	71	J. Pena
	1800	70	J. Pena
	2100	68	J. Pena
	2400	68	D. Marcus

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. D - 4 (B) Side Temp. Reading Location: Tier 2 - Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-14-24	0300	74	S. Baez
	0600	74	A Lopez
	0900	74	A Lopez
	1200	75	A Lopez
	1500	74	Arreola
	1800	74	Arreola
	2100	74	Arreola
	2400	74	S. Baez

Tuesday

Date	Time	Temp.	Name (Print)
10-15-24	0300	74	S. Baez
	0600	74	A Lopez
	0900	74	A Lopez
	1200	75	A Lopez
	1500	75	Arreola
	1800	75	Arreola
	2100	75	Arreola
	2400	74	S. Baez

Wednesday

Date	Time	Temp.	Name (Print)
10-16-24	0300	74	S. Baez
	0600	74	A Lopez
	0900	74	A Lopez
	1200	75	A Lopez
	1500	74	R. PASCUA
	1800	74	R. PASCUA
	2100	74	R. PASCUA
	2400	74	JM

Thursday

Date	Time	Temp.	Name (Print)
10-17-24	0300	74	[illegible]
	0600	74	D. Castrejon
	0900	74	D. Castrejon
	1200	74	D. Castrejon
	1500	75	R. PASCUA
	1800	75	R. PASCUA
	2100	75	R. PASCUA
	2400	75	J. Villareal

Friday

Date	Time	Temp.	Name (Print)
10-18-24	0300	75	J. Villareal
	0600	74	E MENDOZA
	0900	74	E MENDOZA
	1200	74	E MENDOZA
	1500	73	R. PASCUA
	1800	72	R. PASCUA
	2100	72	R. PASCUA
	2400	75	J. Villareal

Saturday

Date	Time	Temp.	Name (Print)
10-19-24	0300	72	J. Villareal
	0600	72	N. CRUZ
	0900	73	N. CRUZ
	1200	75	N. CRUZ
	1500	76	H. Gold
	1800	75	H. Gold
	2100	74	H. Gold
	2400	78	Drake

Sunday

Date	Time	Temp.	Name (Print)
10-20-24	0300	78	Drake
	0600	68	A Lopez
	0900	68	A Lopez
	1200	70	A Lopez
	1500	70	J. Peng
	1800	70	J. Peng
	2100	68	J. Peng
	2400	68	D. Macias

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: 125 Aside Temp. Reading Location: 2nd Tier, Above Dayroom T.V.
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/14/24	0300	70	J. Sanchez
	0600	70	M. Serrato
	0900	70	M. Serrato
	1200	71	M. Serrato
	1500	71	[illegible]
	1800	72	[illegible]
	2100	73	[illegible]
	2400	72	J. Sanchez

Tuesday

Date	Time	Temp.	Name (Print)
10/15/24	0300	70	J. Sanchez
	0600	70	M. CERDA
	0900	71	M. CERDA
	1200	73	M. CERDA
	1500	72	N. Tovar
	1800	73	N. Tovar
	2100	72	N. Tovar
	2400	72	J. Sanchez

Wednesday

Date	Time	Temp.	Name (Print)
10/16/24	0300	70	J. Sanchez
	0600	70	RGuerrero
	0900	70	RGuerrero
	1200	72	RGuerrero
	1500	72	N. Tovar
	1800	71	N. Tovar
	2100	70	N. Tovar
	2400	70	J. Sanchez

Thursday

Date	Time	Temp.	Name (Print)
10/17/24	0300	68	J. Sanchez
	0600	68	RGuerrero
	0900	68	RGuerrero
	1200	70	RGuerrero
	1500	71	N. Tovar
	1800	72	N. Tovar
	2100	71	N. Tovar
	2400	70	M. Ayala

Friday

Date	Time	Temp.	Name (Print)
10/18/24	0300	69	M. Ayala
	0600	69	RGuerrero
	0900	69	RGuerrero
	1200	69	RGuerrero
	1500	70	G. Contreras
	1800	71	G. Contreras
	2100	70	G. Contreras
	2400	70	Diaz

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	69	Diaz
	0600	68	C. Ramirez
	0900	68	C. Ramirez
	1200	70	C. Ramirez
	1500	70	J. Sardinha
	1800	70	J. Sardinha
	2100	70	J. Sardinha
	2400	70	A. MACDONALD

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	70	A. MACDONALD
	0600	70	G. Contreras
	0900	70	G. Contreras
	1200	70	G. Contreras
	1500	70	B. CORRAL
	1800	70	B. CORRAL
	2100	70	B. CORRAL
	2400	70	M. Reynoso

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D5 BSide Temp. Reading Location: 2nd Tier, Above Dayroom T.V.
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/14/24	0300	70	J. Sanchez
	0600	70	M. Serrato
	0900	70	M. Serrato
	1200	71	M. Serrato
	1500	71	M. LULE
	1800	72	M. LULE
	2100	73	M. LULE
	2400	72	J. Sanchez

Tuesday

Date	Time	Temp.	Name (Print)
10/15/24	0300	70	J. Sanchez
	0600	71	M. CERDA
	0900	71	M. CERDA
	1200	72	M. CERDA
	1500	72	N. TOVAR
	1800	73	N. TOVAR
	2100	72	N. TOVAR
	2400	72	J. Sanchez

Wednesday

Date	Time	Temp.	Name (Print)
10/16/24	0300	70	J. Sanchez
	0600	70	R. Guerrero
	0900	70	R. Guerrero
	1200	72	R. Guerrero
	1500	72	N. TOVAR
	1800	71	N. TOVAR
	2100	70	N. TOVAR
	2400	70	J. Sanchez

Thursday

Date	Time	Temp.	Name (Print)
10/17/24	0300	68	J. Sanchez
	0600	68	R. Guerrero
	0900	68	R. Guerrero
	1200	70	R. Guerrero
	1500	71	N. TOVAR
	1800	72	N. TOVAR
	2100	71	N. TOVAR
	2400	70	M. Apodaca

Friday

Date	Time	Temp.	Name (Print)
10/18/24	0300	69	M. Apodaca
	0600	69	R. Guerrero
	0900	69	R. Guerrero
	1200	69	R. Guerrero
	1500	70	G. Contreras
	1800	71	G. Contreras
	2100	70	G. Contreras
	2400	70	Diaz

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	68	Diaz
	0600	68	C. Ramirez
	0900	68	C. Ramirez
	1200	70	C. Ramirez
	1500	70	J. Sardinha
	1800	70	J. Sardinha
	2100	70	J. Sardinha
	2400	70	A. MACKENZIE

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	70	A. MACKENZIE
	0600	70	G. Contreras
	0900	70	G. Contreras
	1200	70	G. Contreras
	1500	70	B. CORRAL
	1800	70	B. CORRAL
	2100	70	B. CORRAL
	2400	70	M. Ramirez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D-6 (A) Side Temp. Reading Location: Tier 2 - Above Dayroom TV (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-14-24	0300	70	D. SANTOYO
	0600	70	STANTON
	0900	71	STANTON
	1200	72	STANTON
	1500	73	R. Aguilar
	1800	73	R. Aguilar
	2100	73	R. Aguilar
	2400	72	D. SANTOYO

Tuesday

Date	Time	Temp.	Name (Print)
10-15-24	0300	71	D. SANTOYO
	0600	71	Medin
	0900	72	Medin
	1200	73	Medin
	1500	73	R. Aguilar
	1800	73	R. Aguilar
	2100	73	R. Aguilar
	2400	71	D. SANTOYO

Wednesday

Date	Time	Temp.	Name (Print)
10-16-24	0300	71	D. SANTOYO
	0600	71	Medin
	0900	72	Medin
	1200	73	Medin
	1500	74	M. VASQUEZ
	1800	72	M. VASQUEZ
	2100	71	M. VASQUEZ
	2400	70	M. VASQUEZ

Thursday

Date	Time	Temp.	Name (Print)
10-17-24	0300	70	M. VASQUEZ
	0600	70	Medin
	0900	71	Medin
	1200	72	Medin
	1500	71	M. VASQUEZ
	1800	71	M. VASQUEZ
	2100	71	M. VASQUEZ
	2400	71	A. Arreola

Friday

Date	Time	Temp.	Name (Print)
10-18-24	0300	71	A. Arreola
	0600	71	Medina
	0900	72	Medina
	1200	73	Medin
	1500	72	M. VASQUEZ
	1800	71	M. VASQUEZ
	2100	71	M. VASQUEZ
	2400	70	M. VASQUEZ

Saturday

Date	Time	Temp.	Name (Print)
10-19-24	0300	70	M. VASQUEZ
	0600	70	Medin
	0900	71	Medin
	1200	72	Medin
	1500	71	Jaramillo
	1800	71	Jaramillo
	2100	70	Jaramillo
	2400	69	D. SANTOYO

Sunday

Date	Time	Temp.	Name (Print)
10-20-24	0300	68	D. SANTOYO
	0600	68	ETOLIVA
	0900	69	ETOLIVA
	1200	72	ETOLIVA
	1500	72	D. SANTOYO
	1800	71	D. SANTOYO
	2100	70	D. SANTOYO
	2400	69	D. SANTOYO

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D-6 (B) Side Temp. Reading Location: Tier 2 - Above Dayroom TV (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-14-24	0300	71	D. SANTOYO
	0600	71	STANTON
	0900	72	STANTON
	1200	73	STANTON
	1500	74	R. Aguilar
	1800	74	R. Aguilar
	2100	74	R. Aguilar
	2400	73	D. SANTOYO

Tuesday

Date	Time	Temp.	Name (Print)
10-15-24	0300	72	D. SANTOYO
	0600	72	Medina
	0900	72	Medina
	1200	73	Medina
	1500	74	R. Aguilar
	1800	74	R. Aguilar
	2100	74	R. Aguilar
	2400	73	D. SANTOYO

Wednesday

Date	Time	Temp.	Name (Print)
10-16-24	0300	72	D. SANTOYO
	0600	71	Medina
	0900	72	Medina
	1200	73	Medina
	1500	74	M. VASQUEZ
	1800	72	M. VASQUEZ
	2100	71	M. VASQUEZ
	2400	70	M. VASQUEZ

Thursday

Date	Time	Temp.	Name (Print)
10-17-24	0300	70	[illegible]
	0600	70	[illegible]
	0900	71	[illegible]
	1200	72	[illegible]
	1500	71	M. VASQUEZ
	1800	71	M. VASQUEZ
	2100	71	M. VASQUEZ
	2400	71	A. Arrala

Friday

Date	Time	Temp.	Name (Print)
10-18-24	0300	71	A. Arrala
	0600	71	Medina
	0900	72	Medina
	1200	73	Medina
	1500	73	M. VASQUEZ
	1800	73	M VASQUEZ
	2100	72	M VASQUEZ
	2400	71	M VASQUEZ

Saturday

Date	Time	Temp.	Name (Print)
10-19-24	0300	70	[illegible]
	0600	70	[illegible]
	0900	71	[illegible]
	1200	72	[illegible]
	1500	71	Jaramillo
	1800	71	Jaramillo
	2100	70	Jaramillo
	2400	70	D. SANTOYO

Sunday

Date	Time	Temp.	Name (Print)
10-20-24	0300	69	D. SANTOYO
	0600	70	ETOLBERT
	0900	70	ETOLBERT
	1200	71	E. TOLBERT
	1500	71	D. SANTOYO
	1800	70	D. SANTOYO
	2100	70	D. SANTOYO
	2400	69	D. SANTOYO

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. M Dorm 1 A-SIDE Temp. Reading Location: 1st Tier - Behind C/O Podium (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/14/24	0300	78	L. TORRES
	0600	76	J. Landeros
	0900	76	J. Landeros
	1200	76	J. Landeros
	1500	77	R. DURAN
	1800	77	R. DURAN
	2100	77	R. DURAN
	2400	76°	J. LOPEZ

Tuesday

Date	Time	Temp.	Name (Print)
10/15/24	0300	72°	J. Lopez
	0600	74	J. Landeros
	0900	76	J. Landeros
	1200	76	J. Landeros
	1500	77	R. DURAN
	1800	77	R. DURAN
	2100	77	R. DURAN
	2400	76	D. Ramirez

Wednesday

Date	Time	Temp.	Name (Print)
10/16/24	0300	74	D. Ramirez
	0600	74°	M. VEGA
	0900	74°	M. VEGA
	1200	75	M. VEGA
	1500	77	M. Rains
	1800	77	M. Rains
	2100	77	M. Rains
	2400	76	V. Nbulaw

Thursday

Date	Time	Temp.	Name (Print)
10/17/24	0300	~~75~~	[illegible]
	0600	73°	M. VEGA
	0900	73°	M. VEGA
	1200	73°	M. VEGA
	1500	76	M. Rains
	1800	76	M. Rains
	2100	76	M. Rains
	2400	74°	J. Lopez

Friday

Date	Time	Temp.	Name (Print)
10/18/24	0300	70°	J. Lopez
	0600	70°	M. VEGA
	0900	70°	M. VEGA
	1200	70°	M. VEGA
	1500	72°	M. Rains
	1800	70	M. Rains
	2100	70	M. Rains
	2400	69°	J. Lopez

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	67°	J. Lopez
	0600	67°	M. VEGA
	0900	67°	M. VEGA
	1200	68°	M. VEGA
	1500	70	R. DURAN
	1800	70	R. DURAN
	2100	70	R. DURAN
	2400	69°	L. TORRES

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	70°	L. TORRES
	0600	70	[illegible]
	0900	70	[illegible]
	1200	70	[illegible]
	1500	70	C. Mibrey
	1800	75	C. Mibrey
	2100	75	C. Mibrey
	2400	74	L. TORRES

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. M Dorm 1 B-SIDE Temp. Reading Location: 1st Tier - Behind C/O Podium (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/14/24	0300	78	L. TORRES
	0600	76	J. Lamberos
	0900	76	J. Lamberos
	1200	76	J. Lamberos
	1500	77	R. DURAN
	1800	77	R. DURAN
	2100	77	R. DURAN
	2400	76°	J. LOPEZ

Tuesday

Date	Time	Temp.	Name (Print)
10/15/24	0300	72	J. LOPEZ
	0600	74	J. Lamberos
	0900	76	J. Lamberos
	1200	76	J. Lamberos
	1500	77	R. DURAN
	1800	77	R. DURAN
	2100	77	R. DURAN
	2400	76	D. RANGEL

Wednesday

Date	Time	Temp.	Name (Print)
10/16/24	0300	74	D. RONQUILLO
	0600	74°	M. VEGA
	0900	74°	M. VEGA
	1200	75°	M. VEGA
	1500	77	M. Rains
	1800	77	M. Rains
	2100	77	M. Rains
	2400	76	V. NOWLAN

Thursday

Date	Time	Temp.	Name (Print)
10/17/24	0300	75	V. NOWLAN
	0600	73°	M. VEGA
	0900	73°	M. VEGA
	1200	73°	M. VEGA
	1500	76	M. Rains
	1800	76	M. Rains
	2100	76	M. Rains
	2400	74	J. LOPEZ

Friday

Date	Time	Temp.	Name (Print)
10/18/24	0300	70	J. LOPEZ
	0600	70°	M. VEGA
	0900	70°	M. VEGA
	1200	70°	M. VEGA
	1500	72	M. Rains
	1800	70	M. Rains
	2100	70	M. Rains
	2400	69	J. LOPEZ

Saturday

Date	Time	Temp.	Name (Print)
10/19/24	0300	67	J. LOPEZ
	0600	67°	M. VEGA
	0900	67°	M. VEGA
	1200	68°	M. VEGA
	1500	70	R. DURAN
	1800	70	R. DURAN
	2100	70	R. DURAN
	2400	69	L. TORRES

Sunday

Date	Time	Temp.	Name (Print)
10/20/24	0300	70	L. TORRES
	0600	70	Guillen A
	0900	70	Guillen
	1200	70	Guillen
	1500	70	C. McGregor
	1800	75	C. McGregor
	2100	75	C. McGregor
	2400	74	C. TORRES

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: M-DORM-2 A-SIDE Temp. Reading Location: BEHIND PODIUM (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10	0300	74	C. HOUSE
	0600	70	VARGAS
	0900	70	VARGAS
14	1200	72	VARGAS
	1500	74	FRYZ
	1800	74	FRYZ
24	2100	74	FRYZ
	2400	73	L. TORRES

Tuesday

Date	Time	Temp.	Name (Print)
10	0300	74	L. TORRES
	0600	74	Gonzalez
	0900	74	Gonzalez
15	1200	74	Gonzalez
	1500	76°	Z. Jones
24	1800	74°	Z. Jones
	2100	74°	Z. Jones
	2400	73°	L. TORRES

Wednesday

Date	Time	Temp.	Name (Print)
10	0300	72	L. TORRES
	0600	72	S. CROWDER
	0900	73	S. CROWDER
16	1200	74	S. CROWDER
	1500	74	J. Medina
24	1800	74	J medina
	2100	74	J medina
	2400	74°	K. Madrigal

Thursday

Date	Time	Temp.	Name (Print)
10	0300	74°	K. Madrigal
	0600	70	VARGAS
	0900	70	VARGAS
17	1200	71	VARGAS
	1500	72	J. Medina
24	1800	72	J Medina
	2100	72	J Medina
	2400	72°	K. Madrigal

Friday

Date	Time	Temp.	Name (Print)
10	0300	70	K. Madrigal
	0600	69	VARGAS
	0900	69	VARGAS
18	1200	69	VARGAS
	1500	70	Medina
24	1800	70	J Medina
	2100	70	J Medina
	2400	69	S hill

Saturday

Date	Time	Temp.	Name (Print)
10	0300	69	S. Hill
	0600	70	M. Garcia
	0900	70	M. Garcia
19	1200	70	M. Garcia
	1500	70	J. Medina
24	1800	69	J medina
	2100	69	J Medina
	2400	69	S-hill

Sunday

Date	Time	Temp.	Name (Print)
10	0300	68	S. hill
	0600	65	VARGAS
	0900	67	VARGAS
20	1200	67	VARGAS
	1500	68	J. Medina
24	1800	68	J Medin-
	2100	68	J Medina
	2400	68	C. HOUSE

Notes

UHT	ACTIVATED	DEACTIVATED
10-14		
10-15		
10-16		
10-17		
10-18		
10-19		
10-20		

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: M-DORM-2 B-SIDE Temp. Reading Location: BEHIND PODIUM (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10	0300	74	C. HOUSE
	0600	70	VARGAS
	0900	70	VARGAS
14	1200	72	VARGAS
	1500	74	FRITZ
	1800	74	FRITZ
24	2100	74	FRITZ
	2400	73.	L TORRES

Tuesday

Date	Time	Temp.	Name (Print)
10	0300	74	L. TORRES
	0600	74	Gonzalez
	0900	74	Gonzalez
15	1200	74	Gonzalez
	1500	76°	Z. Jones
	1800	74°	Z. Jones
24	2100	74°	Z. Jones
	2400	73	C. TORRES

Wednesday

Date	Time	Temp.	Name (Print)
10	0300	72	L. TORRES
	0600	72	S. CROWER
	0900	73	S. CROWER
16	1200	74	S. CROWER
	1500	74	J. Medina
	1800	74	J Medina
24	2100	74	J Medina
	2400	74°	K. Madrigal

Thursday

Date	Time	Temp.	Name (Print)
10	0300	74°	K. Madrigal
	0600	70	VARGAS
	0900	70	VARGAS
17	1200	71	VARGAS
	1500	72	J. Medina
	1800	72	J Medina
24	2100	72	J Medina
	2400	72°	K. Madrigal

Friday

Date	Time	Temp.	Name (Print)
10	0300	70	K. Madrigal
	0600	69	VARGAS
	0900	69	VARGAS
18	1200	69	VARGAS
	1500	70	J. Medina
	1800	70	J Medina
24	2100	70	J Medina
	2400	69	S. Hill

Saturday

Date	Time	Temp.	Name (Print)
10	0300	69	S. Hill
	0600	70	M. Garcia
	0900	70	M. Garcia
19	1200	70	M. Garcia
	1500	70	J. Medina
	1800	69	J. Medina
24	2100	69	J Medina
	2400	69	S. Hill

Sunday

Date	Time	Temp.	Name (Print)
10	0300	68	S. Hill
	0600	65	VARGAS
	0900	67	VARGAS
20	1200	67	VARGAS
	1500	68	J Medina
	1800	68	J Medina
24	2100	68	J Medina
	2400	68	C. HOUSE

Notes

WHT	ACTIVATED	DEACTIVATED
10-14		
10-15		
10-16		
10-17		
10-18		
10-19		
10-20		

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: CTC/INF Temp. Reading Location: Above Isolation Log (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-14-24	0300	71.0	Y. Fernandez
	0600	71.2	Reyes
	0900	71.3	Reyes
	1200	71.3	Reyes
	1500	71.4	Penetta
	1800	71.4	Penetta
	2100	72.5	Penetta
	2400	72.3	Y. Fernandez

Tuesday

Date	Time	Temp.	Name (Print)
10-15-24	0300	72.1	Y. Fernandez
	0600	73.0	Y. Fernandez
	0900	73.2	Reyes
	1200	72.0	Reyes
	1500	72.1	I. Alvarez
	1800	72.1	I. Alvarez
	2100	72.1	I. Alvarez
	2400	72.3	Y. Fernandez

Wednesday

Date	Time	Temp.	Name (Print)
10-16-24	0300	73.0	Y. Fernandez
	0600	73.0	Y. Fernandez
	0900	73.0	Brown
	1200	73.0	Brown
	1500	72.7	Bonetta
	1800	72.4	I. Alvarez
	2100	72.1	Bonetta
	2400	72.3	H. Saez

Thursday

Date	Time	Temp.	Name (Print)
10-17-24	0300	72.7	H. Saez
	0600	73.0	H. Saez
	0900	73.0	H. Saez
	1200	72.9	H. Saez
	1500	72.1	I. Alvarez
	1800	72.1	I. Alvarez
	2100	72.1	I. Alvarez
	2400	72.4	J. Rodriguez

Friday

Date	Time	Temp.	Name (Print)
10-18-24	0300	73.2	J. Rodriguez
	0600	73.2	H. Saez
	0900	73.2	H. Saez
	1200	73.2	H. Saez
	1500	72.3	Penetta
	1800	73.2	Penetta
	2100	73.2	Penetta
	2400	72.2	J. Rodriguez

Saturday

Date	Time	Temp.	Name (Print)
10-19-24	0300	72.1	J. Rodriguez
	0600	72.1	Brown
	0900	72.1	Brown
	1200	72.1	Brown
	1500	71.8	I. Alvarez
	1800	72.7	Penetta
	2100	73.0	I. Alvarez
	2400	72.0	V. Diaz

Sunday

Date	Time	Temp.	Name (Print)
10-20-24	0300	71.0	V. Diaz
	0600	72.5	V. Diaz
	0900	72.5	Brown
	1200	72.4	Brown
	1500	72.2	Dra
	1800	72.3	Dra
	2100	71.4	Dra
	2400	72.3	Y. Fernandez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

OUTSIDE TEMPERATURE RECORD
CDCR 2030 (04/18)

INSTITUTION: North Kern State Prison

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the OUTSIDE ambient air temperature.

Using an accurate thermometer located in a central, heat neutral location, the outside air temperature is to be taken every hour, seven (7) days a week.

Thermometer Location: Central Control Rooftop

Immediately notify the Watch Commander at extension 3141 **when the air temperature reaches 90 degrees.**

Date	Time	Temp.	Printed Name
10-14-24	0100	61	ARIAS
	0200	60	ARIAS
	0300	59	ARIAS
	0400	59	ARIAS
	0500	58	ARIAS
	0600	57	Gonzalez
	0700	57	Gonzalez
	0800	57	Gonzalez
	0900	64	Gonzalez
	1000	70	Gonzalez
	1100	73	Gonzalez
	1200	76	Gonzalez
	1300	79	Gonzalez
	1400	81	Gonzalez
	1500	83	Gonzalez
	1600	84	Gonzalez
	1700	83	Gonzalez
	1800	81	Gonzalez
	1900	78	Gonzalez
	2000	75	Gonzalez
	2100	72	Gonzalez
	2200	69	ARIAS
	2300	68	ARIAS
	2400	65	ARIAS

Date	Time	Temp.	Printed Name
10-15-24	0100	64	ARIAS
	0200	63	ARIAS
	0300	61	ARIAS
	0400	60	ARIAS
	0500	59	ARIAS
	0600	59	Jung
	0700	57	Jung
	0800	59	Jung
	0900	65	Jung
	1000	71	Jung
	1100	75	Jung
	1200	77	Jung
	1300	80	Jung
	1400	82	Moncibaiz
	1500	84	Moncibaiz
	1600	84	Moncibaiz
	1700	84	Moncibaiz
	1800	82	Moncibaiz
	1900	80	Moncibaiz
	2000	77	Moncibaiz
	2100	73	Moncibaiz
	2200	71	Padilla
	2300	68	Padilla
	2400	65	Padilla

DISTRIBUTION: Original: Institution Heat Plan Coordinator

NKSP 10/14/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/14/24	12:15a	62.3	63.1	62.3	25	26.0	2.0	ESE	0.50	4.0	SE	62.3	58.0	58.0	30.124	0.00	0.00	0.028	0.000
10/14/24	12:30a	62.0	62.3	61.9	26	26.7	2.0	SE	0.50	4.0	SE	62.0	57.9	57.9	30.118	0.00	0.00	0.031	0.000
10/14/24	12:45a	61.6	62.0	61.6	27	27.3	1.0	SE	0.25	4.0	SE	61.6	57.6	57.6	30.118	0.00	0.00	0.035	0.000
10/14/24	1:00a	61.4	61.6	61.3	28	28.0	2.0	SE	0.50	4.0	SE	61.4	57.6	57.6	30.119	0.00	0.00	0.037	0.000
10/14/24	1:15a	60.8	61.4	60.8	29	28.3	0.0	SE	0.00	2.0	SE	60.8	57.2	57.2	30.120	0.00	0.00	0.044	0.000
10/14/24	1:30a	60.8	60.9	60.6	30	29.1	1.0	SE	0.25	4.0	SE	60.8	57.3	57.3	30.124	0.00	0.00	0.044	0.000
10/14/24	1:45a	60.3	60.8	60.3	31	29.5	2.0	SE	0.50	4.0	SE	60.3	57.0	57.0	30.122	0.00	0.00	0.049	0.000
10/14/24	2:00a	60.2	60.3	60.0	31	29.4	2.0	SE	0.50	5.0	SE	60.2	56.9	56.9	30.128	0.00	0.00	0.050	0.000
10/14/24	2:15a	59.8	60.2	59.7	31	29.1	2.0	SE	0.50	4.0	SE	59.8	56.5	56.5	30.127	0.00	0.00	0.054	0.000
10/14/24	2:30a	59.9	60.0	59.8	30	28.4	2.0	SE	0.50	4.0	SE	59.9	56.5	56.5	30.127	0.00	0.00	0.053	0.000
10/14/24	2:45a	59.5	59.9	59.5	31	28.8	3.0	SE	0.75	6.0	ESE	59.5	56.2	56.2	30.128	0.00	0.00	0.057	0.000
10/14/24	3:00a	59.6	59.7	59.4	30	28.1	2.0	SE	0.50	6.0	ESE	59.6	56.2	56.2	30.126	0.00	0.00	0.056	0.000
10/14/24	3:15a	59.3	59.7	59.3	29	27.0	3.0	SE	0.75	6.0	ESE	59.3	55.8	55.8	30.129	0.00	0.00	0.059	0.000
10/14/24	3:30a	59.3	59.4	59.2	29	27.0	3.0	SE	0.75	5.0	SE	59.3	55.8	55.8	30.131	0.00	0.00	0.059	0.000
10/14/24	3:45a	59.0	59.3	59.0	30	27.6	2.0	S	0.50	5.0	S	59.0	55.7	55.7	30.132	0.00	0.00	0.063	0.000
10/14/24	4:00a	59.4	59.4	59.0	31	28.7	1.0	S	0.25	4.0	S	59.4	56.1	56.1	30.131	0.00	0.00	0.058	0.000
10/14/24	4:15a	59.0	59.4	59.0	32	29.2	2.0	SSE	0.50	5.0	SSE	59.0	55.8	55.8	30.131	0.00	0.00	0.063	0.000
10/14/24	4:30a	59.0	59.2	59.0	31	28.4	2.0	SSE	0.50	4.0	SSE	59.0	55.8	55.8	30.133	0.00	0.00	0.063	0.000
10/14/24	4:45a	58.3	59.1	58.3	32	28.5	0.0	SSE	0.00	3.0	SSE	58.3	55.2	55.2	30.139	0.00	0.00	0.070	0.000
10/14/24	5:00a	58.2	58.4	58.0	32	28.5	1.0	SE	0.25	4.0	SE	58.2	55.1	55.1	30.139	0.00	0.00	0.071	0.000
10/14/24	5:15a	58.0	58.2	57.9	32	28.3	2.0	SE	0.50	4.0	SE	58.0	54.9	54.9	30.140	0.00	0.00	0.073	0.000
10/14/24	5:30a	57.9	58.1	57.7	32	28.2	2.0	SE	0.50	4.0	SE	57.9	54.8	54.8	30.142	0.00	0.00	0.074	0.000
10/14/24	5:45a	57.5	58.0	57.5	32	27.8	2.0	SE	0.50	6.0	ESE	57.5	54.5	54.5	30.144	0.00	0.00	0.078	0.000
10/14/24	6:00a	57.3	57.6	57.2	32	27.7	3.0	SE	0.75	5.0	SE	57.3	54.3	54.3	30.150	0.00	0.00	0.080	0.000
10/14/24	6:15a	57.3	57.5	57.2	31	26.9	3.0	SE	0.75	5.0	SE	57.3	54.2	54.2	30.154	0.00	0.00	0.080	0.000
10/14/24	6:30a	56.8	57.3	56.8	32	27.2	4.0	SE	1.00	5.0	SE	56.8	53.8	53.8	30.158	0.00	0.00	0.085	0.000
10/14/24	6:45a	56.6	56.9	56.6	33	27.8	3.0	SSE	0.75	5.0	SSE	56.6	53.7	53.7	30.159	0.00	0.00	0.088	0.000
10/14/24	7:00a	57.0	57.0	56.6	33	28.1	3.0	SE	0.75	5.0	SSE	57.0	54.1	54.1	30.163	0.00	0.00	0.083	0.000
10/14/24	7:15a	56.8	57.0	56.8	33	28.0	3.0	SE	0.75	5.0	SE	56.8	53.9	53.9	30.165	0.00	0.00	0.085	0.000
10/14/24	7:30a	56.6	56.8	56.5	34	28.5	3.0	SE	0.75	7.0	SE	56.6	53.8	53.8	30.167	0.00	0.00	0.088	0.000
10/14/24	7:45a	57.1	57.1	56.6	33	28.2	4.0	SE	1.00	7.0	SE	57.1	54.2	54.2	30.170	0.00	0.00	0.082	0.000
10/14/24	8:00a	57.7	57.7	57.1	34	29.5	2.0	SSE	0.50	4.0	SE	57.7	54.8	54.8	30.176	0.00	0.00	0.076	0.000
10/14/24	8:15a	59.3	59.3	57.8	34	30.9	2.0	SSE	0.50	4.0	SSE	59.3	56.2	56.2	30.180	0.00	0.00	0.059	0.000
10/14/24	8:30a	61.3	61.3	59.3	32	31.2	3.0	S	0.75	8.0	SSW	61.3	58.0	58.0	30.183	0.00	0.00	0.039	0.000
10/14/24	8:45a	63.0	63.0	61.3	30	31.0	3.0	S	0.75	8.0	S	63.0	59.5	59.5	30.188	0.00	0.00	0.021	0.000
10/14/24	9:00a	64.4	64.4	63.0	28	30.6	3.0	SSW	0.75	6.0	S	64.4	60.5	60.5	30.190	0.00	0.00	0.006	0.000
10/14/24	9:15a	66.1	66.1	64.4	26	30.2	2.0	SSW	0.50	5.0	SSW	66.1	61.8	61.8	30.194	0.00	0.00	0.000	0.011
10/14/24	9:30a	68.1	68.1	66.1	23	28.9	3.0	SSE	0.75	7.0	S	68.1	63.9	63.9	30.193	0.00	0.00	0.000	0.032
10/14/24	9:45a	69.7	69.7	68.1	21	28.0	3.0	S	0.75	9.0	S	69.7	65.3	65.3	30.193	0.00	0.00	0.000	0.049
10/14/24	10:00a	70.5	70.5	69.6	19	26.2	4.0	SW	1.00	7.0	SSW	70.5	66.2	66.2	30.191	0.00	0.00	0.000	0.057
10/14/24	10:15a	71.3	71.3	70.5	17	24.2	3.0	SSW	0.75	9.0	WSW	71.3	67.1	67.1	30.195	0.00	0.00	0.000	0.066
10/14/24	10:30a	72.3	72.3	71.3	15	22.0	3.0	WSW	0.75	8.0	WSW	72.3	68.3	68.3	30.190	0.00	0.00	0.000	0.076
10/14/24	10:45a	72.4	72.4	72.1	15	22.1	4.0	W	1.00	11.0	W	72.4	68.5	68.5	30.188	0.00	0.00	0.000	0.077
10/14/24	11:00a	73.6	73.6	72.5	13	19.7	5.0	WSW	1.25	10.0	WSW	73.6	69.9	69.9	30.184	0.00	0.00	0.000	0.090
10/14/24	11:15a	74.9	74.9	73.6	10	14.6	5.0	WSW	1.25	11.0	WSW	74.9	71.2	71.2	30.183	0.00	0.00	0.000	0.103
10/14/24	11:30a	75.2	75.3	74.9	9	12.4	6.0	WNW	1.50	13.0	W	75.2	71.4	71.4	30.182	0.00	0.00	0.000	0.106
10/14/24	11:45a	75.8	75.8	75.0	8	10.2	4.0	NW	1.00	11.0	NW	75.8	71.8	71.8	30.179	0.00	0.00	0.000	0.113
10/14/24	12:00p	76.2	76.2	75.8	7	7.5	5.0	W	1.25	9.0	W	76.2	72.0	72.0	30.177	0.00	0.00	0.000	0.117
10/14/24	12:15p	77.5	77.5	76.2	5	1.2	3.0	WNW	0.75	10.0	WNW	77.5	73.6	73.6	30.172	0.00	0.00	0.000	0.130
10/14/24	12:30p	77.6	77.7	77.4	5	1.2	4.0	W	1.00	9.0	WNW	77.6	73.7	73.7	30.166	0.00	0.00	0.000	0.131

NKSP 10/14/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/14/24	12:45p	78.5	78.5	77.6	4	-2.9	3.0	NW	0.75	10.0	NNW	78.5	74.6	74.6	30.151	0.00	0.00	0.000	0.141
10/14/24	1:00p	79.1	79.1	78.5	3	-8.4	4.0	WNW	1.00	9.0	NW	79.1	75.0	75.0	30.148	0.00	0.00	0.000	0.147
10/14/24	1:15p	79.6	79.8	79.1	2	-16.3	4.0	NW	1.00	10.0	WNW	79.6	75.3	75.3	30.143	0.00	0.00	0.000	0.152
10/14/24	1:30p	80.2	80.2	79.6	0	---	4.0	W	1.00	12.0	W	80.2	75.7	75.7	30.132	0.00	0.00	0.000	0.158
10/14/24	1:45p	81.1	81.1	80.2	0	---	3.0	WSW	0.75	8.0	WNW	81.1	76.5	76.5	30.127	0.00	0.00	0.000	0.168
10/14/24	2:00p	81.4	81.4	81.0	0	---	5.0	WNW	1.25	11.0	NW	81.4	76.8	76.8	30.121	0.00	0.00	0.000	0.171
10/14/24	2:15p	82.0	82.1	81.4	0	---	5.0	W	1.25	10.0	W	82.0	77.4	77.4	30.112	0.00	0.00	0.000	0.177
10/14/24	2:30p	82.2	82.3	81.9	0	---	6.0	W	1.50	13.0	NW	82.2	77.6	77.6	30.111	0.00	0.00	0.000	0.179
10/14/24	2:45p	82.6	82.6	82.2	0	---	5.0	NW	1.25	11.0	WNW	82.6	77.9	77.9	30.106	0.00	0.00	0.000	0.183
10/14/24	3:00p	83.2	83.2	82.6	0	---	4.0	WNW	1.00	9.0	WNW	83.2	78.5	78.5	30.102	0.00	0.00	0.000	0.190
10/14/24	3:15p	83.3	83.5	83.1	0	---	4.0	NW	1.00	10.0	NNE	83.3	78.5	78.5	30.098	0.00	0.00	0.000	0.191
10/14/24	3:30p	83.5	83.5	83.1	0	---	5.0	NW	1.25	12.0	NNE	83.5	78.7	78.7	30.098	0.00	0.00	0.000	0.193
10/14/24	3:45p	83.8	83.8	83.3	0	---	5.0	NNW	1.25	11.0	NW	83.8	78.9	78.9	30.094	0.00	0.00	0.000	0.196
10/14/24	4:00p	84.0	84.0	83.6	0	---	5.0	NW	1.25	10.0	WNW	84.0	79.1	79.1	30.088	0.00	0.00	0.000	0.198
10/14/24	4:15p	83.8	84.0	83.7	0	---	6.0	NW	1.50	12.0	NW	83.8	78.9	78.9	30.089	0.00	0.00	0.000	0.196
10/14/24	4:30p	83.8	83.9	83.7	0	---	4.0	NNW	1.00	9.0	NNW	83.8	78.9	78.9	30.085	0.00	0.00	0.000	0.196
10/14/24	4:45p	83.8	84.1	83.7	0	---	4.0	NNW	1.00	8.0	NW	83.8	78.9	78.9	30.085	0.00	0.00	0.000	0.196
10/14/24	5:00p	83.6	83.8	83.6	0	---	4.0	NNW	1.00	9.0	NNW	83.6	78.8	78.8	30.085	0.00	0.00	0.000	0.194
10/14/24	5:15p	83.4	83.6	83.3	0	---	4.0	NNW	1.00	8.0	NW	83.4	78.6	78.6	30.083	0.00	0.00	0.000	0.192
10/14/24	5:30p	83.1	83.4	83.1	0	---	4.0	NNW	1.00	8.0	NW	83.1	78.4	78.4	30.083	0.00	0.00	0.000	0.189
10/14/24	5:45p	82.6	83.1	82.6	0	---	3.0	NNW	0.75	8.0	NNW	82.6	77.9	77.9	30.084	0.00	0.00	0.000	0.183
10/14/24	6:00p	81.8	82.6	81.8	0	---	2.0	NNW	0.50	5.0	NNW	81.8	77.2	77.2	30.092	0.00	0.00	0.000	0.175
10/14/24	6:15p	81.0	81.8	81.0	0	---	2.0	NNW	0.50	4.0	NNW	81.0	76.4	76.4	30.091	0.00	0.00	0.000	0.167
10/14/24	6:30p	79.9	81.0	79.9	0	---	1.0	N	0.25	3.0	NNW	79.9	75.4	75.4	30.090	0.00	0.00	0.000	0.155
10/14/24	6:45p	79.2	79.9	79.2	0	---	0.0	N	0.00	2.0	N	79.2	74.7	74.7	30.093	0.00	0.00	0.000	0.148
10/14/24	7:00p	78.6	79.2	78.6	1	-30.0	0.0	---	0.00	0.0	---	78.6	74.2	74.2	30.099	0.00	0.00	0.000	0.142
10/14/24	7:15p	77.8	78.6	77.7	2	-17.4	0.0	---	0.00	0.0	---	77.8	73.6	73.6	30.101	0.00	0.00	0.000	0.133
10/14/24	7:30p	76.8	77.8	76.8	3	-10.0	0.0	---	0.00	0.0	---	76.8	72.4	72.4	30.106	0.00	0.00	0.000	0.123
10/14/24	7:45p	76.3	76.8	76.2	5	0.3	0.0	---	0.00	0.0	---	76.3	71.8	71.8	30.107	0.00	0.00	0.000	0.118
10/14/24	8:00p	75.6	76.2	75.6	6	3.7	0.0	---	0.00	0.0	---	75.6	71.3	71.3	30.111	0.00	0.00	0.000	0.110
10/14/24	8:15p	75.1	75.6	75.0	5	-0.6	0.0	---	0.00	0.0	---	75.1	70.9	70.9	30.112	0.00	0.00	0.000	0.105
10/14/24	8:30p	74.8	75.1	74.7	7	6.5	0.0	---	0.00	0.0	---	74.8	70.8	70.8	30.114	0.00	0.00	0.000	0.102
10/14/24	8:45p	74.9	75.1	74.8	7	6.6	0.0	---	0.00	0.0	---	74.9	70.9	70.9	30.116	0.00	0.00	0.000	0.103
10/14/24	9:00p	72.4	74.9	72.4	9	10.3	1.0	ESE	0.25	4.0	E	72.4	67.7	67.7	30.115	0.00	0.00	0.000	0.077
10/14/24	9:15p	72.2	72.4	71.8	12	16.7	2.0	ESE	0.50	4.0	ESE	72.2	67.8	67.8	30.120	0.00	0.00	0.000	0.075
10/14/24	9:30p	71.2	72.2	71.2	14	19.5	2.0	ESE	0.50	4.0	SE	71.2	66.7	66.7	30.118	0.00	0.00	0.000	0.065
10/14/24	9:45p	70.8	71.3	70.8	15	20.8	3.0	SE	0.75	4.0	SE	70.8	66.2	66.2	30.120	0.00	0.00	0.000	0.060
10/14/24	10:00p	69.7	70.8	69.7	18	24.3	2.0	SE	0.50	3.0	SE	69.7	65.0	65.0	30.122	0.00	0.00	0.000	0.049
10/14/24	10:15p	68.8	69.7	68.8	19	24.8	1.0	SE	0.25	3.0	SE	68.8	64.1	64.1	30.131	0.00	0.00	0.000	0.040
10/14/24	10:30p	68.7	68.9	68.4	20	26.0	2.0	SE	0.50	3.0	SE	68.7	64.1	64.1	30.131	0.00	0.00	0.000	0.039
10/14/24	10:45p	68.3	68.7	68.3	20	25.6	0.0	SE	0.00	3.0	SE	68.3	63.7	63.7	30.126	0.00	0.00	0.000	0.034
10/14/24	11:00p	68.0	68.4	68.0	20	25.4	1.0	SE	0.25	3.0	SE	68.0	63.4	63.4	30.131	0.00	0.00	0.000	0.031
10/14/24	11:15p	67.2	67.9	67.2	21	25.9	1.0	SE	0.25	3.0	SE	67.2	62.4	62.4	30.132	0.00	0.00	0.000	0.023
10/14/24	11:30p	67.0	67.4	67.0	22	26.9	0.0	SE	0.00	3.0	SE	67.0	62.3	62.3	30.130	0.00	0.00	0.000	0.021
10/14/24	11:45p	66.3	67.0	66.2	23	27.4	0.0	SE	0.00	3.0	SE	66.3	61.6	61.6	30.135	0.00	0.00	0.000	0.014
10/15/24	12:00a	65.8	66.3	65.8	23	26.9	0.0	SE	0.00	2.0	SE	65.8	61.2	61.2	30.134	0.00	0.00	0.000	0.008

NKSP 10/15/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/15/24	12:15a	65.1	65.8	65.1	24	27.4	0.0	SE	0.00	2.0	SE	65.1	60.6	60.6	30.137	0.00	0.00	0.000	0.001
10/15/24	12:30a	64.6	65.1	64.6	24	27.0	0.0	SE	0.00	2.0	SE	64.6	60.1	60.1	30.134	0.00	0.00	0.004	0.000
10/15/24	12:45a	64.4	64.6	64.3	26	28.7	0.0	SE	0.00	2.0	SE	64.4	60.2	60.2	30.133	0.00	0.00	0.006	0.000
10/15/24	1:00a	64.5	64.5	64.3	27	29.7	0.0	SE	0.00	2.0	SE	64.5	60.5	60.5	30.134	0.00	0.00	0.005	0.000
10/15/24	1:15a	64.3	64.5	64.3	27	29.6	0.0	---	0.00	0.0	---	64.3	60.3	60.3	30.130	0.00	0.00	0.007	0.000
10/15/24	1:30a	64.2	64.3	64.1	28	30.4	0.0	---	0.00	0.0	---	64.2	60.3	60.3	30.129	0.00	0.00	0.008	0.000
10/15/24	1:45a	64.4	64.4	64.2	29	31.4	0.0	---	0.00	0.0	---	64.4	60.7	60.7	30.132	0.00	0.00	0.006	0.000
10/15/24	2:00a	63.5	64.4	63.5	28	29.8	0.0	---	0.00	0.0	---	63.5	59.6	59.6	30.133	0.00	0.00	0.016	0.000
10/15/24	2:15a	63.4	63.6	63.3	29	30.6	0.0	---	0.00	0.0	---	63.4	59.7	59.7	30.131	0.00	0.00	0.017	0.000
10/15/24	2:30a	63.2	63.5	63.2	28	29.5	0.0	---	0.00	0.0	---	63.2	59.3	59.3	30.132	0.00	0.00	0.019	0.000
10/15/24	2:45a	62.5	63.3	62.5	28	28.9	0.0	---	0.00	0.0	---	62.5	58.7	58.7	30.132	0.00	0.00	0.026	0.000
10/15/24	3:00a	61.8	62.5	61.8	29	29.3	0.0	---	0.00	0.0	---	61.8	58.1	58.1	30.132	0.00	0.00	0.033	0.000
10/15/24	3:15a	61.4	62.0	61.3	29	28.8	0.0	---	0.00	0.0	---	61.4	57.8	57.8	30.130	0.00	0.00	0.037	0.000
10/15/24	3:30a	60.6	61.3	60.6	30	29.0	0.0	---	0.00	0.0	---	60.6	57.1	57.1	30.127	0.00	0.00	0.046	0.000
10/15/24	3:45a	60.4	60.7	60.4	30	28.8	0.0	---	0.00	0.0	---	60.4	57.0	57.0	30.128	0.00	0.00	0.048	0.000
10/15/24	4:00a	60.0	60.4	60.0	31	29.2	0.0	---	0.00	0.0	---	60.0	56.7	56.7	30.124	0.00	0.00	0.052	0.000
10/15/24	4:15a	59.8	60.0	59.8	31	29.1	0.0	---	0.00	0.0	---	59.8	56.5	56.5	30.123	0.00	0.00	0.054	0.000
10/15/24	4:30a	59.5	59.8	59.5	32	29.6	0.0	---	0.00	0.0	---	59.5	56.3	56.3	30.126	0.00	0.00	0.057	0.000
10/15/24	4:45a	59.5	59.6	59.4	32	29.6	0.0	---	0.00	0.0	---	59.5	56.3	56.3	30.126	0.00	0.00	0.057	0.000
10/15/24	5:00a	59.1	59.5	59.1	32	29.2	0.0	---	0.00	0.0	---	59.1	55.9	55.9	30.131	0.00	0.00	0.061	0.000
10/15/24	5:15a	58.9	59.1	58.7	33	29.8	0.0	---	0.00	0.0	---	58.9	55.8	55.8	30.131	0.00	0.00	0.064	0.000
10/15/24	5:30a	59.2	59.6	58.9	31	28.5	0.0	---	0.00	0.0	---	59.2	55.9	55.9	30.136	0.00	0.00	0.060	0.000
10/15/24	5:45a	58.9	59.2	58.7	32	29.1	0.0	---	0.00	0.0	---	58.9	55.7	55.7	30.139	0.00	0.00	0.064	0.000
10/15/24	6:00a	59.1	59.2	58.8	32	29.2	0.0	---	0.00	0.0	---	59.1	55.9	55.9	30.140	0.00	0.00	0.061	0.000
10/15/24	6:15a	58.2	59.1	58.2	32	28.5	0.0	---	0.00	0.0	---	58.2	55.1	55.1	30.142	0.00	0.00	0.071	0.000
10/15/24	6:30a	58.3	58.3	58.1	34	30.0	0.0	---	0.00	0.0	---	58.3	55.3	55.3	30.143	0.00	0.00	0.070	0.000
10/15/24	6:45a	57.8	58.3	57.8	33	28.9	1.0	S	0.25	6.0	S	57.8	54.8	54.8	30.146	0.00	0.00	0.075	0.000
10/15/24	7:00a	57.3	57.7	57.3	34	29.1	0.0	S	0.00	2.0	S	57.3	54.4	54.4	30.147	0.00	0.00	0.080	0.000
10/15/24	7:15a	57.7	57.8	57.3	34	29.5	0.0	SSE	0.00	4.0	SSE	57.7	54.8	54.8	30.149	0.00	0.00	0.076	0.000
10/15/24	7:30a	57.6	57.7	57.5	34	29.4	1.0	SSE	0.25	4.0	SSE	57.6	54.7	54.7	30.150	0.00	0.00	0.077	0.000
10/15/24	7:45a	58.1	58.1	57.6	35	30.6	2.0	SE	0.50	3.0	SE	58.1	55.2	55.2	30.150	0.00	0.00	0.072	0.000
10/15/24	8:00a	59.0	59.0	58.1	34	30.6	1.0	SE	0.25	3.0	SE	59.0	55.9	55.9	30.157	0.00	0.00	0.063	0.000
10/15/24	8:15a	59.5	59.5	58.9	33	30.3	2.0	SE	0.50	4.0	SE	59.5	56.4	56.4	30.159	0.00	0.00	0.057	0.000
10/15/24	8:30a	61.1	61.1	59.6	33	31.8	2.0	SE	0.50	4.0	SE	61.1	57.8	57.8	30.162	0.00	0.00	0.041	0.000
10/15/24	8:45a	63.3	63.3	61.1	30	31.3	0.0	SE	0.00	2.0	SE	63.3	59.8	59.8	30.163	0.00	0.00	0.018	0.000
10/15/24	9:00a	65.4	65.4	63.3	25	26.6	0.0	SSE	0.00	2.0	SE	65.4	61.0	61.0	30.163	0.00	0.00	0.000	0.004
10/15/24	9:15a	66.6	66.6	65.4	22	26.5	1.0	SSE	0.25	2.0	SSE	66.6	61.9	61.9	30.163	0.00	0.00	0.000	0.017
10/15/24	9:30a	68.3	68.3	66.6	21	26.8	1.0	WSW	0.25	4.0	SW	68.3	63.8	63.8	30.161	0.00	0.00	0.000	0.034
10/15/24	9:45a	70.0	70.0	68.3	18	24.5	2.0	WSW	0.50	5.0	SW	70.0	65.3	65.3	30.159	0.00	0.00	0.000	0.052
10/15/24	10:00a	71.6	71.6	70.0	15	21.5	2.0	SW	0.50	7.0	SSW	71.6	67.3	67.3	30.154	0.00	0.00	0.000	0.069
10/15/24	10:15a	72.9	72.9	71.6	13	19.1	3.0	SSE	0.75	6.0	SSW	72.9	68.9	68.9	30.151	0.00	0.00	0.000	0.082
10/15/24	10:30a	73.6	73.6	72.9	11	15.8	3.0	SSW	0.75	8.0	S	73.6	69.6	69.6	30.152	0.00	0.00	0.000	0.090
10/15/24	10:45a	74.5	74.5	73.6	10	14.3	3.0	SSW	0.75	8.0	S	74.5	70.7	70.7	30.149	0.00	0.00	0.000	0.099
10/15/24	11:00a	75.6	75.6	74.5	8	10.1	3.0	S	0.75	7.0	S	75.6	71.6	71.6	30.151	0.00	0.00	0.000	0.110
10/15/24	11:15a	76.3	76.4	75.6	7	7.6	2.0	S	0.50	8.0	W	76.3	72.1	72.1	30.147	0.00	0.00	0.000	0.118
10/15/24	11:30a	76.8	76.8	76.3	6	4.6	2.0	SW	0.50	8.0	W	76.8	72.7	72.7	30.142	0.00	0.00	0.000	0.123
10/15/24	11:45a	77.4	77.4	76.8	4	-3.7	4.0	W	1.00	9.0	NW	77.4	73.3	73.3	30.133	0.00	0.00	0.000	0.129
10/15/24	12:00p	77.7	77.8	77.3	4	-3.4	4.0	NW	1.00	9.0	NW	77.7	73.7	73.7	30.131	0.00	0.00	0.000	0.132
10/15/24	12:15p	78.7	78.7	77.8	2	-16.8	3.0	WSW	0.75	8.0	WNW	78.7	74.5	74.5	30.124	0.00	0.00	0.000	0.143
10/15/24	12:30p	79.1	79.1	78.7	1	-29.7	5.0	W	1.25	10.0	W	79.1	74.7	74.7	30.121	0.00	0.00	0.000	0.147

NKSP 10/15/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/15/24	12:45p	79.8	79.8	79.1	0	---	4.0	W	1.00	10.0	W	79.8	75.3	75.3	30.114	0.00	0.00	0.000	0.154
10/15/24	1:00p	80.5	80.6	79.8	---	---	5.0	NW	1.25	10.0	NNW	80.5	---	---	30.105	0.00	0.00	0.000	0.161
10/15/24	1:15p	81.4	81.5	80.4	0	---	4.0	NNW	1.00	16.0	NNW	81.4	76.8	76.8	30.094	0.00	0.00	0.000	0.171
10/15/24	1:30p	81.2	81.5	81.2	0	---	5.0	WNW	1.25	11.0	W	81.2	76.6	76.6	30.087	0.00	0.00	0.000	0.169
10/15/24	1:45p	82.3	82.3	81.2	0	---	4.0	NW	1.00	12.0	NW	82.3	77.7	77.7	30.075	0.00	0.00	0.000	0.180
10/15/24	2:00p	82.5	82.8	82.2	0	---	5.0	NNW	1.25	11.0	NNW	82.5	77.9	77.9	30.071	0.00	0.00	0.000	0.182
10/15/24	2:15p	83.1	83.1	82.4	0	---	4.0	NNE	1.00	9.0	NW	83.1	78.4	78.4	30.064	0.00	0.00	0.000	0.189
10/15/24	2:30p	83.3	83.3	83.0	0	---	5.0	NNW	1.25	10.0	NNE	83.3	78.5	78.5	30.059	0.00	0.00	0.000	0.191
10/15/24	2:45p	83.7	83.9	83.3	0	---	4.0	NNE	1.00	13.0	N	83.7	78.9	78.9	30.054	0.00	0.00	0.000	0.195
10/15/24	3:00p	84.2	84.2	83.4	0	---	4.0	NW	1.00	11.0	N	84.2	79.3	79.3	30.053	0.00	0.00	0.000	0.200
10/15/24	3:15p	84.1	84.2	83.8	0	---	4.0	W	1.00	10.0	WNW	84.1	79.2	79.2	30.052	0.00	0.00	0.000	0.199
10/15/24	3:30p	84.3	84.4	84.2	0	---	5.0	NW	1.25	10.0	NW	84.3	79.4	79.4	30.051	0.00	0.00	0.000	0.201
10/15/24	3:45p	84.2	84.3	84.1	0	---	5.0	NW	1.25	10.0	NW	84.2	79.3	79.3	30.048	0.00	0.00	0.000	0.200
10/15/24	4:00p	84.3	84.3	84.0	0	---	6.0	WNW	1.50	12.0	WNW	84.3	79.4	79.4	30.042	0.00	0.00	0.000	0.201
10/15/24	4:15p	84.6	84.9	84.3	0	---	5.0	NW	1.25	9.0	NNW	84.6	79.6	79.6	30.041	0.00	0.00	0.000	0.204
10/15/24	4:30p	84.5	84.6	84.4	0	---	5.0	NNW	1.25	9.0	N	84.5	79.6	79.6	30.038	0.00	0.00	0.000	0.203
10/15/24	4:45p	85.1	85.1	84.5	0	---	5.0	NW	1.25	10.0	NW	85.1	80.1	80.1	30.030	0.00	0.00	0.000	0.209
10/15/24	5:00p	84.6	85.1	84.6	0	---	5.0	NNW	1.25	9.0	NW	84.6	79.6	79.6	30.030	0.00	0.00	0.000	0.204
10/15/24	5:15p	84.4	84.7	84.4	0	---	4.0	NNW	1.00	10.0	NNW	84.4	79.5	79.5	30.031	0.00	0.00	0.000	0.202
10/15/24	5:30p	84.0	84.4	84.0	0	---	5.0	NW	1.25	9.0	NW	84.0	79.1	79.1	30.032	0.00	0.00	0.000	0.198
10/15/24	5:45p	83.5	84.0	83.4	0	---	3.0	NNW	0.75	7.0	NW	83.5	78.7	78.7	30.030	0.00	0.00	0.000	0.193
10/15/24	6:00p	82.7	83.4	82.7	0	---	2.0	NNW	0.50	3.0	NNW	82.7	78.0	78.0	30.032	0.00	0.00	0.000	0.184
10/15/24	6:15p	81.9	82.8	81.9	0	---	1.0	NNW	0.25	3.0	NNW	81.9	77.3	77.3	30.033	0.00	0.00	0.000	0.176
10/15/24	6:30p	81.1	82.0	81.1	0	---	0.0	NNW	0.00	1.0	NNW	81.1	76.5	76.5	30.034	0.00	0.00	0.000	0.168
10/15/24	6:45p	80.8	81.1	80.8	0	---	0.0	---	0.00	0.0	---	80.8	76.2	76.2	30.037	0.00	0.00	0.000	0.165
10/15/24	7:00p	80.3	80.8	80.2	0	---	0.0	---	0.00	0.0	---	80.3	75.8	75.8	30.043	0.00	0.00	0.000	0.159
10/15/24	7:15p	79.6	80.3	79.6	0	---	0.0	---	0.00	0.0	---	79.6	75.1	75.1	30.045	0.00	0.00	0.000	0.152
10/15/24	7:30p	78.9	79.6	78.9	0	---	0.0	---	0.00	0.0	---	78.9	74.4	74.4	30.049	0.00	0.00	0.000	0.145
10/15/24	7:45p	78.1	78.9	78.1	1	-30.3	0.0	---	0.00	0.0	---	78.1	73.8	73.8	30.050	0.00	0.00	0.000	0.136
10/15/24	8:00p	77.2	78.1	77.2	4	-3.8	0.0	S	0.00	1.0	SSW	77.2	73.0	73.0	30.051	0.00	0.00	0.000	0.127
10/15/24	8:15p	75.4	77.2	75.4	8	9.9	0.0	S	0.00	3.0	S	75.4	71.5	71.5	30.056	0.00	0.00	0.000	0.108
10/15/24	8:30p	74.2	75.4	74.1	9	11.7	0.0	SSE	0.00	4.0	S	74.2	70.1	70.1	30.056	0.00	0.00	0.000	0.096
10/15/24	8:45p	73.0	74.2	73.0	11	15.3	0.0	SSE	0.00	1.0	SSE	73.0	68.8	68.8	30.060	0.00	0.00	0.000	0.083
10/15/24	9:00p	73.0	73.0	72.4	13	19.2	0.0	SSE	0.00	2.0	SSE	73.0	69.1	69.1	30.062	0.00	0.00	0.000	0.083
10/15/24	9:15p	72.4	73.0	72.4	12	16.9	1.0	SSE	0.25	3.0	SSE	72.4	68.1	68.1	30.068	0.00	0.00	0.000	0.077
10/15/24	9:30p	71.3	72.4	71.3	16	22.7	2.0	ESE	0.50	4.0	ESE	71.3	67.0	67.0	30.066	0.00	0.00	0.000	0.066
10/15/24	9:45p	71.8	71.8	71.3	16	23.2	2.0	ESE	0.50	4.0	ESE	71.8	67.7	67.7	30.072	0.00	0.00	0.000	0.071
10/15/24	10:00p	71.8	72.0	71.7	17	24.6	1.0	ESE	0.25	3.0	ESE	71.8	67.8	67.8	30.076	0.00	0.00	0.000	0.071
10/15/24	10:15p	70.4	71.8	70.4	19	26.1	1.0	ESE	0.25	3.0	ESE	70.4	66.0	66.0	30.081	0.00	0.00	0.000	0.056
10/15/24	10:30p	69.6	70.5	69.6	19	25.5	1.0	ESE	0.25	2.0	ESE	69.6	65.0	65.0	30.085	0.00	0.00	0.000	0.048
10/15/24	10:45p	69.1	69.5	69.1	20	26.3	0.0	ESE	0.00	2.0	ESE	69.1	64.5	64.5	30.080	0.00	0.00	0.000	0.043
10/15/24	11:00p	68.1	69.0	68.1	20	25.5	0.0	---	0.00	0.0	---	68.1	63.5	63.5	30.083	0.00	0.00	0.000	0.032
10/15/24	11:15p	66.8	68.2	66.8	20	24.4	0.0	---	0.00	0.0	---	66.8	61.9	61.9	30.079	0.00	0.00	0.000	0.019
10/15/24	11:30p	66.2	66.8	66.0	23	27.3	0.0	SSE	0.00	3.0	SE	66.2	61.5	61.5	30.074	0.00	0.00	0.000	0.012
10/15/24	11:45p	65.8	66.3	65.8	24	28.0	1.0	SSE	0.25	4.0	SSE	65.8	61.2	61.2	30.077	0.00	0.00	0.000	0.008
10/16/24	12:00a	65.3	65.8	65.3	24	27.5	0.0	---	0.00	0.0	---	65.3	60.8	60.8	30.075	0.00	0.00	0.000	0.003

NKSP 10/14/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/14/24	12:15a	76.4	55	59.0	76.6	9.99	.0733	351	1	100.0	15
10/14/24	12:30a	76.2	53	57.8	76.3	9.65	.0734	351	1	100.0	15
10/14/24	12:45a	76.1	55	58.8	76.3	10.01	.0733	351	1	100.0	15
10/14/24	1:00a	76.2	51	56.7	76.2	9.35	.0734	351	1	100.0	15
10/14/24	1:15a	76.1	54	58.2	76.2	9.83	.0734	352	1	100.0	15
10/14/24	1:30a	76.2	51	56.7	76.2	9.35	.0734	351	1	100.0	15
10/14/24	1:45a	76.0	54	58.2	76.1	9.83	.0734	351	1	100.0	15
10/14/24	2:00a	76.0	50	56.0	75.9	9.23	.0735	351	1	100.0	15
10/14/24	2:15a	75.9	54	58.1	76.0	9.83	.0734	352	1	100.0	15
10/14/24	2:30a	75.4	50	55.5	75.3	9.24	.0736	351	1	100.0	15
10/14/24	2:45a	75.3	54	57.5	75.4	9.84	.0735	351	1	100.0	15
10/14/24	3:00a	75.1	51	55.7	75.1	9.35	.0736	351	1	100.0	15
10/14/24	3:15a	74.9	54	57.1	75.0	9.85	.0736	351	1	100.0	15
10/14/24	3:30a	74.7	52	55.9	74.7	9.56	.0737	352	1	100.0	15
10/14/24	3:45a	75.0	54	57.2	75.1	9.85	.0736	351	1	100.0	15
10/14/24	4:00a	75.4	51	56.0	75.4	9.35	.0736	351	1	100.0	15
10/14/24	4:15a	75.6	53	57.3	75.7	9.65	.0735	351	1	100.0	15
10/14/24	4:30a	75.7	50	55.7	75.6	9.24	.0735	352	1	100.0	15
10/14/24	4:45a	75.6	53	57.3	75.7	9.65	.0735	351	1	100.0	15
10/14/24	5:00a	75.8	49	55.3	75.6	9.03	.0736	351	1	100.0	15
10/14/24	5:15a	75.5	53	57.2	75.6	9.65	.0735	351	1	100.0	15
10/14/24	5:30a	75.8	49	55.3	75.6	9.03	.0736	352	1	100.0	15
10/14/24	5:45a	75.5	53	57.2	75.6	9.65	.0735	351	1	100.0	15
10/14/24	6:00a	75.8	52	56.9	75.8	9.53	.0735	351	1	100.0	15
10/14/24	6:15a	75.7	51	56.3	75.7	9.35	.0736	351	1	100.0	15
10/14/24	6:30a	75.4	52	56.5	75.4	9.54	.0736	351	1	100.0	15
10/14/24	6:45a	75.7	52	56.8	75.7	9.54	.0735	352	1	100.0	15
10/14/24	7:00a	75.8	48	54.7	75.5	8.93	.0736	351	1	100.0	15
10/14/24	7:15a	75.4	52	56.5	75.4	9.54	.0736	351	1	100.0	15
10/14/24	7:30a	75.6	52	56.7	75.6	9.54	.0736	351	1	100.0	15
10/14/24	7:45a	75.8	48	54.7	75.5	8.93	.0737	352	1	100.0	15
10/14/24	8:00a	75.4	52	56.5	75.4	9.54	.0737	351	1	100.0	15
10/14/24	8:15a	75.8	52	56.9	75.8	9.53	.0736	351	1	100.0	15
10/14/24	8:30a	75.7	51	56.3	75.7	9.35	.0736	351	1	100.0	15
10/14/24	8:45a	76.0	52	57.1	76.0	9.53	.0736	352	1	100.0	15
10/14/24	9:00a	75.9	51	56.5	75.9	9.35	.0736	351	1	100.0	15
10/14/24	9:15a	76.1	53	57.7	76.2	9.65	.0736	351	1	100.0	15
10/14/24	9:30a	76.1	52	57.2	76.1	9.53	.0736	351	1	100.0	15
10/14/24	9:45a	76.4	53	58.0	76.5	9.65	.0735	351	1	100.0	15
10/14/24	10:00a	76.4	53	58.0	76.5	9.65	.0735	352	1	100.0	15
10/14/24	10:15a	76.8	50	56.8	76.7	9.21	.0735	351	1	100.0	15
10/14/24	10:30a	76.8	53	58.4	76.9	9.65	.0734	351	1	100.0	15
10/14/24	10:45a	76.9	52	57.9	76.9	9.51	.0734	351	1	100.0	15
10/14/24	11:00a	77.2	49	56.6	77.0	9.01	.0734	352	1	100.0	15
10/14/24	11:15a	77.6	52	58.6	77.7	9.50	.0733	351	1	100.0	15
10/14/24	11:30a	77.6	53	59.1	77.7	9.65	.0733	351	1	100.0	15
10/14/24	11:45a	77.8	52	58.8	77.9	9.49	.0732	351	1	100.0	15
10/14/24	12:00p	78.1	48	56.8	77.8	8.89	.0733	351	1	100.0	15
10/14/24	12:15p	78.3	52	59.2	78.4	9.48	.0731	352	1	100.0	15
10/14/24	12:30p	78.3	52	59.2	78.4	9.48	.0731	351	1	100.0	15

NKSP 10/14/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/14/24	12:45p	78.4	50	58.2	78.4	9.18	.0731	351	1	100.0	15
10/14/24	1:00p	78.6	48	57.3	78.3	8.88	.0731	351	1	100.0	15
10/14/24	1:15p	78.8	49	58.0	78.7	8.97	.0731	352	1	100.0	15
10/14/24	1:30p	79.0	50	58.8	79.0	9.17	.0730	351	1	100.0	15
10/14/24	1:45p	79.0	50	58.8	79.0	9.17	.0730	351	1	100.0	15
10/14/24	2:00p	79.0	49	58.2	78.9	8.97	.0730	352	1	100.0	15
10/14/24	2:15p	79.0	47	57.0	78.6	8.67	.0730	351	1	100.0	15
10/14/24	2:30p	78.9	46	56.4	78.4	8.47	.0730	351	1	100.0	15
10/14/24	2:45p	78.9	47	57.0	78.5	8.67	.0730	351	1	100.0	15
10/14/24	3:00p	78.6	48	57.3	78.3	8.88	.0730	351	1	100.0	15
10/14/24	3:15p	78.4	45	55.3	77.7	8.38	.0731	351	1	100.0	15
10/14/24	3:30p	78.5	45	55.4	77.9	8.38	.0731	352	1	100.0	15
10/14/24	3:45p	78.5	47	56.6	78.1	8.68	.0730	351	1	100.0	15
10/14/24	4:00p	78.6	45	55.5	78.0	8.38	.0730	351	1	100.0	15
10/14/24	4:15p	78.7	44	55.0	78.0	8.18	.0731	351	1	100.0	15
10/14/24	4:30p	78.7	45	55.6	78.1	8.38	.0730	352	1	100.0	15
10/14/24	4:45p	78.5	49	57.7	78.4	8.98	.0730	351	1	100.0	15
10/14/24	5:00p	78.3	46	55.8	77.8	8.48	.0731	351	1	100.0	15
10/14/24	5:15p	78.5	44	54.8	77.7	8.18	.0731	351	1	100.0	15
10/14/24	5:30p	78.7	46	56.2	78.2	8.48	.0730	352	1	100.0	15
10/14/24	5:45p	78.4	48	57.1	78.1	8.88	.0730	351	1	100.0	15
10/14/24	6:00p	77.9	45	54.8	77.2	8.39	.0732	351	1	100.0	15
10/14/24	6:15p	78.1	44	54.4	77.3	8.19	.0732	351	1	100.0	15
10/14/24	6:30p	78.2	48	56.9	77.9	8.89	.0730	351	1	100.0	15
10/14/24	6:45p	77.7	49	57.0	77.5	9.00	.0731	352	1	100.0	15
10/14/24	7:00p	77.7	46	55.3	77.2	8.50	.0732	351	1	100.0	15
10/14/24	7:15p	77.8	47	56.0	77.4	8.69	.0732	351	1	100.0	15
10/14/24	7:30p	77.6	51	58.0	77.6	9.35	.0731	351	1	100.0	15
10/14/24	7:45p	77.6	50	57.5	77.6	9.20	.0731	352	1	100.0	15
10/14/24	8:00p	77.9	49	57.2	77.8	8.99	.0731	351	1	100.0	15
10/14/24	8:15p	78.2	48	56.9	77.9	8.89	.0731	351	1	100.0	15
10/14/24	8:30p	78.1	52	59.0	78.2	9.49	.0730	351	1	100.0	15
10/14/24	8:45p	78.1	51	58.5	78.2	9.35	.0731	352	1	100.0	15
10/14/24	9:00p	77.8	50	57.7	77.8	9.19	.0731	351	1	100.0	15
10/14/24	9:15p	78.0	49	57.3	77.9	8.99	.0731	351	1	100.0	15
10/14/24	9:30p	77.9	53	59.4	78.1	9.65	.0731	351	1	100.0	15
10/14/24	9:45p	77.6	51	58.0	77.6	9.35	.0732	351	1	100.0	15
10/14/24	10:00p	77.8	50	57.7	77.8	9.19	.0732	352	1	100.0	15
10/14/24	10:15p	77.6	54	59.6	77.8	9.80	.0731	351	1	100.0	15
10/14/24	10:30p	77.5	51	57.9	77.5	9.35	.0732	351	1	100.0	15
10/14/24	10:45p	77.6	55	60.2	77.9	9.95	.0731	351	1	100.0	15
10/14/24	11:00p	77.3	52	58.3	77.3	9.50	.0732	352	1	100.0	15
10/14/24	11:15p	77.5	56	60.6	77.8	10.15	.0731	351	1	100.0	15
10/14/24	11:30p	77.0	54	59.1	77.1	9.81	.0732	351	1	100.0	15
10/14/24	11:45p	77.1	54	59.2	77.3	9.81	.0732	351	1	100.0	15
10/15/24	12:00a	76.8	55	59.4	77.0	9.98	.0732	352	1	100.0	15

NKSP 10/15/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/15/24	12:15a	77.0	52	58.0	77.0	9.51	.0733	350	1	100.0	15
10/15/24	12:30a	76.7	55	59.3	76.9	9.98	.0733	351	1	100.0	15
10/15/24	12:45a	76.6	52	57.7	76.6	9.52	.0733	351	1	100.0	15
10/15/24	1:00a	76.7	56	59.8	77.0	10.18	.0732	352	1	100.0	15
10/15/24	1:15a	76.4	54	58.5	76.5	9.82	.0733	351	1	100.0	15
10/15/24	1:30a	76.6	52	57.7	76.6	9.52	.0733	351	1	100.0	15
10/15/24	1:45a	76.3	55	58.9	76.5	10.00	.0733	351	1	100.0	15
10/15/24	2:00a	76.4	52	57.5	76.4	9.52	.0734	352	1	100.0	15
10/15/24	2:15a	76.1	55	58.8	76.3	10.01	.0734	351	1	100.0	15
10/15/24	2:30a	76.4	53	58.0	76.5	9.65	.0734	351	1	100.0	15
10/15/24	2:45a	76.0	55	58.7	76.2	10.01	.0734	351	1	100.0	15
10/15/24	3:00a	76.3	53	57.9	76.4	9.65	.0734	352	1	100.0	15
10/15/24	3:15a	75.9	55	58.6	76.1	10.01	.0734	351	1	100.0	15
10/15/24	3:30a	76.2	55	58.9	76.4	10.00	.0733	351	1	100.0	15
10/15/24	3:45a	75.8	54	58.0	75.9	9.83	.0734	351	1	100.0	15
10/15/24	4:00a	75.9	55	58.6	76.1	10.01	.0734	351	1	100.0	15
10/15/24	4:15a	75.8	53	57.4	75.9	9.65	.0734	352	1	100.0	15
10/15/24	4:30a	75.8	54	58.0	75.9	9.83	.0734	351	1	100.0	15
10/15/24	4:45a	75.8	51	56.4	75.8	9.35	.0735	351	1	100.0	15
10/15/24	5:00a	75.7	54	57.9	75.8	9.84	.0735	351	1	100.0	15
10/15/24	5:15a	75.9	54	58.1	76.0	9.83	.0734	352	1	100.0	15
10/15/24	5:30a	75.5	53	57.2	75.6	9.65	.0735	351	1	100.0	15
10/15/24	5:45a	75.8	54	58.0	75.9	9.83	.0735	351	1	100.0	15
10/15/24	6:00a	75.8	52	56.9	75.8	9.53	.0735	351	1	100.0	15
10/15/24	6:15a	75.8	54	58.0	75.9	9.83	.0735	351	1	100.0	15
10/15/24	6:30a	76.2	52	57.3	76.2	9.53	.0734	352	1	100.0	15
10/15/24	6:45a	75.8	53	57.4	75.9	9.65	.0735	351	1	100.0	15
10/15/24	7:00a	76.0	54	58.2	76.1	9.83	.0734	351	1	100.0	15
10/15/24	7:15a	75.9	52	57.0	75.9	9.53	.0735	351	1	100.0	15
10/15/24	7:30a	75.8	54	58.0	75.9	9.83	.0735	352	1	100.0	15
10/15/24	7:45a	76.1	52	57.2	76.1	9.53	.0735	351	1	100.0	15
10/15/24	8:00a	75.7	54	57.9	75.8	9.84	.0735	351	1	100.0	15
10/15/24	8:15a	76.2	54	58.3	76.3	9.83	.0734	351	1	100.0	15
10/15/24	8:30a	75.9	53	57.5	76.0	9.65	.0735	352	1	100.0	15
10/15/24	8:45a	76.2	54	58.3	76.3	9.83	.0734	351	1	100.0	15
10/15/24	9:00a	76.2	53	57.8	76.3	9.65	.0735	351	1	100.0	15
10/15/24	9:15a	76.5	54	58.6	76.6	9.82	.0734	351	1	100.0	15
10/15/24	9:30a	76.4	53	58.0	76.5	9.65	.0734	351	1	100.0	15
10/15/24	9:45a	76.8	53	58.4	76.9	9.65	.0733	352	1	100.0	15
10/15/24	10:00a	76.6	53	58.2	76.7	9.65	.0734	351	1	100.0	15
10/15/24	10:15a	77.1	50	57.0	77.0	9.21	.0733	351	1	100.0	15
10/15/24	10:30a	77.2	54	59.3	77.4	9.81	.0732	351	1	100.0	15
10/15/24	10:45a	77.3	51	57.8	77.3	9.35	.0733	352	1	100.0	15
10/15/24	11:00a	77.7	52	58.7	77.8	9.50	.0732	351	1	100.0	15
10/15/24	11:15a	77.6	53	59.1	77.7	9.65	.0732	351	1	100.0	15
10/15/24	11:30a	77.9	50	57.8	77.9	9.19	.0732	351	1	100.0	15
10/15/24	11:45a	78.2	51	58.6	78.3	9.35	.0731	352	1	100.0	15
10/15/24	12:00p	78.1	54	60.1	78.4	9.79	.0730	351	1	100.0	15
10/15/24	12:15p	78.1	52	59.0	78.2	9.49	.0731	351	1	100.0	15
10/15/24	12:30p	78.3	49	57.6	78.2	8.98	.0731	351	1	100.0	15

NKSP 10/15/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/15/24	12:45p	78.5	50	58.3	78.5	9.18	.0730	351	1	100.0	15
10/15/24	1:00p	78.5	52	59.4	78.7	9.48	.0729	352	1	100.0	15
10/15/24	1:15p	78.4	52	59.3	78.6	9.48	.0729	351	1	100.0	15
10/15/24	1:30p	78.4	49	57.7	78.3	8.98	.0730	351	1	100.0	15
10/15/24	1:45p	78.6	47	56.7	78.2	8.68	.0730	351	1	100.0	15
10/15/24	2:00p	78.6	48	57.4	78.6	8.87	.0729	352	1	100.0	15
10/15/24	2:15p	78.7	50	58.5	78.7	9.18	.0728	351	1	100.0	15
10/15/24	2:30p	78.7	49	57.9	78.6	8.98	.0729	351	1	100.0	15
10/15/24	2:45p	78.7	45	55.6	78.1	8.38	.0729	351	1	100.0	15
10/15/24	3:00p	79.0	46	56.5	78.5	8.47	.0729	352	1	100.0	15
10/15/24	3:15p	79.1	48	57.7	78.9	8.87	.0728	351	1	100.0	15
10/15/24	3:30p	79.0	45	55.8	78.4	8.37	.0729	351	1	100.0	15
10/15/24	3:45p	79.2	44	55.4	78.5	8.17	.0729	351	1	100.0	15
10/15/24	4:00p	79.4	45	56.2	78.8	8.36	.0728	351	1	100.0	15
10/15/24	4:15p	79.3	47	57.3	79.0	8.66	.0728	352	1	100.0	15
10/15/24	4:30p	79.2	46	56.6	78.7	8.47	.0728	351	1	100.0	15
10/15/24	4:45p	79.4	43	55.0	78.5	8.05	.0728	351	1	100.0	15
10/15/24	5:00p	79.8	44	55.9	79.1	8.15	.0727	351	1	100.0	15
10/15/24	5:15p	79.7	46	57.1	79.2	8.46	.0727	352	1	100.0	15
10/15/24	5:30p	79.6	43	55.1	78.7	8.05	.0728	351	1	100.0	15
10/15/24	5:45p	79.6	43	55.1	78.7	8.05	.0728	351	1	100.0	15
10/15/24	6:00p	79.6	45	56.4	79.0	8.36	.0727	352	1	100.0	15
10/15/24	6:15p	79.4	45	56.2	78.8	8.36	.0728	351	1	100.0	15
10/15/24	6:30p	79.4	44	55.6	78.7	8.16	.0728	351	1	100.0	15
10/15/24	6:45p	79.4	44	55.6	78.7	8.16	.0728	351	1	100.0	15
10/15/24	7:00p	79.4	45	56.2	78.8	8.36	.0728	351	1	100.0	15
10/15/24	7:15p	79.2	48	57.8	79.0	8.87	.0728	351	1	100.0	15
10/15/24	7:30p	78.9	47	57.0	78.5	8.67	.0729	352	1	100.0	15
10/15/24	7:45p	78.6	46	56.1	78.1	8.48	.0729	351	1	100.0	15
10/15/24	8:00p	78.7	46	56.2	78.2	8.48	.0729	351	1	100.0	15
10/15/24	8:15p	78.6	49	57.8	78.5	8.98	.0729	351	1	100.0	15
10/15/24	8:30p	78.3	50	58.1	78.3	9.18	.0729	352	1	100.0	15
10/15/24	8:45p	78.1	48	56.8	77.8	8.89	.0730	351	1	100.0	15
10/15/24	9:00p	78.2	47	56.3	77.8	8.69	.0730	351	1	100.0	15
10/15/24	9:15p	78.2	51	58.6	78.3	9.35	.0729	351	1	100.0	15
10/15/24	9:30p	78.0	51	58.4	78.1	9.35	.0730	352	1	100.0	15
10/15/24	9:45p	77.9	50	57.8	77.9	9.19	.0730	351	1	100.0	15
10/15/24	10:00p	77.8	49	57.1	77.6	8.99	.0731	351	1	100.0	15
10/15/24	10:15p	77.9	51	58.3	77.9	9.35	.0730	351	1	100.0	15
10/15/24	10:30p	77.6	53	59.1	77.7	9.65	.0730	351	1	100.0	15
10/15/24	10:45p	77.3	52	58.3	77.3	9.50	.0731	352	1	100.0	15
10/15/24	11:00p	77.4	55	60.0	77.6	9.95	.0730	351	1	100.0	15
10/15/24	11:15p	77.0	54	59.1	77.1	9.81	.0731	351	1	100.0	15
10/15/24	11:30p	76.9	52	57.9	76.9	9.51	.0731	351	1	100.0	15
10/15/24	11:45p	76.6	56	59.7	76.9	10.19	.0731	352	1	100.0	15
10/16/24	12:00a	76.4	53	58.0	76.5	9.65	.0732	352	1	100.0	15

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

OUTSIDE TEMPERATURE RECORD

CDCR 2030 (04/18)

INSTITUTION: NKSP

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the OUTSIDE ambient air temperature.

Using an accurate thermometer located in a central, heat neutral location, the outside air temperature is to be taken every hour, seven (7) days a week.

Thermometer Location: Central

Immediately notify the Watch Commander at extension 3141 when the air temperature reaches 90 degrees.

Date	Time	Temp.	Printed Name
10-16	0100	64	PADILLA
	0200	64	PADILLA
	0300	62	PADILLA
	0400	61	PADILLA
	0500	59	PADILLA
	0600	58	VALENCIA
	0700	57	VALENCIA
	0800	58	VALENCIA
	0900	65	VALENCIA
	1000	69	VALENCIA
	1100	72	VALENCIA
	1200	75	VALENCIA
	1300	78	VALENCIA
	1400	80	O. MONCIBAIZ
	1500	81	O. MONCIBAIZ
	1600	82	O. MONCIBAIZ
	1700	81	O. MONCIBAIZ
	1800	78	O. MONCIBAIZ
	1900	76	O. MONCIBAIZ
	2000	74	O. MONCIBAIZ
	2100	72	O. MONCIBAIZ
	2200	70	PADILLA
	2300	67	PADILLA
	2400	65	PADILLA

Date	Time	Temp.	Printed Name
10-17	0100	63	PADILLA
	0200	63	PADILLA
	0300	60	PADILLA
	0400	58	PADILLA
	0500	57	PADILLA
	0600	56	VALENCIA
	0700	56	VALENCIA
	0800	57	VALENCIA
	0900	63	VALENCIA
	1000	67	VALENCIA
	1100	70	VALENCIA
	1200	72	VALENCIA
	1300	74	VALENCIA
	1400	76	MONCIBAIZ
	1500	77	MONCIBAIZ
	1600	77	MONCIBAIZ
	1700	77	MONCIBAIZ
	1800	75	MONCIBAIZ
	1900	71	MONCIBAIZ
	2000	69	MONCIBAIZ
	2100	67.	MONCIBAIZ
	2200	65	PADILLA
	2300	64	PADILLA
	2400	61	PADILLA

DISTRIBUTION: Original: Institution Heat Plan Coordinator

NKSP 10/16/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/16/24	12:15a	65.1	65.3	65.1	25	28.4	1.0	SE	0.25	3.0	SE	65.1	60.7	60.7	30.074	0.00	0.00	0.000	0.001
10/16/24	12:30a	65.2	65.3	65.0	26	29.4	0.0	SE	0.00	2.0	SE	65.2	61.0	61.0	30.073	0.00	0.00	0.000	0.002
10/16/24	12:45a	64.6	65.2	64.5	28	30.7	3.0	SE	0.75	5.0	SE	64.6	60.7	60.7	30.065	0.00	0.00	0.004	0.000
10/16/24	1:00a	64.4	64.7	64.4	27	29.7	1.0	SE	0.25	3.0	SE	64.4	60.4	60.4	30.069	0.00	0.00	0.006	0.000
10/16/24	1:15a	63.9	64.4	63.9	29	31.0	1.0	SE	0.25	3.0	SE	63.9	60.2	60.2	30.068	0.00	0.00	0.011	0.000
10/16/24	1:30a	63.6	63.9	63.6	29	30.7	2.0	SSE	0.50	5.0	W	63.6	59.9	59.9	30.075	0.00	0.00	0.015	0.000
10/16/24	1:45a	64.3	64.3	63.6	29	31.3	1.0	WSW	0.25	4.0	S	64.3	60.6	60.6	30.070	0.00	0.00	0.007	0.000
10/16/24	2:00a	64.4	64.5	64.3	27	29.7	1.0	SE	0.25	3.0	SE	64.4	60.4	60.4	30.070	0.00	0.00	0.006	0.000
10/16/24	2:15a	64.1	64.4	64.1	27	29.4	0.0	SE	0.00	1.0	SE	64.1	60.1	60.1	30.070	0.00	0.00	0.009	0.000
10/16/24	2:30a	63.0	64.1	63.0	27	28.5	0.0	---	0.00	0.0	---	63.0	59.0	59.0	30.066	0.00	0.00	0.021	0.000
10/16/24	2:45a	62.8	63.1	62.8	28	29.2	0.0	---	0.00	0.0	---	62.8	58.9	58.9	30.068	0.00	0.00	0.023	0.000
10/16/24	3:00a	62.6	62.8	62.6	29	29.9	0.0	SE	0.00	1.0	SE	62.6	58.9	58.9	30.068	0.00	0.00	0.025	0.000
10/16/24	3:15a	62.4	62.6	62.4	29	29.7	0.0	---	0.00	0.0	---	62.4	58.7	58.7	30.068	0.00	0.00	0.027	0.000
10/16/24	3:30a	62.2	62.5	62.2	28	28.7	0.0	---	0.00	0.0	---	62.2	58.4	58.4	30.063	0.00	0.00	0.029	0.000
10/16/24	3:45a	62.0	62.2	62.0	27	27.6	0.0	SE	0.00	2.0	SE	62.0	58.0	58.0	30.060	0.00	0.00	0.031	0.000
10/16/24	4:00a	61.6	62.0	61.6	29	29.0	0.0	SE	0.00	1.0	SE	61.6	57.9	57.9	30.055	0.00	0.00	0.035	0.000
10/16/24	4:15a	60.9	61.7	60.9	29	28.4	0.0	SE	0.00	1.0	SE	60.9	57.3	57.3	30.064	0.00	0.00	0.043	0.000
10/16/24	4:30a	60.4	60.9	60.2	31	29.6	0.0	SE	0.00	2.0	SE	60.4	57.0	57.0	30.058	0.00	0.00	0.048	0.000
10/16/24	4:45a	59.9	60.6	59.9	31	29.2	2.0	SE	0.50	4.0	SE	59.9	56.6	56.6	30.060	0.00	0.00	0.053	0.000
10/16/24	5:00a	59.8	60.0	59.7	32	29.9	1.0	SE	0.25	3.0	SE	59.8	56.6	56.6	30.061	0.00	0.00	0.054	0.000
10/16/24	5:15a	59.4	59.9	59.4	31	28.7	1.0	SE	0.25	4.0	SE	59.4	56.1	56.1	30.060	0.00	0.00	0.058	0.000
10/16/24	5:30a	58.8	59.4	58.7	32	29.0	1.0	SSE	0.25	4.0	SE	58.8	55.6	55.6	30.065	0.00	0.00	0.065	0.000
10/16/24	5:45a	58.6	58.8	58.6	33	29.6	0.0	SSE	0.00	2.0	SSE	58.6	55.5	55.5	30.067	0.00	0.00	0.067	0.000
10/16/24	6:00a	58.4	58.6	58.4	32	28.6	0.0	SSE	0.00	2.0	SSE	58.4	55.3	55.3	30.071	0.00	0.00	0.069	0.000
10/16/24	6:15a	58.4	58.6	58.4	31	27.9	2.0	SW	0.50	4.0	SSE	58.4	55.2	55.2	30.069	0.00	0.00	0.069	0.000
10/16/24	6:30a	58.5	58.5	58.4	30	27.1	1.0	SW	0.25	3.0	SW	58.5	55.3	55.3	30.071	0.00	0.00	0.068	0.000
10/16/24	6:45a	58.3	58.7	58.3	30	27.0	2.0	SSE	0.50	4.0	S	58.3	55.1	55.1	30.067	0.00	0.00	0.070	0.000
10/16/24	7:00a	57.7	58.3	57.7	31	27.2	2.0	SSE	0.50	4.0	SSE	57.7	54.6	54.6	30.072	0.00	0.00	0.076	0.000
10/16/24	7:15a	57.7	57.7	57.6	32	28.0	2.0	SSE	0.50	5.0	SSE	57.7	54.6	54.6	30.074	0.00	0.00	0.076	0.000
10/16/24	7:30a	57.6	57.7	57.5	32	27.9	2.0	SSE	0.50	4.0	SSE	57.6	54.6	54.6	30.076	0.00	0.00	0.077	0.000
10/16/24	7:45a	58.1	58.1	57.5	32	28.4	3.0	SE	0.75	5.0	SE	58.1	55.0	55.0	30.078	0.00	0.00	0.072	0.000
10/16/24	8:00a	58.9	58.9	58.1	32	29.1	3.0	SE	0.75	5.0	SE	58.9	55.7	55.7	30.076	0.00	0.00	0.064	0.000
10/16/24	8:15a	61.4	61.4	58.9	31	30.5	3.0	SSE	0.75	5.0	SE	61.4	58.0	58.0	30.075	0.00	0.00	0.037	0.000
10/16/24	8:30a	63.0	63.0	61.4	27	28.5	2.0	SSE	0.50	6.0	S	63.0	59.0	59.0	30.079	0.00	0.00	0.021	0.000
10/16/24	8:45a	64.4	64.4	63.0	24	26.8	1.0	S	0.25	4.0	S	64.4	59.9	59.9	30.086	0.00	0.00	0.006	0.000
10/16/24	9:00a	65.6	65.6	64.4	22	25.7	1.0	SSE	0.25	3.0	SSE	65.6	60.9	60.9	30.087	0.00	0.00	0.000	0.006
10/16/24	9:15a	66.2	66.2	65.6	20	23.9	1.0	SSE	0.25	3.0	SSE	66.2	61.3	61.3	30.089	0.00	0.00	0.000	0.012
10/16/24	9:30a	67.2	67.3	66.1	18	22.2	3.0	SW	0.75	9.0	WNW	67.2	62.2	62.2	30.096	0.00	0.00	0.000	0.023
10/16/24	9:45a	68.3	68.3	67.3	12	13.7	6.0	W	1.50	11.0	WNW	68.3	62.7	62.7	30.097	0.00	0.00	0.000	0.034
10/16/24	10:00a	69.4	69.4	68.3	11	12.5	4.0	W	1.00	9.0	WNW	69.4	63.9	63.9	30.093	0.00	0.00	0.000	0.046
10/16/24	10:15a	70.2	70.2	69.4	10	11.0	3.0	WNW	0.75	7.0	WNW	70.2	64.8	64.8	30.088	0.00	0.00	0.000	0.054
10/16/24	10:30a	70.8	70.8	70.2	9	9.1	2.0	W	0.50	7.0	W	70.8	65.6	65.6	30.081	0.00	0.00	0.000	0.060
10/16/24	10:45a	71.7	71.7	70.8	7	4.2	3.0	NNW	0.75	8.0	WSW	71.7	66.6	66.6	30.077	0.00	0.00	0.000	0.070
10/16/24	11:00a	72.9	73.0	71.7	5	-2.1	3.0	NW	0.75	10.0	NNW	72.9	67.9	67.9	30.074	0.00	0.00	0.000	0.082
10/16/24	11:15a	74.1	74.1	72.9	2	-19.8	4.0	WNW	1.00	11.0	WNW	74.1	69.3	69.3	30.070	0.00	0.00	0.000	0.095
10/16/24	11:30a	74.9	74.9	74.1	1	-32.2	4.0	NNW	1.00	10.0	NNW	74.9	70.3	70.3	30.060	0.00	0.00	0.000	0.103
10/16/24	11:45a	75.3	75.3	74.9	---	---	4.0	N	1.00	11.0	N	75.3	---	---	30.050	0.00	0.00	0.000	0.107
10/16/24	12:00p	75.4	75.4	75.1	0	---	4.0	NNW	1.00	9.0	N	75.4	70.7	70.7	30.050	0.00	0.00	0.000	0.108
10/16/24	12:15p	76.7	76.7	75.4	---	---	2.0	NNE	0.50	9.0	NNE	76.7	---	---	30.045	0.00	0.00	0.000	0.122
10/16/24	12:30p	77.8	77.8	76.7	0	---	4.0	WNW	1.00	11.0	WNW	77.8	73.3	73.3	30.040	0.00	0.00	0.000	0.133

NKSP 10/16/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/16/24	12:45p	78.4	78.4	77.8	0	---	5.0	NW	1.25	10.0	NW	78.4	73.9	73.9	30.033	0.00	0.00	0.000	0.140
10/16/24	1:00p	78.6	78.6	78.2	0	---	6.0	WNW	1.50	15.0	W	78.6	74.1	74.1	30.024	0.00	0.00	0.000	0.142
10/16/24	1:15p	79.5	79.6	78.6	0	---	6.0	WNW	1.50	13.0	W	79.5	75.0	75.0	30.017	0.00	0.00	0.000	0.151
10/16/24	1:30p	80.0	80.1	79.4	0	---	5.0	WNW	1.25	10.0	WNW	80.0	75.5	75.5	30.007	0.00	0.00	0.000	0.156
10/16/24	1:45p	80.2	80.2	80.0	0	---	5.0	NW	1.25	12.0	NW	80.2	75.7	75.7	29.998	0.00	0.00	0.000	0.158
10/16/24	2:00p	80.6	80.7	80.3	0	---	5.0	NW	1.25	11.0	WNW	80.6	76.0	76.0	29.989	0.00	0.00	0.000	0.162
10/16/24	2:15p	81.2	81.3	80.5	0	---	5.0	WNW	1.25	11.0	WSW	81.2	76.6	76.6	29.982	0.00	0.00	0.000	0.169
10/16/24	2:30p	81.0	81.3	81.0	0	---	5.0	WNW	1.25	10.0	WNW	81.0	76.4	76.4	29.971	0.00	0.00	0.000	0.167
10/16/24	2:45p	81.2	81.2	80.9	0	---	4.0	NW	1.00	10.0	NNW	81.2	76.6	76.6	29.965	0.00	0.00	0.000	0.169
10/16/24	3:00p	81.6	81.6	81.2	0	---	5.0	N	1.25	11.0	N	81.6	77.0	77.0	29.957	0.00	0.00	0.000	0.173
10/16/24	3:15p	82.3	82.6	81.7	0	---	5.0	NW	1.25	11.0	NNW	82.3	77.7	77.7	29.958	0.00	0.00	0.000	0.180
10/16/24	3:30p	82.3	82.3	82.0	0	---	6.0	NW	1.50	11.0	NW	82.3	77.7	77.7	29.951	0.00	0.00	0.000	0.180
10/16/24	3:45p	82.1	82.4	82.0	0	---	6.0	NW	1.50	11.0	NW	82.1	77.5	77.5	29.946	0.00	0.00	0.000	0.178
10/16/24	4:00p	82.2	82.2	81.9	0	---	5.0	NW	1.25	10.0	WNW	82.2	77.6	77.6	29.947	0.00	0.00	0.000	0.179
10/16/24	4:15p	82.6	82.7	82.2	0	---	5.0	NW	1.25	10.0	NNW	82.6	77.9	77.9	29.944	0.00	0.00	0.000	0.183
10/16/24	4:30p	82.4	82.8	82.4	0	---	5.0	NNW	1.25	10.0	NNW	82.4	77.8	77.8	29.943	0.00	0.00	0.000	0.181
10/16/24	4:45p	81.9	82.4	81.9	0	---	6.0	N	1.50	11.0	N	81.9	77.3	77.3	29.940	0.00	0.00	0.000	0.176
10/16/24	5:00p	81.6	81.9	81.5	0	---	5.0	NNW	1.25	13.0	N	81.6	77.0	77.0	29.935	0.00	0.00	0.000	0.173
10/16/24	5:15p	81.3	81.6	81.2	0	---	5.0	NW	1.25	12.0	NNW	81.3	76.7	76.7	29.930	0.00	0.00	0.000	0.170
10/16/24	5:30p	80.2	81.2	80.2	0	---	8.0	NW	2.00	13.0	NNW	79.8	75.7	75.3	29.935	0.00	0.00	0.000	0.158
10/16/24	5:45p	79.3	80.2	79.3	0	---	7.0	NW	1.75	12.0	NW	79.3	74.8	74.8	29.930	0.00	0.00	0.000	0.149
10/16/24	6:00p	78.5	79.4	78.5	2	-17.0	6.0	NW	1.50	12.0	NNW	78.5	74.3	74.3	29.933	0.00	0.00	0.000	0.141
10/16/24	6:15p	78.1	78.5	78.1	2	-17.2	6.0	NW	1.50	11.0	NNW	78.1	73.9	73.9	29.938	0.00	0.00	0.000	0.136
10/16/24	6:30p	77.8	78.2	77.8	3	-9.3	6.0	NW	1.50	12.0	NW	77.8	73.7	73.7	29.941	0.00	0.00	0.000	0.133
10/16/24	6:45p	77.0	77.8	76.9	5	0.8	10.0	NW	2.50	17.0	NNW	75.1	72.8	70.9	29.947	0.00	0.00	0.000	0.125
10/16/24	7:00p	76.3	76.9	76.3	6	4.2	11.0	NW	2.75	18.0	NW	74.0	71.9	69.6	29.957	0.00	0.00	0.000	0.118
10/16/24	7:15p	75.9	76.3	75.8	6	3.9	10.0	NW	2.50	16.0	NW	74.0	71.5	69.6	29.956	0.00	0.00	0.000	0.114
10/16/24	7:30p	75.4	75.9	75.4	7	7.0	8.0	NW	2.00	15.0	NW	74.9	71.3	70.8	29.962	0.00	0.00	0.000	0.108
10/16/24	7:45p	74.7	75.4	74.7	8	9.4	4.0	NW	1.00	9.0	NW	74.7	70.7	70.7	29.965	0.00	0.00	0.000	0.101
10/16/24	8:00p	74.4	74.8	74.3	9	11.8	2.0	NW	0.50	6.0	NNW	74.4	70.4	70.4	29.965	0.00	0.00	0.000	0.098
10/16/24	8:15p	74.0	74.4	74.0	10	13.9	1.0	NW	0.25	3.0	NW	74.0	70.0	70.0	29.966	0.00	0.00	0.000	0.094
10/16/24	8:30p	73.4	74.0	73.4	11	15.6	3.0	NW	0.75	7.0	NW	73.4	69.3	69.3	29.973	0.00	0.00	0.000	0.088
10/16/24	8:45p	72.8	73.4	72.8	12	17.2	5.0	NW	1.25	9.0	WNW	72.8	68.7	68.7	29.970	0.00	0.00	0.000	0.081
10/16/24	9:00p	72.2	72.8	72.2	12	16.7	3.0	NW	0.75	7.0	NW	72.2	67.8	67.8	29.968	0.00	0.00	0.000	0.075
10/16/24	9:15p	71.3	72.2	71.3	14	19.6	2.0	WNW	0.50	5.0	NW	71.3	66.8	66.8	29.970	0.00	0.00	0.000	0.066
10/16/24	9:30p	70.5	71.3	70.5	15	20.6	2.0	WNW	0.50	4.0	WNW	70.5	65.8	65.8	29.969	0.00	0.00	0.000	0.057
10/16/24	9:45p	70.0	70.5	70.0	15	20.2	2.0	WNW	0.50	6.0	WNW	70.0	65.0	65.0	29.965	0.00	0.00	0.000	0.052
10/16/24	10:00p	70.3	70.3	70.0	14	18.8	1.0	WNW	0.25	4.0	WNW	70.3	65.4	65.4	29.964	0.00	0.00	0.000	0.055
10/16/24	10:15p	70.2	70.5	70.2	13	17.0	1.0	W	0.25	4.0	W	70.2	65.1	65.1	29.964	0.00	0.00	0.000	0.054
10/16/24	10:30p	69.4	70.3	69.4	14	18.1	3.0	WSW	0.75	9.0	WSW	69.4	64.2	64.2	29.968	0.00	0.00	0.000	0.046
10/16/24	10:45p	67.9	69.4	67.8	15	18.5	4.0	WSW	1.00	9.0	W	67.9	62.7	62.7	29.974	0.00	0.00	0.000	0.030
10/16/24	11:00p	67.1	67.8	67.0	16	19.4	5.0	W	1.25	8.0	W	67.1	61.9	61.9	29.971	0.00	0.00	0.000	0.022
10/16/24	11:15p	66.8	67.1	66.8	16	19.1	1.0	WSW	0.25	5.0	WSW	66.8	61.6	61.6	29.978	0.00	0.00	0.000	0.019
10/16/24	11:30p	66.3	66.8	66.3	17	20.1	3.0	WSW	0.75	7.0	WSW	66.3	61.2	61.2	29.976	0.00	0.00	0.000	0.014
10/16/24	11:45p	65.9	66.3	65.9	17	19.8	2.0	WSW	0.50	7.0	WSW	65.9	60.8	60.8	29.979	0.00	0.00	0.000	0.009
10/17/24	12:00a	65.4	65.9	65.3	17	19.4	1.0	W	0.25	4.0	W	65.4	60.3	60.3	29.979	0.00	0.00	0.000	0.004

NKSP 10/17/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/17/24	12:15a	65.2	65.4	65.1	17	19.2	0.0	W	0.00	3.0	WSW	65.2	60.1	60.1	29.977	0.00	0.00	0.000	0.002
10/17/24	12:30a	65.0	65.2	65.0	18	20.4	0.0	WSW	0.00	3.0	WSW	65.0	60.0	60.0	29.979	0.00	0.00	0.000	0.000
10/17/24	12:45a	64.2	65.2	64.2	18	19.8	0.0	NW	0.00	2.0	NW	64.2	59.2	59.2	29.978	0.00	0.00	0.008	0.000
10/17/24	1:00a	63.6	64.2	63.6	19	20.5	0.0	NW	0.00	1.0	NW	63.6	58.8	58.8	29.979	0.00	0.00	0.015	0.000
10/17/24	1:15a	63.6	63.7	63.5	20	21.7	0.0	NW	0.00	1.0	NW	63.6	58.8	58.8	29.975	0.00	0.00	0.015	0.000
10/17/24	1:30a	63.8	63.8	63.6	20	21.9	0.0	NW	0.00	1.0	NW	63.8	59.0	59.0	29.978	0.00	0.00	0.013	0.000
10/17/24	1:45a	63.7	63.9	63.7	20	21.8	0.0	---	0.00	0.0	---	63.7	58.9	58.9	29.972	0.00	0.00	0.014	0.000
10/17/24	2:00a	63.2	63.6	63.2	20	21.4	0.0	NW	0.00	1.0	NW	63.2	58.5	58.5	29.974	0.00	0.00	0.019	0.000
10/17/24	2:15a	62.5	63.2	62.5	20	20.8	0.0	SSW	0.00	1.0	NW	62.5	57.8	57.8	29.975	0.00	0.00	0.026	0.000
10/17/24	2:30a	61.5	62.5	61.5	22	22.3	0.0	SSW	0.00	1.0	SSW	61.5	57.1	57.1	29.978	0.00	0.00	0.036	0.000
10/17/24	2:45a	60.8	61.5	60.8	24	23.7	0.0	S	0.00	1.0	SSW	60.8	56.6	56.6	29.975	0.00	0.00	0.044	0.000
10/17/24	3:00a	60.7	60.9	60.7	25	24.6	0.0	S	0.00	1.0	S	60.7	56.5	56.5	29.972	0.00	0.00	0.045	0.000
10/17/24	3:15a	60.4	60.7	60.4	25	24.4	0.0	---	0.00	0.0	---	60.4	56.3	56.3	29.971	0.00	0.00	0.048	0.000
10/17/24	3:30a	60.0	60.4	60.0	25	24.0	0.0	S	0.00	1.0	S	60.0	55.9	55.9	29.966	0.00	0.00	0.052	0.000
10/17/24	3:45a	59.5	60.0	59.5	27	25.5	0.0	S	0.00	1.0	S	59.5	55.7	55.7	29.970	0.00	0.00	0.057	0.000
10/17/24	4:00a	58.7	59.6	58.7	28	25.6	0.0	S	0.00	1.0	S	58.7	55.2	55.2	29.969	0.00	0.00	0.066	0.000
10/17/24	4:15a	58.4	58.8	58.4	28	25.4	0.0	S	0.00	2.0	S	58.4	54.9	54.9	29.972	0.00	0.00	0.069	0.000
10/17/24	4:30a	58.6	58.6	58.3	29	26.4	0.0	S	0.00	4.0	S	58.6	55.2	55.2	29.972	0.00	0.00	0.067	0.000
10/17/24	4:45a	57.8	58.6	57.8	29	25.7	1.0	SSE	0.25	2.0	SSE	57.8	54.5	54.5	29.980	0.00	0.00	0.075	0.000
10/17/24	5:00a	57.0	57.8	56.9	30	25.8	1.0	SSE	0.25	3.0	SSE	57.0	53.9	53.9	29.980	0.00	0.00	0.083	0.000
10/17/24	5:15a	56.9	57.3	56.9	31	26.5	2.0	SE	0.50	4.0	SE	56.9	53.9	53.9	29.990	0.00	0.00	0.084	0.000
10/17/24	5:30a	56.6	57.0	56.6	31	26.3	1.0	SSE	0.25	3.0	SSE	56.6	53.6	53.6	29.997	0.00	0.00	0.088	0.000
10/17/24	5:45a	56.5	56.7	56.5	32	27.0	1.0	SSE	0.25	3.0	SSE	56.5	53.6	53.6	29.997	0.00	0.00	0.089	0.000
10/17/24	6:00a	56.0	56.5	56.0	32	26.5	2.0	SSE	0.50	5.0	SSE	56.0	53.1	53.1	29.997	0.00	0.00	0.094	0.000
10/17/24	6:15a	55.9	56.0	55.8	33	27.2	1.0	SSE	0.25	5.0	S	55.9	53.1	53.1	29.992	0.00	0.00	0.095	0.000
10/17/24	6:30a	56.2	56.2	55.9	33	27.4	1.0	SSE	0.25	4.0	S	56.2	53.4	53.4	29.994	0.00	0.00	0.092	0.000
10/17/24	6:45a	56.6	56.6	56.2	33	27.8	2.0	S	0.50	5.0	S	56.6	53.7	53.7	30.001	0.00	0.00	0.088	0.000
10/17/24	7:00a	56.6	56.7	56.5	33	27.8	3.0	SSW	0.75	6.0	SSW	56.6	53.7	53.7	29.996	0.00	0.00	0.088	0.000
10/17/24	7:15a	56.4	56.7	56.4	33	27.6	1.0	S	0.25	5.0	S	56.4	53.5	53.5	29.995	0.00	0.00	0.090	0.000
10/17/24	7:30a	56.4	56.4	56.2	33	27.6	1.0	S	0.25	3.0	S	56.4	53.5	53.5	29.998	0.00	0.00	0.090	0.000
10/17/24	7:45a	56.9	56.9	56.3	33	28.1	0.0	S	0.00	2.0	S	56.9	54.0	54.0	30.001	0.00	0.00	0.084	0.000
10/17/24	8:00a	57.3	57.3	56.9	32	27.7	1.0	SSE	0.25	2.0	SSE	57.3	54.3	54.3	29.995	0.00	0.00	0.080	0.000
10/17/24	8:15a	58.2	58.2	57.3	32	28.5	0.0	SSE	0.00	3.0	SSE	58.2	55.1	55.1	29.997	0.00	0.00	0.071	0.000
10/17/24	8:30a	59.7	59.7	58.2	32	29.8	1.0	SSE	0.25	3.0	SSE	59.7	56.5	56.5	29.998	0.00	0.00	0.055	0.000
10/17/24	8:45a	61.8	61.8	59.8	29	29.2	1.0	SE	0.25	3.0	SE	61.8	58.1	58.1	29.999	0.00	0.00	0.033	0.000
10/17/24	9:00a	63.9	63.9	61.8	24	26.4	0.0	SE	0.00	2.0	SE	63.9	59.4	59.4	30.000	0.00	0.00	0.011	0.000
10/17/24	9:15a	66.2	66.2	63.9	17	20.0	1.0	SE	0.25	3.0	SE	66.2	61.1	61.1	30.001	0.00	0.00	0.000	0.012
10/17/24	9:30a	67.3	67.3	66.2	14	16.4	1.0	SE	0.25	4.0	SE	67.3	62.0	62.0	30.004	0.00	0.00	0.000	0.024
10/17/24	9:45a	67.8	67.8	67.3	12	13.3	1.0	S	0.25	3.0	SE	67.8	62.2	62.2	30.003	0.00	0.00	0.000	0.029
10/17/24	10:00a	67.9	67.9	67.7	11	11.4	2.0	WNW	0.50	6.0	W	67.9	62.2	62.2	30.002	0.00	0.00	0.000	0.030
10/17/24	10:15a	68.4	68.4	67.9	11	11.8	2.0	WNW	0.50	8.0	W	68.4	62.7	62.7	29.998	0.00	0.00	0.000	0.035
10/17/24	10:30a	68.8	68.8	68.2	10	9.9	2.0	W	0.50	8.0	W	68.8	63.1	63.1	29.989	0.00	0.00	0.000	0.040
10/17/24	10:45a	69.4	69.4	68.7	9	8.0	3.0	W	0.75	10.0	WSW	69.4	63.7	63.7	29.990	0.00	0.00	0.000	0.046
10/17/24	11:00a	70.0	70.1	69.4	8	5.9	2.0	W	0.50	8.0	W	70.0	64.3	64.3	29.983	0.00	0.00	0.000	0.052
10/17/24	11:15a	70.3	70.3	69.9	8	6.1	3.0	W	0.75	9.0	W	70.3	64.8	64.8	29.975	0.00	0.00	0.000	0.055
10/17/24	11:30a	71.4	71.4	70.3	7	4.0	3.0	SW	0.75	8.0	SW	71.4	66.2	66.2	29.968	0.00	0.00	0.000	0.067
10/17/24	11:45a	71.7	71.8	71.3	6	0.9	4.0	SW	1.00	12.0	WNW	71.7	66.4	66.4	29.970	0.00	0.00	0.000	0.070
10/17/24	12:00p	72.4	72.4	71.8	6	1.4	4.0	SSW	1.00	10.0	WSW	72.4	67.3	67.3	29.967	0.00	0.00	0.000	0.077
10/17/24	12:15p	72.6	72.8	72.4	4	-7.0	4.0	W	1.00	11.0	WSW	72.6	67.4	67.4	29.966	0.00	0.00	0.000	0.079
10/17/24	12:30p	73.6	73.6	72.6	4	-6.3	4.0	WSW	1.00	9.0	WNW	73.6	68.8	68.8	29.947	0.00	0.00	0.000	0.090

NKSP 10/17/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/17/24	12:45p	74.2	74.4	73.6	2	-19.7	3.0	NW	0.75	9.0	WNW	74.2	69.5	69.5	29.943	0.00	0.00	0.000	0.096
10/17/24	1:00p	74.0	74.2	73.9	2	-19.9	3.0	NW	0.75	11.0	WNW	74.0	69.2	69.2	29.935	0.00	0.00	0.000	0.094
10/17/24	1:15p	75.3	75.3	73.9	0	---	3.0	WSW	0.75	10.0	W	75.3	70.6	70.6	29.928	0.00	0.00	0.000	0.107
10/17/24	1:30p	75.9	75.9	75.3	---	---	2.0	NNW	0.50	10.0	NW	75.9	---	---	29.916	0.00	0.00	0.000	0.114
10/17/24	1:45p	76.1	76.4	75.8	0	---	3.0	W	0.75	9.0	W	76.1	71.5	71.5	29.901	0.00	0.00	0.000	0.116
10/17/24	2:00p	76.3	76.8	76.2	0	---	4.0	WNW	1.00	10.0	WNW	76.3	71.8	71.8	29.898	0.00	0.00	0.000	0.118
10/17/24	2:15p	76.6	76.9	76.2	0	---	4.0	W	1.00	10.0	WNW	76.6	72.1	72.1	29.889	0.00	0.00	0.000	0.121
10/17/24	2:30p	76.9	76.9	76.4	0	---	3.0	NW	0.75	12.0	NNW	76.9	72.5	72.5	29.882	0.00	0.00	0.000	0.124
10/17/24	2:45p	77.1	77.8	76.9	0	---	3.0	NNE	0.75	10.0	NW	77.1	72.7	72.7	29.872	0.00	0.00	0.000	0.126
10/17/24	3:00p	77.5	77.6	76.9	0	---	4.0	NNE	1.00	11.0	NNW	77.5	73.1	73.1	29.872	0.00	0.00	0.000	0.130
10/17/24	3:15p	77.7	77.7	77.5	0	---	5.0	NW	1.25	11.0	N	77.7	73.2	73.2	29.865	0.00	0.00	0.000	0.132
10/17/24	3:30p	77.8	77.8	77.5	0	---	3.0	NW	0.75	11.0	NNW	77.8	73.3	73.3	29.865	0.00	0.00	0.000	0.133
10/17/24	3:45p	78.1	78.1	77.8	0	---	5.0	NW	1.25	11.0	N	78.1	73.6	73.6	29.860	0.00	0.00	0.000	0.136
10/17/24	4:00p	77.8	78.1	77.8	0	---	7.0	NNE	1.75	14.0	NNW	77.8	73.3	73.3	29.860	0.00	0.00	0.000	0.133
10/17/24	4:15p	78.1	78.2	77.8	0	---	8.0	NNW	2.00	15.0	N	77.6	73.6	73.1	29.859	0.00	0.00	0.000	0.136
10/17/24	4:30p	77.6	78.1	77.6	0	---	8.0	NNW	2.00	15.0	N	77.1	73.1	72.6	29.855	0.00	0.00	0.000	0.131
10/17/24	4:45p	77.3	77.6	77.3	0	---	7.0	N	1.75	13.0	NNE	77.3	72.9	72.9	29.846	0.00	0.00	0.000	0.128
10/17/24	5:00p	77.8	77.8	77.3	0	---	7.0	NNW	1.75	16.0	NNE	77.8	73.3	73.3	29.847	0.00	0.00	0.000	0.133
10/17/24	5:15p	77.6	77.8	77.6	0	---	6.0	NNW	1.50	11.0	NW	77.6	73.1	73.1	29.845	0.00	0.00	0.000	0.131
10/17/24	5:30p	77.1	77.7	77.1	0	---	7.0	NNW	1.75	15.0	N	77.1	72.7	72.7	29.843	0.00	0.00	0.000	0.126
10/17/24	5:45p	76.4	77.1	76.4	0	---	5.0	NNW	1.25	12.0	NW	76.4	71.9	71.9	29.846	0.00	0.00	0.000	0.119
10/17/24	6:00p	75.6	76.4	75.6	0	---	6.0	NNW	1.50	12.0	NW	75.6	71.0	71.0	29.851	0.00	0.00	0.000	0.110
10/17/24	6:15p	74.2	75.6	74.2	---	---	8.0	NW	2.00	13.0	NW	73.7	---	---	29.852	0.00	0.00	0.000	0.096
10/17/24	6:30p	73.3	74.2	73.3	0	---	8.0	NNW	2.00	13.0	NNW	72.8	68.1	67.6	29.857	0.00	0.00	0.000	0.086
10/17/24	6:45p	72.3	73.3	72.3	0	---	9.0	NW	2.25	15.0	NW	70.9	66.9	65.5	29.867	0.00	0.00	0.000	0.076
10/17/24	7:00p	71.3	72.3	71.3	0	---	10.0	NW	2.50	18.0	NNW	69.2	65.6	63.5	29.866	0.00	0.00	0.000	0.066
10/17/24	7:15p	70.3	71.3	70.3	0	---	7.0	NW	1.75	12.0	NW	70.3	64.3	64.3	29.872	0.00	0.00	0.000	0.055
10/17/24	7:30p	68.9	70.4	68.9	0	---	5.0	NW	1.25	10.0	NNW	68.9	62.2	62.2	29.879	0.00	0.00	0.000	0.041
10/17/24	7:45p	68.6	68.9	68.6	0	---	7.0	NW	1.75	13.0	WNW	68.6	61.8	61.8	29.884	0.00	0.00	0.000	0.037
10/17/24	8:00p	69.4	69.4	68.6	0	---	10.0	NW	2.50	19.0	NW	67.3	63.0	60.9	29.890	0.00	0.00	0.000	0.046
10/17/24	8:15p	69.2	69.6	69.2	0	---	11.0	NW	2.75	21.0	NW	66.6	62.7	60.1	29.899	0.00	0.00	0.000	0.044
10/17/24	8:30p	68.5	69.2	68.5	0	---	11.0	NW	2.75	18.0	NW	65.9	61.6	59.0	29.910	0.00	0.00	0.000	0.036
10/17/24	8:45p	68.1	68.5	68.1	2	-23.7	11.0	NW	2.75	18.0	NW	65.5	61.2	58.6	29.918	0.00	0.00	0.000	0.032
10/17/24	9:00p	67.8	68.1	67.8	3	-16.1	11.0	NW	2.75	20.0	WNW	65.2	61.0	58.4	29.926	0.00	0.00	0.000	0.029
10/17/24	9:15p	67.3	67.8	67.3	5	-6.1	10.0	NW	2.50	16.0	WNW	65.3	60.7	58.7	29.929	0.00	0.00	0.000	0.024
10/17/24	9:30p	66.7	67.3	66.7	7	0.5	9.0	NW	2.25	15.0	WNW	65.4	60.6	59.3	29.941	0.00	0.00	0.000	0.018
10/17/24	9:45p	66.1	66.8	66.1	8	3.0	6.0	NW	1.50	11.0	NW	66.1	60.3	60.3	29.950	0.00	0.00	0.000	0.011
10/17/24	10:00p	65.6	66.1	65.5	8	2.6	5.0	WNW	1.25	10.0	NW	65.6	59.9	59.9	29.956	0.00	0.00	0.000	0.006
10/17/24	10:15p	64.7	65.5	64.7	9	4.5	5.0	WNW	1.25	9.0	W	64.7	59.3	59.3	29.966	0.00	0.00	0.003	0.000
10/17/24	10:30p	64.5	64.7	64.4	5	-8.1	7.0	WNW	1.75	17.0	WNW	64.5	58.2	58.2	29.966	0.00	0.00	0.005	0.000
10/17/24	10:45p	65.6	65.6	64.5	1	-37.9	8.0	WNW	2.00	15.0	WNW	65.0	58.7	58.1	29.965	0.00	0.00	0.000	0.006
10/17/24	11:00p	64.5	65.5	64.5	2	-26.0	4.0	WNW	1.00	10.0	WNW	64.5	57.9	57.9	29.966	0.00	0.00	0.005	0.000
10/17/24	11:15p	63.1	64.5	63.1	2	-26.9	4.0	WNW	1.00	8.0	W	63.1	56.7	56.7	29.967	0.00	0.00	0.020	0.000
10/17/24	11:30p	61.7	63.1	61.6	2	-27.9	4.0	W	1.00	9.0	W	61.7	55.5	55.5	29.970	0.00	0.00	0.034	0.000
10/17/24	11:45p	61.3	61.6	60.8	0	---	4.0	WNW	1.00	8.0	W	61.3	55.0	55.0	29.970	0.00	0.00	0.039	0.000
10/18/24	12:00a	61.1	61.6	61.1	0	---	4.0	WNW	1.00	9.0	WNW	61.1	54.9	54.9	29.969	0.00	0.00	0.041	0.000

NKSP 10/16/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/16/24	12:15a	76.5	57	60.1	76.8	10.29	.0731	349	1	100.0	15
10/16/24	12:30a	76.1	55	58.8	76.3	10.01	.0732	351	1	100.0	15
10/16/24	12:45a	76.4	55	59.0	76.6	9.99	.0731	352	1	100.0	15
10/16/24	1:00a	76.0	56	59.2	76.3	10.21	.0732	351	1	100.0	15
10/16/24	1:15a	76.2	53	57.8	76.3	9.65	.0732	351	1	100.0	15
10/16/24	1:30a	75.9	57	59.6	76.2	10.31	.0733	351	1	100.0	15
10/16/24	1:45a	75.8	53	57.4	75.9	9.65	.0733	352	1	100.0	15
10/16/24	2:00a	75.8	58	60.0	76.2	10.52	.0732	351	1	100.0	15
10/16/24	2:15a	75.7	54	57.9	75.8	9.84	.0733	351	1	100.0	15
10/16/24	2:30a	75.9	57	59.6	76.2	10.31	.0732	351	1	100.0	15
10/16/24	2:45a	75.8	54	58.0	75.9	9.83	.0733	352	1	100.0	15
10/16/24	3:00a	76.0	57	59.7	76.3	10.31	.0732	351	1	100.0	15
10/16/24	3:15a	75.8	55	58.5	76.0	10.02	.0733	351	1	100.0	15
10/16/24	3:30a	75.9	56	59.1	76.2	10.21	.0732	351	1	100.0	15
10/16/24	3:45a	75.8	53	57.4	75.9	9.65	.0733	351	1	100.0	15
10/16/24	4:00a	75.9	55	58.6	76.1	10.01	.0732	352	1	100.0	15
10/16/24	4:15a	75.7	54	57.9	75.8	9.84	.0733	351	1	100.0	15
10/16/24	4:30a	75.9	54	58.1	76.0	9.83	.0732	351	1	100.0	15
10/16/24	4:45a	75.6	55	58.3	75.8	10.03	.0733	351	1	100.0	15
10/16/24	5:00a	75.8	52	56.9	75.8	9.53	.0733	352	1	100.0	15
10/16/24	5:15a	75.6	55	58.3	75.8	10.03	.0733	351	1	100.0	15
10/16/24	5:30a	75.7	51	56.3	75.7	9.35	.0734	351	1	100.0	15
10/16/24	5:45a	75.3	55	58.0	75.5	10.04	.0733	351	1	100.0	15
10/16/24	6:00a	75.7	53	57.4	75.8	9.65	.0733	351	1	100.0	15
10/16/24	6:15a	75.5	54	57.7	75.6	9.84	.0733	352	1	100.0	15
10/16/24	6:30a	75.8	54	58.0	75.9	9.83	.0733	351	1	100.0	15
10/16/24	6:45a	75.6	53	57.3	75.7	9.65	.0733	351	1	100.0	15
10/16/24	7:00a	75.8	53	57.4	75.9	9.65	.0733	352	1	100.0	15
10/16/24	7:15a	75.7	51	56.3	75.7	9.35	.0734	351	1	100.0	15
10/16/24	7:30a	75.7	53	57.4	75.8	9.65	.0733	351	1	100.0	15
10/16/24	7:45a	75.8	49	55.3	75.6	9.03	.0734	351	1	100.0	15
10/16/24	8:00a	75.7	53	57.4	75.8	9.65	.0733	351	1	100.0	15
10/16/24	8:15a	76.1	51	56.7	76.1	9.35	.0733	352	1	100.0	15
10/16/24	8:30a	75.8	53	57.4	75.9	9.65	.0733	351	1	100.0	15
10/16/24	8:45a	76.2	53	57.8	76.3	9.65	.0733	351	1	100.0	15
10/16/24	9:00a	75.8	53	57.4	75.9	9.65	.0733	351	1	100.0	15
10/16/24	9:15a	76.2	53	57.8	76.3	9.65	.0733	352	1	100.0	15
10/16/24	9:30a	76.0	53	57.6	76.1	9.65	.0733	351	1	100.0	15
10/16/24	9:45a	76.5	52	57.6	76.5	9.52	.0733	351	1	100.0	15
10/16/24	10:00a	76.3	52	57.4	76.3	9.52	.0733	351	1	100.0	15
10/16/24	10:15a	76.9	50	56.8	76.8	9.21	.0732	351	1	100.0	15
10/16/24	10:30a	76.7	51	57.2	76.7	9.35	.0732	352	1	100.0	15
10/16/24	10:45a	76.9	49	56.3	76.7	9.01	.0732	351	1	100.0	15
10/16/24	11:00a	77.3	51	57.8	77.3	9.35	.0731	351	1	100.0	15
10/16/24	11:15a	77.3	51	57.8	77.3	9.35	.0731	351	1	100.0	15
10/16/24	11:30a	77.8	47	56.0	77.4	8.69	.0731	352	1	100.0	15
10/16/24	11:45a	77.9	50	57.8	77.9	9.19	.0730	351	1	100.0	15
10/16/24	12:00p	77.8	49	57.1	77.6	8.99	.0730	351	1	100.0	15
10/16/24	12:15p	78.2	46	55.7	77.7	8.49	.0730	351	1	100.0	15
10/16/24	12:30p	78.5	49	57.7	78.4	8.98	.0728	352	1	100.0	15

NKSP 10/16/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/16/24	12:45p	78.5	48	57.2	78.2	8.88	.0729	351	1	100.0	15
10/16/24	1:00p	78.7	45	55.6	78.1	8.38	.0729	351	1	100.0	15
10/16/24	1:15p	79.1	47	57.1	78.7	8.67	.0727	351	1	100.0	15
10/16/24	1:30p	79.2	48	57.8	79.0	8.87	.0727	351	1	100.0	15
10/16/24	1:45p	79.3	46	56.7	78.8	8.46	.0727	352	1	100.0	15
10/16/24	2:00p	79.7	45	56.5	79.1	8.36	.0726	351	1	100.0	15
10/16/24	2:15p	80.0	45	56.7	79.4	8.35	.0725	351	1	100.0	15
10/16/24	2:30p	80.1	47	58.0	79.8	8.65	.0725	351	1	100.0	15
10/16/24	2:45p	80.1	47	58.0	79.8	8.65	.0724	352	1	100.0	15
10/16/24	3:00p	80.1	45	56.8	79.5	8.35	.0725	351	1	100.0	15
10/16/24	3:15p	80.3	44	56.4	79.6	8.15	.0725	351	1	100.0	15
10/16/24	3:30p	80.3	47	58.2	80.1	8.64	.0724	351	1	100.0	15
10/16/24	3:45p	80.0	47	58.0	79.7	8.65	.0724	351	1	100.0	15
10/16/24	4:00p	79.7	45	56.5	79.1	8.36	.0725	352	1	100.0	15
10/16/24	4:15p	79.7	43	55.2	78.8	8.05	.0726	351	1	100.0	15
10/16/24	4:30p	79.6	46	57.0	79.1	8.46	.0725	351	1	100.0	15
10/16/24	4:45p	79.4	47	57.4	79.1	8.66	.0725	351	1	100.0	15
10/16/24	5:00p	79.2	45	56.0	78.6	8.37	.0726	352	1	100.0	15
10/16/24	5:15p	79.2	44	55.4	78.5	8.17	.0726	351	1	100.0	15
10/16/24	5:30p	79.3	47	57.3	79.0	8.66	.0725	351	1	100.0	15
10/16/24	5:45p	79.0	49	58.2	78.9	8.97	.0725	351	1	100.0	15
10/16/24	6:00p	78.8	47	56.9	78.4	8.67	.0726	352	1	100.0	15
10/16/24	6:15p	78.8	46	56.3	78.3	8.47	.0726	351	1	100.0	15
10/16/24	6:30p	78.8	50	58.6	78.8	9.17	.0725	351	1	100.0	15
10/16/24	6:45p	78.6	50	58.4	78.6	9.18	.0726	351	1	100.0	15
10/16/24	7:00p	78.5	48	57.2	78.2	8.88	.0727	352	1	100.0	15
10/16/24	7:15p	78.6	49	57.8	78.5	8.98	.0726	351	1	100.0	15
10/16/24	7:30p	78.6	52	59.5	78.8	9.48	.0726	351	1	100.0	15
10/16/24	7:45p	78.3	51	58.7	78.4	9.35	.0727	351	1	100.0	15
10/16/24	8:00p	78.2	48	56.9	77.9	8.89	.0727	351	1	100.0	15
10/16/24	8:15p	78.3	52	59.2	78.4	9.48	.0726	352	1	100.0	15
10/16/24	8:30p	78.0	52	58.9	78.1	9.49	.0727	351	1	100.0	15
10/16/24	8:45p	78.0	49	57.3	77.9	8.99	.0728	351	1	100.0	15
10/16/24	9:00p	78.1	54	60.1	78.4	9.79	.0726	351	1	100.0	15
10/16/24	9:15p	77.8	53	59.3	78.0	9.65	.0727	352	1	100.0	15
10/16/24	9:30p	77.8	50	57.7	77.8	9.19	.0728	351	1	100.0	15
10/16/24	9:45p	78.0	53	59.5	78.2	9.65	.0727	351	1	100.0	15
10/16/24	10:00p	77.9	53	59.4	78.1	9.65	.0727	351	1	100.0	15
10/16/24	10:15p	77.9	50	57.8	77.9	9.19	.0727	351	1	100.0	15
10/16/24	10:30p	77.9	54	59.9	78.1	9.79	.0727	352	1	100.0	15
10/16/24	10:45p	77.6	52	58.6	77.7	9.50	.0728	351	1	100.0	15
10/16/24	11:00p	77.8	55	60.3	78.1	9.94	.0727	351	1	100.0	15
10/16/24	11:15p	77.5	53	59.0	77.6	9.65	.0728	351	1	100.0	15
10/16/24	11:30p	77.6	53	59.1	77.7	9.65	.0728	352	1	100.0	15
10/16/24	11:45p	77.2	53	58.7	77.3	9.65	.0728	351	1	100.0	15
10/17/24	12:00a	77.3	51	57.8	77.3	9.35	.0729	351	1	100.0	15

NKSP 10/17/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/17/24	12:15a	77.0	54	59.1	77.1	9.81	.0728	351	1	100.0	15
10/17/24	12:30a	76.5	51	57.0	76.5	9.35	.0730	351	1	100.0	15
10/17/24	12:45a	76.3	55	58.9	76.5	10.00	.0729	351	1	100.0	15
10/17/24	1:00a	75.9	53	57.5	76.0	9.65	.0731	351	1	100.0	15
10/17/24	1:15a	76.1	54	58.2	76.2	9.83	.0730	351	1	100.0	15
10/17/24	1:30a	75.7	54	57.9	75.8	9.84	.0731	352	1	100.0	15
10/17/24	1:45a	75.8	50	55.8	75.7	9.23	.0731	351	1	100.0	15
10/17/24	2:00a	75.5	54	57.7	75.6	9.84	.0731	351	1	100.0	15
10/17/24	2:15a	75.3	52	56.5	75.3	9.54	.0732	351	1	100.0	15
10/17/24	2:30a	75.5	54	57.7	75.6	9.84	.0731	352	1	100.0	15
10/17/24	2:45a	75.1	54	57.3	75.2	9.85	.0732	351	1	100.0	15
10/17/24	3:00a	75.6	52	56.7	75.6	9.54	.0731	351	1	100.0	15
10/17/24	3:15a	75.1	54	57.3	75.2	9.85	.0732	351	1	100.0	15
10/17/24	3:30a	75.5	49	55.0	75.3	9.04	.0732	351	1	100.0	15
10/17/24	3:45a	75.1	54	57.3	75.2	9.85	.0732	352	1	100.0	15
10/17/24	4:00a	75.6	50	55.6	75.5	9.24	.0732	351	1	100.0	15
10/17/24	4:15a	75.2	53	56.9	75.3	9.65	.0732	351	1	100.0	15
10/17/24	4:30a	75.6	49	55.1	75.4	9.04	.0732	351	1	100.0	15
10/17/24	4:45a	75.2	53	56.9	75.3	9.65	.0732	352	1	100.0	15
10/17/24	5:00a	75.7	52	56.8	75.7	9.54	.0731	351	1	100.0	15
10/17/24	5:15a	75.2	52	56.4	75.2	9.55	.0732	351	1	100.0	15
10/17/24	5:30a	75.6	52	56.7	75.6	9.54	.0732	351	1	100.0	15
10/17/24	5:45a	75.5	50	55.6	75.4	9.24	.0732	352	1	100.0	15
10/17/24	6:00a	75.6	51	56.2	75.6	9.35	.0732	351	1	100.0	15
10/17/24	6:15a	75.9	51	56.5	75.9	9.35	.0731	351	1	100.0	15
10/17/24	6:30a	75.6	51	56.2	75.6	9.35	.0732	351	1	100.0	15
10/17/24	6:45a	75.5	51	56.1	75.5	9.35	.0732	351	1	100.0	15
10/17/24	7:00a	75.5	51	56.1	75.5	9.35	.0732	352	1	100.0	15
10/17/24	7:15a	75.0	51	55.6	75.0	9.35	.0733	351	1	100.0	15
10/17/24	7:30a	75.1	52	56.3	75.1	9.55	.0733	351	1	100.0	15
10/17/24	7:45a	75.4	51	56.0	75.4	9.35	.0732	351	1	100.0	15
10/17/24	8:00a	74.9	51	55.6	74.8	9.35	.0733	352	1	100.0	15
10/17/24	8:15a	75.0	52	56.2	75.0	9.55	.0733	351	1	100.0	15
10/17/24	8:30a	75.4	49	54.9	75.2	9.04	.0733	351	1	100.0	15
10/17/24	8:45a	75.2	52	56.4	75.2	9.55	.0733	351	1	100.0	15
10/17/24	9:00a	75.6	52	56.7	75.6	9.54	.0732	351	1	100.0	15
10/17/24	9:15a	75.3	52	56.5	75.3	9.54	.0732	352	1	100.0	15
10/17/24	9:30a	75.8	52	56.9	75.8	9.53	.0732	351	1	100.0	15
10/17/24	9:45a	75.6	51	56.2	75.6	9.35	.0732	351	1	100.0	15
10/17/24	10:00a	76.1	51	56.7	76.1	9.35	.0731	351	1	100.0	15
10/17/24	10:15a	75.8	51	56.4	75.8	9.35	.0732	352	1	100.0	15
10/17/24	10:30a	76.4	49	55.8	76.2	9.02	.0731	351	1	100.0	15
10/17/24	10:45a	76.2	50	56.2	76.1	9.23	.0731	351	1	100.0	15
10/17/24	11:00a	76.5	47	54.8	76.1	8.72	.0731	351	1	100.0	15
10/17/24	11:15a	76.8	50	56.8	76.7	9.21	.0730	352	1	100.0	15
10/17/24	11:30a	76.7	49	56.1	76.5	9.02	.0730	351	1	100.0	15
10/17/24	11:45a	77.2	47	55.4	76.8	8.71	.0729	351	1	100.0	15
10/17/24	12:00p	77.2	50	57.1	77.1	9.21	.0729	351	1	100.0	15
10/17/24	12:15p	77.4	48	56.2	77.1	8.90	.0729	351	1	100.0	15
10/17/24	12:30p	77.8	47	56.0	77.4	8.69	.0728	352	1	100.0	15

NKSP 10/17/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/17/24	12:45p	77.7	49	57.0	77.5	9.00	.0727	351	1	100.0	15
10/17/24	1:00p	77.7	48	56.4	77.4	8.90	.0728	351	1	100.0	15
10/17/24	1:15p	78.0	46	55.5	77.4	8.49	.0727	351	1	100.0	15
10/17/24	1:30p	78.1	49	57.4	78.0	8.99	.0726	352	1	100.0	15
10/17/24	1:45p	77.9	48	56.6	77.6	8.89	.0726	351	1	100.0	15
10/17/24	2:00p	78.0	45	54.9	77.3	8.39	.0727	351	1	100.0	15
10/17/24	2:15p	78.2	47	56.3	77.8	8.69	.0726	351	1	100.0	15
10/17/24	2:30p	78.3	50	58.1	78.3	9.18	.0725	352	1	100.0	15
10/17/24	2:45p	78.2	47	56.3	77.8	8.69	.0725	351	1	100.0	15
10/17/24	3:00p	78.4	46	55.9	77.9	8.48	.0725	351	1	100.0	15
10/17/24	3:15p	78.6	48	57.3	78.3	8.88	.0724	351	1	100.0	15
10/17/24	3:30p	78.6	48	57.3	78.3	8.88	.0724	352	1	100.0	15
10/17/24	3:45p	78.5	45	55.4	77.9	8.38	.0725	351	1	100.0	15
10/17/24	4:00p	78.7	45	55.6	78.1	8.38	.0725	351	1	100.0	15
10/17/24	4:15p	78.8	49	58.0	78.7	8.97	.0724	351	1	100.0	15
10/17/24	4:30p	78.5	47	56.6	78.1	8.68	.0724	351	1	100.0	15
10/17/24	4:45p	78.5	45	55.4	77.9	8.38	.0725	352	1	100.0	15
10/17/24	5:00p	78.7	48	57.4	78.4	8.88	.0724	351	1	100.0	15
10/17/24	5:15p	78.5	48	57.2	78.2	8.88	.0724	351	1	100.0	15
10/17/24	5:30p	78.5	45	55.4	77.9	8.38	.0725	351	1	100.0	15
10/17/24	5:45p	78.6	48	57.3	78.3	8.88	.0724	352	1	100.0	15
10/17/24	6:00p	78.3	49	57.6	78.2	8.98	.0724	351	1	100.0	15
10/17/24	6:15p	78.2	45	55.1	77.5	8.39	.0725	351	1	100.0	15
10/17/24	6:30p	78.2	49	57.5	78.1	8.99	.0725	351	1	100.0	15
10/17/24	6:45p	78.1	48	56.8	77.8	8.89	.0725	351	1	100.0	15
10/17/24	7:00p	78.1	45	55.0	77.4	8.39	.0726	352	1	100.0	15
10/17/24	7:15p	78.0	48	56.7	77.7	8.89	.0725	351	1	100.0	15
10/17/24	7:30p	77.7	47	55.9	77.3	8.70	.0726	351	1	100.0	15
10/17/24	7:45p	77.7	44	54.0	76.9	8.20	.0727	351	1	100.0	15
10/17/24	8:00p	77.4	47	55.6	77.0	8.70	.0727	352	1	100.0	15
10/17/24	8:15p	77.0	47	55.2	76.6	8.71	.0728	351	1	100.0	15
10/17/24	8:30p	77.0	44	53.4	76.3	8.21	.0729	351	1	100.0	15
10/17/24	8:45p	77.0	47	55.2	76.6	8.71	.0729	351	1	100.0	15
10/17/24	9:00p	76.7	47	55.0	76.3	8.72	.0729	352	1	100.0	15
10/17/24	9:15p	76.8	44	53.2	76.1	8.21	.0730	351	1	100.0	15
10/17/24	9:30p	77.1	47	55.3	76.7	8.71	.0729	351	1	100.0	15
10/17/24	9:45p	77.0	47	55.2	76.6	8.71	.0729	351	1	100.0	15
10/17/24	10:00p	77.2	44	53.6	76.5	8.21	.0730	351	1	100.0	15
10/17/24	10:15p	77.0	47	55.2	76.6	8.71	.0730	352	1	100.0	15
10/17/24	10:30p	76.7	46	54.4	76.2	8.52	.0730	351	1	100.0	15
10/17/24	10:45p	76.7	47	55.0	76.3	8.72	.0730	351	1	100.0	15
10/17/24	11:00p	76.4	46	54.1	75.9	8.52	.0731	351	1	100.0	15
10/17/24	11:15p	76.5	45	53.6	75.9	8.42	.0731	352	1	100.0	15
10/17/24	11:30p	75.9	46	53.6	75.4	8.53	.0732	351	1	100.0	15
10/17/24	11:45p	76.1	45	53.2	75.5	8.43	.0732	351	1	100.0	15
10/18/24	12:00a	75.7	44	52.2	75.0	8.24	.0733	352	1	100.0	15

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

OUTSIDE TEMPERATURE RECORD
CDCR 2030 (04/18)

INSTITUTION: MCSP

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the OUTSIDE ambient air temperature.

Using an accurate thermometer located in a central, heat neutral location, the outside air temperature is to be taken every hour, seven (7) days a week.

Thermometer Location: CENTRAL

Immediately notify the Watch Commander at extension 3141 **when the air temperature reaches 90 degrees.**

Date	Time	Temp.	Printed Name
10-18-24	0100	59	PADILLA
	0200	57	PADILLA
	0300	57	PADILLA
	0400	57	PADILLA
	0500	57	PADILLA
	0600	56	VALENCIA
	0700	53	VALENCIA
	0800	51	VALENCIA
	0900	51	VALENCIA
	1000	58	VALENCIA
	1100	60	VALENCIA
	1200	63	VALENCIA
	1300	65	VALENCIA
	1400	68	Gonzalez
	1500	70	Gonzalez
	1600	69	Gonzalez
	1700	69	Gonzalez
	1800	68	Gonzalez
	1900	64	Gonzalez
	2000	61	Gonzalez
	2100	58	Gonzalez
	2200	56	J. FIERRO
	2300	53	J. FIERRO
	2400	50	J. FIERRO

Date	Time	Temp.	Printed Name
10-19-24	0100	49	J. FIERRO
	0200	48	J. FIERRO
	0300	47	J. FIERRO
	0400	45	J. FIERRO
	0500	46	J. FIERRO
	0600	44	Gonzalez
	0700	44	Gonzalez
	0800	46	Gonzalez
	0900	53	Gonzalez
	1000	60	Gonzalez
	1100	65	Gonzalez
	1200	70	Gonzalez
	1300	72	Gonzalez
	1400	74	Gonzalez
	1500	76	Gonzalez
	1600	78	Gonzalez
	1700	77	Gonzalez
	1800	76	Gonzalez
	1900	71	Gonzalez
	2000	69	Gonzalez
	2100	67	Gonzalez
	2200	57.1	Ramirez
	2300	54.2	Ramirez
	2400	53.1	Ramirez

DISTRIBUTION: Original: Institution Heat Plan Coordinator

NKSP 10/18/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/18/24	12:15a	60.9	61.1	60.9	0	---	4.0	W	1.00	10.0	W	60.9	54.7	54.7	29.977	0.00	0.00	0.043	0.000
10/18/24	12:30a	60.3	60.9	60.2	0	---	5.0	W	1.25	9.0	W	60.3	54.2	54.2	29.977	0.00	0.00	0.049	0.000
10/18/24	12:45a	59.6	60.3	59.6	0	---	4.0	WSW	1.00	9.0	WSW	59.6	53.7	53.7	29.982	0.00	0.00	0.056	0.000
10/18/24	1:00a	59.7	59.7	59.5	0	---	5.0	WSW	1.25	11.0	WSW	59.6	53.8	53.7	29.976	0.00	0.00	0.055	0.000
10/18/24	1:15a	59.5	59.7	59.5	0	---	3.0	WSW	0.75	8.0	WSW	59.5	53.6	53.6	29.981	0.00	0.00	0.057	0.000
10/18/24	1:30a	58.8	59.5	58.7	0	---	0.0	NW	0.00	1.0	W	58.8	53.1	53.1	29.987	0.00	0.00	0.065	0.000
10/18/24	1:45a	57.7	58.7	57.7	0	---	0.0	N	0.00	1.0	N	57.7	52.3	52.3	29.991	0.00	0.00	0.076	0.000
10/18/24	2:00a	57.7	57.7	57.5	0	---	0.0	NE	0.00	1.0	N	57.7	52.3	52.3	29.998	0.00	0.00	0.076	0.000
10/18/24	2:15a	58.2	58.3	57.6	0	---	0.0	NW	0.00	4.0	NNW	58.2	52.6	52.6	29.993	0.00	0.00	0.071	0.000
10/18/24	2:30a	58.6	58.6	58.2	0	---	1.0	NNW	0.25	8.0	NNW	58.6	52.9	52.9	29.997	0.00	0.00	0.067	0.000
10/18/24	2:45a	58.3	58.7	58.3	0	---	2.0	NNW	0.50	4.0	NW	58.3	52.7	52.7	30.001	0.00	0.00	0.070	0.000
10/18/24	3:00a	57.9	58.3	57.9	0	---	0.0	NNW	0.00	4.0	NNW	57.9	52.4	52.4	30.006	0.00	0.00	0.074	0.000
10/18/24	3:15a	57.4	57.9	57.4	0	---	0.0	NNW	0.00	1.0	NNW	57.4	52.0	52.0	30.007	0.00	0.00	0.079	0.000
10/18/24	3:30a	57.1	57.5	57.1	0	---	0.0	NNW	0.00	1.0	NNW	57.1	51.8	51.8	30.012	0.00	0.00	0.082	0.000
10/18/24	3:45a	55.3	57.1	55.3	0	---	0.0	NNE	0.00	1.0	NNE	55.3	50.5	50.5	30.016	0.00	0.00	0.101	0.000
10/18/24	4:00a	54.4	55.2	54.4	0	---	0.0	NNE	0.00	2.0	NNE	54.4	49.9	49.9	30.018	0.00	0.00	0.110	0.000
10/18/24	4:15a	54.8	54.8	54.3	0	---	0.0	NNE	0.00	1.0	NNE	54.8	50.2	50.2	30.029	0.00	0.00	0.106	0.000
10/18/24	4:30a	57.1	57.1	54.9	0	---	1.0	WNW	0.25	8.0	W	57.1	51.8	51.8	30.035	0.00	0.00	0.082	0.000
10/18/24	4:45a	57.2	57.4	57.1	0	---	3.0	NW	0.75	6.0	NNW	57.2	51.9	51.9	30.040	0.00	0.00	0.081	0.000
10/18/24	5:00a	57.0	57.2	57.0	0	---	2.0	NW	0.50	5.0	NW	57.0	51.7	51.7	30.042	0.00	0.00	0.083	0.000
10/18/24	5:15a	56.9	57.0	56.9	0	---	2.0	NW	0.50	5.0	NNW	56.9	51.6	51.6	30.048	0.00	0.00	0.084	0.000
10/18/24	5:30a	56.0	57.0	56.0	0	---	0.0	N	0.00	3.0	N	56.0	51.0	51.0	30.055	0.00	0.00	0.094	0.000
10/18/24	5:45a	55.7	56.0	55.6	0	---	0.0	N	0.00	1.0	N	55.7	50.8	50.8	30.059	0.00	0.00	0.097	0.000
10/18/24	6:00a	56.2	56.2	55.7	0	---	0.0	NNW	0.00	1.0	N	56.2	51.1	51.1	30.058	0.00	0.00	0.092	0.000
10/18/24	6:15a	56.3	56.9	56.2	0	---	0.0	NNW	0.00	4.0	N	56.3	51.2	51.2	30.059	0.00	0.00	0.091	0.000
10/18/24	6:30a	55.7	56.3	55.7	0	---	0.0	WNW	0.00	2.0	WNW	55.7	50.8	50.8	30.066	0.00	0.00	0.097	0.000
10/18/24	6:45a	54.7	55.7	54.7	0	---	1.0	WSW	0.25	4.0	WSW	54.7	50.1	50.1	30.075	0.00	0.00	0.107	0.000
10/18/24	7:00a	53.6	54.7	53.6	0	---	1.0	SW	0.25	3.0	WSW	53.6	49.3	49.3	30.081	0.00	0.00	0.119	0.000
10/18/24	7:15a	52.2	53.6	52.1	1	-46.1	0.0	SW	0.00	3.0	SW	52.2	48.5	48.5	30.090	0.00	0.00	0.133	0.000
10/18/24	7:30a	51.6	52.1	51.5	3	-27.1	0.0	SW	0.00	2.0	SW	51.6	48.1	48.1	30.101	0.00	0.00	0.140	0.000
10/18/24	7:45a	50.8	51.6	50.8	3	-27.7	2.0	SW	0.50	5.0	SW	50.8	47.6	47.6	30.108	0.00	0.00	0.148	0.000
10/18/24	8:00a	51.5	51.5	50.8	2	-34.6	1.0	SW	0.25	4.0	SW	51.5	48.0	48.0	30.117	0.00	0.00	0.141	0.000
10/18/24	8:15a	52.5	52.5	51.4	2	-33.9	0.0	SW	0.00	1.0	SW	52.5	48.7	48.7	30.130	0.00	0.00	0.130	0.000
10/18/24	8:30a	53.9	53.9	52.5	---	---	1.0	SW	0.25	4.0	SSW	53.9	---	---	30.143	0.00	0.00	0.116	0.000
10/18/24	8:45a	55.8	55.8	53.9	0	---	3.0	WSW	0.75	9.0	WSW	55.8	50.9	50.9	30.151	0.00	0.00	0.096	0.000
10/18/24	9:00a	57.1	57.1	55.8	0	---	6.0	W	1.50	10.0	WSW	56.1	51.8	50.8	30.153	0.00	0.00	0.082	0.000
10/18/24	9:15a	57.6	57.7	57.1	0	---	6.0	W	1.50	12.0	WNW	56.7	52.2	51.3	30.163	0.00	0.00	0.077	0.000
10/18/24	9:30a	58.0	58.0	57.6	0	---	6.0	WNW	1.50	12.0	NW	57.2	52.5	51.7	30.165	0.00	0.00	0.073	0.000
10/18/24	9:45a	58.2	58.2	57.9	0	---	4.0	NW	1.00	10.0	NW	58.2	52.6	52.6	30.172	0.00	0.00	0.071	0.000
10/18/24	10:00a	58.7	58.7	58.2	0	---	4.0	WNW	1.00	9.0	WNW	58.7	53.0	53.0	30.172	0.00	0.00	0.066	0.000
10/18/24	10:15a	59.0	59.1	58.7	0	---	4.0	W	1.00	9.0	W	59.0	53.2	53.2	30.179	0.00	0.00	0.063	0.000
10/18/24	10:30a	59.2	59.3	58.9	0	---	2.0	N	0.50	6.0	W	59.2	53.4	53.4	30.179	0.00	0.00	0.060	0.000
10/18/24	10:45a	60.5	60.5	59.2	0	---	1.0	WSW	0.25	8.0	WSW	60.5	54.4	54.4	30.182	0.00	0.00	0.047	0.000
10/18/24	11:00a	60.9	61.0	60.4	0	---	2.0	W	0.50	8.0	W	60.9	54.7	54.7	30.181	0.00	0.00	0.043	0.000
10/18/24	11:15a	61.5	61.5	60.9	0	---	2.0	SW	0.50	8.0	SW	61.5	55.2	55.2	30.186	0.00	0.00	0.036	0.000
10/18/24	11:30a	62.2	62.3	61.5	0	---	2.0	WSW	0.50	11.0	SW	62.2	55.8	55.8	30.182	0.00	0.00	0.029	0.000
10/18/24	11:45a	62.7	62.7	62.1	0	---	3.0	SSW	0.75	10.0	S	62.7	56.2	56.2	30.182	0.00	0.00	0.024	0.000
10/18/24	12:00p	63.6	63.6	62.7	0	---	3.0	SSW	0.75	10.0	W	63.6	56.9	56.9	30.184	0.00	0.00	0.015	0.000
10/18/24	12:15p	63.4	63.7	63.3	0	---	4.0	SW	1.00	11.0	SW	63.4	56.8	56.8	30.184	0.00	0.00	0.017	0.000
10/18/24	12:30p	64.4	64.4	63.4	0	---	3.0	SW	0.75	10.0	SW	64.4	57.6	57.6	30.179	0.00	0.00	0.006	0.000

NKSP 10/18/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/18/24	12:45p	64.9	64.9	64.3	0	---	2.0	WSW	0.50	8.0	WSW	64.9	58.0	58.0	30.170	0.00	0.00	0.001	0.000
10/18/24	1:00p	65.5	65.7	65.0	0	---	4.0	SW	1.00	11.0	WSW	65.5	58.5	58.5	30.171	0.00	0.00	0.000	0.005
10/18/24	1:15p	65.9	65.9	65.3	0	---	2.0	SSW	0.50	9.0	SSW	65.9	58.9	58.9	30.164	0.00	0.00	0.000	0.009
10/18/24	1:30p	67.7	67.7	66.0	0	---	3.0	SSW	0.75	10.0	SW	67.7	60.5	60.5	30.161	0.00	0.00	0.000	0.028
10/18/24	1:45p	67.6	67.8	67.3	0	---	2.0	W	0.50	7.0	W	67.6	60.4	60.4	30.154	0.00	0.00	0.000	0.027
10/18/24	2:00p	68.2	68.6	67.7	0	---	2.0	SW	0.50	7.0	WNW	68.2	61.1	61.1	30.152	0.00	0.00	0.000	0.033
10/18/24	2:15p	69.1	69.1	68.1	0	---	2.0	SW	0.50	10.0	WSW	69.1	62.5	62.5	30.149	0.00	0.00	0.000	0.043
10/18/24	2:30p	69.2	69.5	69.1	0	---	3.0	SSW	0.75	9.0	S	69.2	62.7	62.7	30.146	0.00	0.00	0.000	0.044
10/18/24	2:45p	69.8	69.9	69.2	0	---	2.0	SSW	0.50	9.0	SSE	69.8	63.6	63.6	30.146	0.00	0.00	0.000	0.050
10/18/24	3:00p	70.1	70.3	69.6	0	---	4.0	SW	1.00	9.0	SSW	70.1	64.0	64.0	30.145	0.00	0.00	0.000	0.053
10/18/24	3:15p	70.9	70.9	69.9	0	---	2.0	SSW	0.50	8.0	S	70.9	65.1	65.1	30.142	0.00	0.00	0.000	0.061
10/18/24	3:30p	69.9	71.0	69.9	0	---	3.0	NW	0.75	8.0	NW	69.9	63.8	63.8	30.143	0.00	0.00	0.000	0.051
10/18/24	3:45p	69.3	69.9	69.1	0	---	3.0	NNW	0.75	8.0	NNW	69.3	62.9	62.9	30.143	0.00	0.00	0.000	0.045
10/18/24	4:00p	69.5	69.6	69.3	0	---	3.0	NNW	0.75	7.0	W	69.5	63.2	63.2	30.139	0.00	0.00	0.000	0.047
10/18/24	4:15p	69.4	69.7	69.4	0	---	3.0	NNW	0.75	8.0	WNW	69.4	63.0	63.0	30.138	0.00	0.00	0.000	0.046
10/18/24	4:30p	70.0	70.0	69.5	0	---	2.0	N	0.50	7.0	WNW	70.0	63.9	63.9	30.136	0.00	0.00	0.000	0.052
10/18/24	4:45p	70.1	70.1	69.8	0	---	3.0	N	0.75	8.0	WNW	70.1	64.0	64.0	30.137	0.00	0.00	0.000	0.053
10/18/24	5:00p	69.5	70.1	69.5	0	---	3.0	NNW	0.75	8.0	NNW	69.5	63.2	63.2	30.134	0.00	0.00	0.000	0.047
10/18/24	5:15p	69.4	69.5	69.3	0	---	2.0	N	0.50	5.0	NNW	69.4	63.0	63.0	30.133	0.00	0.00	0.000	0.046
10/18/24	5:30p	69.2	69.5	69.2	0	---	2.0	NNW	0.50	4.0	NNW	69.2	62.7	62.7	30.137	0.00	0.00	0.000	0.044
10/18/24	5:45p	68.9	69.3	68.9	0	---	1.0	NNW	0.25	4.0	NNW	68.9	62.2	62.2	30.137	0.00	0.00	0.000	0.041
10/18/24	6:00p	68.4	68.9	68.4	0	---	1.0	NNW	0.25	3.0	NNW	68.4	61.4	61.4	30.137	0.00	0.00	0.000	0.035
10/18/24	6:15p	67.5	68.4	67.5	0	---	2.0	NW	0.50	4.0	NW	67.5	60.3	60.3	30.138	0.00	0.00	0.000	0.026
10/18/24	6:30p	66.2	67.5	66.2	0	---	2.0	NW	0.50	5.0	NW	66.2	59.2	59.2	30.142	0.00	0.00	0.000	0.012
10/18/24	6:45p	65.4	66.2	65.4	0	---	2.0	NW	0.50	4.0	NNW	65.4	58.5	58.5	30.143	0.00	0.00	0.000	0.004
10/18/24	7:00p	64.7	65.4	64.6	0	---	0.0	NNW	0.00	3.0	NNW	64.7	57.9	57.9	30.148	0.00	0.00	0.003	0.000
10/18/24	7:15p	63.4	64.6	63.4	0	---	0.0	NNW	0.00	1.0	NNW	63.4	56.8	56.8	30.153	0.00	0.00	0.017	0.000
10/18/24	7:30p	63.2	63.4	63.1	0	---	0.0	NNW	0.00	1.0	NNW	63.2	56.6	56.6	30.158	0.00	0.00	0.019	0.000
10/18/24	7:45p	62.9	63.2	62.9	0	---	0.0	NNW	0.00	1.0	NNW	62.9	56.3	56.3	30.163	0.00	0.00	0.022	0.000
10/18/24	8:00p	61.8	62.9	61.8	0	---	0.0	NW	0.00	2.0	WNW	61.8	55.4	55.4	30.168	0.00	0.00	0.033	0.000
10/18/24	8:15p	62.0	62.0	61.7	0	---	0.0	---	0.00	0.0	---	62.0	55.6	55.6	30.171	0.00	0.00	0.031	0.000
10/18/24	8:30p	60.3	62.0	60.3	0	---	0.0	SE	0.00	4.0	SE	60.3	54.2	54.2	30.178	0.00	0.00	0.049	0.000
10/18/24	8:45p	58.3	60.2	58.0	2	-30.1	1.0	ESE	0.25	4.0	ESE	58.3	52.8	52.8	30.179	0.00	0.00	0.070	0.000
10/18/24	9:00p	58.6	58.9	58.3	2	-29.9	2.0	SE	0.50	4.0	SE	58.6	53.1	53.1	30.180	0.00	0.00	0.067	0.000
10/18/24	9:15p	57.6	58.6	57.6	7	-6.2	2.0	ESE	0.50	4.0	SE	57.6	52.8	52.8	30.185	0.00	0.00	0.077	0.000
10/18/24	9:30p	57.3	57.8	57.3	7	-6.4	1.0	SE	0.25	4.0	SE	57.3	52.6	52.6	30.188	0.00	0.00	0.080	0.000
10/18/24	9:45p	56.3	57.3	56.3	8	-4.4	1.0	ESE	0.25	3.0	SE	56.3	52.0	52.0	30.190	0.00	0.00	0.091	0.000
10/18/24	10:00p	56.4	56.8	56.3	7	-7.1	0.0	ESE	0.00	1.0	ESE	56.4	51.9	51.9	30.196	0.00	0.00	0.090	0.000
10/18/24	10:15p	55.4	56.4	55.3	8	-5.1	0.0	---	0.00	0.0	---	55.4	51.3	51.3	30.202	0.00	0.00	0.100	0.000
10/18/24	10:30p	55.6	55.8	55.3	8	-4.9	0.0	ESE	0.00	1.0	ESE	55.6	51.4	51.4	30.198	0.00	0.00	0.098	0.000
10/18/24	10:45p	54.1	55.6	54.1	11	0.6	1.0	ESE	0.25	3.0	ESE	54.1	50.5	50.5	30.200	0.00	0.00	0.114	0.000
10/18/24	11:00p	53.1	54.1	53.1	12	1.7	1.0	ESE	0.25	4.0	ESE	53.1	49.8	49.8	30.204	0.00	0.00	0.124	0.000
10/18/24	11:15p	52.4	53.0	52.4	13	2.9	3.0	ESE	0.75	6.0	ESE	52.3	49.3	49.2	30.204	0.00	0.00	0.131	0.000
10/18/24	11:30p	51.6	52.4	51.6	12	0.5	3.0	SE	0.75	7.0	ESE	51.5	48.7	48.6	30.203	0.00	0.00	0.140	0.000
10/18/24	11:45p	50.5	51.6	50.5	12	-0.3	3.0	SE	0.75	5.0	SE	50.3	47.8	47.6	30.203	0.00	0.00	0.151	0.000
10/19/24	12:00a	50.5	50.6	50.5	13	1.4	2.0	SE	0.50	5.0	SE	50.5	47.8	47.8	30.199	0.00	0.00	0.151	0.000

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/18/24	12:15a	75.6	44	52.1	74.9	8.24	.0733	350	1	100.0	15
10/18/24	12:30a	75.7	42	51.0	74.8	7.94	.0733	351	1	100.0	15
10/18/24	12:45a	75.2	44	51.8	74.5	8.25	.0734	351	1	100.0	15
10/18/24	1:00a	75.4	43	51.3	74.6	8.05	.0734	351	1	100.0	15
10/18/24	1:15a	75.2	42	50.5	74.3	7.95	.0734	352	1	100.0	15
10/18/24	1:30a	75.1	43	51.1	74.3	8.05	.0734	351	1	100.0	15
10/18/24	1:45a	75.3	42	50.6	74.4	7.94	.0734	351	1	100.0	15
10/18/24	2:00a	75.2	41	49.9	74.2	7.75	.0735	352	1	100.0	15
10/18/24	2:15a	74.8	42	50.2	73.9	7.95	.0735	351	1	100.0	15
10/18/24	2:30a	74.9	42	50.3	74.0	7.95	.0735	351	1	100.0	15
10/18/24	2:45a	75.1	40	49.1	74.0	7.65	.0735	351	1	100.0	15
10/18/24	3:00a	74.6	42	50.0	73.7	7.96	.0736	351	1	100.0	15
10/18/24	3:15a	74.7	41	49.4	73.7	7.76	.0736	351	1	100.0	15
10/18/24	3:30a	74.9	41	49.6	73.9	7.75	.0736	352	1	100.0	15
10/18/24	3:45a	75.1	41	49.8	74.1	7.75	.0736	351	1	100.0	15
10/18/24	4:00a	75.1	40	49.1	74.0	7.65	.0736	351	1	100.0	15
10/18/24	4:15a	75.2	40	49.2	74.1	7.65	.0736	351	1	100.0	15
10/18/24	4:30a	75.2	38	47.8	74.0	7.35	.0736	352	1	100.0	15
10/18/24	4:45a	74.5	40	48.6	73.4	7.66	.0737	351	1	100.0	15
10/18/24	5:00a	74.6	39	48.0	73.4	7.56	.0737	351	1	100.0	15
10/18/24	5:15a	74.7	39	48.1	73.5	7.56	.0737	351	1	100.0	15
10/18/24	5:30a	74.8	38	47.5	73.6	7.36	.0738	352	1	100.0	15
10/18/24	5:45a	74.8	38	47.5	73.6	7.36	.0738	351	1	100.0	15
10/18/24	6:00a	74.7	38	47.4	73.4	7.36	.0738	351	1	100.0	15
10/18/24	6:15a	74.3	38	47.0	73.0	7.38	.0739	351	1	100.0	15
10/18/24	6:30a	74.4	38	47.1	73.1	7.37	.0739	351	1	100.0	15
10/18/24	6:45a	74.6	37	46.6	73.3	7.26	.0739	352	1	100.0	15
10/18/24	7:00a	74.6	37	46.6	73.3	7.26	.0739	351	1	100.0	15
10/18/24	7:15a	74.7	37	46.7	73.4	7.26	.0739	351	1	100.0	15
10/18/24	7:30a	74.7	36	46.0	73.3	7.06	.0739	351	1	100.0	15
10/18/24	7:45a	74.8	36	46.1	73.4	7.06	.0739	352	1	100.0	15
10/18/24	8:00a	74.8	36	46.1	73.4	7.06	.0740	351	1	100.0	15
10/18/24	8:15a	74.9	36	46.1	73.5	7.05	.0740	351	1	100.0	15
10/18/24	8:30a	75.1	36	46.3	73.8	7.05	.0740	351	1	100.0	15
10/18/24	8:45a	74.6	36	45.9	73.2	7.07	.0741	352	1	100.0	15
10/18/24	9:00a	74.7	36	46.0	73.3	7.06	.0741	351	1	100.0	15
10/18/24	9:15a	74.9	35	45.4	73.5	6.95	.0741	351	1	100.0	15
10/18/24	9:30a	75.0	35	45.5	73.6	6.95	.0741	351	1	100.0	15
10/18/24	9:45a	74.7	35	45.2	73.3	6.96	.0741	351	1	100.0	15
10/18/24	10:00a	75.1	35	45.6	73.7	6.95	.0741	352	1	100.0	15
10/18/24	10:15a	75.3	34	45.0	73.8	6.74	.0741	351	1	100.0	15
10/18/24	10:30a	75.2	35	45.7	73.8	6.95	.0741	351	1	100.0	15
10/18/24	10:45a	75.6	34	45.2	74.1	6.74	.0740	351	1	100.0	15
10/18/24	11:00a	75.5	35	45.9	74.1	6.94	.0740	352	1	100.0	15
10/18/24	11:15a	75.7	34	45.3	74.2	6.74	.0740	351	1	100.0	15
10/18/24	11:30a	75.8	34	45.4	74.3	6.73	.0740	351	1	100.0	15
10/18/24	11:45a	75.7	34	45.3	74.2	6.74	.0740	351	1	100.0	15
10/18/24	12:00p	76.2	33	45.0	74.7	6.55	.0740	351	1	100.0	15
10/18/24	12:15p	75.7	34	45.3	74.2	6.74	.0740	352	1	100.0	15
10/18/24	12:30p	75.9	33	44.7	74.4	6.55	.0740	351	1	100.0	15

NKSP 10/18/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/18/24	12:45p	76.1	33	44.9	74.6	6.55	.0739	351	1	100.0	15
10/18/24	1:00p	75.9	34	45.5	74.4	6.73	.0740	351	1	100.0	15
10/18/24	1:15p	75.9	33	44.7	74.4	6.55	.0740	352	1	100.0	15
10/18/24	1:30p	76.3	32	44.3	74.7	6.42	.0739	351	1	100.0	15
10/18/24	1:45p	76.0	34	45.6	74.5	6.73	.0739	351	1	100.0	15
10/18/24	2:00p	75.7	34	45.3	74.2	6.74	.0739	351	1	100.0	15
10/18/24	2:15p	76.0	32	44.0	74.4	6.43	.0739	352	1	100.0	15
10/18/24	2:30p	76.3	33	45.1	74.8	6.55	.0739	351	1	100.0	15
10/18/24	2:45p	75.9	34	45.5	74.4	6.73	.0739	351	1	100.0	15
10/18/24	3:00p	76.0	33	44.8	74.5	6.55	.0739	351	1	100.0	15
10/18/24	3:15p	76.4	32	44.4	74.8	6.42	.0739	351	1	100.0	15
10/18/24	3:30p	76.6	32	44.5	75.0	6.42	.0738	352	1	100.0	15
10/18/24	3:45p	76.5	33	45.2	74.9	6.55	.0738	351	1	100.0	15
10/18/24	4:00p	76.3	33	45.1	74.8	6.55	.0738	351	1	100.0	15
10/18/24	4:15p	76.5	32	44.4	74.9	6.42	.0738	351	1	100.0	15
10/18/24	4:30p	76.7	32	44.6	75.1	6.42	.0738	352	1	100.0	15
10/18/24	4:45p	76.6	33	45.3	75.0	6.55	.0738	351	1	100.0	15
10/18/24	5:00p	76.6	33	45.3	75.0	6.55	.0738	351	1	100.0	15
10/18/24	5:15p	76.5	33	45.2	74.9	6.55	.0738	351	1	100.0	15
10/18/24	5:30p	76.8	32	44.7	75.2	6.41	.0738	351	1	100.0	15
10/18/24	5:45p	77.0	33	45.7	75.4	6.55	.0737	352	1	100.0	15
10/18/24	6:00p	76.6	34	46.1	75.1	6.72	.0738	351	1	100.0	15
10/18/24	6:15p	76.4	34	45.9	74.9	6.72	.0738	351	1	100.0	15
10/18/24	6:30p	76.7	32	44.6	75.1	6.42	.0738	351	1	100.0	15
10/18/24	6:45p	76.6	34	46.1	75.1	6.72	.0738	352	1	100.0	15
10/18/24	7:00p	76.1	34	45.7	74.6	6.73	.0739	351	1	100.0	15
10/18/24	7:15p	76.4	33	45.2	74.9	6.55	.0739	351	1	100.0	15
10/18/24	7:30p	76.2	35	46.5	74.8	6.93	.0739	351	1	100.0	15
10/18/24	7:45p	76.0	35	46.4	74.6	6.93	.0739	352	1	100.0	15
10/18/24	8:00p	75.9	35	46.3	74.5	6.93	.0739	351	1	100.0	15
10/18/24	8:15p	75.1	35	45.6	73.7	6.95	.0741	351	1	100.0	15
10/18/24	8:30p	75.4	34	45.1	73.9	6.74	.0741	351	1	100.0	15
10/18/24	8:45p	75.1	36	46.3	73.8	7.05	.0741	351	1	100.0	15
10/18/24	9:00p	74.9	36	46.1	73.5	7.05	.0741	352	1	100.0	15
10/18/24	9:15p	75.1	37	47.0	73.8	7.25	.0741	351	1	100.0	15
10/18/24	9:30p	74.6	37	46.6	73.3	7.26	.0742	351	1	100.0	15
10/18/24	9:45p	74.9	37	46.9	73.6	7.25	.0741	351	1	100.0	15
10/18/24	10:00p	74.4	38	47.1	73.1	7.37	.0742	352	1	100.0	15
10/18/24	10:15p	74.9	38	47.6	73.7	7.35	.0741	351	1	100.0	15
10/18/24	10:30p	75.2	37	47.1	73.9	7.25	.0741	351	1	100.0	15
10/18/24	10:45p	75.0	37	47.0	73.7	7.25	.0741	351	1	100.0	15
10/18/24	11:00p	75.4	37	47.3	74.1	7.24	.0741	352	1	100.0	15
10/18/24	11:15p	75.5	37	47.4	74.2	7.24	.0740	351	1	100.0	15
10/18/24	11:30p	75.5	36	46.7	74.2	7.04	.0741	351	1	100.0	15
10/18/24	11:45p	75.4	36	46.6	74.1	7.04	.0741	351	1	100.0	15
10/19/24	12:00a	75.3	36	46.5	74.0	7.04	.0741	351	1	100.0	15

NKSP 10/19/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/19/24	12:15a	50.1	50.5	50.1	15	4.2	3.0	SE	0.75	7.0	SE	49.8	47.6	47.3	30.199	0.00	0.00	0.155	0.000
10/19/24	12:30a	50.7	50.7	50.1	15	4.6	2.0	SE	0.50	5.0	SE	50.7	48.0	48.0	30.194	0.00	0.00	0.149	0.000
10/19/24	12:45a	50.3	50.8	50.3	14	2.8	3.0	SE	0.75	5.0	SE	50.0	47.7	47.4	30.193	0.00	0.00	0.153	0.000
10/19/24	1:00a	49.8	50.3	49.7	15	3.9	2.0	SE	0.50	5.0	SE	49.8	47.3	47.3	30.193	0.00	0.00	0.158	0.000
10/19/24	1:15a	49.6	49.9	49.6	14	2.3	2.0	ESE	0.50	4.0	SE	49.6	47.1	47.1	30.190	0.00	0.00	0.160	0.000
10/19/24	1:30a	49.3	49.6	49.3	17	6.2	2.0	ESE	0.50	3.0	ESE	49.3	47.0	47.0	30.194	0.00	0.00	0.164	0.000
10/19/24	1:45a	49.5	49.5	49.3	16	5.1	1.0	ESE	0.25	3.0	ESE	49.5	47.1	47.1	30.189	0.00	0.00	0.161	0.000
10/19/24	2:00a	48.9	49.5	48.9	16	4.6	3.0	ESE	0.75	4.0	ESE	48.4	46.5	46.0	30.190	0.00	0.00	0.168	0.000
10/19/24	2:15a	49.2	49.2	48.9	16	4.8	2.0	ESE	0.50	4.0	ESE	49.2	46.8	46.8	30.192	0.00	0.00	0.165	0.000
10/19/24	2:30a	48.9	49.2	48.9	15	3.2	0.0	ESE	0.00	1.0	ESE	48.9	46.5	46.5	30.193	0.00	0.00	0.168	0.000
10/19/24	2:45a	47.5	48.9	47.4	15	2.1	0.0	SW	0.00	3.0	SW	47.5	45.2	45.2	30.196	0.00	0.00	0.182	0.000
10/19/24	3:00a	47.0	47.5	46.7	18	5.6	0.0	SW	0.00	2.0	SW	47.0	44.8	44.8	30.190	0.00	0.00	0.188	0.000
10/19/24	3:15a	47.3	47.6	47.0	16	3.3	0.0	SSE	0.00	2.0	SSE	47.3	45.0	45.0	30.181	0.00	0.00	0.184	0.000
10/19/24	3:30a	45.9	47.2	45.9	17	3.5	3.0	E	0.75	6.0	ESE	45.1	43.7	42.9	30.180	0.00	0.00	0.199	0.000
10/19/24	3:45a	45.5	45.9	45.4	21	7.8	2.0	E	0.50	4.0	E	45.5	43.4	43.4	30.182	0.00	0.00	0.203	0.000
10/19/24	4:00a	45.7	45.8	45.5	21	7.9	0.0	E	0.00	3.0	E	45.7	43.6	43.6	30.181	0.00	0.00	0.201	0.000
10/19/24	4:15a	45.9	46.0	45.7	21	8.1	1.0	E	0.25	3.0	E	45.9	43.8	43.8	30.183	0.00	0.00	0.199	0.000
10/19/24	4:30a	46.4	46.4	45.8	22	9.6	0.0	E	0.00	2.0	E	46.4	44.3	44.3	30.187	0.00	0.00	0.194	0.000
10/19/24	4:45a	47.0	47.0	46.3	20	7.9	1.0	E	0.25	3.0	E	47.0	44.8	44.8	30.191	0.00	0.00	0.188	0.000
10/19/24	5:00a	46.7	47.0	46.7	19	6.5	0.0	---	0.00	0.0	---	46.7	44.5	44.5	30.192	0.00	0.00	0.191	0.000
10/19/24	5:15a	46.1	46.7	46.1	19	6.0	0.0	E	0.00	2.0	E	46.1	44.0	44.0	30.190	0.00	0.00	0.197	0.000
10/19/24	5:30a	45.4	46.1	45.4	19	5.5	0.0	E	0.00	3.0	E	45.4	43.3	43.3	30.195	0.00	0.00	0.204	0.000
10/19/24	5:45a	44.5	45.4	44.5	19	4.7	2.0	E	0.50	4.0	ESE	44.5	42.4	42.4	30.197	0.00	0.00	0.214	0.000
10/19/24	6:00a	44.6	44.7	44.3	20	5.9	2.0	ESE	0.50	5.0	SE	44.6	42.5	42.5	30.203	0.00	0.00	0.213	0.000
10/19/24	6:15a	44.9	44.9	44.5	21	7.3	3.0	SE	0.75	7.0	SE	43.9	42.8	41.8	30.209	0.00	0.00	0.209	0.000
10/19/24	6:30a	45.1	45.2	44.9	19	5.2	3.0	SE	0.75	6.0	ESE	44.1	43.0	42.0	30.204	0.00	0.00	0.207	0.000
10/19/24	6:45a	44.9	45.1	44.8	20	6.2	1.0	SE	0.25	4.0	SE	44.9	42.8	42.8	30.205	0.00	0.00	0.209	0.000
10/19/24	7:00a	44.5	44.9	44.5	21	6.9	3.0	ESE	0.75	6.0	ESE	43.5	42.5	41.5	30.210	0.00	0.00	0.214	0.000
10/19/24	7:15a	44.2	44.4	44.2	24	9.6	3.0	ESE	0.75	4.0	ESE	43.1	42.3	41.2	30.206	0.00	0.00	0.217	0.000
10/19/24	7:30a	44.2	44.2	44.1	25	10.5	2.0	ESE	0.50	4.0	ESE	44.2	42.3	42.3	30.211	0.00	0.00	0.217	0.000
10/19/24	7:45a	44.9	44.9	44.2	24	10.2	2.0	ESE	0.50	4.0	ESE	44.9	43.0	43.0	30.215	0.00	0.00	0.209	0.000
10/19/24	8:00a	46.0	46.0	44.9	23	10.2	0.0	ESE	0.00	2.0	ESE	46.0	44.0	44.0	30.225	0.00	0.00	0.198	0.000
10/19/24	8:15a	47.7	47.7	46.1	19	7.4	0.0	---	0.00	0.0	---	47.7	45.5	45.5	30.230	0.00	0.00	0.180	0.000
10/19/24	8:30a	49.7	49.7	47.8	16	5.2	0.0	---	0.00	0.0	---	49.7	47.3	47.3	30.227	0.00	0.00	0.159	0.000
10/19/24	8:45a	50.8	50.8	49.7	13	1.6	0.0	ESE	0.00	1.0	ESE	50.8	48.1	48.1	30.231	0.00	0.00	0.148	0.000
10/19/24	9:00a	53.2	53.2	50.8	9	-4.3	0.0	---	0.00	0.0	---	53.2	49.7	49.7	30.241	0.00	0.00	0.123	0.000
10/19/24	9:15a	54.2	54.2	53.2	7	-8.7	0.0	SW	0.00	3.0	SW	54.2	50.2	50.2	30.244	0.00	0.00	0.112	0.000
10/19/24	9:30a	57.0	57.0	54.2	1	-43.1	0.0	SW	0.00	1.0	SW	57.0	51.8	51.8	30.243	0.00	0.00	0.083	0.000
10/19/24	9:45a	58.4	58.4	57.0	0	---	0.0	SW	0.00	2.0	SW	58.4	52.8	52.8	30.241	0.00	0.00	0.069	0.000
10/19/24	10:00a	60.5	60.5	58.5	0	---	0.0	SSW	0.00	1.0	SSW	60.5	54.4	54.4	30.237	0.00	0.00	0.047	0.000
10/19/24	10:15a	62.7	62.7	60.5	0	---	1.0	S	0.25	3.0	SSW	62.7	56.2	56.2	30.234	0.00	0.00	0.024	0.000
10/19/24	10:30a	63.8	63.8	62.7	0	---	1.0	SW	0.25	5.0	SSW	63.8	57.1	57.1	30.232	0.00	0.00	0.013	0.000
10/19/24	10:45a	64.1	64.1	63.8	0	---	2.0	SW	0.50	6.0	SW	64.1	57.4	57.4	30.231	0.00	0.00	0.009	0.000
10/19/24	11:00a	65.9	65.9	64.1	0	---	2.0	WSW	0.50	7.0	SSW	65.9	58.9	58.9	30.230	0.00	0.00	0.000	0.009
10/19/24	11:15a	67.5	67.5	65.8	0	---	0.0	WNW	0.00	3.0	WNW	67.5	60.3	60.3	30.228	0.00	0.00	0.000	0.026
10/19/24	11:30a	69.0	69.0	67.5	0	---	0.0	SW	0.00	4.0	WNW	69.0	62.4	62.4	30.226	0.00	0.00	0.000	0.042
10/19/24	11:45a	69.5	69.5	68.7	0	---	1.0	SW	0.25	4.0	NW	69.5	63.2	63.2	30.224	0.00	0.00	0.000	0.047
10/19/24	12:00p	70.2	70.2	69.5	0	---	0.0	WNW	0.00	2.0	W	70.2	64.2	64.2	30.220	0.00	0.00	0.000	0.054
10/19/24	12:15p	71.9	72.0	70.1	0	---	1.0	E	0.25	4.0	ESE	71.9	66.4	66.4	30.216	0.00	0.00	0.000	0.072
10/19/24	12:30p	72.5	72.5	71.9	0	---	1.0	SSW	0.25	4.0	SSE	72.5	67.1	67.1	30.206	0.00	0.00	0.000	0.078

NKSP 10/19/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/19/24	12:45p	72.6	72.9	72.5	0	---	1.0	ENE	0.25	4.0	ENE	72.6	67.2	67.2	30.202	0.00	0.00	0.000	0.079
10/19/24	1:00p	72.3	72.7	72.1	0	---	3.0	ENE	0.75	8.0	NNE	72.3	66.9	66.9	30.197	0.00	0.00	0.000	0.076
10/19/24	1:15p	72.8	72.9	72.3	0	---	3.0	NE	0.75	7.0	NE	72.8	67.5	67.5	30.189	0.00	0.00	0.000	0.081
10/19/24	1:30p	73.4	73.4	72.8	0	---	3.0	NE	0.75	8.0	NNE	73.4	68.3	68.3	30.186	0.00	0.00	0.000	0.088
10/19/24	1:45p	74.2	74.2	73.4	0	---	3.0	N	0.75	7.0	NNE	74.2	69.3	69.3	30.173	0.00	0.00	0.000	0.096
10/19/24	2:00p	74.3	74.5	74.2	0	---	4.0	NE	1.00	10.0	N	74.3	69.5	69.5	30.165	0.00	0.00	0.000	0.097
10/19/24	2:15p	75.1	75.2	74.3	0	---	4.0	NNE	1.00	10.0	N	75.1	70.4	70.4	30.162	0.00	0.00	0.000	0.105
10/19/24	2:30p	75.7	75.7	75.1	0	---	2.0	NNE	0.50	8.0	N	75.7	71.1	71.1	30.160	0.00	0.00	0.000	0.111
10/19/24	2:45p	76.2	76.2	75.7	0	---	4.0	NNE	1.00	11.0	NE	76.2	71.6	71.6	30.160	0.00	0.00	0.000	0.117
10/19/24	3:00p	76.7	76.7	76.2	0	---	2.0	NE	0.50	9.0	NNE	76.7	72.2	72.2	30.160	0.00	0.00	0.000	0.122
10/19/24	3:15p	76.9	77.0	76.7	0	---	4.0	NE	1.00	9.0	NE	76.9	72.5	72.5	30.157	0.00	0.00	0.000	0.124
10/19/24	3:30p	77.6	77.6	76.9	0	---	4.0	NNE	1.00	9.0	N	77.6	73.1	73.1	30.155	0.00	0.00	0.000	0.131
10/19/24	3:45p	77.9	78.0	77.6	0	---	4.0	NE	1.00	10.0	NE	77.9	73.4	73.4	30.153	0.00	0.00	0.000	0.134
10/19/24	4:00p	78.1	78.2	77.8	0	---	3.0	NNE	0.75	9.0	N	78.1	73.6	73.6	30.150	0.00	0.00	0.000	0.136
10/19/24	4:15p	78.1	78.2	78.0	0	---	5.0	NE	1.25	10.0	NE	78.1	73.6	73.6	30.150	0.00	0.00	0.000	0.136
10/19/24	4:30p	78.1	78.1	78.0	0	---	5.0	N	1.25	10.0	N	78.1	73.6	73.6	30.146	0.00	0.00	0.000	0.136
10/19/24	4:45p	78.1	78.2	78.0	0	---	5.0	NNE	1.25	10.0	NE	78.1	73.6	73.6	30.145	0.00	0.00	0.000	0.136
10/19/24	5:00p	77.8	78.1	77.8	0	---	4.0	NE	1.00	10.0	NE	77.8	73.3	73.3	30.143	0.00	0.00	0.000	0.133
10/19/24	5:15p	77.7	77.9	77.6	0	---	4.0	NE	1.00	6.0	NE	77.7	73.2	73.2	30.140	0.00	0.00	0.000	0.132
10/19/24	5:30p	77.5	77.7	77.4	0	---	3.0	NE	0.75	6.0	NE	77.5	73.1	73.1	30.140	0.00	0.00	0.000	0.130
10/19/24	5:45p	77.0	77.4	76.9	0	---	2.0	NE	0.50	5.0	ENE	77.0	72.6	72.6	30.141	0.00	0.00	0.000	0.125
10/19/24	6:00p	76.0	76.9	76.0	0	---	3.0	NE	0.75	5.0	NE	76.0	71.4	71.4	30.142	0.00	0.00	0.000	0.115
10/19/24	6:15p	74.8	76.0	74.8	0	---	2.0	NE	0.50	4.0	NE	74.8	70.1	70.1	30.144	0.00	0.00	0.000	0.102
10/19/24	6:30p	73.6	74.6	73.6	0	---	1.0	NE	0.25	2.0	NE	73.6	68.5	68.5	30.144	0.00	0.00	0.000	0.090
10/19/24	6:45p	72.5	73.6	72.5	0	---	0.0	NE	0.00	2.0	NE	72.5	67.1	67.1	30.144	0.00	0.00	0.000	0.078
10/19/24	7:00p	71.3	72.4	71.3	0	---	0.0	NE	0.00	1.0	NE	71.3	65.6	65.6	30.146	0.00	0.00	0.000	0.066
10/19/24	7:15p	70.8	71.3	70.8	0	---	0.0	NE	0.00	2.0	NE	70.8	64.9	64.9	30.148	0.00	0.00	0.000	0.060
10/19/24	7:30p	70.5	70.9	70.5	0	---	0.0	NE	0.00	1.0	NE	70.5	64.6	64.6	30.152	0.00	0.00	0.000	0.057
10/19/24	7:45p	70.2	70.5	70.1	0	---	0.0	---	0.00	0.0	---	70.2	64.2	64.2	30.157	0.00	0.00	0.000	0.054
10/19/24	8:00p	69.0	70.3	69.0	0	---	0.0	---	0.00	0.0	---	69.0	62.4	62.4	30.158	0.00	0.00	0.000	0.042
10/19/24	8:15p	68.3	69.0	68.3	0	---	0.0	---	0.00	0.0	---	68.3	61.3	61.3	30.164	0.00	0.00	0.000	0.034
10/19/24	8:30p	68.1	68.3	68.0	0	---	0.0	NE	0.00	2.0	NE	68.1	61.0	61.0	30.164	0.00	0.00	0.000	0.032
10/19/24	8:45p	67.7	68.4	67.7	0	---	0.0	NE	0.00	2.0	NE	67.7	60.5	60.5	30.166	0.00	0.00	0.000	0.028
10/19/24	9:00p	67.3	67.8	67.3	0	---	0.0	NE	0.00	1.0	NE	67.3	60.2	60.2	30.163	0.00	0.00	0.000	0.024
10/19/24	9:15p	66.5	67.4	66.5	0	---	0.0	NE	0.00	2.0	NE	66.5	59.5	59.5	30.166	0.00	0.00	0.000	0.016
10/19/24	9:30p	62.5	66.5	62.5	0	---	1.0	NE	0.25	7.0	ESE	62.5	56.0	56.0	30.176	0.00	0.00	0.026	0.000
10/19/24	9:45p	58.0	62.3	58.0	8	-3.1	3.0	ESE	0.75	7.0	ESE	58.0	53.3	53.3	30.180	0.00	0.00	0.073	0.000
10/19/24	10:00p	57.1	58.0	57.1	12	4.9	1.0	ESE	0.25	4.0	ESE	57.1	52.9	52.9	30.181	0.00	0.00	0.062	0.000
10/19/24	10:15p	57.2	57.2	57.0	11	3.1	2.0	ESE	0.50	4.0	ESE	57.2	53.0	53.0	30.182	0.00	0.00	0.081	0.000
10/19/24	10:30p	55.8	57.2	55.8	11	2.0	2.0	SE	0.50	4.0	ESE	55.8	51.8	51.8	30.187	0.00	0.00	0.096	0.000
10/19/24	10:45p	54.8	55.9	54.8	13	4.8	3.0	SE	0.75	6.0	ESE	54.8	51.0	51.0	30.187	0.00	0.00	0.106	0.000
10/19/24	11:00p	54.2	54.9	54.2	14	5.9	3.0	ESE	0.75	6.0	ESE	54.2	50.6	50.6	30.188	0.00	0.00	0.112	0.000
10/19/24	11:15p	54.3	54.4	54.1	12	2.7	2.0	ESE	0.50	5.0	SE	54.3	50.6	50.6	30.193	0.00	0.00	0.111	0.000
10/19/24	11:30p	53.7	54.3	53.6	10	-1.7	2.0	SE	0.50	4.0	SE	53.7	50.2	50.2	30.187	0.00	0.00	0.118	0.000
10/19/24	11:45p	54.4	54.4	53.6	9	-3.4	2.0	SE	0.50	4.0	SE	54.4	50.6	50.6	30.186	0.00	0.00	0.110	0.000
10/20/24	12:00a	53.1	54.4	53.1	11	-0.1	2.0	SE	0.50	5.0	SE	53.1	49.8	49.8	30.191	0.00	0.00	0.124	0.000

NKSP 10/19/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/19/24	12:15a	75.2	36	46.4	73.9	7.05	.0741	350	1	100.0	15
10/19/24	12:30a	75.1	36	46.3	73.8	7.05	.0741	351	1	100.0	15
10/19/24	12:45a	75.1	36	46.3	73.8	7.05	.0741	351	1	100.0	15
10/19/24	1:00a	75.0	36	46.2	73.7	7.05	.0741	352	1	100.0	15
10/19/24	1:15a	74.9	36	46.1	73.5	7.05	.0741	351	1	100.0	15
10/19/24	1:30a	74.8	36	46.1	73.4	7.06	.0742	351	1	100.0	15
10/19/24	1:45a	74.7	36	46.0	73.3	7.06	.0742	351	1	100.0	15
10/19/24	2:00a	74.6	36	45.9	73.2	7.07	.0742	351	1	100.0	15
10/19/24	2:15a	74.6	36	45.9	73.2	7.07	.0742	352	1	100.0	15
10/19/24	2:30a	74.5	36	45.8	73.1	7.07	.0742	351	1	100.0	15
10/19/24	2:45a	74.7	35	45.2	73.3	6.96	.0742	351	1	100.0	15
10/19/24	3:00a	74.8	35	45.3	73.4	6.95	.0742	351	1	100.0	15
10/19/24	3:15a	74.9	35	45.4	73.5	6.95	.0741	352	1	100.0	15
10/19/24	3:30a	74.8	35	45.3	73.4	6.95	.0741	351	1	100.0	15
10/19/24	3:45a	74.6	35	45.1	73.2	6.96	.0742	351	1	100.0	15
10/19/24	4:00a	74.3	35	44.9	72.8	6.96	.0742	351	1	100.0	15
10/19/24	4:15a	74.3	35	44.9	72.8	6.96	.0742	351	1	100.0	15
10/19/24	4:30a	74.4	35	45.0	72.9	6.96	.0742	352	1	100.0	15
10/19/24	4:45a	74.4	35	45.0	72.9	6.96	.0742	351	1	100.0	15
10/19/24	5:00a	74.5	35	45.0	73.1	6.96	.0742	351	1	100.0	15
10/19/24	5:15a	74.2	35	44.8	72.7	6.97	.0743	351	1	100.0	15
10/19/24	5:30a	74.1	35	44.7	72.6	6.97	.0743	352	1	100.0	15
10/19/24	5:45a	73.9	35	44.5	72.4	6.97	.0743	351	1	100.0	15
10/19/24	6:00a	73.8	35	44.4	72.3	6.97	.0744	351	1	100.0	15
10/19/24	6:15a	73.6	35	44.2	72.0	6.98	.0744	351	1	100.0	15
10/19/24	6:30a	73.6	35	44.2	72.0	6.98	.0744	352	1	100.0	15
10/19/24	6:45a	73.4	35	44.1	71.8	6.98	.0744	351	1	100.0	15
10/19/24	7:00a	73.3	35	44.0	71.7	6.98	.0745	351	1	100.0	15
10/19/24	7:15a	73.2	35	43.9	71.5	6.99	.0745	351	1	100.0	15
10/19/24	7:30a	73.2	35	43.9	71.5	6.99	.0745	351	1	100.0	15
10/19/24	7:45a	73.6	35	44.2	72.0	6.98	.0744	352	1	100.0	15
10/19/24	8:00a	73.9	35	44.5	72.4	6.97	.0744	351	1	100.0	15
10/19/24	8:15a	74.1	35	44.7	72.6	6.97	.0744	351	1	100.0	15
10/19/24	8:30a	74.2	35	44.8	72.7	6.97	.0744	351	1	100.0	15
10/19/24	8:45a	74.4	35	45.0	72.9	6.96	.0743	352	1	100.0	15
10/19/24	9:00a	74.4	34	44.2	72.8	6.76	.0744	351	1	100.0	15
10/19/24	9:15a	74.1	35	44.7	72.6	6.97	.0744	351	1	100.0	15
10/19/24	9:30a	74.5	35	45.0	73.1	6.96	.0743	351	1	100.0	15
10/19/24	9:45a	74.7	35	45.2	73.3	6.96	.0743	351	1	100.0	15
10/19/24	10:00a	75.0	34	44.7	73.5	6.75	.0743	352	1	100.0	15
10/19/24	10:15a	75.3	34	45.0	73.8	6.74	.0742	351	1	100.0	15
10/19/24	10:30a	75.0	34	44.7	73.5	6.75	.0743	351	1	100.0	15
10/19/24	10:45a	75.1	34	44.8	73.6	6.75	.0742	351	1	100.0	15
10/19/24	11:00a	75.3	34	45.0	73.8	6.74	.0742	352	1	100.0	15
10/19/24	11:15a	75.2	34	44.9	73.7	6.75	.0742	351	1	100.0	15
10/19/24	11:30a	75.5	34	45.2	74.0	6.74	.0742	351	1	100.0	15
10/19/24	11:45a	75.9	33	44.7	74.4	6.55	.0741	351	1	100.0	15
10/19/24	12:00p	75.7	34	45.3	74.2	6.74	.0741	352	1	100.0	15
10/19/24	12:15p	75.8	33	44.6	74.3	6.55	.0741	351	1	100.0	15
10/19/24	12:30p	76.1	32	44.1	74.5	6.43	.0741	351	1	100.0	15

NKSP 10/19/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/19/24	12:45p	76.2	33	45.0	74.7	6.55	.0740	351	1	100.0	15
10/19/24	1:00p	76.2	34	45.8	74.7	6.73	.0740	351	1	100.0	15
10/19/24	1:15p	76.2	33	45.0	74.7	6.55	.0740	352	1	100.0	15
10/19/24	1:30p	76.5	33	45.2	74.9	6.55	.0739	351	1	100.0	15
10/19/24	1:45p	76.7	32	44.6	75.1	6.42	.0739	351	1	100.0	15
10/19/24	2:00p	76.8	33	45.5	75.2	6.55	.0738	351	1	100.0	15
10/19/24	2:15p	76.8	33	45.5	75.2	6.55	.0738	352	1	100.0	15
10/19/24	2:30p	76.8	33	45.5	75.2	6.55	.0738	351	1	100.0	15
10/19/24	2:45p	77.1	32	45.0	75.5	6.41	.0738	351	1	100.0	15
10/19/24	3:00p	77.4	32	45.2	75.7	6.40	.0737	351	1	100.0	15
10/19/24	3:15p	77.4	33	46.0	75.8	6.55	.0737	352	1	100.0	15
10/19/24	3:30p	77.3	33	45.9	75.7	6.55	.0737	351	1	100.0	15
10/19/24	3:45p	77.0	33	45.7	75.4	6.55	.0738	351	1	100.0	15
10/19/24	4:00p	77.3	32	45.1	75.6	6.40	.0737	351	1	100.0	15
10/19/24	4:15p	77.5	32	45.3	75.8	6.40	.0737	351	1	100.0	15
10/19/24	4:30p	77.3	33	45.9	75.7	6.55	.0737	352	1	100.0	15
10/19/24	4:45p	77.2	34	46.7	75.6	6.71	.0737	351	1	100.0	15
10/19/24	5:00p	77.2	34	46.7	75.6	6.71	.0737	351	1	100.0	15
10/19/24	5:15p	77.3	33	45.9	75.7	6.55	.0737	351	1	100.0	15
10/19/24	5:30p	77.4	33	46.0	75.8	6.55	.0737	352	1	100.0	15
10/19/24	5:45p	77.3	34	46.7	75.7	6.70	.0737	351	1	100.0	15
10/19/24	6:00p	77.0	34	46.5	75.5	6.71	.0737	351	1	100.0	15
10/19/24	6:15p	77.1	34	46.6	75.5	6.71	.0737	351	1	100.0	15
10/19/24	6:30p	77.3	33	45.9	75.7	6.55	.0737	352	1	100.0	15
10/19/24	6:45p	76.9	34	46.4	75.4	6.71	.0737	351	1	100.0	15
10/19/24	7:00p	76.6	34	46.1	75.1	6.72	.0738	351	1	100.0	15
10/19/24	7:15p	76.7	34	46.2	75.2	6.72	.0738	351	1	100.0	15
10/19/24	7:30p	76.7	35	47.0	75.2	6.92	.0738	351	1	100.0	15
10/19/24	7:45p	76.4	35	46.7	75.0	6.92	.0738	352	1	100.0	15
10/19/24	8:00p	76.1	35	46.5	74.7	6.93	.0739	351	1	100.0	15
10/19/24	8:15p	76.2	35	46.5	74.8	6.93	.0739	351	1	100.0	15
10/19/24	8:30p	75.9	35	46.3	74.5	6.93	.0739	351	1	100.0	15
10/19/24	8:45p	76.0	35	46.4	74.6	6.93	.0739	352	1	100.0	15
10/19/24	9:00p	75.9	35	46.3	74.5	6.93	.0739	351	1	100.0	15
10/19/24	9:15p	75.6	35	46.0	74.2	6.94	.0740	351	1	100.0	15
10/19/24	9:30p	75.8	36	46.9	74.5	7.03	.0739	351	1	100.0	15
10/19/24	9:45p	75.4	36	46.6	74.1	7.04	.0740	351	1	100.0	15
10/19/24	10:00p	75.6	36	46.8	74.3	7.04	.0740	352	1	100.0	15
10/19/24	10:15p	75.2	37	47.1	73.9	7.25	.0740	351	1	100.0	15
10/19/24	10:30p	75.3	37	47.2	74.0	7.24	.0740	351	1	100.0	15
10/19/24	10:45p	75.6	37	47.5	74.3	7.24	.0740	351	1	100.0	15
10/19/24	11:00p	75.2	37	47.1	73.9	7.25	.0741	352	1	100.0	15
10/19/24	11:15p	75.0	37	47.0	73.7	7.25	.0741	351	1	100.0	15
10/19/24	11:30p	75.0	37	47.0	73.7	7.25	.0741	351	1	100.0	15
10/19/24	11:45p	75.0	36	46.2	73.7	7.05	.0741	351	1	100.0	15
10/20/24	12:00a	75.0	36	46.2	73.7	7.05	.0741	352	1	100.0	15

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

OUTSIDE TEMPERATURE RECORD

CDCR 2030 (04/18)

INSTITUTION: NKSP

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the OUTSIDE ambient air temperature.

Using an accurate thermometer located in a central, heat neutral location, the outside air temperature is to be taken every hour, seven (7) days a week.

Thermometer Location: CENTRAL CONTROL ROOFTOP

Immediately notify the Watch Commander at extension 3141 when the air temperature reaches 90 degrees.

Date	Time	Temp.	Printed Name
10/20/24	0100	53.7	Ramos
	0200	51.1	Ramos
	0300	50.7	Ramos
	0400	49.8	Ramos
	0500	49.1	Ramos
	0600	47	Gonzalez
	0700	46	Gonzalez
	0800	49	Gonzalez
	0900	56	Gonzalez
	1000	67	Gonzalez
	1100	71	Gonzalez
	1200	76	Gonzalez
	1300	78	Gonzalez
	1400	80	Lopez G
	1500	82	Lopez G
	1600	83	Lopez G
	1700	82	Lopez G
	1800	80	Lopez G
	1900	75	Lopez G
	2000	72	Lopez G
	2100	65	Lopez G.
	2200	61	Arias
	2300	58	Arias
	2400	55	Arias

Date	Time	Temp.	Printed Name
10/21/24	0100	54	Arias
	0200	53	Arias
	0300	53	Arias
	0400	54	Arias
	0500	53	Arias
	0600	52	Jones
	0700	47	Jones
	0800	49	Jones
	0900	57.	Jones
	1000	64	Jones
	1100	70	Jones
	1200	75	Jones
	1300	78	Jones
	1400	80	Gonzalez
	1500	82	Gonzalez
	1600	83	Gonzalez
	1700	83	Gonzalez
	1800	80	Gonzalez
	1900	74	Gonzalez
	2000	72	Gonzalez
	2100	65	Gonzalez
	2200	62	Dunn
	2300	59	Dunn
	2400	58	Dunn

DISTRIBUTION: Original: Institution Heat Plan Coordinator

NKSP 10/20/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/20/24	12:15a	52.4	53.1	52.4	11	-0.7	3.0	ESE	0.75	5.0	SE	52.3	49.3	49.2	30.191	0.00	0.00	0.131	0.000
10/20/24	12:30a	52.2	52.4	52.2	12	1.0	3.0	ESE	0.75	4.0	ESE	52.1	49.1	49.0	30.189	0.00	0.00	0.133	0.000
10/20/24	12:45a	53.2	53.2	52.2	7	-9.5	3.0	E	0.75	6.0	E	53.2	49.5	49.5	30.193	0.00	0.00	0.123	0.000
10/20/24	1:00a	53.7	53.8	53.2	6	-12.2	2.0	E	0.50	3.0	E	53.7	49.8	49.8	30.190	0.00	0.00	0.118	0.000
10/20/24	1:15a	53.3	53.7	53.2	7	-9.4	0.0	E	0.00	1.0	E	53.3	49.6	49.6	30.191	0.00	0.00	0.122	0.000
10/20/24	1:30a	53.0	53.4	53.0	8	-6.9	0.0	---	0.00	0.0	---	53.0	49.5	49.5	30.190	0.00	0.00	0.125	0.000
10/20/24	1:45a	52.1	53.0	52.1	8	-7.6	0.0	E	0.00	2.0	E	52.1	48.9	48.9	30.190	0.00	0.00	0.134	0.000
10/20/24	2:00a	51.1	52.2	51.0	11	-1.7	1.0	E	0.25	3.0	E	51.1	48.3	48.3	30.191	0.00	0.00	0.145	0.000
10/20/24	2:15a	50.3	51.0	50.3	9	-6.5	2.0	ESE	0.50	4.0	ESE	50.3	47.6	47.6	30.196	0.00	0.00	0.153	0.000
10/20/24	2:30a	50.6	50.6	50.3	11	-2.1	1.0	ESE	0.25	3.0	ESE	50.6	47.9	47.9	30.194	0.00	0.00	0.150	0.000
10/20/24	2:45a	51.2	51.2	50.5	9	-5.8	1.0	ESE	0.25	4.0	ESE	51.2	48.3	48.3	30.199	0.00	0.00	0.144	0.000
10/20/24	3:00a	50.7	51.2	50.7	11	-2.0	1.0	ESE	0.25	4.0	ESE	50.7	48.0	48.0	30.201	0.00	0.00	0.149	0.000
10/20/24	3:15a	51.0	51.0	50.7	8	-8.4	1.0	E	0.25	3.0	E	51.0	48.0	48.0	30.199	0.00	0.00	0.146	0.000
10/20/24	3:30a	51.8	51.8	51.0	6	-13.6	0.0	E	0.00	1.0	E	51.8	48.5	48.5	30.199	0.00	0.00	0.138	0.000
10/20/24	3:45a	51.3	51.9	51.3	7	-10.9	0.0	E	0.00	1.0	E	51.3	48.2	48.2	30.196	0.00	0.00	0.143	0.000
10/20/24	4:00a	49.8	51.3	49.7	9	-6.9	0.0	E	0.00	1.0	E	49.8	47.2	47.2	30.196	0.00	0.00	0.158	0.000
10/20/24	4:15a	49.2	49.8	49.1	12	-1.4	0.0	SSE	0.00	3.0	SE	49.2	46.7	46.7	30.193	0.00	0.00	0.165	0.000
10/20/24	4:30a	49.1	49.2	49.0	14	1.9	0.0	SSE	0.00	1.0	SSE	49.1	46.7	46.7	30.197	0.00	0.00	0.166	0.000
10/20/24	4:45a	49.4	49.4	49.1	13	0.5	0.0	---	0.00	0.0	---	49.4	46.9	46.9	30.200	0.00	0.00	0.162	0.000
10/20/24	5:00a	49.1	49.4	49.0	13	0.3	0.0	SSE	0.00	1.0	SSE	49.1	46.6	46.6	30.201	0.00	0.00	0.166	0.000
10/20/24	5:15a	49.4	49.4	48.9	12	-1.2	0.0	---	0.00	0.0	---	49.4	46.9	46.9	30.203	0.00	0.00	0.162	0.000
10/20/24	5:30a	49.9	49.9	49.4	11	-2.6	0.0	---	0.00	0.0	---	49.9	47.4	47.4	30.208	0.00	0.00	0.157	0.000
10/20/24	5:45a	48.9	50.0	48.9	11	-3.4	0.0	---	0.00	0.0	---	48.9	46.3	46.3	30.208	0.00	0.00	0.168	0.000
10/20/24	6:00a	47.2	48.9	47.2	14	0.3	0.0	SSE	0.00	2.0	SSE	47.2	44.8	44.8	30.213	0.00	0.00	0.185	0.000
10/20/24	6:15a	47.5	47.5	47.1	16	3.4	0.0	SSE	0.00	1.0	SSE	47.5	45.2	45.2	30.212	0.00	0.00	0.182	0.000
10/20/24	6:30a	47.5	47.6	47.4	17	4.8	0.0	SSE	0.00	1.0	SSE	47.5	45.2	45.2	30.216	0.00	0.00	0.182	0.000
10/20/24	6:45a	46.8	47.5	46.8	17	4.2	1.0	ESE	0.25	4.0	ESE	46.8	44.5	44.5	30.215	0.00	0.00	0.190	0.000
10/20/24	7:00a	46.9	47.2	46.9	17	4.3	1.0	ESE	0.25	3.0	ESE	46.9	44.6	44.6	30.216	0.00	0.00	0.189	0.000
10/20/24	7:15a	47.6	47.6	46.9	15	2.1	2.0	ESE	0.50	4.0	ESE	47.6	45.2	45.2	30.217	0.00	0.00	0.181	0.000
10/20/24	7:30a	48.5	48.5	47.6	16	4.3	2.0	ESE	0.50	4.0	ESE	48.5	46.1	46.1	30.217	0.00	0.00	0.172	0.000
10/20/24	7:45a	49.1	49.2	48.5	12	-1.4	3.0	ESE	0.75	4.0	ESE	48.6	46.6	46.1	30.220	0.00	0.00	0.166	0.000
10/20/24	8:00a	49.8	49.8	49.1	14	2.4	1.0	ESE	0.25	3.0	ESE	49.8	47.3	47.3	30.225	0.00	0.00	0.158	0.000
10/20/24	8:15a	50.2	50.2	49.6	16	5.6	1.0	ESE	0.25	3.0	ESE	50.2	47.7	47.7	30.231	0.00	0.00	0.154	0.000
10/20/24	8:30a	52.6	52.6	50.2	10	-2.6	0.0	ESE	0.00	3.0	ESE	52.6	49.4	49.4	30.236	0.00	0.00	0.129	0.000
10/20/24	8:45a	54.3	54.3	52.6	6	-11.8	0.0	E	0.00	2.0	ESE	54.3	50.2	50.2	30.243	0.00	0.00	0.111	0.000
10/20/24	9:00a	56.3	56.3	54.4	3	-23.9	1.0	E	0.25	4.0	E	56.3	51.4	51.4	30.246	0.00	0.00	0.091	0.000
10/20/24	9:15a	58.5	58.5	56.4	1	-42.2	1.0	ENE	0.25	3.0	E	58.5	52.9	52.9	30.246	0.00	0.00	0.068	0.000
10/20/24	9:30a	61.3	61.3	58.5	0	---	0.0	ENE	0.00	2.0	ENE	61.3	55.0	55.0	30.245	0.00	0.00	0.039	0.000
10/20/24	9:45a	63.6	63.6	61.3	0	---	0.0	E	0.00	1.0	E	63.6	56.9	56.9	30.242	0.00	0.00	0.015	0.000
10/20/24	10:00a	67.1	67.1	63.6	0	---	0.0	E	0.00	1.0	E	67.1	60.0	60.0	30.237	0.00	0.00	0.000	0.022
10/20/24	10:15a	67.3	67.5	67.1	0	---	0.0	E	0.00	2.0	E	67.3	60.2	60.2	30.238	0.00	0.00	0.000	0.024
10/20/24	10:30a	68.0	68.1	67.2	0	---	0.0	E	0.00	2.0	E	68.0	60.8	60.8	30.230	0.00	0.00	0.000	0.031
10/20/24	10:45a	70.4	70.4	68.1	0	---	0.0	E	0.00	2.0	E	70.4	64.4	64.4	30.229	0.00	0.00	0.000	0.056
10/20/24	11:00a	71.8	71.8	70.4	0	---	0.0	---	0.00	0.0	---	71.8	66.2	66.2	30.226	0.00	0.00	0.000	0.071
10/20/24	11:15a	73.0	73.0	71.8	0	---	0.0	NNW	0.00	3.0	WNW	73.0	67.7	67.7	30.219	0.00	0.00	0.000	0.083
10/20/24	11:30a	73.9	73.9	73.0	0	---	1.0	NNE	0.25	3.0	NNE	73.9	69.0	69.0	30.217	0.00	0.00	0.000	0.093
10/20/24	11:45a	75.4	75.5	73.9	0	---	1.0	NE	0.25	4.0	SW	75.4	70.7	70.7	30.209	0.00	0.00	0.000	0.108
10/20/24	12:00p	76.5	76.5	75.4	0	---	0.0	NE	0.00	2.0	NE	76.5	72.0	72.0	30.206	0.00	0.00	0.000	0.120
10/20/24	12:15p	76.4	76.6	76.4	0	---	2.0	NNE	0.50	5.0	NNE	76.4	71.9	71.9	30.198	0.00	0.00	0.000	0.119
10/20/24	12:30p	76.6	76.7	76.3	0	---	2.0	NW	0.50	6.0	NE	76.6	72.1	72.1	30.194	0.00	0.00	0.000	0.121

NKSP 10/20/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/20/24	12:45p	77.2	77.2	76.6	0	---	3.0	NNE	0.75	7.0	NNE	77.2	72.8	72.8	30.188	0.00	0.00	0.000	0.127
10/20/24	1:00p	78.0	78.0	77.2	0	---	3.0	NNE	0.75	8.0	NW	78.0	73.5	73.5	30.181	0.00	0.00	0.000	0.135
10/20/24	1:15p	78.8	78.8	78.0	0	---	3.0	NNE	0.75	8.0	NNE	78.8	74.3	74.3	30.171	0.00	0.00	0.000	0.144
10/20/24	1:30p	79.5	79.5	78.7	0	---	3.0	NE	0.75	8.0	NE	79.5	75.0	75.0	30.166	0.00	0.00	0.000	0.151
10/20/24	1:45p	79.9	79.9	79.4	0	---	2.0	ENE	0.50	7.0	NNE	79.9	75.4	75.4	30.160	0.00	0.00	0.000	0.155
10/20/24	2:00p	80.9	80.9	79.9	0	---	2.0	NE	0.50	7.0	NNE	80.9	76.3	76.3	30.157	0.00	0.00	0.000	0.166
10/20/24	2:15p	81.4	81.4	80.9	0	---	2.0	NW	0.50	8.0	NW	81.4	76.8	76.8	30.154	0.00	0.00	0.000	0.171
10/20/24	2:30p	81.9	82.0	81.3	0	---	2.0	NW	0.50	6.0	WNW	81.9	77.3	77.3	30.153	0.00	0.00	0.000	0.176
10/20/24	2:45p	82.5	82.5	81.8	0	---	2.0	WSW	0.50	7.0	W	82.5	77.9	77.9	30.149	0.00	0.00	0.000	0.182
10/20/24	3:00p	82.7	82.9	82.5	0	---	3.0	WNW	0.75	6.0	W	82.7	78.0	78.0	30.149	0.00	0.00	0.000	0.184
10/20/24	3:15p	83.0	83.1	82.7	0	---	3.0	WNW	0.75	9.0	N	83.0	78.3	78.3	30.145	0.00	0.00	0.000	0.188
10/20/24	3:30p	83.2	83.2	82.9	0	---	4.0	NW	1.00	8.0	NNE	83.2	78.5	78.5	30.140	0.00	0.00	0.000	0.190
10/20/24	3:45p	83.3	83.4	83.1	0	---	3.0	NNW	0.75	7.0	NNE	83.3	78.5	78.5	30.138	0.00	0.00	0.000	0.191
10/20/24	4:00p	83.3	83.4	83.2	0	---	3.0	NNE	0.75	9.0	N	83.3	78.5	78.5	30.134	0.00	0.00	0.000	0.191
10/20/24	4:15p	83.5	83.8	83.3	0	---	3.0	NNE	0.75	7.0	NE	83.5	78.7	78.7	30.132	0.00	0.00	0.000	0.193
10/20/24	4:30p	83.2	83.5	83.1	0	---	4.0	NE	1.00	8.0	N	83.2	78.5	78.5	30.130	0.00	0.00	0.000	0.190
10/20/24	4:45p	83.0	83.3	83.0	0	---	4.0	N	1.00	8.0	NE	83.0	78.3	78.3	30.131	0.00	0.00	0.000	0.188
10/20/24	5:00p	82.9	83.1	82.9	0	---	4.0	NNE	1.00	8.0	NNE	82.9	78.2	78.2	30.128	0.00	0.00	0.000	0.186
10/20/24	5:15p	82.7	83.0	82.7	0	---	4.0	NNE	1.00	8.0	NNE	82.7	78.0	78.0	30.131	0.00	0.00	0.000	0.184
10/20/24	5:30p	82.0	82.8	82.0	0	---	4.0	NNE	1.00	8.0	NE	82.0	77.4	77.4	30.124	0.00	0.00	0.000	0.177
10/20/24	5:45p	81.0	82.0	81.0	0	---	4.0	NE	1.00	7.0	NNE	81.0	76.4	76.4	30.123	0.00	0.00	0.000	0.167
10/20/24	6:00p	80.2	81.0	80.2	0	---	3.0	NE	0.75	4.0	NE	80.2	75.7	75.7	30.128	0.00	0.00	0.000	0.158
10/20/24	6:15p	78.8	80.2	78.7	0	---	2.0	NE	0.50	4.0	NE	78.8	74.3	74.3	30.128	0.00	0.00	0.000	0.144
10/20/24	6:30p	77.6	78.8	77.6	0	---	1.0	NE	0.25	3.0	NE	77.6	73.1	73.1	30.130	0.00	0.00	0.000	0.131
10/20/24	6:45p	76.3	77.6	76.3	0	---	1.0	NE	0.25	2.0	NE	76.3	71.8	71.8	30.134	0.00	0.00	0.000	0.118
10/20/24	7:00p	75.1	76.4	75.1	0	---	0.0	---	0.00	0.0	---	75.1	70.4	70.4	30.133	0.00	0.00	0.000	0.105
10/20/24	7:15p	73.4	75.1	73.4	0	---	0.0	---	0.00	0.0	---	73.4	68.3	68.3	30.135	0.00	0.00	0.000	0.088
10/20/24	7:30p	72.7	73.4	72.7	0	---	0.0	NNE	0.00	2.0	NE	72.7	67.3	67.3	30.137	0.00	0.00	0.000	0.080
10/20/24	7:45p	72.5	72.7	72.4	0	---	1.0	NNE	0.25	2.0	NNE	72.5	67.1	67.1	30.142	0.00	0.00	0.000	0.078
10/20/24	8:00p	72.0	72.6	72.0	0	---	0.0	NNE	0.00	2.0	NNE	72.0	66.5	66.5	30.144	0.00	0.00	0.000	0.073
10/20/24	8:15p	71.2	72.0	71.1	0	---	0.0	NNE	0.00	1.0	NNE	71.2	65.5	65.5	30.147	0.00	0.00	0.000	0.065
10/20/24	8:30p	71.3	71.3	70.9	0	---	1.0	NNE	0.25	2.0	NNE	71.3	65.6	65.6	30.152	0.00	0.00	0.000	0.066
10/20/24	8:45p	69.2	71.3	69.2	0	---	1.0	NNE	0.25	3.0	NNE	69.2	62.7	62.7	30.153	0.00	0.00	0.000	0.044
10/20/24	9:00p	65.7	69.1	65.7	0	---	2.0	ESE	0.50	4.0	ESE	65.7	58.7	58.7	30.157	0.00	0.00	0.000	0.007
10/20/24	9:15p	64.6	65.7	64.6	1	-38.5	3.0	ESE	0.75	4.0	ESE	64.6	57.9	57.9	30.159	0.00	0.00	0.004	0.000
10/20/24	9:30p	63.7	64.6	63.7	1	-39.0	2.0	SE	0.50	4.0	ESE	63.7	57.1	57.1	30.163	0.00	0.00	0.014	0.000
10/20/24	9:45p	63.0	63.8	63.0	1	-39.5	1.0	ESE	0.25	9.0	SSW	63.0	56.5	56.5	30.165	0.00	0.00	0.021	0.000
10/20/24	10:00p	61.5	63.0	61.3	4	-14.7	2.0	SSW	0.50	10.0	WSW	61.5	55.5	55.5	30.171	0.00	0.00	0.036	0.000
10/20/24	10:15p	61.4	61.8	61.4	3	-20.4	2.0	ESE	0.50	4.0	SE	61.4	55.4	55.4	30.174	0.00	0.00	0.037	0.000
10/20/24	10:30p	61.0	61.4	61.0	7	-3.7	3.0	ESE	0.75	4.0	ESE	61.0	55.6	55.6	30.178	0.00	0.00	0.042	0.000
10/20/24	10:45p	60.6	61.1	60.6	4	-15.4	1.0	ESE	0.25	4.0	SE	60.6	54.8	54.8	30.178	0.00	0.00	0.046	0.000
10/20/24	11:00p	58.5	60.6	58.5	6	-8.7	2.0	SE	0.50	4.0	SE	58.5	53.4	53.4	30.179	0.00	0.00	0.068	0.000
10/20/24	11:15p	58.2	58.5	58.2	10	1.8	1.0	ESE	0.25	4.0	ESE	58.2	53.8	53.8	30.181	0.00	0.00	0.071	0.000
10/20/24	11:30p	58.2	58.3	58.2	7	-5.8	2.0	SE	0.50	4.0	ESE	58.2	53.3	53.3	30.182	0.00	0.00	0.071	0.000
10/20/24	11:45p	57.5	58.2	57.5	6	-9.4	2.0	SE	0.50	5.0	SE	57.5	52.6	52.6	30.182	0.00	0.00	0.078	0.000
10/21/24	12:00a	55.7	57.6	55.7	9	-2.4	3.0	SE	0.75	5.0	SE	55.7	51.6	51.6	30.179	0.00	0.00	0.097	0.000

NKSP 10/21/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/21/24	12:15a	55.1	55.7	55.1	13	5.0	3.0	ESE	0.75	6.0	ESE	55.1	51.3	51.3	30.178	0.00	0.00	0.103	0.000
10/21/24	12:30a	54.8	55.1	54.8	13	4.8	3.0	ESE	0.75	7.0	ESE	54.8	51.0	51.0	30.178	0.00	0.00	0.106	0.000
10/21/24	12:45a	54.3	54.9	54.3	12	2.7	2.0	SE	0.50	8.0	SE	54.3	50.6	50.6	30.174	0.00	0.00	0.111	0.000
10/21/24	1:00a	54.0	54.3	53.9	13	4.2	2.0	SE	0.50	7.0	SE	54.0	50.4	50.4	30.171	0.00	0.00	0.115	0.000
10/21/24	1:15a	53.8	54.0	53.7	13	4.0	2.0	SE	0.50	5.0	SE	53.8	50.3	50.3	30.168	0.00	0.00	0.117	0.000
10/21/24	1:30a	53.6	53.8	53.6	12	2.1	1.0	SE	0.25	4.0	SE	53.6	50.1	50.1	30.170	0.00	0.00	0.119	0.000
10/21/24	1:45a	53.6	53.6	53.4	10	-1.8	2.0	SE	0.50	7.0	SE	53.6	50.1	50.1	30.167	0.00	0.00	0.119	0.000
10/21/24	2:00a	53.7	53.9	53.6	11	0.3	4.0	SE	1.00	7.0	SE	53.1	50.2	49.6	30.167	0.00	0.00	0.118	0.000
10/21/24	2:15a	54.0	54.0	53.7	9	-3.7	4.0	SE	1.00	8.0	ESE	53.5	50.3	49.8	30.166	0.00	0.00	0.115	0.000
10/21/24	2:30a	54.2	54.2	54.0	7	-8.7	4.0	SE	1.00	8.0	SE	53.7	50.2	49.7	30.165	0.00	0.00	0.112	0.000
10/21/24	2:45a	54.3	54.3	54.1	6	-11.8	3.0	SE	0.75	7.0	SE	54.3	50.2	50.2	30.166	0.00	0.00	0.111	0.000
10/21/24	3:00a	53.9	54.3	53.9	5	-15.7	2.0	SE	0.50	4.0	SE	53.9	49.8	49.8	30.166	0.00	0.00	0.116	0.000
10/21/24	3:15a	53.7	53.9	53.6	5	-15.9	3.0	ESE	0.75	7.0	ESE	53.7	49.7	49.7	30.159	0.00	0.00	0.118	0.000
10/21/24	3:30a	54.5	54.5	53.7	5	-15.3	4.0	ESE	1.00	7.0	ESE	54.1	50.3	49.9	30.155	0.00	0.00	0.109	0.000
10/21/24	3:45a	54.4	54.5	54.2	3	-25.2	4.0	ESE	1.00	8.0	ESE	53.9	50.1	49.6	30.151	0.00	0.00	0.110	0.000
10/21/24	4:00a	54.1	54.6	54.1	2	-32.8	1.0	SE	0.25	4.0	SE	54.1	49.8	49.8	30.155	0.00	0.00	0.114	0.000
10/21/24	4:15a	54.0	54.1	54.0	1	-45.0	2.0	SE	0.50	5.0	SE	54.0	49.7	49.7	30.155	0.00	0.00	0.115	0.000
10/21/24	4:30a	53.1	54.1	53.1	6	-12.7	2.0	ESE	0.50	4.0	ESE	53.1	49.4	49.4	30.158	0.00	0.00	0.124	0.000
10/21/24	4:45a	53.1	53.1	52.9	6	-12.7	3.0	ESE	0.75	4.0	ESE	53.1	49.4	49.4	30.162	0.00	0.00	0.124	0.000
10/21/24	5:00a	53.4	53.5	53.0	5	-16.1	1.0	ESE	0.25	3.0	ESE	53.4	49.5	49.5	30.167	0.00	0.00	0.121	0.000
10/21/24	5:15a	53.1	53.5	53.1	6	-12.7	0.0	ESE	0.00	1.0	ESE	53.1	49.4	49.4	30.171	0.00	0.00	0.124	0.000
10/21/24	5:30a	52.3	53.1	52.3	8	-7.4	1.0	ENE	0.25	4.0	ENE	52.3	49.0	49.0	30.174	0.00	0.00	0.132	0.000
10/21/24	5:45a	52.0	52.3	51.9	9	-5.2	1.0	ENE	0.25	4.0	ENE	52.0	48.9	48.9	30.177	0.00	0.00	0.135	0.000
10/21/24	6:00a	52.5	52.5	52.0	8	-7.3	1.0	ENE	0.25	4.0	ENE	52.5	49.2	49.2	30.182	0.00	0.00	0.130	0.000
10/21/24	6:15a	52.6	52.7	52.5	8	-7.2	0.0	ENE	0.00	1.0	ENE	52.6	49.2	49.2	30.186	0.00	0.00	0.129	0.000
10/21/24	6:30a	50.7	52.6	50.7	10	-4.0	0.0	S	0.00	3.0	S	50.7	48.0	48.0	30.189	0.00	0.00	0.149	0.000
10/21/24	6:45a	48.6	50.6	48.6	15	2.9	3.0	WSW	0.75	5.0	WSW	48.1	46.2	45.7	30.195	0.00	0.00	0.171	0.000
10/21/24	7:00a	47.8	48.6	47.8	17	5.0	3.0	W	0.75	6.0	W	47.2	45.5	44.9	30.203	0.00	0.00	0.179	0.000
10/21/24	7:15a	48.2	48.2	47.7	16	4.0	0.0	WNW	0.00	3.0	WNW	48.2	45.8	45.8	30.202	0.00	0.00	0.175	0.000
10/21/24	7:30a	49.2	49.2	48.3	14	1.9	0.0	W	0.00	1.0	WNW	49.2	46.7	46.7	30.204	0.00	0.00	0.165	0.000
10/21/24	7:45a	50.0	50.0	49.1	12	-0.7	0.0	W	0.00	1.0	W	50.0	47.5	47.5	30.205	0.00	0.00	0.156	0.000
10/21/24	8:00a	49.6	50.1	49.6	13	0.7	0.0	W	0.00	1.0	W	49.6	47.1	47.1	30.206	0.00	0.00	0.160	0.000
10/21/24	8:15a	50.8	50.8	49.4	13	1.6	0.0	N	0.00	1.0	N	50.8	48.1	48.1	30.210	0.00	0.00	0.148	0.000
10/21/24	8:30a	53.5	53.5	50.8	10	-1.9	0.0	---	0.00	0.0	---	53.5	50.1	50.1	30.216	0.00	0.00	0.120	0.000
10/21/24	8:45a	55.2	55.2	53.5	6	-11.1	0.0	N	0.00	1.0	N	55.2	50.9	50.9	30.222	0.00	0.00	0.102	0.000
10/21/24	9:00a	57.4	57.4	55.2	2	-30.7	1.0	SSW	0.25	5.0	WSW	57.4	52.2	52.2	30.222	0.00	0.00	0.079	0.000
10/21/24	9:15a	59.4	59.4	57.4	0	---	1.0	SW	0.25	4.0	SW	59.4	53.5	53.5	30.225	0.00	0.00	0.058	0.000
10/21/24	9:30a	61.8	61.8	59.5	0	---	1.0	SW	0.25	4.0	WSW	61.8	55.4	55.4	30.227	0.00	0.00	0.033	0.000
10/21/24	9:45a	63.3	63.3	61.8	0	---	1.0	SSW	0.25	5.0	SSW	63.3	56.7	56.7	30.226	0.00	0.00	0.018	0.000
10/21/24	10:00a	64.9	64.9	63.2	0	---	1.0	SSW	0.25	4.0	SSW	64.9	58.0	58.0	30.224	0.00	0.00	0.001	0.000
10/21/24	10:15a	66.9	66.9	64.9	0	---	1.0	SSE	0.25	4.0	S	66.9	59.8	59.8	30.218	0.00	0.00	0.000	0.020
10/21/24	10:30a	68.3	68.3	66.9	0	---	1.0	SSE	0.25	6.0	SSE	68.3	61.3	61.3	30.214	0.00	0.00	0.000	0.034
10/21/24	10:45a	69.3	69.3	68.3	0	---	1.0	SSW	0.25	5.0	S	69.3	62.9	62.9	30.214	0.00	0.00	0.000	0.045
10/21/24	11:00a	70.4	70.5	69.3	0	---	1.0	SSW	0.25	4.0	SSW	70.4	64.4	64.4	30.215	0.00	0.00	0.000	0.056
10/21/24	11:15a	71.7	71.8	70.5	0	---	1.0	SSW	0.25	5.0	WSW	71.7	66.1	66.1	30.210	0.00	0.00	0.000	0.070
10/21/24	11:30a	73.0	73.0	71.8	0	---	1.0	SSW	0.25	6.0	S	73.0	67.7	67.7	30.207	0.00	0.00	0.000	0.083
10/21/24	11:45a	74.6	74.6	72.9	0	---	1.0	SW	0.25	5.0	SSW	74.6	69.8	69.8	30.200	0.00	0.00	0.000	0.100
10/21/24	12:00p	75.1	75.1	74.6	0	---	2.0	SSW	0.50	6.0	SSW	75.1	70.4	70.4	30.196	0.00	0.00	0.000	0.105
10/21/24	12:15p	75.6	76.0	75.1	0	---	2.0	W	0.50	5.0	S	75.6	71.0	71.0	30.195	0.00	0.00	0.000	0.110
10/21/24	12:30p	76.7	76.7	75.5	0	---	2.0	WNW	0.50	7.0	WSW	76.7	72.2	72.2	30.186	0.00	0.00	0.000	0.122

NKSP 10/21/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/21/24	12:45p	77.9	77.9	76.7	0	---	1.0	SW	0.25	4.0	WSW	77.9	73.4	73.4	30.182	0.00	0.00	0.000	0.134
10/21/24	1:00p	78.7	78.9	77.9	0	---	2.0	WNW	0.50	7.0	W	78.7	74.2	74.2	30.178	0.00	0.00	0.000	0.143
10/21/24	1:15p	79.1	79.1	78.6	0	---	1.0	WNW	0.25	7.0	W	79.1	74.6	74.6	30.169	0.00	0.00	0.000	0.147
10/21/24	1:30p	80.8	80.8	79.1	0	---	1.0	WSW	0.25	5.0	WSW	80.8	76.2	76.2	30.159	0.00	0.00	0.000	0.165
10/21/24	1:45p	80.6	80.9	80.6	0	---	2.0	NW	0.50	5.0	SSW	80.6	76.0	76.0	30.153	0.00	0.00	0.000	0.162
10/21/24	2:00p	80.8	80.9	80.6	0	---	3.0	NW	0.75	12.0	NW	80.8	76.2	76.2	30.149	0.00	0.00	0.000	0.165
10/21/24	2:15p	81.1	81.1	80.8	0	---	3.0	NW	0.75	9.0	NW	81.1	76.5	76.5	30.148	0.00	0.00	0.000	0.168
10/21/24	2:30p	81.9	81.9	81.1	0	---	4.0	W	1.00	8.0	WNW	81.9	77.3	77.3	30.144	0.00	0.00	0.000	0.176
10/21/24	2:45p	82.5	82.5	81.8	0	---	3.0	WSW	0.75	9.0	W	82.5	77.9	77.9	30.142	0.00	0.00	0.000	0.182
10/21/24	3:00p	82.6	82.9	82.5	0	---	4.0	NE	1.00	9.0	ENE	82.6	77.9	77.9	30.130	0.00	0.00	0.000	0.183
10/21/24	3:15p	82.9	82.9	82.5	0	---	3.0	NE	0.75	9.0	N	82.9	78.2	78.2	30.124	0.00	0.00	0.000	0.186
10/21/24	3:30p	83.0	83.0	82.7	0	---	4.0	NE	1.00	8.0	NNE	83.0	78.3	78.3	30.125	0.00	0.00	0.000	0.188
10/21/24	3:45p	83.3	83.4	83.0	0	---	3.0	NE	0.75	7.0	NNE	83.3	78.5	78.5	30.122	0.00	0.00	0.000	0.191
10/21/24	4:00p	83.5	83.6	83.3	0	---	3.0	NE	0.75	8.0	NNE	83.5	78.7	78.7	30.120	0.00	0.00	0.000	0.193
10/21/24	4:15p	83.7	83.7	83.4	0	---	3.0	N	0.75	8.0	NNE	83.7	78.9	78.9	30.116	0.00	0.00	0.000	0.195
10/21/24	4:30p	83.7	83.8	83.6	0	---	4.0	NE	1.00	9.0	NNE	83.7	78.9	78.9	30.112	0.00	0.00	0.000	0.195
10/21/24	4:45p	83.5	83.8	83.4	0	---	4.0	NNE	1.00	8.0	NNW	83.5	78.7	78.7	30.107	0.00	0.00	0.000	0.193
10/21/24	5:00p	83.2	83.5	83.1	0	---	5.0	NNE	1.25	9.0	N	83.2	78.5	78.5	30.105	0.00	0.00	0.000	0.190
10/21/24	5:15p	82.8	83.2	82.8	0	---	4.0	NNE	1.00	8.0	NNE	82.8	78.1	78.1	30.105	0.00	0.00	0.000	0.185
10/21/24	5:30p	82.0	82.6	82.0	0	---	3.0	NNE	0.75	7.0	NNE	82.0	77.4	77.4	30.103	0.00	0.00	0.000	0.177
10/21/24	5:45p	81.1	82.1	81.1	0	---	2.0	NE	0.50	5.0	NNE	81.1	76.5	76.5	30.106	0.00	0.00	0.000	0.168
10/21/24	6:00p	80.6	81.1	80.6	0	---	2.0	NNE	0.50	4.0	NNE	80.6	76.0	76.0	30.105	0.00	0.00	0.000	0.162
10/21/24	6:15p	79.0	80.6	79.0	0	---	1.0	NE	0.25	3.0	NNE	79.0	74.5	74.5	30.110	0.00	0.00	0.000	0.146
10/21/24	6:30p	77.8	79.0	77.8	0	---	1.0	NE	0.25	2.0	NE	77.8	73.3	73.3	30.110	0.00	0.00	0.000	0.133
10/21/24	6:45p	76.7	77.8	76.7	0	---	1.0	NE	0.25	3.0	NE	76.7	72.2	72.2	30.110	0.00	0.00	0.000	0.122
10/21/24	7:00p	74.9	76.7	74.9	0	---	2.0	NE	0.50	3.0	NE	74.9	70.2	70.2	30.113	0.00	0.00	0.000	0.103
10/21/24	7:15p	74.0	74.9	74.0	0	---	1.0	NE	0.25	3.0	NE	74.0	69.1	69.1	30.118	0.00	0.00	0.000	0.094
10/21/24	7:30p	73.9	74.0	73.8	0	---	1.0	NE	0.25	3.0	NE	73.9	69.0	69.0	30.117	0.00	0.00	0.000	0.093
10/21/24	7:45p	73.9	74.0	73.7	0	---	2.0	E	0.50	3.0	E	73.9	69.0	69.0	30.115	0.00	0.00	0.000	0.093
10/21/24	8:00p	72.6	73.9	72.6	0	---	1.0	E	0.25	3.0	E	72.6	67.2	67.2	30.117	0.00	0.00	0.000	0.079
10/21/24	8:15p	70.0	72.5	70.0	0	---	2.0	E	0.50	3.0	E	70.0	63.9	63.9	30.120	0.00	0.00	0.000	0.052
10/21/24	8:30p	67.9	69.9	67.8	0	---	3.0	SE	0.75	5.0	SE	67.9	60.7	60.7	30.122	0.00	0.00	0.000	0.030
10/21/24	8:45p	67.3	67.8	67.3	0	---	2.0	SE	0.50	4.0	SE	67.3	60.2	60.2	30.127	0.00	0.00	0.000	0.024
10/21/24	9:00p	65.9	67.3	65.9	0	---	1.0	SE	0.25	3.0	SE	65.9	58.9	58.9	30.126	0.00	0.00	0.000	0.009
10/21/24	9:15p	64.5	65.8	64.5	0	---	2.0	SE	0.50	3.0	SE	64.5	57.7	57.7	30.127	0.00	0.00	0.005	0.000
10/21/24	9:30p	63.6	64.5	63.6	2	-25.6	3.0	ESE	0.75	4.0	ESE	63.6	57.1	57.1	30.130	0.00	0.00	0.015	0.000
10/21/24	9:45p	63.1	63.5	63.0	5	-9.1	3.0	ESE	0.75	4.0	ESE	63.1	57.0	57.0	30.133	0.00	0.00	0.020	0.000
10/21/24	10:00p	62.5	63.1	62.5	4	-14.0	2.0	ESE	0.50	4.0	ESE	62.5	56.4	56.4	30.134	0.00	0.00	0.026	0.000
10/21/24	10:15p	62.0	62.5	62.0	3	-20.0	2.0	SE	0.50	4.0	ESE	62.0	55.8	55.8	30.141	0.00	0.00	0.031	0.000
10/21/24	10:30p	61.5	62.0	61.5	3	-20.3	2.0	SE	0.50	4.0	SE	61.5	55.4	55.4	30.141	0.00	0.00	0.036	0.000
10/21/24	10:45p	59.3	61.6	59.3	7	-4.9	2.0	SW	0.50	9.0	WSW	59.3	54.2	54.2	30.152	0.00	0.00	0.059	0.000
10/21/24	11:00p	58.8	59.3	58.4	12	6.2	2.0	SW	0.50	6.0	WSW	58.8	54.2	54.2	30.158	0.00	0.00	0.065	0.000
10/21/24	11:15p	59.7	59.7	58.8	11	5.0	0.0	WNW	0.00	6.0	WNW	59.7	55.0	55.0	30.158	0.00	0.00	0.055	0.000
10/21/24	11:30p	60.4	60.4	59.6	8	-1.3	0.0	---	0.00	0.0	---	60.4	55.3	55.3	30.160	0.00	0.00	0.048	0.000
10/21/24	11:45p	59.9	60.6	59.9	9	0.8	2.0	ESE	0.50	6.0	ESE	59.9	55.0	55.0	30.157	0.00	0.00	0.053	0.000
10/22/24	12:00a	58.1	59.9	58.1	12	5.7	3.0	ESE	0.75	4.0	ESE	58.1	53.7	53.7	30.159	0.00	0.00	0.072	0.000

NKSP 10/20/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/20/24	12:15a	75.0	36	46.2	73.7	7.05	.0741	350	1	100.0	15
10/20/24	12:30a	74.9	36	46.1	73.5	7.05	.0741	351	1	100.0	15
10/20/24	12:45a	74.9	36	46.1	73.5	7.05	.0741	351	1	100.0	15
10/20/24	1:00a	74.8	35	45.3	73.4	6.95	.0742	352	1	100.0	15
10/20/24	1:15a	74.7	35	45.2	73.3	6.96	.0742	351	1	100.0	15
10/20/24	1:30a	74.6	35	45.1	73.2	6.96	.0742	351	1	100.0	15
10/20/24	1:45a	74.6	35	45.1	73.2	6.96	.0742	351	1	100.0	15
10/20/24	2:00a	74.4	35	45.0	72.9	6.96	.0742	352	1	100.0	15
10/20/24	2:15a	74.4	35	45.0	72.9	6.96	.0742	351	1	100.0	15
10/20/24	2:30a	74.2	35	44.8	72.7	6.97	.0743	351	1	100.0	15
10/20/24	2:45a	74.1	35	44.7	72.6	6.97	.0743	351	1	100.0	15
10/20/24	3:00a	74.0	35	44.6	72.5	6.97	.0743	351	1	100.0	15
10/20/24	3:15a	73.9	35	44.5	72.4	6.97	.0743	352	1	100.0	15
10/20/24	3:30a	73.9	35	44.5	72.4	6.97	.0743	351	1	100.0	15
10/20/24	3:45a	73.9	34	43.8	72.3	6.77	.0743	351	1	100.0	15
10/20/24	4:00a	74.0	34	43.8	72.4	6.77	.0743	351	1	100.0	15
10/20/24	4:15a	73.8	34	43.7	72.2	6.77	.0744	352	1	100.0	15
10/20/24	4:30a	73.8	34	43.7	72.2	6.77	.0744	351	1	100.0	15
10/20/24	4:45a	73.8	34	43.7	72.2	6.77	.0744	351	1	100.0	15
10/20/24	5:00a	73.8	34	43.7	72.2	6.77	.0744	351	1	100.0	15
10/20/24	5:15a	73.7	34	43.6	72.0	6.78	.0744	352	1	100.0	15
10/20/24	5:30a	73.7	34	43.6	72.0	6.78	.0744	351	1	100.0	15
10/20/24	5:45a	73.5	34	43.4	71.8	6.78	.0744	351	1	100.0	15
10/20/24	6:00a	73.5	35	44.2	71.9	6.98	.0744	351	1	100.0	15
10/20/24	6:15a	73.5	35	44.2	71.9	6.98	.0744	351	1	100.0	15
10/20/24	6:30a	73.5	35	44.2	71.9	6.98	.0744	352	1	100.0	15
10/20/24	6:45a	73.4	35	44.1	71.8	6.98	.0745	351	1	100.0	15
10/20/24	7:00a	73.5	35	44.2	71.9	6.98	.0744	351	1	100.0	15
10/20/24	7:15a	73.5	35	44.2	71.9	6.98	.0744	351	1	100.0	15
10/20/24	7:30a	73.4	35	44.1	71.8	6.98	.0745	352	1	100.0	15
10/20/24	7:45a	73.7	35	44.3	72.1	6.98	.0744	351	1	100.0	15
10/20/24	8:00a	73.9	35	44.5	72.4	6.97	.0744	351	1	100.0	15
10/20/24	8:15a	74.0	35	44.6	72.5	6.97	.0744	351	1	100.0	15
10/20/24	8:30a	74.0	35	44.6	72.5	6.97	.0744	352	1	100.0	15
10/20/24	8:45a	74.2	35	44.8	72.7	6.97	.0744	351	1	100.0	15
10/20/24	9:00a	74.6	35	45.1	73.2	6.96	.0743	351	1	100.0	15
10/20/24	9:15a	74.9	35	45.4	73.5	6.95	.0743	351	1	100.0	15
10/20/24	9:30a	74.4	35	45.0	72.9	6.96	.0744	351	1	100.0	15
10/20/24	9:45a	74.3	35	44.9	72.8	6.96	.0744	352	1	100.0	15
10/20/24	10:00a	75.0	35	45.5	73.6	6.95	.0742	351	1	100.0	15
10/20/24	10:15a	74.4	35	45.0	72.9	6.96	.0743	351	1	100.0	15
10/20/24	10:30a	75.1	34	44.8	73.6	6.75	.0742	351	1	100.0	15
10/20/24	10:45a	74.6	34	44.4	73.1	6.76	.0743	352	1	100.0	15
10/20/24	11:00a	75.2	33	44.1	73.6	6.55	.0742	351	1	100.0	15
10/20/24	11:15a	75.1	34	44.8	73.6	6.75	.0742	351	1	100.0	15
10/20/24	11:30a	75.1	34	44.8	73.6	6.75	.0742	351	1	100.0	15
10/20/24	11:45a	75.5	34	45.2	74.0	6.74	.0741	351	1	100.0	15
10/20/24	12:00p	75.8	33	44.6	74.3	6.55	.0741	352	1	100.0	15
10/20/24	12:15p	75.7	34	45.3	74.2	6.74	.0741	351	1	100.0	15
10/20/24	12:30p	75.6	34	45.4	74.3	6.73	.0740	351	1	100.0	15

NKSP 10/20/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/20/24	12:45p	76.0	34	45.6	74.5	6.73	.0740	351	1	100.0	15
10/20/24	1:00p	76.3	33	45.1	74.8	6.55	.0739	352	1	100.0	15
10/20/24	1:15p	76.7	33	45.4	75.1	6.55	.0739	351	1	100.0	15
10/20/24	1:30p	76.7	33	45.4	75.1	6.55	.0738	351	1	100.0	15
10/20/24	1:45p	76.6	33	45.3	75.0	6.55	.0738	351	1	100.0	15
10/20/24	2:00p	76.8	33	45.5	75.2	6.55	.0738	352	1	100.0	15
10/20/24	2:15p	77.0	33	45.7	75.4	6.55	.0738	351	1	100.0	15
10/20/24	2:30p	77.3	32	45.1	75.6	6.40	.0737	351	1	100.0	15
10/20/24	2:45p	77.5	31	44.5	75.8	6.20	.0737	351	1	100.0	15
10/20/24	3:00p	77.6	31	44.6	75.8	6.20	.0737	351	1	100.0	15
10/20/24	3:15p	77.7	31	44.6	75.9	6.20	.0737	352	1	100.0	15
10/20/24	3:30p	77.9	32	45.7	76.1	6.39	.0736	351	1	100.0	15
10/20/24	3:45p	77.9	32	45.7	76.1	6.39	.0736	351	1	100.0	15
10/20/24	4:00p	77.9	32	45.7	76.1	6.39	.0736	351	1	100.0	15
10/20/24	4:15p	77.8	32	45.6	76.1	6.39	.0736	352	1	100.0	15
10/20/24	4:30p	77.7	32	45.5	76.0	6.40	.0736	351	1	100.0	15
10/20/24	4:45p	78.0	31	44.9	76.2	6.19	.0736	351	1	100.0	15
10/20/24	5:00p	78.2	31	45.1	76.4	6.19	.0735	351	1	100.0	15
10/20/24	5:15p	78.2	31	45.1	76.4	6.19	.0736	352	1	100.0	15
10/20/24	5:30p	78.0	32	45.7	76.2	6.39	.0735	351	1	100.0	15
10/20/24	5:45p	77.6	33	46.2	75.9	6.55	.0736	351	1	100.0	15
10/20/24	6:00p	77.1	33	45.8	75.5	6.55	.0737	351	1	100.0	15
10/20/24	6:15p	77.1	33	45.8	75.5	6.55	.0737	351	1	100.0	15
10/20/24	6:30p	77.0	32	44.9	75.4	6.41	.0737	352	1	100.0	15
10/20/24	6:45p	76.9	33	45.6	75.3	6.55	.0737	351	1	100.0	15
10/20/24	7:00p	76.6	34	46.1	75.1	6.72	.0738	351	1	100.0	15
10/20/24	7:15p	76.0	34	45.6	74.5	6.73	.0739	351	1	100.0	15
10/20/24	7:30p	76.1	35	46.5	74.7	6.93	.0738	352	1	100.0	15
10/20/24	7:45p	76.3	34	45.9	74.8	6.72	.0738	351	1	100.0	15
10/20/24	8:00p	75.9	35	46.3	74.5	6.93	.0739	351	1	100.0	15
10/20/24	8:15p	75.5	35	45.9	74.1	6.94	.0739	351	1	100.0	15
10/20/24	8:30p	75.8	34	45.4	74.3	6.73	.0739	352	1	100.0	15
10/20/24	8:45p	75.6	35	46.0	74.2	6.94	.0739	351	1	100.0	15
10/20/24	9:00p	75.3	36	46.5	74.0	7.04	.0740	351	1	100.0	15
10/20/24	9:15p	75.6	35	46.0	74.2	6.94	.0740	351	1	100.0	15
10/20/24	9:30p	75.1	37	47.0	73.8	7.25	.0740	351	1	100.0	15
10/20/24	9:45p	75.0	37	47.0	73.7	7.25	.0740	352	1	100.0	15
10/20/24	10:00p	75.0	38	47.7	73.8	7.35	.0740	351	1	100.0	15
10/20/24	10:15p	74.6	37	46.6	73.3	7.26	.0741	351	1	100.0	15
10/20/24	10:30p	74.7	38	47.4	73.4	7.36	.0741	351	1	100.0	15
10/20/24	10:45p	74.9	37	46.9	73.6	7.25	.0741	352	1	100.0	15
10/20/24	11:00p	74.6	38	47.3	73.3	7.37	.0741	351	1	100.0	15
10/20/24	11:15p	75.1	38	47.8	73.9	7.35	.0740	351	1	100.0	15
10/20/24	11:30p	74.4	38	47.1	73.1	7.37	.0741	351	1	100.0	15
10/20/24	11:45p	74.6	38	47.3	73.3	7.37	.0741	351	1	100.0	15
10/21/24	12:00a	74.9	37	46.9	73.6	7.25	.0741	352	1	100.0	15

NKSP 10/21/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/21/24	12:15a	75.1	37	47.0	73.8	7.25	.0740	350	1	100.0	15
10/21/24	12:30a	75.3	37	47.2	74.0	7.24	.0740	351	1	100.0	15
10/21/24	12:45a	75.3	37	47.2	74.0	7.24	.0740	352	1	100.0	15
10/21/24	1:00a	75.3	37	47.2	74.0	7.24	.0740	351	1	100.0	15
10/21/24	1:15a	75.2	37	47.1	73.9	7.25	.0740	351	1	100.0	15
10/21/24	1:30a	75.2	36	46.4	73.9	7.05	.0740	351	1	100.0	15
10/21/24	1:45a	75.1	36	46.3	73.8	7.05	.0740	352	1	100.0	15
10/21/24	2:00a	75.0	36	46.2	73.7	7.05	.0741	351	1	100.0	15
10/21/24	2:15a	75.0	36	46.2	73.7	7.05	.0741	351	1	100.0	15
10/21/24	2:30a	74.9	36	46.1	73.5	7.05	.0741	351	1	100.0	15
10/21/24	2:45a	74.9	36	46.1	73.5	7.05	.0741	351	1	100.0	15
10/21/24	3:00a	74.8	36	46.1	73.4	7.06	.0741	352	1	100.0	15
10/21/24	3:15a	74.7	35	45.2	73.3	6.96	.0741	351	1	100.0	15
10/21/24	3:30a	74.6	35	45.1	73.2	6.96	.0741	351	1	100.0	15
10/21/24	3:45a	74.6	36	45.9	73.2	7.07	.0741	351	1	100.0	15
10/21/24	4:00a	74.7	35	45.2	73.3	6.96	.0741	352	1	100.0	15
10/21/24	4:15a	74.8	35	45.3	73.4	6.95	.0741	351	1	100.0	15
10/21/24	4:30a	74.9	35	45.4	73.5	6.95	.0741	351	1	100.0	15
10/21/24	4:45a	74.9	35	45.4	73.5	6.95	.0741	351	1	100.0	15
10/21/24	5:00a	74.8	35	45.3	73.4	6.95	.0741	351	1	100.0	15
10/21/24	5:15a	74.8	35	45.3	73.4	6.95	.0741	352	1	100.0	15
10/21/24	5:30a	74.7	35	45.2	73.3	6.96	.0741	351	1	100.0	15
10/21/24	5:45a	74.7	35	45.2	73.3	6.96	.0741	351	1	100.0	15
10/21/24	6:00a	74.7	35	45.2	73.3	6.96	.0742	351	1	100.0	15
10/21/24	6:15a	74.7	35	45.2	73.3	6.96	.0742	352	1	100.0	15
10/21/24	6:30a	74.6	35	45.1	73.2	6.96	.0742	351	1	100.0	15
10/21/24	6:45a	74.5	35	45.0	73.1	6.96	.0742	351	1	100.0	15
10/21/24	7:00a	74.2	35	44.8	72.7	6.97	.0743	352	1	100.0	15
10/21/24	7:15a	74.0	35	44.6	72.5	6.97	.0743	351	1	100.0	15
10/21/24	7:30a	74.0	35	44.6	72.5	6.97	.0743	351	1	100.0	15
10/21/24	7:45a	73.9	35	44.5	72.4	6.97	.0744	351	1	100.0	15
10/21/24	8:00a	74.0	35	44.6	72.5	6.97	.0743	351	1	100.0	15
10/21/24	8:15a	74.0	35	44.6	72.5	6.97	.0743	351	1	100.0	15
10/21/24	8:30a	74.2	35	44.8	72.7	6.97	.0743	352	1	100.0	15
10/21/24	8:45a	74.4	35	45.0	72.9	6.96	.0743	351	1	100.0	15
10/21/24	9:00a	74.6	35	45.1	73.2	6.96	.0743	351	1	100.0	15
10/21/24	9:15a	74.9	35	45.4	73.5	6.95	.0742	351	1	100.0	15
10/21/24	9:30a	75.2	35	45.7	73.8	6.95	.0742	352	1	100.0	15
10/21/24	9:45a	75.4	35	45.8	74.0	6.94	.0742	351	1	100.0	15
10/21/24	10:00a	75.3	34	45.0	73.8	6.74	.0742	351	1	100.0	15
10/21/24	10:15a	75.0	35	45.5	73.6	6.95	.0742	351	1	100.0	15
10/21/24	10:30a	75.5	34	45.2	74.0	6.74	.0741	351	1	100.0	15
10/21/24	10:45a	75.0	35	45.5	73.6	6.95	.0742	352	1	100.0	15
10/21/24	11:00a	75.4	33	44.3	73.9	6.55	.0742	351	1	100.0	15
10/21/24	11:15a	75.3	35	45.7	73.9	6.94	.0741	351	1	100.0	15
10/21/24	11:30a	75.0	34	44.7	73.5	6.75	.0742	351	1	100.0	15
10/21/24	11:45a	75.6	33	44.5	74.1	6.55	.0741	352	1	100.0	15
10/21/24	12:00p	75.5	34	45.2	74.0	6.74	.0741	351	1	100.0	15
10/21/24	12:15p	75.4	34	45.1	73.9	6.74	.0741	351	1	100.0	15
10/21/24	12:30p	75.6	34	45.2	74.1	6.74	.0740	351	1	100.0	15

NKSP 10/21/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/21/24	12:45p	76.0	33	44.8	74.5	6.55	.0740	352	1	100.0	15
10/21/24	1:00p	76.2	34	45.8	74.7	6.73	.0739	351	1	100.0	15
10/21/24	1:15p	76.3	34	45.9	74.8	6.72	.0739	351	1	100.0	15
10/21/24	1:30p	76.1	34	45.7	74.6	6.73	.0739	351	1	100.0	15
10/21/24	1:45p	76.4	34	45.9	74.9	6.72	.0738	351	1	100.0	15
10/21/24	2:00p	76.8	33	45.5	75.2	6.55	.0738	352	1	100.0	15
10/21/24	2:15p	77.3	33	45.9	75.7	6.55	.0737	351	1	100.0	15
10/21/24	2:30p	77.5	33	46.1	75.8	6.55	.0737	351	1	100.0	15
10/21/24	2:45p	77.6	33	46.2	75.9	6.55	.0736	351	1	100.0	15
10/21/24	3:00p	77.8	33	46.4	76.1	6.55	.0736	352	1	100.0	15
10/21/24	3:15p	77.9	33	46.5	76.2	6.55	.0735	351	1	100.0	15
10/21/24	3:30p	78.1	32	45.8	76.3	6.39	.0735	351	1	100.0	15
10/21/24	3:45p	78.3	32	46.0	76.5	6.38	.0735	351	1	100.0	15
10/21/24	4:00p	78.5	32	46.2	76.7	6.38	.0735	352	1	100.0	15
10/21/24	4:15p	78.5	32	46.2	76.7	6.38	.0734	351	1	100.0	15
10/21/24	4:30p	78.4	32	46.1	76.6	6.38	.0735	351	1	100.0	15
10/21/24	4:45p	78.3	32	46.0	76.5	6.38	.0735	351	1	100.0	15
10/21/24	5:00p	78.4	32	46.1	76.6	6.38	.0734	351	1	100.0	15
10/21/24	5:15p	78.5	32	46.2	76.7	6.38	.0734	352	1	100.0	15
10/21/24	5:30p	78.7	31	45.5	76.9	6.18	.0734	351	1	100.0	15
10/21/24	5:45p	78.7	32	46.4	76.9	6.38	.0734	351	1	100.0	15
10/21/24	6:00p	78.6	32	46.3	76.8	6.38	.0734	351	1	100.0	15
10/21/24	6:15p	78.4	33	46.9	76.7	6.55	.0734	352	1	100.0	15
10/21/24	6:30p	78.2	33	46.7	76.5	6.55	.0735	351	1	100.0	15
10/21/24	6:45p	78.1	33	46.6	76.4	6.55	.0735	351	1	100.0	15
10/21/24	7:00p	78.1	32	45.8	76.3	6.39	.0735	352	1	100.0	15
10/21/24	7:15p	78.0	33	46.6	76.3	6.55	.0735	351	1	100.0	15
10/21/24	7:30p	77.7	34	47.1	76.1	6.70	.0735	351	1	100.0	15
10/21/24	7:45p	77.4	34	46.8	75.8	6.70	.0736	351	1	100.0	15
10/21/24	8:00p	77.6	33	46.2	75.9	6.55	.0736	351	1	100.0	15
10/21/24	8:15p	77.6	34	47.0	76.0	6.70	.0736	351	1	100.0	15
10/21/24	8:30p	77.0	35	47.2	75.5	6.91	.0736	352	1	100.0	15
10/21/24	8:45p	77.0	35	47.2	75.5	6.91	.0736	351	1	100.0	15
10/21/24	9:00p	77.2	34	46.7	75.6	6.71	.0736	351	1	100.0	15
10/21/24	9:15p	76.9	36	47.9	75.5	7.01	.0736	351	1	100.0	15
10/21/24	9:30p	76.7	36	47.7	75.3	7.02	.0737	352	1	100.0	15
10/21/24	9:45p	76.9	35	47.2	75.4	6.91	.0737	351	1	100.0	15
10/21/24	10:00p	76.6	37	48.4	75.3	7.22	.0737	351	1	100.0	15
10/21/24	10:15p	76.4	37	48.2	75.1	7.22	.0737	351	1	100.0	15
10/21/24	10:30p	76.4	37	48.2	75.1	7.22	.0737	352	1	100.0	15
10/21/24	10:45p	75.8	37	47.7	74.5	7.23	.0739	351	1	100.0	15
10/21/24	11:00p	76.0	37	47.8	74.7	7.23	.0738	351	1	100.0	15
10/21/24	11:15p	76.2	36	47.3	74.8	7.03	.0738	351	1	100.0	15
10/21/24	11:30p	75.7	38	48.3	74.5	7.34	.0739	351	1	100.0	15
10/21/24	11:45p	75.9	38	48.5	74.7	7.33	.0738	352	1	100.0	15
10/22/24	12:00a	76.1	37	47.9	74.8	7.23	.0738	351	1	100.0	15

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB- 1 Temp. Reading Location: 2ND TIER A-SECTION
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-21-24	0300	61	Hill
	0600	62	Cunny
	0900	64	Cunny
	1200	64	Cunny
	1500	67	R. Knight
	1800	69	R. Knight
	2100	69	R. Knight
	2400	67	D Hu

Tuesday

Date	Time	Temp.	Name (Print)
10-22-24	0300	64	D. Hu
	0600	62	Cunny
	0900	65	Cunny
	1200	67	Cunny
	1500	65	D. Castrejon
	1800	65	D. Castrejon
	2100	65	D. Castrejon
	2400	63	D Hu

Wednesday

Date	Time	Temp.	Name (Print)
10-23-24	0300	61	D. Hu
	0600	63	E. Andrade
	0900	65	E. Andrade
	1200	67	E. Andrade
	1500	69	D. Castrejon
	1800	69	D. Castrejon
	2100	69	D. Castrejon
	2400	65	D. Hu

Thursday

Date	Time	Temp.	Name (Print)
10-24-24	0300	62	D. Hu
	0600	65	E. Andrade
	0900	67	E. Andrade
	1200	68	E. Andrade
	1500	68	D. Castrejon
	1800	68	D. Castrejon
	2100	68	D. Castrejon
	2400	64	D. Hu

Friday

Date	Time	Temp.	Name (Print)
10-25-24	0300	62	D. Hu
	0600	64	R. Rivera
	0900	65	R. Rivera
	1200	66	R. Rivera
	1500	66	Munoz
	1800	66	Munoz
	2100	66	Munoz
	2400	68	Cill

Saturday

Date	Time	Temp.	Name (Print)
10/26/24	0300	64	Cill
	0600	65	J Galegos
	0900	67	J Galegos
	1200	67	J Galegos
	1500	66	E Munoz
	1800	66	E Munoz
	2100	66	E Munoz
	2400	67	L. Cill

Sunday

Date	Time	Temp.	Name (Print)
10/27/24	0300	67	L. Cill
	0600	62	C. Ramirez
	0900	65	C. Ramirez
	1200	65	C. Ramirez
	1500	64	R. Knight
	1800	62	R. Knight
	2100	62	R. Knight
	2400	64	Cabalay

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB- 1 Temp. Reading Location: 2ND TIER B-SECTION
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-21-24	0300	61	D Hue
	0600	62	Cuarny
	0900	64	Cuarny
	1200	64	Cuarny
	1500	67	R. Wright
	1800	69	R. Knight
	2100	69	R. Knight
	2400	67	D Hue

Tuesday

Date	Time	Temp.	Name (Print)
10-22-24	0300	64	D-Hue
	0600	62	Cuarny
	0900	67	Cuarny
	1200	68	Cuarny
	1500	65	D. Castrejon
	1800	65	D. Castrejon
	2100	65	D-Castrejon
	2400	63	D. Hue

Wednesday

Date	Time	Temp.	Name (Print)
10-23-24	0300	61	D.Hue
	0600	63	E. Andrade
	0900	65	E Andrade
	1200	67	E Andrade
	1500	69	D-Castrejon
	1800	69	D-Castrejon
	2100	69	D. Castrejon
	2400	65	D.Hue

Thursday

Date	Time	Temp.	Name (Print)
10/24	0300	62	D.Hue
	0600	65	E. Andrade
	0900	67	E Andrade
	1200	68	E Andrade
	1500	68	D Castrejon
	1800	69	D Castrejon
	2100	69	D. Castrejon
	2400	64	D. Hue

Friday

Date	Time	Temp.	Name (Print)
10/25	0300	62	D.Hue
	0600	65	[illegible]
	0900	64	[illegible]
	1200	64	Mavera
	1500	66	MENDOZA
	1800	66	MENDOZA
	2100	66	MENDOZA
	2400	68	Gill

Saturday

Date	Time	Temp.	Name (Print)
10/26/24	0300	65	Gill
	0600	65	J GALLEGOS
	0900	67	J GALLEGOS
	1200	67	J GALLEGOS
	1500	66	E MENDOZA
	1800	66	E MENDOZA
	2100	66	E MENDOZA
	2400	67	Gill

Sunday

Date	Time	Temp.	Name (Print)
10/27/24	0300	67	G. Gill
	0600	62	C-Ramirez
	0900	65	C-Ramirez
	1200	65	C-Ramirez
	1500	64	R. Knight
	1800	62	R. Knight
	2100	62	R. Knight
	2400	63	[illegible]

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB-2 Temp. Reading Location: 2nd Tier - A section
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21	0300	64	J Blanco
	0600	63	R-Lira
	0900	74	R-Lira
	1200	75	R-Lira
	1500	70	O Lobo
	1800	69	O Lobo
	2100	67	O Lobo
	2400	67	J Blanco

Tuesday

Date	Time	Temp.	Name (Print)
10/22	0300	65	J Blanco
	0600	64	R-Lira
	0900	65	R-Lira
	1200	66	R-Lira
	1500	69	O Lobo
	1800	68	O Lobo
	2100	67	O Lobo
	2400	67	J Blanco

Wednesday

Date	Time	Temp.	Name (Print)
10/23	0300	65	J Blanco
	0600	64	R. Lira
	0900	65	R. Lira
	1200	67	R. Lira
	1500	69	O Lobo
	1800	68	O Lobo
	2100	67	O Lobo
	2400	65	G Rios

Thursday

Date	Time	Temp.	Name (Print)
10/24	0300	65	G. Rios
	0600	64	R-Lira
	0900	65	R-Lira
	1200	66	R. Lira
	1500	66	Josan
	1800	66	Josan
	2100	68	Josan
	2400	65	G. Rios

Friday

Date	Time	Temp.	Name (Print)
10/25	0300	62	G. Rios
	0600	62	Hinojosa
	0900	62	Hinojosa
	1200	62	Hinojosa
	1500	67	R. Knight
	1800	70	R. Knight
	2100	70	R. Knight
	2400	68	G Rios

Saturday

Date	Time	Temp.	Name (Print)
10/26	0300	63	D. Hu
	0600	63	[illegible]
	0900	65	[illegible]
	1200	67	[illegible]
	1500	69	[illegible]
	1800	69	R. Knight
	2100	69	R. Knight
	2400	68	J Blanco

Sunday

Date	Time	Temp.	Name (Print)
10/27	0300	66	J Blanco
	0600	64	R-Lira
	0900	65	R-Lira
	1200	64	R-Lira
	1500	69°	B. CORRAL
	1800	69°	B. CORRAL
	2100	69	B. CORRAL
	2400	68	J Blanco

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB-2 Temp. Reading Location: 2nd Tier - B section (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21	0300	64	J Blanco
	0600	63	R. Lira
	0900	64	R. Lira
	1200	65	R. Lira
	1500	70	O Rubio
	1800	69	O Rubio
	2100	67	O Rubio
	2400	67	J Blanco

Tuesday

Date	Time	Temp.	Name (Print)
10/22	0300	65	J Blanco
	0600	64	R. Lira
	0900	65	R. Lira
	1200	66	R. Lira
	1500	69	O Rubio
	1800	68	O Rubio
	2100	67	O Rubio
	2400	67	J Blanco

Wednesday

Date	Time	Temp.	Name (Print)
10/23	0300	65	J Blanco
	0600	64	R. Lira
	0900	65	R. Lira
	1200	69	R Lira
	1500	70	O Rubio
	1800	68	O Rubio
	2100	67	O Rubio
	2400	65	G Rios

Thursday

Date	Time	Temp.	Name (Print)
10/24	0300	65	G. Rios
	0600	64	R. Lira
	0900	65	R. Lira
	1200	66	R. Lira
	1500	66	Lozano
	1800	66	Lozano
	2100	68	Lozano
	2400	65	G Rios

Friday

Date	Time	Temp.	Name (Print)
10/25	0300	62	G Rios
	0600	61	Hinojosa
	0900	61	Hinojosa
	1200	61	Hinojosa
	1500	69	R. Knight
	1800	70	R. Knight
	2100	70	R. Knight
	2400	65	G Rios

Saturday

Date	Time	Temp.	Name (Print)
10/26	0300	63	D [illegible]
	0600	63	[illegible]
	0900	65	[illegible]
	1200	67	[illegible]
	1500	69	R. Knight
	1800	69	R. Knight
	2100	69	R. Knight
	2400	68	J Blanco

Sunday

Date	Time	Temp.	Name (Print)
10/27	0300	66	J Blanco
	0600	64	R. Lira
	0900	66	R. Lira
	1200	66	R. Lira
	1500	69	B. Corral
	1800	69	B. Corral
	2100	68	B. Corral
	2400	68	J Blanco

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB-J Temp. Reading Location: A-Section 2nd Tier
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-21-24	0300	59	Gill
	0600	58	Saldana
	0900	59	Saldana
	1200	60	Saldana
	1500	61	HINOJOSA
	1800	61	HINOJOSA
	2100	60	HINOJOSA
	2400	60	Reveles

Tuesday

Date	Time	Temp.	Name (Print)
10-22 2024	0300	59	Reveles
	0600	60	CHAN
	0900	60	CHAN
	1200	63	CHAN
	1500	64	R. Borquez
	1800	63	R. Borquez
	2100	61	R. Borquez
	2400	60	Reveles

Wednesday

Date	Time	Temp.	Name (Print)
10.23.24	0300	58°	LANE
	0600	60	Pompa
	0900	60	Pompa
	1200	60	Pompa
	1500	60	GRAYSON
	1800	60	GRAYSON
	2100	60	GRAYSON
	2400	61°	LANE

Thursday

Date	Time	Temp.	Name (Print)
10.24.24	0300	59°	LANE
	0600	59	Saldana
	0900	59	Saldana
	1200	60	Saldana
	1500	60	R. Knight
	1800	60	R. Knight
	2100	60	R. Knight
	2400	60°	LANE

Friday

Date	Time	Temp.	Name (Print)
10.25.24	0300	59°	LANE
	0600	59	Reveles
	0900	60	Reveles
	1200	61	Reveles
	1500	61	HINOJOSA
	1800	61	HINOJOSA
	2100	60	HINOJOSA
	2400	60°	LANE

Saturday

Date	Time	Temp.	Name (Print)
10.26.24	0300	59°	LANE
	0600	59	Saldana
	0900	59	Saldana
	1200	60	Saldana
	1500	61	CRUZ
	1800	60	CRUZ
	2100	59	CRUZ
	2400	60°	LANE

Sunday

Date	Time	Temp.	Name (Print)
10.27.24	0300	59°	LANE
	0600	59	Saldana
	0900	60	Saldana
	1200	61	Saldana
	1500	60	HINOJOSA
	1800	60	HINOJOSA
	2100	60	HINOJOSA
	2400	59°	LANE

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB-3 Temp. Reading Location: B-Section 2nd Tier
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-21-24	0300	59	GALL
	0600	58°	Saldana
	0900	59	Saldana
	1200	60	Saldana
	1500	60	HINOJOSA
	1800	60	HINOJOSA
	2100	61	HINOJOSA
	2400	60	Reveles

Tuesday

Date	Time	Temp.	Name (Print)
10-22 2024	0300	59	Reveles
	0600	60	CHAN
	0900	60	CHAN
	1200	63	CHAN
	1500	64	R. Borquez
	1800	63	R. Borquez
	2100	61	R. Borquez
	2400	60	Reveles

Wednesday

Date	Time	Temp.	Name (Print)
10-23-24	0300	58°	LANE
	0600	60	Pompa
	0900	60	Pompa
	1200	60	Pompa
	1500	60	GRAYSON
	1800	60	GRAYSON
	2100	60	GRAYSON
	2400	61°	LANE

Thursday

Date	Time	Temp.	Name (Print)
10-24-24	0300	59°	LANE
	0600	59	Saldana
	0900	59	Saldana
	1200	60	Saldana
	1500	60	R. Knight
	1800	60	R. Knight
	2100	60	R. Knight
	2400	60°	LANE

Friday

Date	Time	Temp.	Name (Print)
10-25-24	0300	59°	LANE
	0600	59	Reveles
	0900	60	Reveles
	1200	61	Reveles
	1500	61	HINOJOSA
	1800	61	HINOJOSA
	2100	60	HINOJOSA
	2400	60°	LANE

Saturday

Date	Time	Temp.	Name (Print)
10-26-24	0300	59°	LANE
	0600	59	Saldana
	0900	59	Saldana
	1200	60	Saldana
	1500	61	CRUZ
	1800	60	CRUZ
	2100	59	CRUZ
	2400	60°	LANE

Sunday

Date	Time	Temp.	Name (Print)
10-27-24	0300	59°	LANE
	0600	59	Saldana
	0900	60	Saldana
	1200	61	Saldana
	1500	61	HINOJOSA
	1800	61	HINOJOSA
	2100	60	HINOJOSA
	2400	59°	LANE

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: A4-A Temp. Reading Location: dayroom
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-21-2024	0300	63	Revelos
	0600	62	CHAN
	0900	62	CHAN
	1200	64	CHAN
	1500	68	Baeza
	1800	67	Baeza
	2100	64	Baeza
	2400	66	PRICE

Tuesday

Date	Time	Temp.	Name (Print)
10/22/24	0300	66	PRICE
	0600	66	O.Montoya
	0900	66	O.Montoya
	1200	66	O.Montoya
	1500	66	Z. Green
	1800	66	Z. Green
	2100	64	Z. Green
	2400	66	PRICE

Wednesday

Date	Time	Temp.	Name (Print)
10/23/24	0300	66	PRICE
	0600	66	O.Montoya
	0900	66	O.Montoya
	1200	66	O.Montoya
	1500	64	Baeza
	1800	67	Baeza
	2100	64	Baeza
	2400	66	PRICE

Thursday

Date	Time	Temp.	Name (Print)
10/24/22	0300	66	PRICE
	0600	66	O.Montoya
	0900	66	O.Montoya
	1200	66	O.Montoya
	1500	65	Baeza
	1800	65	Baeza
	2100	64	Baeza
	2400	66	PRICE

Friday

Date	Time	Temp.	Name (Print)
10/25/24	0300	66	PRICE
	0600	66	O.Montoya
	0900	66	O.Montoya
	1200	66	O.Montoya
	1500	68	CHAN
	1800	68	CHAN
	2100	68	CHAN
	2400	66	PRICE

Saturday

Date	Time	Temp.	Name (Print)
10/26/24	0300	66	PRICE
	0600	66	O.Montoya
	0900	66	O.Montoya
	1200	66	O.Montoya
	1500	67	L. Diaz
	1800	66	L. Diaz
	2100	66	L. Diaz
	2400	66	C. Ramirez

Sunday

Date	Time	Temp.	Name (Print)
10/27/24	0300	66	C. Ramirez
	0600	66	O.Montoya
	0900	66	O.Montoya
	1200	66	O.Montoya
	1500	65	GRAYSON
	1800	65	GRAYSON
	2100	65	GRAYSON
	2400	65	Revelos [illegible]

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: A4-B Temp. Reading Location: dayroom
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-21-2024	0300	63	Reyes
	0600	62	CHAN
	0900	62	CHAN
	1200	64	CHAN
	1500	68	Baeza
	1800	66	Baeza
	2100	64	Baeza
	2400	66	PRICE

Tuesday

Date	Time	Temp.	Name (Print)
10/22/24	0300	66	PRICE
	0600	66	D.Montoya
	0900	66	D.Montoya
	1200	66	D.Montoya
	1500	66	Z.Green
	1800	66	Z. Green
	2100	64	Z. Green
	2400	66	PRICE

Wednesday

Date	Time	Temp.	Name (Print)
10/23/24	0300	66	PRICE
	0600	66	D.Montoya
	0900	66	D.Montoya
	1200	66	D.Montoya
	1500	68	Baeza
	1800	67	Baeza
	2100	66	Baeza
	2400	66	PRICE

Thursday

Date	Time	Temp.	Name (Print)
10/24/24	0300	66	PRICE
	0600	66	D.Montoya
	0900	66	D.Montoya
	1200	66	D.Montoya
	1500	65	Baeza
	1800	65	Baeza
	2100	69	Baeza
	2400	66	PRICE

Friday

Date	Time	Temp.	Name (Print)
10/25/24	0300	66	PRICE
	0600	66	D.Montoya
	0900	66	D.Montoya
	1200	66	D.Montoya
	1500	66	CHAN
	1800	68	CHAN
	2100	68	CHAN
	2400	66	PRICE

Saturday

Date	Time	Temp.	Name (Print)
10/26/24	0300	66	PRICE
	0600	66	D.Montoya
	0900	66	D.Montoya
	1200	66	D.Montoya
	1500	67	L.Diaz
	1800	66	L.Diaz
	2100	66	L.Diaz
	2400	65	C.Ramirez

Sunday

Date	Time	Temp.	Name (Print)
10/27/24	0300	65	C.Ramirez
	0600	66	D.Montoya
	0900	66	D.Montoya
	1200	66	D.Montoya
	1500	65	GRAYSON
	1800	65	GRAYSON
	2100	65	GRAYSON
	2400	64	Reyes Gomez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB5 Temp. Reading Location: 2ND Tier 'A' sec
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10	0300	65	D. Pena
.	0600	65	Pompa
	0900	65	Pompa
21	1200	65	Pompa
.	1500	68	GRAYSON
	1800	68	GRAYSON
24	2100	68	GRAYSON
	2400	66	D. Pena

Tuesday

Date	Time	Temp.	Name (Print)
10	0300	65	D. Pena
.	0600	65	Pompa
	0900	65	Pompa
22	1200	65	Pompa
.	1500	68	GRAYSON
	1800	68	GRAYSON
24	2100	68	GRAYSON
	2400	66	D. Pena

Wednesday

Date	Time	Temp.	Name (Print)
10	0300	65	D. Pena
.	0600	64	J. SCHULTZ
	0900	66°	J. SCHULTZ
23	1200	67°	J. SCHULTZ
.	1500	68	G. Rios
	1800	68	G. Rios
24	2100	67	G. Rios
	2400	67	D. Pena

Thursday

Date	Time	Temp.	Name (Print)
10	0300	66	D. Pena
.	0600	64°	J. SCHULTZ
	0900	66°	J. SCHULTZ
24	1200	67°	J. SCHULTZ
.	1500	67	G. Rios
	1800	67	G. Rios
24	2100	67	G. Rios
	2400	66	Revelo

Friday

Date	Time	Temp.	Name (Print)
10	0300	65	Revelo
.	0600	64°	J. SCHULTZ
	0900	66°	J. SCHULTZ
25	1200	68°	J. SCHULTZ
.	1500	68	G. Rios
	1800	68	G. Rios
24	2100	68	G. Rios
	2400	66	C. Ramiscal

Saturday

Date	Time	Temp.	Name (Print)
10	0300	65°	C. Ramiscal
.	0600	64°	J. SCHULTZ
	0900	65°	J. SCHULTZ
26	1200	68°	J. SCHULTZ
.	1500	67	Gill
	1800	67	Gill
24	2100	67	Gill
	2400	65	D Hu

Sunday

Date	Time	Temp.	Name (Print)
10	0300	64	D. Hu
.	0600	65°	J. SCHULTZ
	0900	65°	J. SCHULTZ
27	1200	66°	J. SCHULTZ
.	1500	67	Gill
	1800	67	Gill
24	2100	67	Gill
	2400	67	Cancer

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB5 Temp. Reading Location: 2ND Tier 'B' Sec
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10	0300	65	A. Pendon
	0600	65	Pungu
	0900	66	Pungu
21	1200	66	Pungu
	1500	68	GRAYSON
	1800	68	GRAYSON
24	2100	68	GRAYSON
	2400	66	A. Pendon

Tuesday

Date	Time	Temp.	Name (Print)
10	0300	65	A. Pendon
	0600	65	Pungu
	0900	66	Pungu
22	1200	67	Pungu
	1500	68	GRAYSON
	1800	68	GRAYSON
24	2100	68	GRAYSON
	2400	66	A. Pendon

Wednesday

Date	Time	Temp.	Name (Print)
10	0300	65	A. Pendon
	0600	64°	J. SCHAUTZ
	0900	66°	J. SCHAUTZ
23	1200	67°	J. SCHAUTZ
	1500	68	G. Rios
	1800	68	G. Rios
24	2100	67	G. Rios
	2400	67	A. Pendon

Thursday

Date	Time	Temp.	Name (Print)
10	0300	66	A. Pendon
	0600	64°	J. SCHAUTZ
	0900	66°	J. SCHAUTZ
24	1200	67°	J. SCHAUTZ
	1500	67	G. Rios
	1800	67	G. Rios
24	2100	67	G. Rios
	2400	66	Revelos

Friday

Date	Time	Temp.	Name (Print)
10	0300	65	Revelos
	0600	64°	J. SCHAUTZ
	0900	66°	J. SCHAUTZ
25	1200	68°	J. SCHAUTZ
	1500	68	G. Rios
	1800	68	G. Rios
24	2100	68	G. Rios
	2400	66	C. Ramirez

Saturday

Date	Time	Temp.	Name (Print)
10	0300	65	C. Ramirez
	0600	64°	J. SCHAUTZ
	0900	65°	J. SCHAUTZ
26	1200	66°	J. SCHAUTZ
	1500	67	Gill
	1800	67	Gill
24	2100	67	Gill
	2400	65	Hill

Sunday

Date	Time	Temp.	Name (Print)
10	0300	65	Hill
	0600	66°	J. SCHAUTZ
	0900	65°	J. SCHAUTZ
27	1200	66°	J. SCHAUTZ
	1500	67	Gill
	1800	67	Gill
24	2100	67	Gill
	2400	67	CORREA

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITA

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 1 A or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday 10-21-24

Date	Time	Temp.	Name (Print)
10-21-24	0300	70	Mijd
	0600	72	GALLEGOS
	0900	72	GALLEGOS
	1200	72	GALLEGOS
	1500	72	J SOTO
	1800	71	J SOTO
	2100	71	J SOTO
	2400	70	R MATA

Tuesday

Date	Time	Temp.	Name (Print)
10-22-24	0300	70	R MATA
	0600	70	R Ramirez
	0900	70	R Ramirez
	1200	72	R Ramirez
	1500	73	J Soto
	1800	72	J Soto
	2100	70	J Soto
	2400	70	R MATA

Wednesday

Date	Time	Temp.	Name (Print)
10-23-24	0300	69	R MATA
	0600	70	R Ramirez
	0900	70	R Ramirez
	1200	72	R Ramirez
	1500	72	J Soto
	1800	71	J Soto
	2100	71	J Soto
	2400	71	R MATA

Thursday

Date	Time	Temp.	Name (Print)
10-24-24	0300	70	R MATA
	0600	72	R Ramirez
	0900	72	R Ramirez
	1200	75	R Ramirez
	1500	74	J Soto
	1800	73	J Soto
	2100	71	J Soto
	2400	70	J. Cisneros

Friday

Date	Time	Temp.	Name (Print)
10-25-24	0300	70	J. Cisneros
	0600	70	R Ramirez
	0900	70	R Ramirez
	1200	72	R Ramirez
	1500	70°	Morgan J
	1800	72	[illegible]
	2100	72	Morgan
	2400	71	J. Cisneros

Saturday

Date	Time	Temp.	Name (Print)
10-26-24	0300	70	J. Cisneros
	0600	70	SHALL
	0900	71	SHALL
	1200	72	SHALL
	1500	72	F. Garcia
	1800	70°	F Garcia
	2100	72	F Garcia
	2400	70	R MATA

Sunday

Date	Time	Temp.	Name (Print)
10-27-24	0300	70°	R MATA
	0600	70°	SHALL
	0900	70°	SHALL
	1200	72	SHALL
	1500	72	LOGAN
	1800	72	LOGAN
	2100	70	LOGAN
	2400	69	R MATA

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITA

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 1 A or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-21-24	0300	70	Mejia
	0600	72	GALLEGOS
	0900	72	GALLEGOS
	1200	72	GALLEGOS
	1500	72	J Soto
	1800	71	J Soto
	2100	71	J Soto
	2400	71	RMATZ

Tuesday

Date	Time	Temp.	Name (Print)
10-22-24	0300	71	RMATZ
	0600	70	R Ramirez
	0900	70	R Ramirez
	1200	72	R. Ramirez
	1500	73	J Soto
	1800	72	J Soto
	2100	72	J Soto
	2400	70	RMATZ

Wednesday

Date	Time	Temp.	Name (Print)
10-23-24	0300	70	RMATZ
	0600	70	R Ramirez
	0900	70	R Ramirez
	1200	72	R Ramirez
	1500	72	J Soto
	1800	72	J Soto
	2100	71	J Soto
	2400	70	RMATZ

Thursday

Date	Time	Temp.	Name (Print)
10-24	0300	70	RMATZ
	0600	70	R Ramirez
	0900	70	R Ramirez
	1200	72	R Ramirez
	1500	73	J Soto
	1800	73	J Soto
	2100	72	J Soto
	2400	70	J. Cisneros

Friday

Date	Time	Temp.	Name (Print)
10-25-24	0300	70	J. Cisneros
	0600	70	R. Ramirez
	0900	70	R. Ramirez
	1200	72	R. Ramirez
	1500	72°	[illegible]
	1800	72°	[illegible]
	2100	72°	[illegible]
	2400	71	J. Cisneros

Saturday

Date	Time	Temp.	Name (Print)
10-26-24	0300	70	J-Cisneros
	0600	70	SMALL
	0900	71	SMALL
	1200	72	SMALL
	1500	73	FGarcia
	1800	73	FGarcia
	2100	72	FGarcia
	2400	70	RMATZ

Sunday

Date	Time	Temp.	Name (Print)
10-27-24	0300	69°	RMATZ
	0600	70	Small
	0900	71	Small
	1200	73	Small
	1500	72	LOGAN
	1800	72	LOGAN
	2100	70	LOGAN
	2400	70	RMATZ

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITA

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD #2A (A or B) Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21/24	0300	68	N. Rodriguez
	0600	68	N. Rodriguez
	0900	70	A. Ortiz
	1200	70	A. Ortiz
	1500	76	R. SALAZAR
	1800	77	R. SALAZAR
	2100	76	R. SALAZAR
	2400	70	N. Rodriguez

Tuesday

Date	Time	Temp.	Name (Print)
10-22-24	0300	69	N. Rodriguez
	0600	68	N. Rodriguez
	0900	70	A. Ortiz
	1200	71	A. Ortiz
	1500	76	R. SALAZAR
	1800	77	R. SALAZAR
	2100	76	R. SALAZAR
	2400	75	Earnest

Wednesday

Date	Time	Temp.	Name (Print)
10-23-24	0300	75	Earnest
	0600	71	Ortiz
	0900	72	Ortiz
	1200	73	Ortiz
	1500	76	R. SALAZAR
	1800	77	R. SALAZAR
	2100	76	R. SALAZAR
	2400	75	Earnest

Thursday

Date	Time	Temp.	Name (Print)
10-24-24	0300	75	Earnest
	0600	75	Ortiz
	0900	75	Ortiz
	1200	75	Ortiz
	1500	76	R. SALAZAR
	1800	77	R. SALAZAR
	2100	76	R. SALAZAR
	2400	76	Earnest

Friday

Date	Time	Temp.	Name (Print)
10-25-24	0300	75	Earnest
	0600	74	Ortiz
	0900	74	Ortiz
	1200	74	Ortiz
	1500	74	PASUMBAL
	1800	75	PASUMBAL
	2100	74	PASUMBAL
	2400	74	Earnest

Saturday

Date	Time	Temp.	Name (Print)
10-26-24	0300	74	Earnest
	0600	74	Ortiz
	0900	74	Ortiz
	1200	74	Ortiz
	1500	74	PASUMBAL
	1800	74	PASUMBAL
	2100	74	PASUMBAL
	2400	74	Earnest

Sunday

Date	Time	Temp.	Name (Print)
10-27-24	0300	74	Earnest
	0600	74	Ortiz
	0900	74	Ortiz
	1200	74	Ortiz
	1500	76	R. SALAZAR
	1800	76	R. SALAZAR
	2100	76	R. SALAZAR
	2400	76	G. Linares

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITA

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD #2B A or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21/24	0300	68	N. Rodriguez
	0600	68	N. Rodriguez
	0900	71	G. Ortiz
	1200	71	G. Ortiz
	1500	76	R. SALAZAR
	1800	77	R. SALAZAR
	2100	76	R. SALAZAR
	2400	70	N. Rodriguez

Tuesday

Date	Time	Temp.	Name (Print)
10-22-24	0300	69	N. Rodriguez
	0600	68	N. Rodriguez
	0900	71	G. Ortiz
	1200	71	G. Ortiz
	1500	76	R. SALAZAR
	1800	77	R. SALAZAR
	2100	76	R. SALAZAR
	2400	75	Earnest

Wednesday

Date	Time	Temp.	Name (Print)
10-23-24	0300	74	Earnest
	0600	74	Ortiz
	0900	74	Ortiz
	1200	74	Ortiz
	1500	76	R. SALAZAR
	1800	77	R. SALAZAR
	2100	76	R. SALAZAR
	2400	75	Earnest

Thursday

Date	Time	Temp.	Name (Print)
10-24-24	0300	74	Earnest
	0600	74	Ortiz
	0900	74	Ortiz
	1200	75	Ortiz
	1500	76	R. SALAZAR
	1800	77	R. SALAZAR
	2100	76	R. SALAZAR
	2400	75	Earnest

Friday

Date	Time	Temp.	Name (Print)
10-25-24	0300	74	Earnest
	0600	74	Ortiz
	0900	74	Ortiz
	1200	74	Ortiz
	1500	74	PASUMBAL
	1800	75	PASUMBAL
	2100	74	PASUMBAL
	2400	74	Earnest

Saturday

Date	Time	Temp.	Name (Print)
10-26-24	0300	74	Earnest
	0600	74	Ortiz
	0900	74	Ortiz
	1200	74	Ortiz
	1500	74	PASUMBAL
	1800	74	PASUMBAL
	2100	74	PASUMBAL
	2400	74	Earnest

Sunday

Date	Time	Temp.	Name (Print)
10-27-24	0300	74	Earnest
	0600	74	Ortiz
	0900	74	Ortiz
	1200	74	Ortiz
	1500	76	R. SALAZAR
	1800	76	R. SALAZAR
	2100	76	R. SALAZAR
	2400	74	G. Lunapes

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITA

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 3 A or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21/24	0300	68	LOGAN
	0600	68	King
	0900	70	King
	1200	70	King
	1500	69	H. Martinez
	1800	69	H. Martinez
	2100	68	H. Martinez
	2400	69	Z. Green

Tuesday

Date	Time	Temp.	Name (Print)
10/22/24	0300	68	Z. Green
	0600	64	APEREZ
	0900	64	APEREZ
	1200	64	APEREZ
	1500	70	PASUMBAL
	1800	71	PASUMBAL
	2100	70	PASUMBAL
	2400	68	Z. Green

Wednesday

Date	Time	Temp.	Name (Print)
10/23/24	0300	66	Z. Green
	0600	65	APEREZ
	0900	65	APEREZ
	1200	65	APEREZ
	1500	68	CAMPOS
	1800	68	CAMPOS
	2100	68	CAMPOS
	2400	68	R. Cisneros

Thursday

Date	Time	Temp.	Name (Print)
10-24-24	0300	67	R. Cisneros
	0600	66	APEREZ
	0900	66	APEREZ
	1200	66	APEREZ
	1500	66	H. Martinez
	1800	67	H. Martinez
	2100	66	H. Martinez
	2400	66	R. Cisneros

Friday

Date	Time	Temp.	Name (Print)
10-25-24	0300	66	R. Cisneros
	0600	64	APEREZ
	0900	64	APEREZ
	1200	64	G. APEREZ
	1500	65	G. Martinez
	1800	67	G. Martinez
	2100	68	G. Martinez
	2400	70	R. Cisneros

Saturday

Date	Time	Temp.	Name (Print)
10-26-24	0300	69	R. Cisneros
	0600	62	APEREZ
	0900	62	APEREZ
	1200	60	APEREZ
	1500	67	Hughes
	1800	67	Hughes
	2100	67	Hughes
	2400	62	LOGAN

Sunday

Date	Time	Temp.	Name (Print)
10/27/24	0300	67	LOGAN
	0600	62	King
	0900	68	King
	1200	70	King
	1500	70	B. PRECIADO
	1800	70	B. PRECIADO
	2100	69	B. PRECIADO
	2400	69	Logan

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITA

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 3 A or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21/24	0300	68	Logan
	0600	68	King
	0900	70	King
	1200	70	King
	1500	69	H. [illegible]
	1800	69	H. [illegible]
	2100	69	[illegible]
	2400	68	Z. Green

Tuesday

Date	Time	Temp.	Name (Print)
10/22/24	0300	68	Z. Green
	0600	64	APerez
	0900	64	APerez
	1200	64	A Perez
	1500	70	PASUMBAL
	1800	71	PASUMBAL
	2100	70	PASUMBAL
	2400	68	Z. Green

Wednesday

Date	Time	Temp.	Name (Print)
10/23/24	0300	67	Z. Green
	0600	64	APerez
	0900	64	APerez
	1200	64	APerez
	1500	68	Campos
	1800	68	Campos
	2100	68	Campos
	2400	68	R. Cisneros

Thursday

Date	Time	Temp.	Name (Print)
10-24-24	0300	67	R. Cisneros
	0600	65	APerez
	0900	65	APerez
	1200	65	APerez
	1500	67	H. Marmon
	1800	67	H. Marmon
	2100	67	H. Marmon
	2400	67	R. Cisneros

Friday

Date	Time	Temp.	Name (Print)
10-25-24	0300	66	R. Cisneros
	0600	64	APerez
	0900	64	APerez
	1200	64	APerez
	1500	65	G. Martinez
	1800	67	G. Martinez
	2100	67	G. Martinez
	2400	70	R. Cisneros

Saturday

Date	Time	Temp.	Name (Print)
10-26-24	0300	69	R. Cisneros
	0600	62	APerez
	0900	62	APerez
	1200	62	APerez
	1500	62	S. Hughes
	1800	62	S. Hughes
	2100	62	S. Hughes
	2400	62	Logan

Sunday

Date	Time	Temp.	Name (Print)
10/27/24	0300	62	Logan
	0600	62	King
	0900	68	King
	1200	70	King
	1500	70	B. Preciado
	1800	70	B. Preciado
	2100	69	B. Preciado
	2400	24	Logan

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITA

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # A (A or B) Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-21-24	0300	70	P. Cerda
	0600	70	J. Hernandez
	0900	70	J. Hernandez
	1200	70	J. Hernandez
	1500	71	PASUMBAL
	1800	72	PASUMBAL
	2100	72	PASUMBAL
	2400	70	LOGAN

Tuesday

Date	Time	Temp.	Name (Print)
10-22-24	0300	70	LOGAN
	0600	70	J. Hernandez
	0900	70	J. Hernandez
	1200	70	J. Hernandez
	1500	72	SOLORIO
	1800	72	SOLORIO
	2100	72	SOLORIO
	2400	68	N. Rodriguez

Wednesday

Date	Time	Temp.	Name (Print)
10-23-24	0300	68	N. Rodriguez
	0600	68	J. Hernandez
	0900	68	J. Hernandez
	1200	69	J. Hernandez
	1500	70	SOLORIO
	1800	70	SOLORIO
	2100	70	SOLORIO
	2400	68	P. Cerda

Thursday

Date	Time	Temp.	Name (Print)
10-24-24	0300	68	P. Cerda
	0600	69	J. Hernandez
	0900	68	J. Hernandez
	1200	69	J. Hernandez
	1500	70	SOLORIO
	1800	70	SOLORIO
	2100	70	SOLORIO
	2400	68	P. Cerda

Friday

Date	Time	Temp.	Name (Print)
10-25-24	0300	68	P. Cerda
	0600	68	King
	0900	68	King
	1200	70	King
	1500	70	Lage
	1800	70	Lage
	2100	70	Lage
	2400	68	P. Cerda

Saturday

Date	Time	Temp.	Name (Print)
10-26-24	0300	68	P. Cerda
	0600	68	King
	0900	70	King
	1200	70	King
	1500	70	Guzman
	1800	69	Guzman
	2100	69	Guzman
	2400	68	P. Cerda

Sunday

Date	Time	Temp.	Name (Print)
10-27-24	0300	68	P. Cerda
	0600	68	PASUMBAL
	0900	68	PASUMBAL
	1200	68	PASUMBAL
	1500	68	PASUMBAL
	1800	68	PASUMBAL
	2100	68	PASUMBAL
	2400	68	P. Cerda

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITA

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # B A or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-21-24	0300	70	Picerda
	0600	70	J. Hernandez
	0900	70	J. Hernandez
	1200	70	J. Hernandez
	1500	71	PASUMBAL
	1800	72	PASUMBAL
	2100	72	PASUMBAL
	2400	70	LOGAN

Tuesday

Date	Time	Temp.	Name (Print)
10-22-24	0300	70	LOGAN
	0600	70	J. Hernandez
	0900	70	J. Hernandez
	1200	70	J. Hernandez
	1500	70	SOLORIO
	1800	70	SOLORIO
	2100	70	SOLORIO
	2400	68	N. Rodriguez

Wednesday

Date	Time	Temp.	Name (Print)
10-23-24	0300	68	N. Rodriguez
	0600	69	J. Hernandez
	0900	69	J. Hernandez
	1200	69	J. Hernandez
	1500	70	SOLORIO
	1800	72	SOLORIO
	2100	72	SOLORIO
	2400	68	Picerda

Thursday

Date	Time	Temp.	Name (Print)
10-24-24	0300	68	Picerda
	0600	69	J. Hernandez
	0900	68	J. Hernandez
	1200	69	J. Hernandez
	1500	72	SOLORIO
	1800	72	SOLORIO
	2100	72	SOLORIO
	2400	68	Picerda

Friday

Date	Time	Temp.	Name (Print)
10-25-24	0300	68	Picerda
	0600	68	King
	0900	68	King
	1200	70	King
	1500	71	GAGE
	1800	70	GAGE
	2100	70	GAGE
	2400	70	Picerda

Saturday

Date	Time	Temp.	Name (Print)
10-26-24	0300	68	Picerda
	0600	68	King
	0900	70	King
	1200	70	King
	1500	70	[illegible]
	1800	07	[illegible]
	2100	6[illegible]	[illegible]
	2400	68	Picerda

Sunday

Date	Time	Temp.	Name (Print)
10-27-24	0300	68	Picerda
	0600	68	PASUMBAL
	0900	68	PASUMBAL
	1200	68	PASUMBAL
	1500	68	PASUMBAL
	1800	68	PASUMBAL
	2100	68	PASUMBAL
	2400	68	Picerda

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITA

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 3 (A or B) Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21/24	0300	64	[illegible]
	0600	66	[illegible]
	0900	60	[illegible]
	1200	60	[illegible]
	1500	71	J. ortega
	1800	71	J. ortega
	2100	70	J. ortega
	2400	69	[illegible]

Tuesday

Date	Time	Temp.	Name (Print)
10/22/24	0300	69	[illegible]
	0600	69	[illegible]
	0900	69	[illegible]
	1200	64	[illegible]
	1500	72	Ovejar
	1800	72	Ovejar
	2100	70	O. Vejar
	2400	69	[illegible]

Wednesday

Date	Time	Temp.	Name (Print)
10/23/24	0300	64	[illegible]
	0600	69	E. CRUZ
	0900	72	[illegible]
	1200	[illegible]	[illegible]
	1500	72	Ovejar
	1800	72	O. Vejar
	2100	70	O. Vejar
	2400	69	[illegible]

Thursday

Date	Time	Temp.	Name (Print)
10/24/23	0300	76	[illegible]
	0600	77	E. CRUZ
	0900	75	[illegible]
	1200	75	[illegible]
	1500	73	O. Vejar / Ceccampos
	1800	73	Ceccampos
	2100	73	Ceccampos
	2400	69	LOGAN

Friday

Date	Time	Temp.	Name (Print)
10/25/24	0300	69	LOGAN
	0600	69	E. CRUZ
	0900	74	E. CRUZ
	1200	74	E. CRUZ
	1500	72	Ceccampos
	1800	72	Ceccampos
	2100	72	Ceccampos
	2400	60	Ceccampos

Saturday

Date	Time	Temp.	Name (Print)
10/26/27	0300	60	Ceccampos
	0600	69	[illegible]
	0900	69	[illegible]
	1200	74	E. CRUZ
	1500	74	[illegible]
	1800	70	[illegible]
	2100	70	[illegible]
	2400	62	[illegible]

Sunday

Date	Time	Temp.	Name (Print)
10/27/24	0300	67	[illegible]
	0600	68	E. CRUZ
	0900	75	E. CRUZ
	1200	75	E. CRUZ
	1500	60	[illegible]
	1800	68	[illegible]
	2100	68	E. CRUZ
	2400	66	[illegible]

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITA

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 5 A or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21/24	0300	69	[illegible]
	0600	69	[illegible]
	0900	69	[illegible]
	1200	69	[illegible]
	1500	72	J. Ortega
	1800	71	J. Ortega
	2100	70	J. Ortega
	2400	69	[illegible]

Tuesday

Date	Time	Temp.	Name (Print)
10/22/29	0300	69	[illegible]
	0600	69	[illegible]
	0900	69	[illegible]
	1200	69	[illegible]
	1500	72	O. Vejar
	1800	72	O. Vejar
	2100	70	O. Vejar
	2400	69	[illegible]

Wednesday

Date	Time	Temp.	Name (Print)
10/23/22	0300	69	[illegible]
	0600	69	E. Cruz
	0900	72	[illegible]
	1200	72	[illegible]
	1500	72	O. Vejar
	1800	72	O. Vejar
	2100	70	O. Vejar
	2400	69	[illegible]

Thursday

Date	Time	Temp.	Name (Print)
10/24/23	0300	69	[illegible]
	0600	69	E. Cruz
	0900	74	E. Cruz
	1200	74	E. Cruz
	1500	73	G. Campos
	1800	73	G. Campos
	2100	73	G. Campos
	2400	69	Logan

Friday

Date	Time	Temp.	Name (Print)
10/25/24	0300	69	Logan
	0600	69	E. Cruz
	0900	75	E. Cruz
	1200	75	E. Cruz
	1500	72	G. Campos
	1800	72	G. Campos
	2100	72	G. Campos
	2400	68	G. Campos

Saturday

Date	Time	Temp.	Name (Print)
10/26/24	0300	68	G. Campos
	0600	69	E. Cruz
	0900	72	E. Cruz
	1200	72	E. Cruz
	1500	69	Lara
	1800	69	Lara
	2100	69	Lara
	2400	67	[illegible]

Sunday

Date	Time	Temp.	Name (Print)
10/27/29	0300	67	[illegible]
	0600	69	[illegible]
	0900	74	E. Cruz
	1200	74	E. Cruz
	1500	76	Rodriguez
	1800	76	Rodriguez
	2100	70	Rodriguez
	2400	70	[illegible]

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B6 Temp. Reading Location: A POD
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21/24	0300	70	M. Romero
	0600	71	Lopez
	0900	71	Lopez
	1200	72	Lopez
	1500	74	J. Navarro
	1800	74	J. Navarro
	2100	74	J. Navarro
	2400	72	D Sis

Tuesday

Date	Time	Temp.	Name (Print)
10.22.24	0300	71	D Sis
	0600	71	Lopez
	0900	71	Lopez
	1200	71	Lopez
	1500	72	Rains
	1800	72	Rains
	2100	70	Rains
	2400	70	D Sis

Wednesday

Date	Time	Temp.	Name (Print)
10.23.24	0300	72	D Sis
	0600	71	Lopez
	0900	71	Lopez
	1200	71	Lopez
	1500	72	Rains
	1800	72	Rains
	2100	70	Rains
	2400	70	M. Romero

Thursday

Date	Time	Temp.	Name (Print)
10.24.24	0300	70	M. Romero
	0600	70	Lopez
	0900	72	Lopez
	1200	74	Lopez
	1500	74	Y. Contreras
	1800	75	Y. Contreras
	2100	74	Y. Contreras
	2400	71	M. Romero

Friday

Date	Time	Temp.	Name (Print)
10.25.24	0300	70	M. Romero
	0600	70	F. Wynn Murcia
	0900	70	F. Wynn Murcia
	1200	71	F. Wynn Murcia
	1500	73	Y. Contreras
	1800	74	Y. Contreras
	2100	73	Y. Contreras
	2400	72	M. Romero

Saturday

Date	Time	Temp.	Name (Print)
10.26.24	0300	70	M. Romero
	0600	70	[illegible]
	0900	70	[illegible]
	1200	71	[illegible]
	1500	73	Y. Contreras
	1800	73	Y. Contreras
	2100	72	Y. Contreras
	2400	70	M. Romero

Sunday

Date	Time	Temp.	Name (Print)
10.27.24	0300	70	M. Romero
	0600	69	[illegible]
	0900	70	[illegible]
	1200	71	[illegible]
	1500	71	J. Navarro
	1800	70	J. Navarro
	2100	70	J. Navarro
	2400	68	D. Ross

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B6 Temp. Reading Location: B Pod
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 8141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21/24	0300	70	M. Romero
	0600	71	Lopez
	0900	71	Lopez
	1200	72	Lopez
	1500	74	J. Navarro
	1800	74	J. Navarro
	2100	74	J. Navarro
	2400	72	D. SLS

Tuesday

Date	Time	Temp.	Name (Print)
10-22-24	0300	71	D. SLS
	0600	71	Lopez
	0900	72	Lopez
	1200	72	Lopez
	1500	72	Rains
	1800	72	Rains
	2100	70	Rains
	2400	70	D SLS

Wednesday

Date	Time	Temp.	Name (Print)
10-23-24	0300	70	D. SLS
	0600	71	Lopez
	0900	71	Lopez
	1200	71	Lopez
	1500	72	Rains
	1800	72	Rains
	2100	70	Rains
	2400	70	M. Romero

Thursday

Date	Time	Temp.	Name (Print)
10-24-24	0300	70	M. Romero
	0600	71	Lopez
	0900	74	Lopez
	1200	74	Lopez
	1500	75	Y. Carrasco
	1800	75	Y. Carrasco
	2100	74	Y. Carrasco
	2400	71	M. Romero

Friday

Date	Time	Temp.	Name (Print)
10-25-24	0300	70	M. Romero
	0600	70	[illegible]
	0900	70	[illegible]
	1200	71	[illegible]
	1500	72	Y. Carrasco
	1800	73	Y. Carrasco
	2100	72	Y. Carrasco
	2400	71	M. Romero

Saturday

Date	Time	Temp.	Name (Print)
10-26-24	0300	70	M. Romero
	0600	70	[illegible]
	0900	70	[illegible]
	1200	71	[illegible]
	1500	73	Y. Carrasco
	1800	73	Y. Carrasco
	2100	72	Y. Carrasco
	2400	70	M. Romero

Sunday

Date	Time	Temp.	Name (Print)
10-27-24	0300	70	M. Romero
	0600	69	[illegible]
	0900	70	[illegible]
	1200	71.0	[illegible]
	1500	71	J. Navarro
	1800	70	J. Navarro
	2100	69	J. Navarro
	2400	68	B. ROSS

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATI

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NCSP Housing Unit: 12A Temp. Reading Location: Day Room Above T.V.
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21/24	0300	72°	Pennul
	0600	72	McIntosh
	0900	72	McIntosh
	1200	72	McIntosh
	1500	70	M. Franklin
	1800	70	M. Franklin
	2100	70	M. Franklin
	2400	70	L. Moore

Tuesday

Date	Time	Temp.	Name (Print)
10/22/24	0300	70	L. Moore
	0600	70	McIntosh
	0900	70	McIntosh
	1200	71	McIntosh
	1500	71	M. Serrato
	1800	71	M. Serrato
	2100	71	M. Serrato
	2400	70	Ellison

Wednesday

Date	Time	Temp.	Name (Print)
10/23/24	0300	70	Ellison
	0600	70	McIntosh
	0900	71	McIntosh
	1200	71	McIntosh
	1500	71	M. Serrato
	1800	71	M. Serrato
	2100	71	M. Serrato
	2400	70	Ellison

Thursday

Date	Time	Temp.	Name (Print)
10/24/24	0300	70	Ellison
	0600	70	McIntosh
	0900	71	McIntosh
	1200	71	McIntosh
	1500	70	Ellison
	1800	70	Ellison
	2100	70	Ellison
	2400	70	Ellison

Friday

Date	Time	Temp.	Name (Print)
10/25/24	0300	70	Ellison
	0600	70	McIntosh
	0900	71	McIntosh
	1200	70	Riley
	1500	70	Riley
	1800	71	Riley
	2100	71	Riley
	2400	70	Ellison

Saturday

Date	Time	Temp.	Name (Print)
10/26/24	0300	70	Ellison
	0600	70	T. Delos Santos
	0900	72	T. Delos Santos
	1200	76	T. Delos Santos
	1500	70	D. ESTRADA
	1800	70	D. ESTRADA
	2100	70	D. ESTRADA
	2400	70	D. ESTRADA

Sunday

Date	Time	Temp.	Name (Print)
10/27/24	0300	70	Ellison
	0600	70	Gutierrez
	0900	70	Gutierrez
	1200	72	Gutierrez
	1500	72	M. Franklin
	1800	70	M. Franklin
	2100	70	M. Franklin
	2400	70	Pennul

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C2 B5 D6 Temp. Reading Location: 2nd TIER
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-21-24	0300	74	L. Montes
	0600	74°	A. Casillas
	0900	75°	A. Casillas
	1200	75°	A. Casillas
	1500	73	D. Alvarado
	1800	74	D. Alvarado
	2100	74	D. Alvarado
	2400	74	A. Walter

Tuesday

Date	Time	Temp.	Name (Print)
10/22/24	0300	74	A. Walter
	0600	74°	A. Casillas
	0900	74°	A. Casillas
	1200	74°	A. Casillas
	1500	75	A. Walter
	1800	75	A. Walter
	2100	74	A. Walter
	2400	74	A. Walter

Wednesday

Date	Time	Temp.	Name (Print)
10-23-24	0300	74	A. Walter
	0600	74	A. Anaya
	0900	75	A. Anaya
	1200	75	A. Anaya
	1500	74	Riley
	1800	74	Riley
	2100	74	Riley
	2400	74	A. Walter

Thursday

Date	Time	Temp.	Name (Print)
10/24/24	0300	74	A. Walter
	0600	74	R. Anaya
	0900	75	R. Anaya
	1200	75	R. Anaya
	1500	75	Cotton
	1800	75	Cotton
	2100	74	Cotton
	2400	74	A. Walter

Friday

Date	Time	Temp.	Name (Print)
10/25/24	0300	73	Cotton
	0600	73°	A. Casillas
	0900	73	A. Casillas
	1200	74°	A. Casillas
	1500	75	Cotton
	1800	75	Cotton
	2100	74	Cotton
	2400	73	Cotton

Saturday

Date	Time	Temp.	Name (Print)
10/26/24	0300	73	A. Martinez
	0600	73°	A. Casillas
	0900	73°	A. Casillas
	1200	74°	A. Casillas
	1500	74°	Chavez
	1800	74°	Chavez
	2100	73°	Chavez
	2400	73	A. Martinez

Sunday

Date	Time	Temp.	Name (Print)
10/27/24	0300	71	L. Montes
	0600	72°	A. Casillas
	0900	72°	A. Casillas
	1200	72°	A. Casillas
	1500	72	D. Alvarado
	1800	72	D. Alvarado
	2100	71	D. Alvarado
	2400	70	L. Montes

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C 3A SDCC Temp. Reading Location: 2nd TIER
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension *3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-21-24	0300	78	CANACHO
	0600	78	TORRES
	0900	78	TORRES
	1200	78	TORRES
	1500	79	Green
	1800	79	Green
	2100	79	Green
	2400	79	CANACHO

Tuesday

Date	Time	Temp.	Name (Print)
10-22-24	0300	75	CANACHO
	0600	70	M. Run
	0900	70	M. Run
	1200	70	M. Run
	1500	71	A. SUAREZ
	1800	71	A. SUAREZ
	2100	71	A. SUAREZ
	2400	73	CANACHO

Wednesday

Date	Time	Temp.	Name (Print)
10-23-24	0300	71	CANACHO
	0600	70	M. Run
	0900	70	M. Run
	1200	70	M. Run
	1500	71	A. SUAREZ
	1800	71	A. SUAREZ
	2100	71	A. SUAREZ
	2400	71	CANACHO

Thursday

Date	Time	Temp.	Name (Print)
10-24-25	0300	71	CANACHO
	0600	69	M. Run
	0900	70	M. Run
	1200	70	M. Run
	1500	71	A. SUAREZ
	1800	71	A. SUAREZ
	2100	71	A. SUAREZ
	2400	70	L. Montes

Friday

Date	Time	Temp.	Name (Print)
10-25-24	0300	70	L. Montes
	0600	70	M. Run
	0900	70	M. Run
	1200	71	M. Run
	1500	71	A. Suarez
	1800	72	A. Suarez
	2100	71	A. Suarez
	2400	71	L. Montes

Saturday

Date	Time	Temp.	Name (Print)
10-26-24	0300	70	L. Montes
	0600	70	L. Torres
	0900	70	TORRES
	1200	70	TORRES
	1500	70	D. ALVARADO
	1800	70	M. Yang
	2100	70	M. Yang
	2400	70	CANACHO

Sunday

Date	Time	Temp.	Name (Print)
10-27-24	0300	70	CANACHO
	0600	70	D. ESTRADA
	0900	70	D. ESTRADA
	1200	70	D. ESTRADA
	1500	71	Riley
	1800	70	Riley
	2100	70	Riley
	2400	70	CANACHO

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C3B Temp. Reading Location: Tier 2, Above TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21/24	0300	70	ETORRES
	0600	70	D.Valencia
	0900	70	D.Valencia
	1200	70	D.Valencia
	1500	72	JACOSTA
	1800	72	JACOSTA
	2100	72	JACOSTA
	2400	72	ETORRES

Tuesday

Date	Time	Temp.	Name (Print)
10/22/24	0300	70	E.TORRES
	0600	70	D.Valencia
	0900	70	D.Valencia
	1200	70	D.Valencia
	1500	70	JACOSTA
	1800	70	JACOSTA
	2100	70	JACOSTA
	2400	70°	ETORRES

Wednesday

Date	Time	Temp.	Name (Print)
10/23/24	0300	70	ETORRES
	0600	70	D.Valencia
	0900	70	D.Valencia
	1200	70	D.Valencia
	1500	70	JACOSTA
	1800	70	JACOSTA
	2100	69	JACOSTA
	2400	68	ETORRES

Thursday

Date	Time	Temp.	Name (Print)
10/24/24	0300	68	ETORRES
	0600	68	J. JONES
	0900	69	J. JONES
	1200	70	J. JONES
	1500	73	R Aguilar
	1800	73	R Aguilar
	2100	72	R. Aguilar
	2400	70	ETORRES

Friday

Date	Time	Temp.	Name (Print)
10/25/24	0300	68	ETORRES
	0600	69	J. JONES
	0900	69	J. JONES
	1200	69	J. JONES
	1500	71	R-Aguilar
	1800	71	R Aguilar
	2100	70	R. Aguilar
	2400	69	G Ramirez

Saturday

Date	Time	Temp.	Name (Print)
10/26/24	0300	69	G-Ramirez
	0600	70	~~G Ramirez~~ D.Valencia
	0900	70	D.Valencia
	1200	70	D Valencia
	1500	70	M. Franklin
	1800	70	M. Franklin
	2100	70	M. Franklin
	2400	70	C.WITCHER

Sunday

Date	Time	Temp.	Name (Print)
10/27/24	0300	70°	C.W ITCHER
	0600	68	L. TORRES
	0900	68	L. TORRES
	1200	68	L. TORRES
	1500	68	JACOSTA
	1800	68	JACOSTA
	2100	68	JACOSTA
	2400	68	ETORRES

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITATION

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: 3141 Temp. Reading Location: ABOVE TV DAYROOM
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21/24	0300	70°	S. RALL
	0600	70	E. Torres
	0900	71	E. Torres
	1200	71	E. Torres
	1500	73	Vielmas
	1800	72	Vielmas
	2100	71	Vielmas
	2400	72°	S. RALL

Tuesday

Date	Time	Temp.	Name (Print)
10/22/24	0300	70	S. RALL
	0600	68	J. Padilla
	0900	68	J. Padilla
	1200	70	J. Padilla
	1500	75	Vielmas
	1800	74	Vielmas
	2100	73	Vielmas
	2400	72	Martinez

Wednesday

Date	Time	Temp.	Name (Print)
10/23/24	0300	71	Martinez
	0600	70°	Z. Jones
	0900	72°	Z. Jones
	1200	72°	Z. Jones
	1500	75	Vielmas
	1800	74	Vielmas
	2100	73	Vielmas
	2400	72	C. WITCHER

Thursday

Date	Time	Temp.	Name (Print)
10/24/24	0300	72	C. WITCHER
	0600	72	E. Torres
	0900	72	E. Torres
	1200	73	E. Torres
	1500	74	Vielmas
	1800	75	Vielmas
	2100	73	Vielmas
	2400	70	S. Hill

Friday

Date	Time	Temp.	Name (Print)
10/25/24	0300	69	S. Hill
	0600	69	E. Torres
	0900	69	E. Torres
	1200	70	E. Torres
	1500	73	Vielmas
	1800	73	Vielmas
	2100	71	Vielmas
	2400	69	S. Hill

Saturday

Date	Time	Temp.	Name (Print)
10/26/24	0300	68	S. Hill
	0600	69	E. Torres
	0900	68	E. Torres
	1200	69	E. Torres
	1500	70	[illegible]
	1800	70	[illegible]
	2100	70	[illegible]
	2400	69.	S. Hill

Sunday

Date	Time	Temp.	Name (Print)
10/27/24	0300	67	S. Hill
	0600	65	E. Torres
	0900	67	E. Torres
	1200	68	E. Torres
	1500	69	E. Torres
	1800	69	E. Torres
	2100	69	E. Torres
	2400	68°	S. RALL

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITATION

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C4 B Temp. Reading Location: left side of T.V.
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21/24	0300	67	witcher
	0600	67	J. Padilla
	0900	68	J. Padilla
	1200	68	J. Padilla
	1500	68	Tovar
	1800	67	Tovar
	2100	66	Tovar
	2400	66	H-Gill

Tuesday

Date	Time	Temp.	Name (Print)
10/22/24	0300	65	H-Gill
	0600	68	A Herrera
	0900	68	A Herrera
	1200	70	A. Herrera
	1500	71	P. Henry
	1800	71	P. Henry
	2100	72	P. Henry
	2400	70	P. Ranero

Wednesday

Date	Time	Temp.	Name (Print)
10/23/24	0300	68	P. Ranero
	0600	67°	A Herrera
	0900	68°	A Herrera
	1200	68°	A Herrera
	1500	73	R Aguilar
	1800	73	R Aguilar
	2100	72	R Aguilar
	2400	71	P. Ranero

Thursday

Date	Time	Temp.	Name (Print)
10/24/24	0300	69	P. Ranero
	0600	68°	A. Herrera
	0900	68°	A. Herrera
	1200	70°	A. Herrera
	1500	70°	K. MADRIGAL
	1800	70	K. MADRIGAL
	2100	70°	K. MADRIGAL
	2400	68	P. Ranero

Friday

Date	Time	Temp.	Name (Print)
10/25/24	0300	67	P. Ranero
	0600	68	A. Herrera
	0900	69	A. Herrera
	1200	70	A. Herrera
	1500	70	Tovar
	1800	69	Tovar
	2100	69	Tovar
	2400	68	JACQUES

Saturday

Date	Time	Temp.	Name (Print)
10/26/24	0300	68	JACQUES
	0600	69	A. Herrera
	0900	68	A. Herrera
	1200	69	A. Herrera
	1500	69	Tovar
	1800	69	Tovar
	2100	68	Tovar
	2400	68	JACQUES

Sunday

Date	Time	Temp.	Name (Print)
10/27/24	0300	68	JACQUES
	0600	68	J. Padilla
	0900	68	J. Padilla
	1200	68	J. Padilla
	1500	69	Tovar
	1800	68	Tovar
	2100	68	Tovar
	2400	68	C. WITCHER

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. D - 1 (A) Side Temp. Reading Location: Tier 2 - Above Dayroom TV (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21	0300	73	B. COVERT
	0600	73	B. COVERT
	0900	73	B. COVERT
	1200	74	B. COVERT
	1500	74	S. MORENO
	1800	74	S. MORENO
	2100	70	S. MORENO
	2400	70	W. COLBERT

Tuesday

Date	Time	Temp.	Name (Print)
10/22	0300	70	W. COLBERT
	0600	71	B. COVERT
	0900	71	B. COVERT
	1200	71	B. COVERT
	1500	72	J. NIETO
	1800	71	J. NIETO
	2100	71	J. NIETO
	2400	71	W. Colbert

Wednesday

Date	Time	Temp.	Name (Print)
10/23	0300	70	W. Colbert
	0600	70	B. COVERT
	0900	71	B. COVERT
	1200	71	B. COVERT
	1500	71	J. NIETO
	1800	71	J. NIETO
	2100	71	J. NIETO
	2400	71	R. MIRALES

Thursday

Date	Time	Temp.	Name (Print)
10/24	0300	70	R. MIRALES
	0600	71	J. Ramirez
	0900	71	J. Ramirez
	1200	71	J. Ramirez
	1500	72	J. NIETO
	1800	71	J. NIETO
	2100	71	J. NIETO
	2400	70	DeVoto

Friday

Date	Time	Temp.	Name (Print)
10/25	0300	70	DeVoto
	0600	70	B. COVERT
	0900	71	B. COVERT
	1200	71	B. COVERT
	1500	71	J. NIETO
	1800	71	J. NIETO
	2100	71	J. NIETO
	2400	71	C. VALENCIA

Saturday

Date	Time	Temp.	Name (Print)
10/26	0300	70	C. VALENCIA
	0600	70	E MENDEZ
	0900	70	E MENDEZ
	1200	70	E MENDEZ
	1500	71	J. NIETO
	1800	70	J. NIETO
	2100	70	J. NIETO
	2400	70	W. COLBERT

Sunday

Date	Time	Temp.	Name (Print)
10/27	0300	70	W. Colbert
	0600	70	E MENDEZ
	0900	70	E MENDEZ
	1200	70	E MENDEZ
	1500	70	I. BERRONES
	1800	70	I. BERRONES
	2100	70	I. BERRONES
	2400	70	W. Colbert

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D1 (B-SIDE) Temp. Reading Location: 2ND TIER ABOVE DAYROOM TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21	0300	73	B. COVERT
	0600	73	B. COVERT
	0900	73	B. COVERT
	1200	74	B. COVERT
	1500	74	S. MORENO
	1800	74	S. MORENO
	2100	70	S. MORENO
	2400	70	W. COLBERT

Tuesday

Date	Time	Temp.	Name (Print)
10/22	0300	70	W. COLBERT
	0600	70	B. COVERT
	0900	71	B. COVERT
	1200	71	B. COVERT
	1500	72	J. NIETO
	1800	71	J. NIETO
	2100	71	J. NIETO
	2400	71	W. Colbert

Wednesday

Date	Time	Temp.	Name (Print)
10/23	0300	70	W. Colbert
	0600	70	B. COVERT
	0900	71	B. COVERT
	1200	71	B. COVERT
	1500	71	J. NIETO
	1800	71	J. NIETO
	2100	71	J. NIETO
	2400	71	R. MORALES

Thursday

Date	Time	Temp.	Name (Print)
10/24	0300	70	R. MORALES
	0600	71	J. Ramirez
	0900	71	J. Ramirez
	1200	71	J. Ramirez
	1500	72	J. NIETO
	1800	71	J. NIETO
	2100	71	J. NIETO
	2400	70	DeNoto

Friday

Date	Time	Temp.	Name (Print)
10/25	0300	76	DeNoto
	0600	70	B. Covert
	0900	70	B. Covert
	1200	71	B. Covert
	1500	71	J. NIETO
	1800	71	J. NIETO
	2100	71	J. NIETO
	2400	71	C. VALENCIA

Saturday

Date	Time	Temp.	Name (Print)
10/26	0300	70	C. VALENCIA
	0600	70	E. MENDEZ
	0900	70	E. MENDEZ
	1200	70	E. MENDEZ
	1500	71	J. NIETO
	1800	70	J. NIETO
	2100	70	J. NIETO
	2400	70	W. Colbert

Sunday

Date	Time	Temp.	Name (Print)
10/27	0300	70	W. COLBERT
	0600	70	E. MENDEZ
	0900	70	E. MENDEZ
	1200	70	E. MENDEZ
	1500	70	I. BERRONES
	1800	70	I. BERRONES
	2100	70	I. BERRONES
	2400	70	W. Colbert

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D2 (A) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21/24	0300	67	J. Villarreal
	0600	67	J. Villarreal
	0900	68	Beltran
	1200	69	Beltran
	1500	71	C. McGregor
	1800	71	C. McGregor
	2100	71	C. McGregor
	2400	72	NAVARRETE

Tuesday

Date	Time	Temp.	Name (Print)
10/22/24	0300	70	NAVARRETE
	0600	68	Beltran
	0900	69	Beltran
	1200	69	Beltran
	1500	69	S. Moreno
	1800	69	S. Moreno
	2100	69	S. Moreno
	2400	70	R. Roberts

Wednesday

Date	Time	Temp.	Name (Print)
10/23/24	0300	69	R. Roberts
	0600	70	Curry
	0900	72	Curry
	1200	72	Tijerina
	1500	70	Arnold
	1800	70	Arnold
	2100	70	Arnold
	2400	70	R. Roberts

Thursday

Date	Time	Temp.	Name (Print)
10/24/24	0300	70	R. Roberts
	0600	68	Beltran
	0900	69	Beltran
	1200	70	Beltran
	1500	70	C. Solano
	1800	70	C. Solano
	2100	70	C. Solano
	2400	70	R. Roberts

Friday

Date	Time	Temp.	Name (Print)
10/25/24	0300	70	R. Roberts
	0600	69	G. Contreras
	0900	70	G. Contreras
	1200	70	G. Contreras
	1500	70	C. Solano
	1800	70	C. Solano
	2100	70	C. Solano
	2400	70	R. Roberts

Saturday

Date	Time	Temp.	Name (Print)
10/26/24	0300	70	R. Roberts
	0600	68	G. Contreras
	0900	69	G. Contreras
	1200	70	G. Contreras
	1500	70	Rodriguez
	1800	70	Rodriguez
	2100	70	Rodriguez
	2400	70	R. Roberts

Sunday

Date	Time	Temp.	Name (Print)
10/27/24	0300	70	R. Roberts
	0600	70	B. Xiong
	0900	70	B. Xiong
	1200	70	B. Xiong
	1500	70	J. Valencia
	1800	70	J. Valencia
	2100	70	J. Valencia
	2400	70	A. Malonado

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D2 (B) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21/24	0300	67	J. Villarreal
	0600	67	J. Villarreal
	0900	68	Belhan
	1200	68	Belhan
	1500	72	C. McGregor
	1800	72	C. McGregor
	2100	72	C. McGregor
	2400	72	M NAVARRETE

Tuesday

Date	Time	Temp.	Name (Print)
10/22/24	0300	70	NAVARRETE
	0600	68	Belhan
	0900	68	Belhan
	1200	69	Belhan
	1500	69	S. Moreno
	1800	69	S. Moreno
	2100	69	S. Moreno
	2400	71	R Roberts

Wednesday

Date	Time	Temp.	Name (Print)
10/23/24	0300	71	R Roberts
	0600	72	Cunning
	0900	72	Evans
	1200	72	Trujillo
	1500	70	Hurson
	1800	70	Hurson
	2100	70	Hurson
	2400	71	R Roberts

Thursday

Date	Time	Temp.	Name (Print)
10/24/24	0300	71	R. Roberts
	0600	69	Belhan
	0900	69	Belhan
	1200	70	Belhan
	1500	70	C. Solano
	1800	70	C. Solano
	2100	70	C. Solano
	2400	70	R Roberts

Friday

Date	Time	Temp.	Name (Print)
10/25/24	0300	70	R Roberts
	0600	69	G. Contreras
	0900	71	G. Contreras
	1200	70	G. Contreras
	1500	70	C. Solano
	1800	70	C. Solano
	2100	70	C. Solano
	2400	71	R Roberts

Saturday

Date	Time	Temp.	Name (Print)
10/26/24	0300	71	R Roberts
	0600	68	G. Contreras
	0900	70	G. Contreras
	1200	70	G. Contreras
	1500	70	[illegible]
	1800	70	[illegible]
	2100	70	[illegible]
	2400	71	R Roberts

Sunday

Date	Time	Temp.	Name (Print)
10/27/24	0300	71	R Roberts
	0600	70	B Kong
	0900	70	B Kong
	1200	70	B Kong
	1500	70	J. Valencia
	1800	70	J. Valencia
	2100	70	J. Valencia
	2400	70	A. MALDONADO

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D3 (A) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-21-24	0300	67	C. VALENCIA
	0600	68	J. ESQUIVEL
	0900	70	J. ESQUIVEL
	1200	72	J. ESQUIVEL
	1500	72	S. Gonzalez
	1800	72	S. Gonzalez
	2100	72	S. Gonzalez
	2400	70	M. Grant

Tuesday

Date	Time	Temp.	Name (Print)
10-22-24	0300	70	M. Grant
	0600	71	J. ESQUIVEL
	0900	72	J. ESQUIVEL
	1200	73	J. ESQUIVEL
	1500	72	S. Gonzalez
	1800	70	S. Gonzalez
	2100	70	S. Gonzalez
	2400	70	M. Grant

Wednesday

Date	Time	Temp.	Name (Print)
10-23-24	0300	70	M. Grant
	0600	70	D. Castrejon
	0900	70	D. Castrejon
	1200	70	D. Castrejon
	1500	71	Z. Jones
	1800	71	Z. Jones
	2100	71	Z. Jones
	2400	70	M. Grant

Thursday

Date	Time	Temp.	Name (Print)
10-24-24	0300	70	M. Grant
	0600	66	N. Tovar
	0900	68	N. Tovar
	1200	69	N. Tovar
	1500	69	J. Jones
	1800	69	J. Jones
	2100	69	J. Jones
	2400	70	M. Grant

Friday

Date	Time	Temp.	Name (Print)
10-25-24	0300	70	M. Grant
	0600	70	J. ESQUIVEL
	0900	71	J. ESQUIVEL
	1200	73	J. ESQUIVEL
	1500	70	M. Grant
	1800	70	M. Grant
	2100	70	M. Grant
	2400	70	M. Grant

Saturday

Date	Time	Temp.	Name (Print)
10-26-24	0300	70	M. Grant
	0600	70	S. Mejia
	0900	70	S. Mejia
	1200	70	S. Mejia
	1500	70	C. Salas
	1800	70	C. Salas
	2100	70	C. Salas
	2400	70	Raquido

Sunday

Date	Time	Temp.	Name (Print)
10-27-24	0300	70	Raquido
	0600	70	J. ESQUIVEL
	0900	71	J. ESQUIVEL
	1200	73	J. ESQUIVEL
	1500	72	[illegible]
	1800	72	[illegible]
	2100	71	[illegible]
	2400	71	[illegible]

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D3 (B) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-21-24	0300	67	C. VALENCIA
	0600	68	J. ESQUIVEL
	0900	70	J. ESQUIVEL
	1200	72	J. ESQUIVEL
	1500	73	S. Gonzalez
	1800	73	S. Gonzalez
	2100	73	S. Gonzalez
	2400	71	M. Grant

Tuesday

Date	Time	Temp.	Name (Print)
10-22-24	0300	71	M. Grant
	0600	71	J. ESQUIVEL
	0900	72	J. ESQUIVEL
	1200	73	J. ESQUIVEL
	1500	72	S. Gonzalez
	1800	70	S. Gonzalez
	2100	70	S. Gonzalez
	2400	71	M. Grant

Wednesday

Date	Time	Temp.	Name (Print)
10-23-24	0300	71	M. Grant
	0600	71	D. Castrejon
	0900	71	D. Castrejon
	1200	71	D. Castrejon
	1500	72	Z. Jones
	1800	72	Z. Jones
	2100	71	Z. Jones
	2400	71	M. Grant

Thursday

Date	Time	Temp.	Name (Print)
10-24-24	0300	71	M. Grant
	0600	66	N. Tovar
	0900	68	N. Tovar
	1200	69	N. Tovar
	1500	70	J. JONES
	1800	70	J. JONES
	2100	69	J. JONES
	2400	71	M. Grant

Friday

Date	Time	Temp.	Name (Print)
10-25-24	0300	70	M. Grant
	0600	70	J. ESQUIVEL
	0900	71	J. ESQUIVEL
	1200	72	J. ESQUIVEL
	1500	71	M. Grant
	1800	71	M. Grant
	2100	71	M. Grant
	2400	71	M. Grant

Saturday

Date	Time	Temp.	Name (Print)
10-26-24	0300	71	M. Grant
	0600	70	S. Mejia
	0900	70	S. Mejia
	1200	70	S. Mejia
	1500	70	C. Solano
	1800	70	C. Solano
	2100	70	C. Solano
	2400	71	Raguado

Sunday

Date	Time	Temp.	Name (Print)
10-27-24	0300	70	Raguado
	0600	70	J. ESQUIVEL
	0900	71	J. ESQUIVEL
	1200	73	J. ESQUIVEL
	1500	72	Gamez
	1800	72	Gamez
	2100	71	Gamez
	2400	71	[illegible]

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. D - 4 (A) Side Temp. Reading Location: Tier 2 - Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-21-24	0300	68	D. Mendez
	0600	68	A Lupe
	0900	68	A Lupe
	1200	70	A Lupe
	1500	70	Arvalo
	1800	70	Arvalo
	2100	68	Arvalo
	2400	70	S. Baez

Tuesday

Date	Time	Temp.	Name (Print)
10-22-24	0300	70	S. Baez
	0600	70	A Lupe
	0900	70	A Lupe
	1200	70	A Lupe
	1500	70	Arvalo
	1800	70	Arvalo
	2100	70	Arvalo
	2400	70	S. Baez

Wednesday

Date	Time	Temp.	Name (Print)
10-23-24	0300	70	S. Baez
	0600	70	A Lupe
	0900	70	A Lupe
	1200	70	A Lupe
	1500	70	P. Aun
	1800	70	P. Aun
	2100	70	J. [illegible]
	2400	70	[illegible]

Thursday

Date	Time	Temp.	Name (Print)
10-24-24	0300	70	J. [illegible]
	0600	70	D. Castrejon
	0900	70	D. Castrejon
	1200	70	D. Castrejon
	1500	70	R. PASCUA
	1800	70	R. PASCUA
	2100	70	R. PASCUA
	2400	68	Morales

Friday

Date	Time	Temp.	Name (Print)
10-25-24	0300	68	Morales
	0600	68	E Mendez
	0900	70	E MENDEZ
	1200	70	E MENDEZ
	1500	70	R. PASCUA
	1800	70	R. PASCUA
	2100	70	R. PASCUA
	2400	69	Drake

Saturday

Date	Time	Temp.	Name (Print)
10-26-24	0300	69.0	Drake
	0600	68	A Lupe
	0900	70	A Lupe
	1200	70	A Lupe
	1500	70	R. PASCUA
	1800	70	R. PASCUA
	2100	70	R. PASCUA
	2400	70	S. Baez

Sunday

Date	Time	Temp.	Name (Print)
10-27-24	0300	70	S Baez
	0600	70	A Lopez
	0900	70	A Lupe
	1200	70	A Lupe
	1500	70	R. PASCUA
	1800	70	R. PASCUA
	2100	70	R. PASCUA
	2400	70	S. Baez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAC. D-4 B side Temp. Reading Location: Above Day room TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-21-24	0300	69	D. [illegible]
	0600	68	A Lopez
	0900	68	A Lopez
	1200	70	A Lopez
	1500	70	Arnold
	1800	70	Arnold
	2100	68	Arnold
	2400	70	S. Baez

Tuesday

Date	Time	Temp.	Name (Print)
10-22-24	0300	70	S. Baez
	0600	70	A Lopez
	0900	70	A Lopez
	1200	70	A Lopez
	1500	70	Arnold
	1800	70	Arnold
	2100	70	Arnold
	2400	70	S. Baez

Wednesday

Date	Time	Temp.	Name (Print)
10-23-24	0300	70	S. Baez
	0600	70	A Lopez
	0900	70	A Lopez
	1200	70	A Lopez
	1500	70	P. Ha
	1800	70	P. Ha
	2100	70	SW
	2400	70	SW

Thursday

Date	Time	Temp.	Name (Print)
10-24-24	0300	70	SW
	0600	70	D. Castejon
	0900	70	D. Castejon
	1200	70	D. Castejon
	1500	70	R. PASCUA
	1800	70	R. PASCUA
	2100	70	R. PASCUA
	2400	68	Morales

Friday

Date	Time	Temp.	Name (Print)
10-25-24	0300	68	Morales
	0600	68	G Munoz
	0900	68	G Munoz
	1200	68	G Munoz
	1500	70	R. PASCUA
	1800	70	R. PASCUA
	2100	70	R. PASCUA
	2400	69	Drake

Saturday

Date	Time	Temp.	Name (Print)
10-26-24	0300	69	Drake
	0600	68	A Lopez
	0900	70	A Lopez
	1200	70	A Lopez
	1500	70	R. PASCUA
	1800	70	R. PASCUA
	2100	70	R. PASCUA
	2400	70	S. Baez

Sunday

Date	Time	Temp.	Name (Print)
10-27-24	0300	70	S. Baez
	0600	70	A Lopez
	0900	70	A Lopez
	1200	70	A Lopez
	1500	70	R. PASCUA
	1800	70	R. PASCUA
	2100	70	R. PASCUA
	2400	70	S. Baez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. D - 5 (A) Side Temp. Reading Location: Tier 2 - Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10.21.24	0300	70	Racmdo
	0600	70	B. Covert
	0900	70	B. Covert
	1200	70	B. Covert
	1500	71	S. Moreno
	1800	71	S. Moreno
	2100	71	S. Moreno
	2400	72	J. Sanchez

Tuesday

Date	Time	Temp.	Name (Print)
10.22.24	0300	70	J. Sanchez
	0600	70	C. Ramirez
	0900	70	B. Covert
	1200	70	B. Covert
	1500	70	M. Franklin
	1800	70	M. Franklin
	2100	70	M. Franklin
	2400	70	J. Sanchez

Wednesday

Date	Time	Temp.	Name (Print)
10.23.24	0300	68	J. Sanchez
	0600	69	Teague
	0900	70	Teague
	1200	70	Teague
	1500	71	N. Tovar
	1800	72	N. Tovar
	2100	71	N. Tovar
	2400	70	J. Sanchez

Thursday

Date	Time	Temp.	Name (Print)
10.24.24	0300	68	J. Sanchez
	0600	68	R. Guerrero
	0900	70	R. Guerrero
	1200	70	R. Guerrero
	1500	71	N. Tovar
	1800	70	N. Tovar
	2100	69	N. Tovar
	2400	69	J. Sanchez

Friday

Date	Time	Temp.	Name (Print)
10.25.24	0300	68	J. Sanchez
	0600	68	R. Guerrero
	0900	68	R. Guerrero
	1200	70	R. Guerrero
	1500	71	G. Contreras
	1800	71	G. Contreras
	2100	71	G. Contreras
	2400	71	A. Maldonado

Saturday

Date	Time	Temp.	Name (Print)
10.26.24	0300	69	A. Maldonado
	0600	68	R. Guerrero
	0900	70	R. Guerrero
	1200	70	R. Guerrero
	1500	70	J. Sardaha
	1800	70	J. Sardaha
	2100	70	J. Sardaha
	2400	70	A. Maldonado

Sunday

Date	Time	Temp.	Name (Print)
10.27.24	0300	70	A. Maldonado
	0600	69	G. Contreras
	0900	69	G. Contreras
	1200	69	G. Contreras
	1500	68	[illegible]
	1800	68	[illegible]
	2100	68	[illegible]
	2400	68	J. Sanchez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. D - 5 (A) Side Temp. Reading Location: Tier 2 - Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10.21.24	0300	70	RAMIREZ
	0600	70	B. Covert
	0900	70	B. Covert
	1200	70	B. Covert
	1500	71	S. Moreno
	1800	71	S. Moreno
	2100	71	S. Moreno
	2400	72	J. Sanchez

Tuesday

Date	Time	Temp.	Name (Print)
10.22.24	0300	70	J. Sanchez
	0600	70	C. RAMOS
	0900	70	B. Covert
	1200	70	B. Covert
	1500	70	M. Franklin
	1800	70	M. Franklin
	2100	70	M. Franklin
	2400	70	J. Sanchez

Wednesday

Date	Time	Temp.	Name (Print)
10.23.24	0300	68	J. Sanchez
	0600	70	Teague
	0900	70	Teague
	1200	70	Teague
	1500	71	M. Tovar
	1800	72	M. Tovar
	2100	71	M. Tovar
	2400	70	J. Sanchez

Thursday

Date	Time	Temp.	Name (Print)
10.24.24	0300	68	J. Sanchez
	0600	68	R. Guerrero
	0900	70	R. Guerrero
	1200	70	R. Guerrero
	1500	71	N. Tovar
	1800	70	N. Tovar
	2100	69	N. Tovar
	2400	69	J. Sanchez

Friday

Date	Time	Temp.	Name (Print)
10.25.24	0300	68	J. Sanchez
	0600	68	R. Guerrero
	0900	68	R. Guerrero
	1200	70	R. Guerrero
	1500	71	G. Contreras
	1800	70	G. Contreras
	2100	70	G. Contreras
	2400	70	A. MARONAD

Saturday

Date	Time	Temp.	Name (Print)
10.26.24	0300	69	A. MARONAD
	0600	68	R. Guerrero
	0900	70	R. Guerrero
	1200	70	R. Guerrero
	1500	70	J. Sardinha
	1800	70	J. Sardinha
	2100	70	J. Sardinha
	2400	70	A. MARONAD

Sunday

Date	Time	Temp.	Name (Print)
10.27.24	0300	70	A. MARONAD
	0600	68	G. Contreras
	0900	68	G. Contreras
	1200	68	G. Contreras
	1500	68	Arias
	1800	68	Arias
	2100	68	Arias
	2400	68	J. Sanchez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D-6 (A) Side Temp. Reading Location: Tier 2 - Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-21-24	0300	67	D. SANTOYO
	0600	67	G. MACNOWAN
	0900	69	G. MACNOWAN
	1200	69	MANNING
	1500	69	MANNING
	1800	68	MANNING
	2100	68	MANNING
	2400	68	D SANTOYO

Tuesday

Date	Time	Temp.	Name (Print)
10-22-24	0300	67	D. SANTOYO
	0600	67	Medina
	0900	69	Medina
	1200	70	Medina
	1500	69	R. Aguilar
	1800	69	R. Aguilar
	2100	69	R. Aguilar
	2400	69	D SANTOYO

Wednesday

Date	Time	Temp.	Name (Print)
10-23-24	0300	68	D. SANTOYO
	0600	69	Medina
	0900	70	Medina
	1200	71	Medina
	1500	71	M. VASQUEZ
	1800	71	M. VASQUEZ
	2100	70	M. VASQUEZ
	2400	70	M. VASQUEZ

Thursday

Date	Time	Temp.	Name (Print)
10-24-24	0300	70	[illegible]
	0600	71	[illegible]
	0900	72	[illegible]
	1200	73	[illegible]
	1500	72	M. VASQUEZ
	1800	71	M. VASQUEZ
	2100	70	M. VASQUEZ
	2400	71	K. Gibson

Friday

Date	Time	Temp.	Name (Print)
10-25-24	0300	70	K. Gibson
	0600	70	Medina
	0900	71	Medina
	1200	72	Medina
	1500	72	M. VASQUEZ
	1800	72	M. VASQUEZ
	2100	72	M. VASQUEZ
	2400	71	M. VASQUEZ

Saturday

Date	Time	Temp.	Name (Print)
10-26-24	0300	71	M. VASQUEZ
	0600	71	Medina
	0900	71	Medina
	1200	72	Medina
	1500	71	A. Arreola
	1800	71	A. Arreola
	2100	70	A. Arreola
	2400	70	A. Martin

Sunday

Date	Time	Temp.	Name (Print)
10-27-24	0300	70	A. Martin
	0600	69	R.D. Sotelo
	0900	69	R.D. Sotelo
	1200	71	R.D. Sotelo
	1500	70	D. SANTOYO
	1800	69	D. SANTOYO
	2100	69	D. SANTOYO
	2400	68	D. SANTOYO

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D-6 (B) Side Temp. Reading Location: Tier 2 - Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-21-24	0300	69	D. SANTOYO
	0600	69	G. MARANON
	0900	69	G. MARANON
	1200	69	MANNING
	1500	69	MANNING
	1800	68	MANNING
	2100	68	MANNING
	2400	68	D. SANTOYO

Tuesday

Date	Time	Temp.	Name (Print)
10-22-24	0300	68	D. SANTOYO
	0600	68	Medina
	0900	69	Medina
	1200	70	Medina
	1500	71	R. Aguilar
	1800	71	R. Aguilar
	2100	70	R. Aguilar
	2400	70	D. SANTOYO

Wednesday

Date	Time	Temp.	Name (Print)
10-23-24	0300	69	D. SANTOYO
	0600	69	Medina
	0900	70	Medina
	1200	71	Medina
	1500	71°	M. VASQUEZ
	1800	71°	M. VASQUEZ
	2100	70°	M. VASQUEZ
	2400	70°	M. VASQUEZ

Thursday

Date	Time	Temp.	Name (Print)
10-24-24	0300	70°	M. VASQUEZ
	0600	71	Medina
	0900	72	Medina
	1200	73	Medina
	1500	72°	M. VASQUEZ
	1800	71°	M. VASQUEZ
	2100	70°	M. VASQUEZ
	2400	71	K. Gibson

Friday

Date	Time	Temp.	Name (Print)
10-25-24	0300	70	K. Gibson
	0600	70	Medina
	0900	71	Medina
	1200	72	Medina
	1500	72°	M. VASQUEZ
	1800	72°	M. VASQUEZ
	2100	72°	M. VASQUEZ
	2400	71	M. VASQUEZ

Saturday

Date	Time	Temp.	Name (Print)
10-26-24	0300	71	M. VASQUEZ
	0600	71	Medina
	0900	72	Medina
	1200	72	Medina
	1500	71	A. Arreola
	1800	71	A. Arreola
	2100	70	A. Arreola
	2400	70	A. Martinez

Sunday

Date	Time	Temp.	Name (Print)
10-27-24	0300	70	A. Martinez
	0600	69°	D. Solis
	0900	69°	D. Solis
	1200	71°	D. Solis
	1500	71	D. SANTOYO
	1800	70	D. SANTOYO
	2100	69	D. SANTOYO
	2400	69	D. SANTOYO

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. M Dorm 1 A-Side Temp. Reading Location: 1st Tier - Behind C/O Podium (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21/24	0300	70	[illegible]
	0600	70	J. Islas Lopez
	0900	70	J. Islas Lopez
	1200	70	J. Islas Lopez
	1500	70	R. DURAN
	1800	70	R. DURAN
	2100	70	R. DURAN
	2400	67	Diaz

Tuesday

Date	Time	Temp.	Name (Print)
10/22/24	0300	67	Diaz
	0600	67	J. Islas Lopez
	0900	68	J. Islas Lopez
	1200	68	J. Islas Lopez
	1500	70	R. DURAN
	1800	70	R. DURAN
	2100	69	R. DURAN
	2400	68	J. LOPEZ

Wednesday

Date	Time	Temp.	Name (Print)
10/23/24	0300	68	J. LOPEZ
	0600	68°	M. VEGA
	0900	68°	M. VEGA
	1200	69°	M. VEGA
	1500	69	I. FRITZ
	1800	69	I. [illegible]
	2100	69	I. [illegible]
	2400	69°	J. LOPEZ

Thursday

Date	Time	Temp.	Name (Print)
10/24/24	0300	66°	J. LOPEZ
	0600	67°	M. VEGA
	0900	68°	M. VEGA
	1200	69	M. VEGA
	1500	69°	R. LOR
	1800	69°	R. LOR
	2100	69°	R. LOR
	2400	68	J. LOPEZ

Friday

Date	Time	Temp.	Name (Print)
10/25/24	0300	66°	J. LOPEZ
	0600	66°	M. VEGA
	0900	67°	M. VEGA
	1200	68°	M. VEGA
	1500	62	[illegible]
	1800	68	[illegible]
	2100	68	[illegible]
	2400	68	J. LOPEZ

Saturday

Date	Time	Temp.	Name (Print)
10/26/24	0300	66°	J. LOPEZ
	0600	67°	M. VEGA
	0900	68°	M. VEGA
	1200	69°	M. VEGA
	1500	70	J. MONTOYA
	1800	70	J. MONTOYA
	2100	70	J. MONTOYA
	2400	69	J. MONTOYA

Sunday

Date	Time	Temp.	Name (Print)
10/27/24	0300	68	J. MONTOYA
	0600	68°	M. VEGA
	0900	68°	M. VEGA
	1200	69°	M. VEGA
	1500	70	J. MONTOYA
	1800	70	J. MONTOYA
	2100	70	J. MONTOYA
	2400	70	J. MONTOYA

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. M Dorm 1 B-side Temp. Reading Location: 1st Tier - Behind C/O Podium (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21/24	0300	70	[illegible]
	0600	70	J. Loreleros
	0900	70	J. Loreleros
	1200	70	J. Loreleros
	1500	70	R. DURAN
	1800	70	R. DURAN
	2100	70	R. DURAN
	2400	67	Diaz

Tuesday

Date	Time	Temp.	Name (Print)
10/22/24	0300	67	Diaz
	0600	67	J. Loreleros
	0900	68	J. Loreleros
	1200	68	J. Loreleros
	1500	70	R. DURAN
	1800	70	R. DURAN
	2100	68	R. DURAN
	2400	68°	J. Lopez

Wednesday

Date	Time	Temp.	Name (Print)
10/23/24	0300	68°	J. Lopez
	0600	68°	M. VEGA
	0900	68°	M. VEGA
	1200	69°	M. VEGA
	1500	69	I. Fritz
	1800	69	I. Fritz
	2100	69	I. Fritz
	2400	69°	J. Lopez

Thursday

Date	Time	Temp.	Name (Print)
10/24/24	0300	66°	J. Lopez
	0600	67°	M. VEGA
	0900	68°	M. VEGA
	1200	69°	M. VEGA
	1500	69°	R. LOR
	1800	69°	R. LOR
	2100	69°	R. LOR
	2400	68°	J. Lopez

Friday

Date	Time	Temp.	Name (Print)
10/25/24	0300	65°	J. Lopez
	0600	66°	M. VEGA
	0900	67°	M. VEGA
	1200	68°	M. VEGA
	1500	69	I. Fritz
	1800	69	[illegible]
	2100	69	[illegible]
	2400	68°	J. Lopez

Saturday

Date	Time	Temp.	Name (Print)
10/26/24	0300	66°	J. Lopez
	0600	67°	M. VEGA
	0900	68°	M. VEGA
	1200	69°	M. VEGA
	1500	70	J. MONTOYA
	1800	70	J. MONTOYA
	2100	70	J. MONTOYA
	2400	69	J. MONTOYA

Sunday

Date	Time	Temp.	Name (Print)
10/27/24	0300	68	J. MONTOYA
	0600	68°	M. VEGA
	0900	68°	M. VEGA
	1200	69°	M. VEGA
	1500	70	J. MONTOYA
	1800	70	J. MONTOYA
	2100	70	J. MONTOYA
	2400	70	J. MONTOYA

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: M-DORM-2 A-SIDE Temp. Reading Location: BEHIND PODIUM (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/21/24	0300	68	C. HOUSE
	0600	65	VARGAS
	0900	65	VARGAS
	1200	67	VARGAS
	1500	69	I. FRAZ
	1800	69	I. FRAZ
	2100	68	I. FRAZ
	2400	67	R. DURAN

Tuesday

Date	Time	Temp.	Name (Print)
10/22/24	0300	66	R. DURAN
	0600	65	J. ENRIQUEZ
	0900	66	J. ENRIQUEZ
	1200	67	J. ENRIQUEZ
	1500	69	I. FRAZ
	1800	69	I. FRAZ
	2100	69	I. FRAZ
	2400	69	R. DURAN

Wednesday

Date	Time	Temp.	Name (Print)
10/23/24	0300	67	R. DURAN
	0600	65	J. MAYORGA
	0900	69	J. MAYORGA
	1200	69	J. MAYORGA
	1500	69	J Medina
	1800	69	J Medina
	2100	69	J Medina
	2400	68	K. MADRIGAL

Thursday

Date	Time	Temp.	Name (Print)
10/24/24	0300	66°	K. MADRIGAL
	0600	65	VARGAS
	0900	65	VARGAS
	1200	65	VARGAS
	1500	68	J. Medina
	1800	68	J. Medina
	2100	68	J. Medina
	2400	68°	K. Madrigal

Friday

Date	Time	Temp.	Name (Print)
10/25/24	0300	66°	K. MADRIGAL
	0600	65	VARGAS
	0900	65	VARGAS
	1200	65	VARGAS
	1500	68	J. Medina
	1800	68	medina
	2100	68	medina
	2400	68°	K. MADRIGAL

Saturday

Date	Time	Temp.	Name (Print)
10/26/24	0300	66	K. MADRIGAL
	0600	65	VARGAS
	0900	65	VARGAS
	1200	65	VARGAS
	1500	68	medina
	1800	68	medina
	2100	68	medina
	2400	66	Tovar

Sunday

Date	Time	Temp.	Name (Print)
10/27/24	0300	66	Tovar
	0600	65	VARGAS
	0900	65	VARGAS
	1200	65	VARGAS
	1500	68	J. medina
	1800	68	J Medina
	2100	68	J Medina
	2400	68	C. HOUSE

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: M-Dorm-2 B-SIDE Temp. Reading Location: BEHIND PODIUM (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/1	0300	68	C. House
	0600	65	VARGAS
	0900	65	VARGAS
	1200	67	VARGAS
	1500	69	I. Fritz
	1800	69	I. Fritz
	2100	68	I. Fritz
	2400	67	R. DURAN

Tuesday

Date	Time	Temp.	Name (Print)
10/2	0300	66	R. DURAN
	0600	65	J. ENRIQUEZ
	0900	66	J ENRIQUEZ
	1200	67	J ENRIQUEZ
	1500	69	I. Fritz
	1800	69	I. Fritz
	2100	69	I. Fritz
	2400	68	R. DURAN

Wednesday

Date	Time	Temp.	Name (Print)
10/3	0300	67	R. DURAN
	0600	65	J. MAYORGA
	0900	69	J. MAYORGA
	1200	69	J. MAYORGA
	1500	69	J medina
	1800	69	J medina
	2100	69	J medina
	2400	68	K. MADRIGAL

Thursday

Date	Time	Temp.	Name (Print)
10/4	0300	66°	K. MADRIGAL
	0600	65	VARGAS
	0900	65	VARGAS
	1200	65	VARGAS
	1500	68	J medina
	1800	68	J medina
	2100	68	J medina
	2400	68	K. MADRIGAL

Friday

Date	Time	Temp.	Name (Print)
10/5	0300	66°	K. MADRIGAL
	0600	65	VARGAS
	0900	65	VARGAS
	1200	65	VARGAS
	1500	68	J. Medina
	1800	68	Medina
	2100	68	Medina
	2400	68	K. MADRIGAL

Saturday

Date	Time	Temp.	Name (Print)
10/6	0300	66	K. MADRIGAL
	0600	65	VARGAS
	0900	65	VARGAS
	1200	65	VARGAS
	1500	68	medina
	1800	68	medina
	2100	68	medina
	2400	66	Tovar

Sunday

Date	Time	Temp.	Name (Print)
10/7	0300	66	Tovar
	0600	65	VARGAS
	0900	65	VARGAS
	1200	65	VARGAS
	1500	68	J. medina
	1800	68	J medina
	2100	68	J medina
	2400	68	C. House

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: CTC/INF Temp. Reading Location: Above Isolation Ice (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-21-24	0300	71.1	Y. Fernandez
	0600	71.1	Brown
	0900	71.1	Brown
	1200	71.2	Brown
	1500	72.3	Penetta
	1800	72.5	Penetta
	2100	72.5	Penetta
	2400	72.3	Y. Fernandez

Tuesday

Date	Time	Temp.	Name (Print)
10-22-24	0300	72.3	Y. Fernandez
	0600	72.3	Brown
	0900	72.3	Brown
	1200	72.3	Brown
	1500	72.1	I. Alvarez
	1800	72.3	I. Alvarez
	2100	72.1	I. Alvarez
	2400	72.1	Y. Fernandez

Wednesday

Date	Time	Temp.	Name (Print)
10-23-24	0300	72.1	Y. Fernandez
	0600	72.1	Brown
	0900	72.1	Brown
	1200	72.1	Brown
	1500	71.4	Borlikha
	1800	72.1	I. Alvarez
	2100	72.1	I. Alvarez
	2400	72.4	Y. Fernandez

Thursday

Date	Time	Temp.	Name (Print)
10-24-24	0300	72.3	Y. Fernandez
	0600	72.7	H. Saez
	0900	72.5	H. Saez
	1200	72.1	H. Saez
	1500	72.1	I. Alvarez
	1800	72.1	I. Alvarez
	2100	72.1	I. Alvarez
	2400	72.1	[illegible]

Friday

Date	Time	Temp.	Name (Print)
10-25-24	0300	72.4	[illegible]
	0600	72.7	H. Saez
	0900	72.5	H. Saez
	1200	72.6	H. Saez
	1500	73.0	Penetta
	1800	72.7	Penetta
	2100	73.0	I. Alvarez
	2400	73.3	Chico

Saturday

Date	Time	Temp.	Name (Print)
10-26-24	0300	73.2	Chico
	0600	72.0	Brown
	0900	72.0	Brown
	1200	72.0	Brown
	1500	72.0	Penetta
	1800	73.2	Penetta
	2100	73.2	Penetta
	2400	72	V. Nzekwu

Sunday

Date	Time	Temp.	Name (Print)
10-27-24	0300	72	V. Nzekwu
	0600	73.0	Brown
	0900	73.0	Brown
	1200	73.0	Brown
	1500	73.0	Penetta
	1800	74.1	Penetta
	2100	74.1	Penetta
	2400	73.9	Y. Fernandez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

OUTSIDE TEMPERATURE RECORD

CDCR 2030 (04/18)

INSTITUTION: NKSP

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the OUTSIDE ambient air temperature.

Using an accurate thermometer located in a central, heat neutral location, the outside air temperature is to be taken every hour, seven (7) days a week.

Thermometer Location: CENTRAL CONTROL

Immediately notify the Watch Commander at extension 3141 when the air temperature reaches 90 degrees.

Date	Time	Temp.	Printed Name
10/22	0100	56	DUNN
	0200	54	DUNN
	0300	54	DUNN
	0400	50	DUNN
	0500	49	DUNN
	0600	49	VALENCIA
	0700	48	VALENCIA
	0800	50	VALENCIA
	0900	58	VALENCIA
	1000	64	VALENCIA
	1100	69	VALENCIA
	1200	72	VALENCIA
	1300	75	VALENCIA
	1400	78	MONCIBAIZ
	1500	81	MONCIBAIZ
	1600	82	MONCIBAIZ
	1700	82	MONCIBAIZ
	1800	78	MONCIBAIZ
	1900	74	MONCIBAIZ
	2000	72	MONCIBAIZ
	2100	65	MONCIBAIZ
	2200	60	PADILLA
	2300	57	PADILLA
	2400	57	PADILLA

Date	Time	Temp.	Printed Name
10/23	0100	56	PADILLA
	0200	54	PADILLA
	0300	52	PADILLA
	0400	51	PADILLA
	0500	50	PADILLA
	0600	48	VALENCIA
	0700	48	VALENCIA
	0800	50	VALENCIA
	0900	55	VALENCIA
	1000	63	VALENCIA
	1100	68	VALENCIA
	1200	72	VALENCIA
	1300	75	VALENCIA
	1400	78	MONCIBAIZ
	1500	79	MONCIBAIZ
	1600	81	MONCIBAIZ
	1700	81	MONCIBAIZ
	1800	79	MONCIBAIZ
	1900	75	MONCIBAIZ
	2000	71	MONCIBAIZ
	2100	66	MONCIBAIZ
	2200	61	PADILLA
	2300	58	PADILLA
	2400	56	PADILLA

DISTRIBUTION: Original: Institution Heat Plan Coordinator

NKSP 10/22/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/22/24	12:15a	57.1	58.1	57.1	12	4.9	2.0	SE	0.50	6.0	ESE	57.1	52.9	52.9	30.164	0.00	0.00	0.082	0.000
10/22/24	12:30a	57.1	57.2	57.0	11	3.0	0.0	SSE	0.00	3.0	SSE	57.1	52.9	52.9	30.165	0.00	0.00	0.082	0.000
10/22/24	12:45a	57.4	57.4	57.1	10	1.2	0.0	SSE	0.00	2.0	SSE	57.4	53.1	53.1	30.162	0.00	0.00	0.079	0.000
10/22/24	1:00a	56.9	57.4	56.9	11	2.8	1.0	SSE	0.25	3.0	SSE	56.9	52.7	52.7	30.163	0.00	0.00	0.084	0.000
10/22/24	1:15a	56.3	57.0	56.3	12	4.2	1.0	SE	0.25	3.0	SE	56.3	52.2	52.2	30.162	0.00	0.00	0.091	0.000
10/22/24	1:30a	55.7	56.3	55.6	13	5.5	1.0	SE	0.25	4.0	SE	55.7	51.8	51.8	30.170	0.00	0.00	0.097	0.000
10/22/24	1:45a	55.0	55.6	55.0	14	6.6	3.0	ESE	0.75	6.0	ESE	55.0	51.2	51.2	30.173	0.00	0.00	0.104	0.000
10/22/24	2:00a	54.7	55.1	54.6	14	6.3	1.0	ESE	0.25	4.0	ESE	54.7	51.0	51.0	30.174	0.00	0.00	0.107	0.000
10/22/24	2:15a	54.8	54.8	54.5	15	8.0	0.0	SE	0.00	1.0	SE	54.8	51.0	51.0	30.174	0.00	0.00	0.106	0.000
10/22/24	2:30a	55.2	55.3	54.8	15	8.3	0.0	---	0.00	0.0	---	55.2	51.4	51.4	30.173	0.00	0.00	0.102	0.000
10/22/24	2:45a	55.5	55.5	55.1	14	7.0	0.0	SE	0.00	1.0	SE	55.5	51.6	51.6	30.178	0.00	0.00	0.099	0.000
10/22/24	3:00a	54.1	55.5	54.1	12	2.5	0.0	SE	0.00	1.0	SE	54.1	50.5	50.5	30.179	0.00	0.00	0.114	0.000
10/22/24	3:15a	52.0	54.1	52.0	16	7.1	0.0	SE	0.00	2.0	SE	52.0	49.0	49.0	30.180	0.00	0.00	0.135	0.000
10/22/24	3:30a	50.5	52.0	50.5	20	10.9	1.0	SE	0.25	4.0	SE	50.5	48.1	48.1	30.182	0.00	0.00	0.151	0.000
10/22/24	3:45a	49.7	50.6	49.7	22	12.3	2.0	SE	0.50	5.0	SE	49.7	47.5	47.5	30.179	0.00	0.00	0.159	0.000
10/22/24	4:00a	50.0	50.0	49.7	22	12.6	1.0	SE	0.25	3.0	SE	50.0	47.8	47.8	30.180	0.00	0.00	0.156	0.000
10/22/24	4:15a	49.7	50.0	49.7	22	12.3	1.0	SE	0.25	3.0	SE	49.7	47.5	47.5	30.184	0.00	0.00	0.159	0.000
10/22/24	4:30a	49.4	49.7	49.4	22	12.1	1.0	SE	0.25	4.0	SE	49.4	47.2	47.2	30.189	0.00	0.00	0.162	0.000
10/22/24	4:45a	49.0	49.4	49.0	23	12.7	1.0	SE	0.25	4.0	SE	49.0	46.9	46.9	30.196	0.00	0.00	0.167	0.000
10/22/24	5:00a	49.0	49.1	49.0	24	13.7	1.0	SSE	0.25	5.0	SE	49.0	46.9	46.9	30.196	0.00	0.00	0.167	0.000
10/22/24	5:15a	49.0	49.1	48.8	24	13.7	3.0	SSE	0.75	7.0	SE	48.5	46.9	46.4	30.203	0.00	0.00	0.167	0.000
10/22/24	5:30a	49.1	49.1	49.0	24	13.8	1.0	SSE	0.25	4.0	SSE	49.1	47.0	47.0	30.210	0.00	0.00	0.166	0.000
10/22/24	5:45a	49.2	49.3	49.1	23	12.9	2.0	SSE	0.50	4.0	SSE	49.2	47.1	47.1	30.211	0.00	0.00	0.165	0.000
10/22/24	6:00a	49.4	49.4	49.2	22	12.1	1.0	SSE	0.25	4.0	SSE	49.4	47.2	47.2	30.212	0.00	0.00	0.162	0.000
10/22/24	6:15a	49.1	49.4	49.1	22	11.8	1.0	SSE	0.25	4.0	S	49.1	46.9	46.9	30.212	0.00	0.00	0.166	0.000
10/22/24	6:30a	49.5	49.6	49.1	21	11.1	1.0	S	0.25	5.0	S	49.5	47.3	47.3	30.213	0.00	0.00	0.161	0.000
10/22/24	6:45a	49.5	49.8	49.5	19	8.9	1.0	SE	0.25	4.0	SSE	49.5	47.2	47.2	30.212	0.00	0.00	0.161	0.000
10/22/24	7:00a	48.3	49.4	48.3	21	10.1	3.0	ESE	0.75	7.0	ESE	47.7	46.1	45.5	30.214	0.00	0.00	0.174	0.000
10/22/24	7:15a	47.7	48.3	47.6	23	11.6	4.0	SE	1.00	9.0	SE	46.2	45.6	44.1	30.210	0.00	0.00	0.180	0.000
10/22/24	7:30a	47.4	47.7	47.4	23	11.4	4.0	SE	1.00	7.0	SE	45.9	45.3	43.8	30.214	0.00	0.00	0.183	0.000
10/22/24	7:45a	48.9	48.9	47.4	22	11.7	2.0	SE	0.50	5.0	SE	48.9	46.7	46.7	30.213	0.00	0.00	0.168	0.000
10/22/24	8:00a	50.8	50.8	48.9	19	9.9	1.0	SSE	0.25	5.0	SE	50.8	48.2	48.2	30.222	0.00	0.00	0.146	0.000
10/22/24	8:15a	52.4	52.4	50.8	17	8.8	2.0	SE	0.50	5.0	SE	52.4	49.4	49.4	30.220	0.00	0.00	0.131	0.000
10/22/24	8:30a	54.3	54.3	52.4	13	4.4	3.0	SE	0.75	8.0	SE	54.3	50.6	50.6	30.219	0.00	0.00	0.111	0.000
10/22/24	8:45a	56.1	56.1	54.3	11	2.2	2.0	SE	0.50	5.0	SE	56.1	52.1	52.1	30.232	0.00	0.00	0.093	0.000
10/22/24	9:00a	58.4	58.4	56.1	8	-2.8	1.0	SE	0.25	4.0	SE	58.4	53.6	53.6	30.230	0.00	0.00	0.069	0.000
10/22/24	9:15a	60.9	60.9	58.4	3	-20.8	1.0	S	0.25	4.0	S	60.9	55.0	55.0	30.233	0.00	0.00	0.043	0.000
10/22/24	9:30a	62.9	62.9	60.9	0	---	2.0	SSE	0.50	5.0	SSE	62.9	56.3	56.3	30.237	0.00	0.00	0.022	0.000
10/22/24	9:45a	64.3	64.3	62.9	0	---	2.0	SSE	0.50	5.0	WSW	64.3	57.5	57.5	30.240	0.00	0.00	0.007	0.000
10/22/24	10:00a	64.5	64.5	64.2	0	---	2.0	SW	0.50	6.0	SW	64.5	57.7	57.7	30.235	0.00	0.00	0.005	0.000
10/22/24	10:15a	65.7	65.7	64.5	0	---	1.0	SW	0.25	4.0	SW	65.7	58.7	58.7	30.233	0.00	0.00	0.000	0.007
10/22/24	10:30a	67.0	67.0	65.7	0	---	1.0	SW	0.25	3.0	SW	67.0	59.9	59.9	30.232	0.00	0.00	0.000	0.021
10/22/24	10:45a	69.4	69.4	67.1	0	---	1.0	SE	0.25	3.0	SW	69.4	63.0	63.0	30.230	0.00	0.00	0.000	0.046
10/22/24	11:00a	69.0	69.5	69.0	0	---	2.0	NNW	0.50	5.0	NW	69.0	62.4	62.4	30.222	0.00	0.00	0.000	0.042
10/22/24	11:15a	69.6	69.6	68.9	0	---	2.0	NNW	0.50	4.0	WNW	69.6	63.3	63.3	30.222	0.00	0.00	0.000	0.048
10/22/24	11:30a	70.5	70.5	69.5	0	---	2.0	NNE	0.50	6.0	NNE	70.5	64.6	64.6	30.220	0.00	0.00	0.000	0.057
10/22/24	11:45a	71.2	71.3	70.5	0	---	2.0	NW	0.50	5.0	NNW	71.2	65.5	65.5	30.215	0.00	0.00	0.000	0.065
10/22/24	12:00p	72.6	72.6	71.3	0	---	2.0	NNW	0.50	8.0	NNE	72.6	67.2	67.2	30.206	0.00	0.00	0.000	0.079
10/22/24	12:15p	73.2	73.2	72.6	0	---	3.0	W	0.75	7.0	W	73.2	68.0	68.0	30.205	0.00	0.00	0.000	0.085
10/22/24	12:30p	74.0	74.0	73.2	0	---	3.0	WNW	0.75	7.0	W	74.0	69.1	69.1	30.199	0.00	0.00	0.000	0.094

NKSP 10/22/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/22/24	12:45p	75.1	75.1	74.0	0	---	2.0	NW	0.50	7.0	WNW	75.1	70.4	70.4	30.194	0.00	0.00	0.000	0.105
10/22/24	1:00p	75.9	75.9	75.1	0	---	2.0	NW	0.50	5.0	NW	75.9	71.3	71.3	30.189	0.00	0.00	0.000	0.114
10/22/24	1:15p	77.2	77.2	75.9	0	---	2.0	WSW	0.50	7.0	WSW	77.2	72.8	72.8	30.183	0.00	0.00	0.000	0.127
10/22/24	1:30p	77.8	77.9	77.2	0	---	3.0	NNW	0.75	6.0	W	77.8	73.3	73.3	30.177	0.00	0.00	0.000	0.133
10/22/24	1:45p	78.3	78.3	77.8	0	---	3.0	N	0.75	8.0	NNE	78.3	73.8	73.8	30.172	0.00	0.00	0.000	0.139
10/22/24	2:00p	78.8	78.8	78.3	0	---	3.0	N	0.75	8.0	N	78.8	74.3	74.3	30.161	0.00	0.00	0.000	0.144
10/22/24	2:15p	80.4	80.4	78.8	0	---	2.0	W	0.50	7.0	W	80.4	75.9	75.9	30.151	0.00	0.00	0.000	0.160
10/22/24	2:30p	80.7	80.7	80.1	0	---	2.0	W	0.50	8.0	W	80.7	76.1	76.1	30.152	0.00	0.00	0.000	0.164
10/22/24	2:45p	81.1	81.2	80.7	0	---	2.0	NNW	0.50	9.0	WNW	81.1	76.5	76.5	30.146	0.00	0.00	0.000	0.168
10/22/24	3:00p	81.2	81.4	81.1	0	---	3.0	NNE	0.75	8.0	NNE	81.2	76.6	76.6	30.141	0.00	0.00	0.000	0.169
10/22/24	3:15p	81.1	81.3	81.0	0	---	4.0	NW	1.00	8.0	NNE	81.1	76.5	76.5	30.146	0.00	0.00	0.000	0.168
10/22/24	3:30p	81.5	81.5	81.1	0	---	3.0	NNE	0.75	9.0	NNE	81.5	76.9	76.9	30.143	0.00	0.00	0.000	0.172
10/22/24	3:45p	81.8	81.8	81.4	0	---	4.0	NW	1.00	8.0	NNW	81.8	77.2	77.2	30.138	0.00	0.00	0.000	0.175
10/22/24	4:00p	82.2	82.2	81.8	0	---	4.0	NW	1.00	10.0	NW	82.2	77.6	77.6	30.133	0.00	0.00	0.000	0.179
10/22/24	4:15p	82.3	82.3	82.1	0	---	4.0	NNW	1.00	9.0	NNW	82.3	77.7	77.7	30.131	0.00	0.00	0.000	0.180
10/22/24	4:30p	82.0	82.2	82.0	0	---	3.0	NNW	0.75	7.0	NNE	82.0	77.4	77.4	30.130	0.00	0.00	0.000	0.177
10/22/24	4:45p	82.1	82.2	82.0	0	---	3.0	NNW	0.75	9.0	NNW	82.1	77.5	77.5	30.129	0.00	0.00	0.000	0.178
10/22/24	5:00p	82.0	82.2	82.0	0	---	3.0	NNW	0.75	7.0	NW	82.0	77.4	77.4	30.126	0.00	0.00	0.000	0.177
10/22/24	5:15p	81.8	82.1	81.8	0	---	3.0	N	0.75	7.0	NNE	81.8	77.2	77.2	30.126	0.00	0.00	0.000	0.175
10/22/24	5:30p	81.2	81.8	81.2	0	---	4.0	N	1.00	8.0	NNW	81.2	76.6	76.6	30.125	0.00	0.00	0.000	0.169
10/22/24	5:45p	80.2	81.2	80.2	0	---	3.0	N	0.75	4.0	NNW	80.2	75.7	75.7	30.130	0.00	0.00	0.000	0.158
10/22/24	6:00p	78.6	80.2	78.5	0	---	2.0	NNE	0.50	4.0	NNE	78.6	74.1	74.1	30.128	0.00	0.00	0.000	0.142
10/22/24	6:15p	77.3	78.6	77.3	0	---	3.0	NNE	0.75	4.0	NNE	77.3	72.9	72.9	30.131	0.00	0.00	0.000	0.128
10/22/24	6:30p	76.3	77.3	76.3	0	---	3.0	NNE	0.75	4.0	NNE	76.3	71.8	71.8	30.135	0.00	0.00	0.000	0.118
10/22/24	6:45p	75.4	76.3	75.4	0	---	2.0	NNE	0.50	3.0	NNE	75.4	70.7	70.7	30.137	0.00	0.00	0.000	0.108
10/22/24	7:00p	74.3	75.4	74.3	0	---	1.0	NNE	0.25	3.0	NNE	74.3	69.5	69.5	30.148	0.00	0.00	0.000	0.097
10/22/24	7:15p	73.3	74.3	73.3	0	---	1.0	NNE	0.25	3.0	NNE	73.3	68.1	68.1	30.150	0.00	0.00	0.000	0.086
10/22/24	7:30p	72.5	73.3	72.5	0	---	1.0	NE	0.25	2.0	NE	72.5	67.1	67.1	30.153	0.00	0.00	0.000	0.078
10/22/24	7:45p	72.4	72.5	72.3	0	---	1.0	NE	0.25	2.0	NE	72.4	67.0	67.0	30.153	0.00	0.00	0.000	0.077
10/22/24	8:00p	72.3	72.5	72.3	0	---	1.0	NE	0.25	2.0	NE	72.3	66.9	66.9	30.152	0.00	0.00	0.000	0.076
10/22/24	8:15p	71.0	72.4	71.0	0	---	0.0	NE	0.00	1.0	NE	71.0	65.2	65.2	30.150	0.00	0.00	0.000	0.063
10/22/24	8:30p	68.8	71.1	68.8	0	---	0.0	---	0.00	0.0	---	68.8	62.1	62.1	30.153	0.00	0.00	0.000	0.040
10/22/24	8:45p	66.3	68.7	66.3	2	-24.9	0.0	---	0.00	0.0	---	66.3	59.5	59.5	30.157	0.00	0.00	0.000	0.014
10/22/24	9:00p	65.4	66.2	65.4	1	-38.0	1.0	SE	0.25	4.0	SE	65.4	58.6	58.6	30.161	0.00	0.00	0.000	0.004
10/22/24	9:15p	63.7	65.4	63.7	5	-8.7	2.0	SE	0.50	4.0	SE	63.7	57.5	57.5	30.165	0.00	0.00	0.014	0.000
10/22/24	9:30p	63.0	63.6	63.0	9	3.2	3.0	SE	0.75	4.0	ESE	63.0	57.7	57.7	30.172	0.00	0.00	0.021	0.000
10/22/24	9:45p	62.6	63.0	62.5	8	0.3	2.0	SE	0.50	4.0	SE	62.6	57.1	57.1	30.177	0.00	0.00	0.025	0.000
10/22/24	10:00p	60.8	62.6	60.8	9	1.5	2.0	SE	0.50	4.0	SE	60.8	55.8	55.8	30.181	0.00	0.00	0.044	0.000
10/22/24	10:15p	60.4	60.8	60.3	10	3.5	1.0	SE	0.25	3.0	SE	60.4	55.6	55.6	30.183	0.00	0.00	0.048	0.000
10/22/24	10:30p	59.2	60.5	59.2	12	6.5	1.0	SE	0.25	3.0	SE	59.2	54.6	54.6	30.187	0.00	0.00	0.060	0.000
10/22/24	10:45p	58.8	59.2	58.8	12	6.2	2.0	SSE	0.50	4.0	SSE	58.8	54.2	54.2	30.188	0.00	0.00	0.065	0.000
10/22/24	11:00p	57.7	58.8	57.6	15	10.3	1.0	SSE	0.25	5.0	S	57.7	53.4	53.4	30.191	0.00	0.00	0.076	0.000
10/22/24	11:15p	58.3	58.3	57.7	15	10.8	1.0	SE	0.25	4.0	SSE	58.3	53.8	53.8	30.191	0.00	0.00	0.070	0.000
10/22/24	11:30p	58.0	58.6	58.0	14	9.0	0.0	SE	0.00	2.0	SE	58.0	53.6	53.6	30.191	0.00	0.00	0.073	0.000
10/22/24	11:45p	57.5	58.0	57.4	16	11.6	1.0	SE	0.25	3.0	SE	57.5	53.3	53.3	30.194	0.00	0.00	0.078	0.000
10/23/24	12:00a	57.7	57.7	57.3	18	14.4	1.0	SE	0.25	4.0	SSE	57.7	53.5	53.5	30.196	0.00	0.00	0.076	0.000

NKSP 10/23/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/23/24	12:15a	57.1	57.6	57.1	18	13.9	1.0	S	0.25	5.0	S	57.1	53.1	53.1	30.193	0.00	0.00	0.082	0.000
10/23/24	12:30a	57.5	57.5	56.8	13	6.9	2.0	S	0.50	6.0	SSE	57.5	53.2	53.2	30.193	0.00	0.00	0.078	0.000
10/23/24	12:45a	57.6	58.0	57.6	13	7.0	1.0	S	0.25	5.0	S	57.6	53.3	53.3	30.200	0.00	0.00	0.077	0.000
10/23/24	1:00a	56.3	57.6	56.3	15	9.2	1.0	SSE	0.25	4.0	SSE	56.3	52.2	52.2	30.200	0.00	0.00	0.091	0.000
10/23/24	1:15a	55.7	56.3	55.5	18	12.8	3.0	ESE	0.75	4.0	ESE	55.7	51.9	51.9	30.201	0.00	0.00	0.097	0.000
10/23/24	1:30a	56.0	56.0	55.7	18	13.0	0.0	ESE	0.00	3.0	ESE	56.0	52.1	52.1	30.207	0.00	0.00	0.094	0.000
10/23/24	1:45a	55.7	56.1	55.6	16	10.1	0.0	ESE	0.00	2.0	ESE	55.7	51.8	51.8	30.207	0.00	0.00	0.097	0.000
10/23/24	2:00a	54.9	55.7	54.8	18	12.1	2.0	ESE	0.50	4.0	ESE	54.9	51.3	51.3	30.204	0.00	0.00	0.105	0.000
10/23/24	2:15a	54.5	54.8	54.5	19	13.0	3.0	ESE	0.75	6.0	ESE	54.5	51.0	51.0	30.205	0.00	0.00	0.109	0.000
10/23/24	2:30a	54.2	54.7	54.2	17	10.3	2.0	ESE	0.50	6.0	ESE	54.2	50.7	50.7	30.213	0.00	0.00	0.112	0.000
10/23/24	2:45a	53.3	54.2	53.2	18	10.8	3.0	SE	0.75	5.0	SE	53.3	50.0	50.0	30.211	0.00	0.00	0.122	0.000
10/23/24	3:00a	52.8	53.3	52.8	19	11.6	2.0	SE	0.50	4.0	SE	52.8	49.7	49.7	30.205	0.00	0.00	0.127	0.000
10/23/24	3:15a	52.8	52.9	52.7	21	13.9	2.0	SE	0.50	4.0	SE	52.8	49.8	49.8	30.200	0.00	0.00	0.127	0.000
10/23/24	3:30a	52.6	52.9	52.6	20	12.6	0.0	SE	0.00	2.0	SE	52.6	49.6	49.6	30.204	0.00	0.00	0.129	0.000
10/23/24	3:45a	51.8	52.5	51.8	23	15.1	0.0	SE	0.00	3.0	SSE	51.8	49.2	49.2	30.206	0.00	0.00	0.138	0.000
10/23/24	4:00a	51.9	51.9	51.8	23	15.2	1.0	SSE	0.25	4.0	SSE	51.9	49.2	49.2	30.199	0.00	0.00	0.136	0.000
10/23/24	4:15a	52.0	52.1	51.9	22	14.3	0.0	SSE	0.00	3.0	SSE	52.0	49.3	49.3	30.197	0.00	0.00	0.135	0.000
10/23/24	4:30a	51.0	51.9	51.0	23	14.4	1.0	SSE	0.25	3.0	SSE	51.0	48.5	48.5	30.200	0.00	0.00	0.146	0.000
10/23/24	4:45a	50.2	51.0	50.2	25	15.7	1.0	SE	0.25	3.0	SSE	50.2	48.0	48.0	30.200	0.00	0.00	0.154	0.000
10/23/24	5:00a	50.2	50.2	50.0	26	16.6	0.0	SE	0.00	3.0	SE	50.2	48.1	48.1	30.199	0.00	0.00	0.154	0.000
10/23/24	5:15a	50.0	50.2	50.0	26	16.4	0.0	S	0.00	2.0	S	50.0	47.9	47.9	30.200	0.00	0.00	0.156	0.000
10/23/24	5:30a	49.5	50.1	49.5	26	16.0	1.0	SSE	0.25	4.0	S	49.5	47.4	47.4	30.204	0.00	0.00	0.161	0.000
10/23/24	5:45a	49.0	49.5	49.0	26	15.6	1.0	SSE	0.25	4.0	SSE	49.0	46.9	46.9	30.205	0.00	0.00	0.167	0.000
10/23/24	6:00a	48.9	49.1	48.8	27	16.3	2.0	SE	0.50	5.0	SE	48.9	46.9	46.9	30.210	0.00	0.00	0.168	0.000
10/23/24	6:15a	48.7	48.9	48.7	27	16.2	2.0	SE	0.50	4.0	SE	48.7	46.7	46.7	30.208	0.00	0.00	0.170	0.000
10/23/24	6:30a	48.2	48.7	48.2	28	16.6	2.0	SE	0.50	4.0	SE	48.2	46.3	46.3	30.206	0.00	0.00	0.175	0.000
10/23/24	6:45a	48.1	48.2	48.0	28	16.5	1.0	SE	0.25	3.0	SE	48.1	46.2	46.2	30.212	0.00	0.00	0.176	0.000
10/23/24	7:00a	48.1	48.2	48.1	29	17.3	1.0	SE	0.25	3.0	SE	48.1	46.2	46.2	30.212	0.00	0.00	0.176	0.000
10/23/24	7:15a	48.5	48.5	48.1	29	17.6	2.0	SE	0.50	5.0	SE	48.5	46.6	46.6	30.212	0.00	0.00	0.172	0.000
10/23/24	7:30a	48.5	48.5	48.4	28	16.8	2.0	SE	0.50	5.0	SE	48.5	46.5	46.5	30.214	0.00	0.00	0.172	0.000
10/23/24	7:45a	49.0	49.0	48.4	28	17.3	3.0	SE	0.75	6.0	ESE	49.5	47.0	46.5	30.218	0.00	0.00	0.167	0.000
10/23/24	8:00a	50.3	50.3	49.0	25	15.8	2.0	SE	0.50	4.0	SE	50.3	48.1	48.1	30.219	0.00	0.00	0.153	0.000
10/23/24	8:15a	51.2	51.2	50.3	24	15.6	2.0	SE	0.50	4.0	SE	51.2	48.7	48.7	30.222	0.00	0.00	0.144	0.000
10/23/24	8:30a	52.3	52.3	51.2	23	15.5	1.0	SE	0.25	4.0	SE	52.3	49.5	49.5	30.231	0.00	0.00	0.132	0.000
10/23/24	8:45a	53.8	53.8	52.3	22	15.8	1.0	SE	0.25	4.0	SE	53.8	50.6	50.6	30.235	0.00	0.00	0.117	0.000
10/23/24	9:00a	55.9	55.9	53.8	19	14.2	2.0	SE	0.50	4.0	SE	55.9	52.1	52.1	30.235	0.00	0.00	0.095	0.000
10/23/24	9:15a	58.3	58.3	55.9	15	10.8	1.0	SSE	0.25	4.0	SSE	58.3	53.8	53.8	30.238	0.00	0.00	0.070	0.000
10/23/24	9:30a	60.4	60.4	58.3	12	7.5	2.0	SSE	0.50	5.0	SE	60.4	55.6	55.6	30.237	0.00	0.00	0.048	0.000
10/23/24	9:45a	62.3	62.3	60.4	8	0.1	2.0	SSE	0.50	5.0	S	62.3	56.9	56.9	30.237	0.00	0.00	0.028	0.000
10/23/24	10:00a	63.6	63.6	62.2	7	-1.8	2.0	S	0.50	7.0	SE	63.6	57.8	57.8	30.239	0.00	0.00	0.015	0.000
10/23/24	10:15a	65.2	65.2	63.6	5	-7.6	1.0	S	0.25	6.0	SSW	65.2	58.8	58.8	30.238	0.00	0.00	0.000	0.002
10/23/24	10:30a	66.2	66.2	65.2	3	-17.2	2.0	SW	0.50	7.0	S	66.2	59.5	59.5	30.239	0.00	0.00	0.000	0.012
10/23/24	10:45a	66.8	66.8	66.1	1	-37.2	2.0	SW	0.50	8.0	WSW	66.8	59.8	59.8	30.234	0.00	0.00	0.000	0.019
10/23/24	11:00a	68.6	68.7	66.8	0	---	1.0	SSW	0.25	6.0	S	68.6	61.8	61.8	30.231	0.00	0.00	0.000	0.037
10/23/24	11:15a	70.0	70.0	68.7	0	---	2.0	SW	0.50	8.0	SSW	70.0	63.9	63.9	30.228	0.00	0.00	0.000	0.052
10/23/24	11:30a	71.5	71.5	70.0	0	---	2.0	SSW	0.50	6.0	SSW	71.5	65.8	65.8	30.223	0.00	0.00	0.000	0.068
10/23/24	11:45a	71.9	71.9	71.5	0	---	1.0	SW	0.25	4.0	WSW	71.9	66.4	66.4	30.214	0.00	0.00	0.000	0.072
10/23/24	12:00p	72.6	72.6	71.9	0	---	2.0	W	0.50	7.0	W	72.6	67.2	67.2	30.211	0.00	0.00	0.000	0.079
10/23/24	12:15p	73.3	73.3	72.5	0	---	2.0	W	0.50	6.0	WNW	73.3	68.1	68.1	30.206	0.00	0.00	0.000	0.086
10/23/24	12:30p	74.3	74.3	73.3	0	---	4.0	NW	1.00	10.0	NW	74.3	69.5	69.5	30.200	0.00	0.00	0.000	0.097

NKSP 10/23/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/23/24	12:45p	74.6	74.6	74.3	0	---	4.0	WNW	1.00	10.0	W	74.6	69.8	69.8	30.192	0.00	0.00	0.000	0.100
10/23/24	1:00p	75.2	75.2	74.6	0	---	3.0	NW	0.75	8.0	W	75.2	70.5	70.5	30.191	0.00	0.00	0.000	0.106
10/23/24	1:15p	76.4	76.4	75.2	0	---	2.0	W	0.50	6.0	W	76.4	71.9	71.9	30.185	0.00	0.00	0.000	0.119
10/23/24	1:30p	77.4	77.4	76.4	0	---	3.0	WNW	0.75	9.0	WNW	77.4	73.0	73.0	30.180	0.00	0.00	0.000	0.129
10/23/24	1:45p	77.5	77.6	77.4	0	---	4.0	NW	1.00	10.0	NNW	77.5	73.1	73.1	30.173	0.00	0.00	0.000	0.130
10/23/24	2:00p	78.4	78.4	77.5	0	---	5.0	WNW	1.25	10.0	NW	78.4	73.9	73.9	30.169	0.00	0.00	0.000	0.140
10/23/24	2:15p	79.0	79.0	78.4	0	---	4.0	NNW	1.00	10.0	W	79.0	74.5	74.5	30.163	0.00	0.00	0.000	0.146
10/23/24	2:30p	79.1	79.2	79.0	0	---	4.0	NW	1.00	11.0	NW	79.1	74.6	74.6	30.160	0.00	0.00	0.000	0.147
10/23/24	2:45p	80.1	80.1	79.2	0	---	4.0	NW	1.00	10.0	NW	80.1	75.6	75.6	30.159	0.00	0.00	0.000	0.157
10/23/24	3:00p	79.8	80.2	79.7	0	---	5.0	NW	1.25	10.0	NW	79.8	75.3	75.3	30.155	0.00	0.00	0.000	0.154
10/23/24	3:15p	80.4	80.4	79.8	0	---	5.0	NNE	1.25	11.0	NNE	80.4	75.9	75.9	30.155	0.00	0.00	0.000	0.160
10/23/24	3:30p	80.5	80.5	80.2	0	---	5.0	NW	1.25	11.0	N	80.5	75.9	75.9	30.153	0.00	0.00	0.000	0.161
10/23/24	3:45p	80.6	80.7	80.4	0	---	5.0	NW	1.25	10.0	NNW	80.6	76.0	76.0	30.146	0.00	0.00	0.000	0.162
10/23/24	4:00p	81.0	81.0	80.6	0	---	4.0	NNW	1.00	11.0	NW	81.0	76.4	76.4	30.144	0.00	0.00	0.000	0.167
10/23/24	4:15p	81.0	81.2	80.9	0	---	5.0	NW	1.25	10.0	NW	81.0	76.4	76.4	30.147	0.00	0.00	0.000	0.167
10/23/24	4:30p	81.1	81.1	80.9	0	---	3.0	NW	0.75	8.0	NNW	81.1	76.5	76.5	30.143	0.00	0.00	0.000	0.168
10/23/24	4:45p	80.9	81.1	80.9	0	---	3.0	NNE	0.75	7.0	NNE	80.9	76.3	76.3	30.137	0.00	0.00	0.000	0.166
10/23/24	5:00p	81.0	81.0	80.9	0	---	2.0	NNW	0.50	5.0	NNW	81.0	76.4	76.4	30.132	0.00	0.00	0.000	0.167
10/23/24	5:15p	80.9	81.1	80.9	0	---	2.0	NW	0.50	5.0	WNW	80.9	76.3	76.3	30.133	0.00	0.00	0.000	0.166
10/23/24	5:30p	80.7	80.9	80.7	0	---	1.0	NNW	0.25	3.0	NW	80.7	76.1	76.1	30.132	0.00	0.00	0.000	0.164
10/23/24	5:45p	80.4	80.7	80.3	0	---	1.0	NNW	0.25	3.0	NNW	80.4	75.9	75.9	30.131	0.00	0.00	0.000	0.160
10/23/24	6:00p	79.6	80.3	79.6	0	---	1.0	NNW	0.25	2.0	NNW	79.6	75.1	75.1	30.132	0.00	0.00	0.000	0.152
10/23/24	6:15p	78.7	79.6	78.7	0	---	0.0	NNW	0.00	2.0	NNW	78.7	74.2	74.2	30.129	0.00	0.00	0.000	0.143
10/23/24	6:30p	77.8	78.7	77.8	0	---	0.0	---	0.00	0.0	---	77.8	73.3	73.3	30.127	0.00	0.00	0.000	0.133
10/23/24	6:45p	76.9	77.8	76.8	0	---	0.0	SSW	0.00	2.0	SSW	76.9	72.5	72.5	30.128	0.00	0.00	0.000	0.124
10/23/24	7:00p	75.1	76.9	75.1	0	---	1.0	SSW	0.25	2.0	SSW	75.1	70.4	70.4	30.143	0.00	0.00	0.000	0.105
10/23/24	7:15p	73.9	75.1	73.9	0	---	0.0	S	0.00	1.0	S	73.9	69.0	69.0	30.149	0.00	0.00	0.000	0.093
10/23/24	7:30p	72.8	73.9	72.8	0	---	0.0	---	0.00	0.0	---	72.8	67.5	67.5	30.150	0.00	0.00	0.000	0.081
10/23/24	7:45p	71.9	72.8	71.9	0	---	0.0	---	0.00	0.0	---	71.9	66.4	66.4	30.151	0.00	0.00	0.000	0.072
10/23/24	8:00p	71.1	71.9	71.0	0	---	0.0	---	0.00	0.0	---	71.1	65.3	65.3	30.151	0.00	0.00	0.000	0.064
10/23/24	8:15p	70.9	71.0	70.7	0	---	0.0	---	0.00	0.0	---	70.9	65.1	65.1	30.155	0.00	0.00	0.000	0.061
10/23/24	8:30p	70.2	70.9	70.2	0	---	0.0	---	0.00	0.0	---	70.2	64.2	64.2	30.153	0.00	0.00	0.000	0.054
10/23/24	8:45p	68.3	70.1	68.3	1	-36.2	1.0	SE	0.25	4.0	S	68.3	61.4	61.4	30.148	0.00	0.00	0.000	0.034
10/23/24	9:00p	66.2	68.2	66.1	4	-11.4	3.0	SE	0.75	5.0	SE	66.2	59.6	59.6	30.150	0.00	0.00	0.000	0.012
10/23/24	9:15p	65.2	66.2	65.2	6	-3.8	3.0	SE	0.75	5.0	SE	65.2	59.0	59.0	30.150	0.00	0.00	0.000	0.002
10/23/24	9:30p	63.6	65.2	63.6	10	5.9	3.0	ESE	0.75	7.0	ESE	63.6	58.4	58.4	30.151	0.00	0.00	0.015	0.000
10/23/24	9:45p	63.0	63.6	63.0	15	14.6	4.0	ESE	1.00	7.0	ESE	63.0	57.9	57.9	30.149	0.00	0.00	0.021	0.000
10/23/24	10:00p	61.8	63.0	61.8	17	16.5	3.0	ESE	0.75	6.0	ESE	61.8	57.0	57.0	30.152	0.00	0.00	0.033	0.000
10/23/24	10:15p	60.9	61.8	60.9	18	17.0	3.0	ESE	0.75	6.0	ESE	60.9	56.3	56.3	30.149	0.00	0.00	0.043	0.000
10/23/24	10:30p	60.6	60.9	60.4	16	14.1	2.0	SE	0.50	4.0	ESE	60.6	55.9	55.9	30.154	0.00	0.00	0.046	0.000
10/23/24	10:45p	58.8	60.5	58.8	16	12.6	2.0	SE	0.50	4.0	SE	58.8	54.3	54.3	30.159	0.00	0.00	0.065	0.000
10/23/24	11:00p	58.3	58.7	58.3	16	12.2	2.0	SE	0.50	4.0	SE	58.3	53.9	53.9	30.155	0.00	0.00	0.070	0.000
10/23/24	11:15p	58.1	58.4	58.0	18	14.8	3.0	SE	0.75	5.0	SE	58.1	53.9	53.9	30.152	0.00	0.00	0.072	0.000
10/23/24	11:30p	57.8	58.2	57.7	19	15.7	3.0	SE	0.75	5.0	SE	57.8	53.7	53.7	30.154	0.00	0.00	0.075	0.000
10/23/24	11:45p	57.2	57.8	57.2	20	16.4	1.0	SE	0.25	5.0	SE	57.2	53.3	53.3	30.149	0.00	0.00	0.081	0.000
10/24/24	12:00a	56.9	57.2	56.6	22	18.4	0.0	SE	0.00	2.0	SE	56.9	53.1	53.1	30.148	0.00	0.00	0.084	0.000

NKSP 10/22/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/22/24	12:15a	75.6	38	48.2	74.4	7.34	.0739	350	1	100.0	15
10/22/24	12:30a	75.5	38	48.1	74.3	7.34	.0739	352	1	100.0	15
10/22/24	12:45a	75.6	37	47.5	74.3	7.24	.0739	351	1	100.0	15
10/22/24	1:00a	75.7	37	47.6	74.4	7.24	.0739	351	1	100.0	15
10/22/24	1:15a	75.7	37	47.6	74.4	7.24	.0739	351	1	100.0	15
10/22/24	1:30a	75.8	37	47.7	74.5	7.23	.0739	351	1	100.0	15
10/22/24	1:45a	75.8	37	47.7	74.5	7.23	.0739	352	1	100.0	15
10/22/24	2:00a	75.8	37	47.7	74.5	7.23	.0739	351	1	100.0	15
10/22/24	2:15a	75.7	37	47.6	74.4	7.24	.0739	351	1	100.0	15
10/22/24	2:30a	75.6	36	46.8	74.3	7.04	.0740	351	1	100.0	15
10/22/24	2:45a	75.6	37	47.5	74.3	7.24	.0740	352	1	100.0	15
10/22/24	3:00a	75.5	36	46.7	74.2	7.04	.0740	351	1	100.0	15
10/22/24	3:15a	75.3	36	46.5	74.0	7.04	.0740	351	1	100.0	15
10/22/24	3:30a	75.2	36	46.4	73.9	7.05	.0741	351	1	100.0	15
10/22/24	3:45a	75.1	37	47.0	73.8	7.25	.0740	352	1	100.0	15
10/22/24	4:00a	74.9	37	46.9	73.6	7.25	.0741	351	1	100.0	15
10/22/24	4:15a	75.0	37	47.0	73.7	7.25	.0741	351	1	100.0	15
10/22/24	4:30a	74.9	37	46.9	73.6	7.25	.0741	351	1	100.0	15
10/22/24	4:45a	74.8	37	46.8	73.5	7.25	.0741	351	1	100.0	15
10/22/24	5:00a	74.6	37	46.6	73.3	7.26	.0742	352	1	100.0	15
10/22/24	5:15a	74.6	37	46.6	73.3	7.26	.0742	351	1	100.0	15
10/22/24	5:30a	74.6	37	46.6	73.3	7.26	.0742	351	1	100.0	15
10/22/24	5:45a	74.6	37	46.6	73.3	7.26	.0742	351	1	100.0	15
10/22/24	6:00a	74.6	38	47.3	73.3	7.37	.0742	352	1	100.0	15
10/22/24	6:15a	74.6	38	47.3	73.3	7.37	.0742	351	1	100.0	15
10/22/24	6:30a	74.4	37	46.4	73.1	7.26	.0742	351	1	100.0	15
10/22/24	6:45a	74.4	37	46.4	73.1	7.26	.0742	351	1	100.0	15
10/22/24	7:00a	74.3	37	46.3	73.0	7.26	.0743	351	1	100.0	15
10/22/24	7:15a	74.4	37	46.4	73.1	7.26	.0742	352	1	100.0	15
10/22/24	7:30a	74.4	37	46.4	73.1	7.26	.0742	351	1	100.0	15
10/22/24	7:45a	74.2	37	46.2	72.8	7.27	.0743	351	1	100.0	15
10/22/24	8:00a	74.2	37	46.2	72.8	7.27	.0743	351	1	100.0	15
10/22/24	8:15a	74.3	37	46.3	73.0	7.26	.0743	352	1	100.0	15
10/22/24	8:30a	74.5	37	46.5	73.2	7.26	.0742	351	1	100.0	15
10/22/24	8:45a	74.6	37	46.6	73.3	7.26	.0743	351	1	100.0	15
10/22/24	9:00a	74.7	37	46.7	73.4	7.26	.0742	351	1	100.0	15
10/22/24	9:15a	74.9	37	46.9	73.6	7.25	.0742	352	1	100.0	15
10/22/24	9:30a	75.2	36	46.4	73.9	7.05	.0742	351	1	100.0	15
10/22/24	9:45a	74.9	37	46.9	73.6	7.25	.0742	351	1	100.0	15
10/22/24	10:00a	75.3	37	47.2	74.0	7.24	.0742	351	1	100.0	15
10/22/24	10:15a	75.4	37	47.3	74.1	7.24	.0741	351	1	100.0	15
10/22/24	10:30a	75.5	37	47.4	74.2	7.24	.0741	352	1	100.0	15
10/22/24	10:45a	75.7	37	47.6	74.4	7.24	.0741	351	1	100.0	15
10/22/24	11:00a	76.0	37	47.8	74.7	7.23	.0740	351	1	100.0	15
10/22/24	11:15a	76.1	37	47.9	74.8	7.23	.0740	351	1	100.0	15
10/22/24	11:30a	76.4	37	48.2	75.1	7.22	.0739	352	1	100.0	15
10/22/24	11:45a	76.8	37	48.6	75.5	7.21	.0739	351	1	100.0	15
10/22/24	12:00p	76.9	37	48.6	75.6	7.21	.0738	351	1	100.0	15
10/22/24	12:15p	77.1	37	48.8	75.8	7.21	.0738	351	1	100.0	15
10/22/24	12:30p	77.4	37	49.1	76.0	7.20	.0737	351	1	100.0	15

NKSP 10/22/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/22/24	12:45p	77.6	36	48.5	76.1	7.00	.0737	352	1	100.0	15
10/22/24	1:00p	77.9	36	48.8	76.4	6.99	.0736	351	1	100.0	15
10/22/24	1:15p	78.1	36	49.0	76.6	6.99	.0736	351	1	100.0	15
10/22/24	1:30p	78.2	37	49.8	76.8	7.19	.0735	351	1	100.0	15
10/22/24	1:45p	78.2	37	49.8	76.8	7.19	.0735	352	1	100.0	15
10/22/24	2:00p	78.4	37	50.0	77.0	7.18	.0735	351	1	100.0	15
10/22/24	2:15p	78.5	37	50.1	77.1	7.18	.0734	351	1	100.0	15
10/22/24	2:30p	78.1	36	49.0	76.6	6.99	.0735	351	1	100.0	15
10/22/24	2:45p	78.1	35	48.2	76.5	6.89	.0735	352	1	100.0	15
10/22/24	3:00p	78.1	36	49.0	76.6	6.99	.0735	351	1	100.0	15
10/22/24	3:15p	78.0	37	49.6	76.6	7.19	.0735	351	1	100.0	15
10/22/24	3:30p	77.8	37	49.4	76.4	7.19	.0735	351	1	100.0	15
10/22/24	3:45p	77.8	36	48.7	76.3	6.99	.0736	351	1	100.0	15
10/22/24	4:00p	78.1	35	48.2	76.5	6.89	.0735	352	1	100.0	15
10/22/24	4:15p	78.0	37	49.6	76.6	7.19	.0734	351	1	100.0	15
10/22/24	4:30p	77.9	37	49.5	76.5	7.19	.0735	351	1	100.0	15
10/22/24	4:45p	77.8	36	48.7	76.3	6.99	.0735	351	1	100.0	15
10/22/24	5:00p	77.9	35	48.0	76.3	6.89	.0735	352	1	100.0	15
10/22/24	5:15p	78.1	35	48.2	76.5	6.89	.0735	351	1	100.0	15
10/22/24	5:30p	78.1	37	49.7	76.7	7.19	.0734	351	1	100.0	15
10/22/24	5:45p	78.0	37	49.6	76.6	7.19	.0734	351	1	100.0	15
10/22/24	6:00p	78.0	36	48.9	76.5	6.99	.0735	352	1	100.0	15
10/22/24	6:15p	78.3	35	48.4	76.7	6.88	.0734	351	1	100.0	15
10/22/24	6:30p	78.3	36	49.1	76.8	6.98	.0734	351	1	100.0	15
10/22/24	6:45p	78.0	37	49.6	76.6	7.19	.0735	351	1	100.0	15
10/22/24	7:00p	77.7	37	49.3	76.3	7.20	.0735	351	1	100.0	15
10/22/24	7:15p	77.8	36	48.7	76.3	6.99	.0736	352	1	100.0	15
10/22/24	7:30p	77.8	36	48.7	76.3	6.99	.0736	351	1	100.0	15
10/22/24	7:45p	77.4	37	49.1	76.0	7.20	.0736	351	1	100.0	15
10/22/24	8:00p	77.1	37	48.8	75.8	7.21	.0736	351	1	100.0	15
10/22/24	8:15p	77.0	36	48.0	75.6	7.01	.0737	352	1	100.0	15
10/22/24	8:30p	76.6	39	49.8	75.4	7.52	.0737	351	1	100.0	15
10/22/24	8:45p	76.0	39	49.2	74.8	7.53	.0738	351	1	100.0	15
10/22/24	9:00p	76.2	37	48.0	74.9	7.23	.0738	351	1	100.0	15
10/22/24	9:15p	76.0	40	49.9	74.9	7.63	.0738	352	1	100.0	15
10/22/24	9:30p	75.5	40	49.5	74.4	7.64	.0739	351	1	100.0	15
10/22/24	9:45p	75.8	38	48.4	74.6	7.33	.0739	351	1	100.0	15
10/22/24	10:00p	75.5	41	50.1	74.5	7.75	.0739	351	1	100.0	15
10/22/24	10:15p	75.5	40	49.5	74.4	7.64	.0739	351	1	100.0	15
10/22/24	10:30p	75.8	40	49.8	74.7	7.63	.0739	352	1	100.0	15
10/22/24	10:45p	75.6	40	49.6	74.5	7.64	.0739	351	1	100.0	15
10/22/24	11:00p	75.5	40	49.5	74.4	7.64	.0739	351	1	100.0	15
10/22/24	11:15p	75.8	40	49.8	74.7	7.63	.0739	351	1	100.0	15
10/22/24	11:30p	74.7	41	49.4	73.7	7.76	.0741	352	1	100.0	15
10/22/24	11:45p	75.0	40	49.0	73.9	7.65	.0740	351	1	100.0	15
10/23/24	12:00a	75.4	40	49.4	74.3	7.64	.0740	351	1	100.0	15

NKSP 10/23/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/23/24	12:15a	75.6	40	49.6	74.5	7.64	.0739	351	1	100.0	15
10/23/24	12:30a	74.7	41	49.4	73.7	7.76	.0741	351	1	100.0	15
10/23/24	12:45a	74.8	40	48.9	73.7	7.65	.0741	351	1	100.0	15
10/23/24	1:00a	75.0	40	49.0	73.9	7.65	.0740	351	1	100.0	15
10/23/24	1:15a	75.2	40	49.2	74.1	7.65	.0740	351	1	100.0	15
10/23/24	1:30a	75.3	40	49.3	74.2	7.64	.0740	352	1	100.0	15
10/23/24	1:45a	75.4	40	49.4	74.3	7.64	.0740	351	1	100.0	15
10/23/24	2:00a	75.4	40	49.4	74.3	7.64	.0740	351	1	100.0	15
10/23/24	2:15a	75.3	39	48.6	74.1	7.54	.0740	351	1	100.0	15
10/23/24	2:30a	75.3	39	48.6	74.1	7.54	.0741	352	1	100.0	15
10/23/24	2:45a	75.3	39	48.6	74.1	7.54	.0740	351	1	100.0	15
10/23/24	3:00a	75.2	39	48.5	74.0	7.55	.0740	351	1	100.0	15
10/23/24	3:15a	75.1	39	48.4	73.9	7.55	.0741	351	1	100.0	15
10/23/24	3:30a	75.1	39	48.4	73.9	7.55	.0741	351	1	100.0	15
10/23/24	3:45a	75.0	39	48.4	73.8	7.55	.0741	352	1	100.0	15
10/23/24	4:00a	74.9	39	48.3	73.7	7.55	.0741	351	1	100.0	15
10/23/24	4:15a	74.9	39	48.3	73.7	7.55	.0741	351	1	100.0	15
10/23/24	4:30a	74.9	39	48.3	73.7	7.55	.0741	351	1	100.0	15
10/23/24	4:45a	74.9	39	48.3	73.7	7.55	.0741	352	1	100.0	15
10/23/24	5:00a	74.9	39	48.3	73.7	7.55	.0741	351	1	100.0	15
10/23/24	5:15a	74.7	39	48.1	73.5	7.56	.0741	351	1	100.0	15
10/23/24	5:30a	74.7	39	48.1	73.5	7.56	.0741	351	1	100.0	15
10/23/24	5:45a	74.6	39	48.0	73.4	7.56	.0741	351	1	100.0	15
10/23/24	6:00a	74.6	40	48.7	73.5	7.66	.0741	352	1	100.0	15
10/23/24	6:15a	74.6	39	48.0	73.4	7.56	.0742	351	1	100.0	15
10/23/24	6:30a	74.5	39	47.9	73.3	7.56	.0742	351	1	100.0	15
10/23/24	6:45a	74.4	39	47.8	73.2	7.56	.0742	351	1	100.0	15
10/23/24	7:00a	74.4	39	47.8	73.2	7.56	.0742	352	1	100.0	15
10/23/24	7:15a	74.3	39	47.7	73.1	7.56	.0742	351	1	100.0	15
10/23/24	7:30a	74.3	39	47.7	73.1	7.56	.0742	351	1	100.0	15
10/23/24	7:45a	74.2	39	47.6	73.0	7.57	.0742	351	1	100.0	15
10/23/24	8:00a	74.3	39	47.7	73.1	7.56	.0742	352	1	100.0	15
10/23/24	8:15a	74.4	39	47.8	73.2	7.56	.0742	351	1	100.0	15
10/23/24	8:30a	74.5	39	47.9	73.3	7.56	.0742	351	1	100.0	15
10/23/24	8:45a	74.8	39	48.2	73.6	7.55	.0742	351	1	100.0	15
10/23/24	9:00a	74.9	39	48.3	73.7	7.55	.0742	351	1	100.0	15
10/23/24	9:15a	75.1	39	48.4	73.9	7.55	.0741	352	1	100.0	15
10/23/24	9:30a	75.3	39	48.6	74.1	7.54	.0741	351	1	100.0	15
10/23/24	9:45a	75.6	39	48.9	74.4	7.54	.0741	351	1	100.0	15
10/23/24	10:00a	75.1	39	48.4	73.9	7.55	.0742	352	1	100.0	15
10/23/24	10:15a	75.4	39	48.7	74.2	7.54	.0741	351	1	100.0	15
10/23/24	10:30a	75.7	38	48.3	74.5	7.34	.0741	351	1	100.0	15
10/23/24	10:45a	75.5	40	49.5	74.4	7.64	.0740	351	1	100.0	15
10/23/24	11:00a	75.8	37	47.7	74.5	7.23	.0741	351	1	100.0	15
10/23/24	11:15a	75.7	39	49.0	74.5	7.54	.0740	352	1	100.0	15
10/23/24	11:30a	75.6	39	48.9	74.4	7.54	.0740	351	1	100.0	15
10/23/24	11:45a	76.1	38	48.6	74.9	7.33	.0739	351	1	100.0	15
10/23/24	12:00p	75.9	39	49.2	74.7	7.53	.0739	351	1	100.0	15
10/23/24	12:15p	75.9	39	49.2	74.7	7.53	.0739	351	1	100.0	15
10/23/24	12:30p	76.2	37	48.0	74.9	7.23	.0739	352	1	100.0	15

NKSP 10/23/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/23/24	12:45p	76.7	38	49.2	75.5	7.32	.0738	351	1	100.0	15
10/23/24	1:00p	76.6	38	49.1	75.4	7.32	.0738	351	1	100.0	15
10/23/24	1:15p	76.4	38	48.9	75.2	7.32	.0738	351	1	100.0	15
10/23/24	1:30p	76.9	36	47.9	75.5	7.01	.0738	352	1	100.0	15
10/23/24	1:45p	77.0	38	49.4	75.7	7.31	.0737	351	1	100.0	15
10/23/24	2:00p	77.0	38	49.4	75.7	7.31	.0737	351	1	100.0	15
10/23/24	2:15p	77.0	38	49.4	75.7	7.31	.0737	351	1	100.0	15
10/23/24	2:30p	77.2	36	48.2	75.8	7.01	.0737	352	1	100.0	15
10/23/24	2:45p	77.5	37	49.2	76.1	7.20	.0736	351	1	100.0	15
10/23/24	3:00p	77.6	39	50.7	76.4	7.50	.0735	351	1	100.0	15
10/23/24	3:15p	77.6	39	50.7	76.4	7.50	.0735	351	1	100.0	15
10/23/24	3:30p	77.8	37	49.4	76.4	7.19	.0735	351	1	100.0	15
10/23/24	3:45p	78.0	36	48.9	76.5	6.99	.0735	352	1	100.0	15
10/23/24	4:00p	78.0	38	50.3	76.6	7.29	.0735	351	1	100.0	15
10/23/24	4:15p	77.8	38	50.2	76.5	7.29	.0735	351	1	100.0	15
10/23/24	4:30p	77.7	38	50.1	76.4	7.30	.0735	351	1	100.0	15
10/23/24	4:45p	78.2	36	49.1	76.7	6.99	.0735	352	1	100.0	15
10/23/24	5:00p	78.2	38	50.5	76.8	7.29	.0734	351	1	100.0	15
10/23/24	5:15p	78.1	38	50.4	76.7	7.29	.0734	351	1	100.0	15
10/23/24	5:30p	78.2	37	49.8	76.8	7.19	.0734	351	1	100.0	15
10/23/24	5:45p	78.4	36	49.2	76.9	6.98	.0734	352	1	100.0	15
10/23/24	6:00p	78.3	38	50.6	76.9	7.28	.0734	351	1	100.0	15
10/23/24	6:15p	77.9	39	50.9	76.6	7.49	.0734	351	1	100.0	15
10/23/24	6:30p	77.8	38	50.2	76.5	7.29	.0734	351	1	100.0	15
10/23/24	6:45p	77.9	37	49.5	76.5	7.19	.0735	351	1	100.0	15
10/23/24	7:00p	77.7	39	50.8	76.4	7.50	.0735	352	1	100.0	15
10/23/24	7:15p	77.0	40	50.8	75.9	7.61	.0736	351	1	100.0	15
10/23/24	7:30p	76.9	38	49.4	75.6	7.31	.0737	351	1	100.0	15
10/23/24	7:45p	77.1	39	50.2	75.9	7.51	.0736	351	1	100.0	15
10/23/24	8:00p	76.5	41	51.0	75.5	7.75	.0737	352	1	100.0	15
10/23/24	8:15p	76.4	40	50.3	75.3	7.62	.0737	351	1	100.0	15
10/23/24	8:30p	76.7	39	49.9	75.5	7.52	.0737	351	1	100.0	15
10/23/24	8:45p	76.3	41	50.9	75.3	7.75	.0737	351	1	100.0	15
10/23/24	9:00p	76.0	41	50.6	75.0	7.75	.0737	351	1	100.0	15
10/23/24	9:15p	76.3	40	50.2	75.2	7.62	.0737	352	1	100.0	15
10/23/24	9:30p	75.7	42	51.0	74.8	7.94	.0738	351	1	100.0	15
10/23/24	9:45p	75.6	41	50.2	74.6	7.75	.0738	351	1	100.0	15
10/23/24	10:00p	75.9	43	51.8	75.1	8.05	.0737	351	1	100.0	15
10/23/24	10:15p	75.4	44	52.0	74.7	8.24	.0738	352	1	100.0	15
10/23/24	10:30p	75.6	41	50.2	74.6	7.75	.0738	351	1	100.0	15
10/23/24	10:45p	75.1	44	51.7	74.4	8.25	.0739	351	1	100.0	15
10/23/24	11:00p	75.2	42	50.5	74.3	7.95	.0739	352	1	100.0	15
10/23/24	11:15p	74.9	44	51.5	74.2	8.25	.0739	351	1	100.0	15
10/23/24	11:30p	74.9	43	50.9	74.1	8.05	.0739	351	1	100.0	15
10/23/24	11:45p	74.6	44	51.2	73.9	8.26	.0739	351	1	100.0	15
10/24/24	12:00a	75.0	41	49.7	74.0	7.75	.0739	351	1	100.0	15

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

OUTSIDE TEMPERATURE RECORD

CDCR 2030 (04/18)

INSTITUTION: MKSP

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the OUTSIDE ambient air temperature.

Using an accurate thermometer located in a central, heat neutral location, the outside air temperature is to be taken every hour, seven (7) days a week.

Thermometer Location: Control

Immediately notify the Watch Commander at extension 3141 when the air temperature reaches 90 degrees.

Date	Time	Temp.	Printed Name
10-24	0100	56	PADILLA
	0200	56	PADILLA
	0300	55	PADILLA
	0400	53	PADILLA
	0500	51	PADILLA
	0600	52	VALENCIA
	0700	48	VALENCIA
	0800	48	VALENCIA
	0900	54	VALENCIA
	1000	59	VALENCIA
	1100	67	VALENCIA
	1200	67	VALENCIA
	1300	69	VALENCIA
	1400	72	MONCIBAIZ
	1500	74	MONCIBAIZ
	1600	75	MONCIBAIZ
	1700	75	MONCIBAIZ
	1800	74	MONCIBAIZ
	1900	69	MONCIBAIZ
	2000	65	MONCIBAIZ
	2100	63	MONCIBAIZ
	2200	60	PADILLA
	2300	55	PADILLA
	2400	53	PADILLA

Date	Time	Temp.	Printed Name
10-25	0100	52	PADILLA
	0200	50	PADILLA
	0300	50	PADILLA
	0400	48	PADILLA
	0500	48	PADILLA
	0600	47	VALENCIA
	0700	46	VALENCIA
	0800	49	VALENCIA
	0900	54	VALENCIA
	1000	63	VALENCIA
	1100	69	VALENCIA
	1200	75	VALENCIA
	1300	76	VALENCIA
	1400	80	MONCIBAIZ
	1500	82	MONCIBAIZ
	1600	83	MONCIBAIZ
	1700	83	MONCIBAIZ
	1800	81	MONCIBAIZ
	1900	77	MONCIBAIZ
	2000	73	MONCIBAIZ
	2100	68	MONCIBAIZ
	2200	62	J. FIERRO
	2300	62	J. FIERRO
	2400	59	J. FIERRO

DISTRIBUTION: Original: Institution Heat Plan Coordinator

NKSP 10/24/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/24/24	12:15a	56.9	57.0	56.8	23	19.4	0.0	SE	0.00	2.0	SE	56.9	53.1	53.1	30.143	0.00	0.00	0.084	0.000
10/24/24	12:30a	56.6	56.8	56.6	23	19.2	0.0	SE	0.00	1.0	SE	56.6	52.9	52.9	30.138	0.00	0.00	0.088	0.000
10/24/24	12:45a	56.5	56.6	56.5	23	19.1	0.0	SE	0.00	1.0	SE	56.5	52.8	52.8	30.138	0.00	0.00	0.089	0.000
10/24/24	1:00a	56.4	56.5	56.4	23	19.0	0.0	---	0.00	0.0	---	56.4	52.7	52.7	30.140	0.00	0.00	0.090	0.000
10/24/24	1:15a	56.3	56.4	56.3	23	18.9	0.0	SE	0.00	1.0	SE	56.3	52.6	52.6	30.132	0.00	0.00	0.091	0.000
10/24/24	1:30a	56.0	56.3	55.9	22	17.6	0.0	SE	0.00	1.0	SE	56.0	52.3	52.3	30.131	0.00	0.00	0.094	0.000
10/24/24	1:45a	56.3	56.3	56.0	20	15.7	0.0	SE	0.00	2.0	SE	56.3	52.5	52.5	30.131	0.00	0.00	0.091	0.000
10/24/24	2:00a	56.0	56.5	56.0	19	14.3	0.0	SE	0.00	2.0	SE	56.0	52.2	52.2	30.129	0.00	0.00	0.094	0.000
10/24/24	2:15a	56.2	56.2	55.6	20	15.6	0.0	---	0.00	0.0	---	56.2	52.4	52.4	30.130	0.00	0.00	0.092	0.000
10/24/24	2:30a	56.5	56.6	56.2	18	13.4	0.0	SE	0.00	1.0	SE	56.5	52.5	52.5	30.127	0.00	0.00	0.089	0.000
10/24/24	2:45a	55.9	56.5	55.9	20	15.3	0.0	---	0.00	0.0	---	55.9	52.1	52.1	30.127	0.00	0.00	0.095	0.000
10/24/24	3:00a	55.1	55.9	55.1	22	16.9	0.0	SE	0.00	1.0	SE	55.1	51.7	51.7	30.130	0.00	0.00	0.103	0.000
10/24/24	3:15a	53.9	55.1	53.9	22	15.9	0.0	SE	0.00	1.0	SE	53.9	50.7	50.7	30.128	0.00	0.00	0.116	0.000
10/24/24	3:30a	53.7	53.9	53.7	22	15.7	0.0	SE	0.00	1.0	SE	53.7	50.5	50.5	30.126	0.00	0.00	0.118	0.000
10/24/24	3:45a	53.6	53.7	53.5	22	15.6	0.0	---	0.00	0.0	---	53.6	50.5	50.5	30.123	0.00	0.00	0.119	0.000
10/24/24	4:00a	53.6	53.7	53.6	22	15.6	0.0	SE	0.00	1.0	SE	53.6	50.5	50.5	30.122	0.00	0.00	0.119	0.000
10/24/24	4:15a	53.4	53.7	53.4	22	15.4	0.0	SE	0.00	1.0	SE	53.4	50.3	50.3	30.122	0.00	0.00	0.121	0.000
10/24/24	4:30a	52.4	53.3	52.3	22	14.6	0.0	SE	0.00	2.0	SE	52.4	49.6	49.6	30.120	0.00	0.00	0.131	0.000
10/24/24	4:45a	51.7	52.3	51.7	25	17.0	0.0	SE	0.00	2.0	SE	51.7	49.2	49.2	30.119	0.00	0.00	0.139	0.000
10/24/24	5:00a	51.7	51.8	51.6	26	17.9	0.0	SE	0.00	1.0	SE	51.7	49.2	49.2	30.123	0.00	0.00	0.139	0.000
10/24/24	5:15a	51.2	51.7	51.2	26	17.4	0.0	---	0.00	0.0	---	51.2	48.8	48.8	30.126	0.00	0.00	0.144	0.000
10/24/24	5:30a	50.7	51.2	50.6	27	17.9	0.0	---	0.00	0.0	---	50.7	48.5	48.5	30.133	0.00	0.00	0.149	0.000
10/24/24	5:45a	51.6	51.7	50.7	26	17.8	0.0	WSW	0.00	3.0	WSW	51.6	49.1	49.1	30.134	0.00	0.00	0.140	0.000
10/24/24	6:00a	52.0	52.0	51.6	27	19.0	0.0	WSW	0.00	3.0	WSW	52.0	49.5	49.5	30.135	0.00	0.00	0.135	0.000
10/24/24	6:15a	51.3	52.0	51.3	26	17.5	0.0	WSW	0.00	1.0	WSW	51.3	48.9	48.9	30.138	0.00	0.00	0.143	0.000
10/24/24	6:30a	50.4	51.3	50.4	27	17.6	0.0	SSW	0.00	3.0	SSW	50.4	48.3	48.3	30.140	0.00	0.00	0.152	0.000
10/24/24	6:45a	49.9	50.4	49.9	28	18.0	0.0	S	0.00	2.0	S	49.9	47.9	47.9	30.139	0.00	0.00	0.157	0.000
10/24/24	7:00a	48.8	50.0	48.8	29	17.9	1.0	S	0.25	4.0	SSE	48.8	46.9	46.9	30.142	0.00	0.00	0.169	0.000
10/24/24	7:15a	48.0	48.8	48.0	31	18.8	1.0	S	0.25	3.0	S	48.0	46.1	46.1	30.141	0.00	0.00	0.177	0.000
10/24/24	7:30a	47.9	48.0	47.8	31	18.7	0.0	S	0.00	2.0	S	47.9	46.0	46.0	30.136	0.00	0.00	0.178	0.000
10/24/24	7:45a	47.8	48.0	47.8	31	18.6	1.0	S	0.25	4.0	S	47.8	46.0	46.0	30.139	0.00	0.00	0.179	0.000
10/24/24	8:00a	48.0	48.0	47.8	31	18.8	0.0	S	0.00	3.0	S	48.0	46.1	46.1	30.147	0.00	0.00	0.177	0.000
10/24/24	8:15a	49.2	49.3	47.9	30	19.0	0.0	---	0.00	0.0	---	49.2	47.3	47.3	30.152	0.00	0.00	0.165	0.000
10/24/24	8:30a	51.5	51.5	49.3	26	17.7	0.0	---	0.00	0.0	---	51.5	49.1	49.1	30.154	0.00	0.00	0.141	0.000
10/24/24	8:45a	53.6	53.6	51.5	18	11.0	0.0	S	0.00	2.0	S	53.6	50.3	50.3	30.159	0.00	0.00	0.119	0.000
10/24/24	9:00a	54.5	54.5	53.7	15	7.7	0.0	SSW	0.00	2.0	S	54.5	50.8	50.8	30.162	0.00	0.00	0.109	0.000
10/24/24	9:15a	55.6	55.6	54.5	13	5.4	0.0	SSW	0.00	3.0	SSW	55.6	51.7	51.7	30.169	0.00	0.00	0.098	0.000
10/24/24	9:30a	56.9	56.9	55.6	11	2.8	0.0	SW	0.00	2.0	SSW	56.9	52.7	52.7	30.165	0.00	0.00	0.084	0.000
10/24/24	9:45a	58.6	58.6	56.9	6	-8.6	1.0	W	0.25	4.0	W	58.6	53.4	53.4	30.167	0.00	0.00	0.067	0.000
10/24/24	10:00a	59.5	59.5	58.6	5	-11.7	1.0	WNW	0.25	6.0	W	59.5	54.0	54.0	30.167	0.00	0.00	0.057	0.000
10/24/24	10:15a	59.9	59.9	59.4	4	-15.8	2.0	W	0.50	7.0	W	59.9	54.2	54.2	30.166	0.00	0.00	0.053	0.000
10/24/24	10:30a	61.0	61.0	59.9	3	-20.7	2.0	W	0.50	7.0	WSW	61.0	55.0	55.0	30.154	0.00	0.00	0.042	0.000
10/24/24	10:45a	62.7	62.7	61.0	0	---	3.0	W	0.75	8.0	W	62.7	56.2	56.2	30.155	0.00	0.00	0.024	0.000
10/24/24	11:00a	63.8	63.8	62.7	---	---	4.0	WSW	1.00	8.0	W	63.8	---	---	30.149	0.00	0.00	0.013	0.000
10/24/24	11:15a	65.1	65.1	63.8	0	---	4.0	SW	1.00	7.0	SW	65.1	58.2	58.2	30.148	0.00	0.00	0.000	0.001
10/24/24	11:30a	65.7	65.7	65.1	0	---	4.0	WSW	1.00	8.0	WSW	65.7	58.7	58.7	30.145	0.00	0.00	0.000	0.007
10/24/24	11:45a	66.7	66.8	65.7	0	---	2.0	SW	0.50	7.0	W	66.7	59.6	59.6	30.145	0.00	0.00	0.000	0.018
10/24/24	12:00p	67.0	67.2	66.8	0	---	2.0	W	0.50	6.0	WNW	67.0	59.9	59.9	30.141	0.00	0.00	0.000	0.021
10/24/24	12:15p	67.1	67.1	66.7	0	---	2.0	WSW	0.50	7.0	WSW	67.1	60.0	60.0	30.134	0.00	0.00	0.000	0.022
10/24/24	12:30p	67.6	67.8	67.1	0	---	3.0	WSW	0.75	7.0	WSW	67.6	60.4	60.4	30.126	0.00	0.00	0.000	0.027

NKSP 10/24/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/24/24	12:45p	68.5	68.5	67.6	0	---	3.0	WSW	0.75	8.0	SSW	68.5	61.6	61.6	30.122	0.00	0.00	0.000	0.036
10/24/24	1:00p	69.1	69.1	68.4	0	---	3.0	SW	0.75	7.0	SW	69.1	62.5	62.5	30.115	0.00	0.00	0.000	0.043
10/24/24	1:15p	69.8	69.8	69.1	0	---	2.0	SW	0.50	8.0	WSW	69.8	63.6	63.6	30.104	0.00	0.00	0.000	0.050
10/24/24	1:30p	70.3	70.4	69.8	0	---	2.0	W	0.50	7.0	W	70.3	64.3	64.3	30.095	0.00	0.00	0.000	0.055
10/24/24	1:45p	70.9	70.9	70.3	0	---	2.0	WNW	0.50	7.0	W	70.9	65.1	65.1	30.085	0.00	0.00	0.000	0.061
10/24/24	2:00p	72.5	72.5	70.9	0	---	1.0	WSW	0.25	4.0	W	72.5	67.1	67.1	30.076	0.00	0.00	0.000	0.078
10/24/24	2:15p	73.1	73.1	72.5	0	---	1.0	W	0.25	6.0	W	73.1	67.8	67.8	30.071	0.00	0.00	0.000	0.084
10/24/24	2:30p	74.1	74.1	73.1	0	---	1.0	W	0.25	4.0	W	74.1	69.2	69.2	30.064	0.00	0.00	0.000	0.095
10/24/24	2:45p	74.6	74.8	74.1	0	---	1.0	NNW	0.25	3.0	WNW	74.6	69.8	69.8	30.053	0.00	0.00	0.000	0.100
10/24/24	3:00p	74.2	74.7	74.2	0	---	1.0	NNE	0.25	4.0	NNE	74.2	69.3	69.3	30.048	0.00	0.00	0.000	0.096
10/24/24	3:15p	74.6	74.6	74.2	0	---	1.0	NNE	0.25	4.0	N	74.6	69.8	69.8	30.042	0.00	0.00	0.000	0.100
10/24/24	3:30p	75.2	75.2	74.6	0	---	2.0	NNE	0.50	5.0	NE	75.2	70.5	70.5	30.038	0.00	0.00	0.000	0.105
10/24/24	3:45p	75.0	75.2	74.8	0	---	2.0	NE	0.50	5.0	NE	75.0	70.3	70.3	30.036	0.00	0.00	0.000	0.104
10/24/24	4:00p	75.5	75.5	75.0	0	---	1.0	NE	0.25	4.0	N	75.5	70.9	70.9	30.030	0.00	0.00	0.000	0.109
10/24/24	4:15p	76.2	76.3	75.5	0	---	1.0	WNW	0.25	4.0	NNW	76.2	71.6	71.6	30.030	0.00	0.00	0.000	0.117
10/24/24	4:30p	75.6	76.1	75.6	0	---	1.0	NNE	0.25	4.0	NW	75.6	71.0	71.0	30.028	0.00	0.00	0.000	0.110
10/24/24	4:45p	75.4	75.9	75.4	0	---	1.0	N	0.25	4.0	NW	75.4	70.7	70.7	30.022	0.00	0.00	0.000	0.108
10/24/24	5:00p	75.6	75.6	75.3	0	---	1.0	N	0.25	3.0	N	75.6	71.0	71.0	30.017	0.00	0.00	0.000	0.110
10/24/24	5:15p	76.1	76.2	75.6	0	---	0.0	NNW	0.00	1.0	NNW	76.1	71.5	71.5	30.011	0.00	0.00	0.000	0.116
10/24/24	5:30p	76.2	76.2	75.8	0	---	0.0	---	0.00	0.0	---	76.2	71.6	71.6	30.011	0.00	0.00	0.000	0.117
10/24/24	5:45p	76.5	76.9	76.2	0	---	1.0	S	0.25	3.0	N	76.5	72.0	72.0	30.008	0.00	0.00	0.000	0.120
10/24/24	6:00p	74.9	76.5	74.9	0	---	1.0	S	0.25	3.0	S	74.9	70.2	70.2	30.006	0.00	0.00	0.000	0.103
10/24/24	6:15p	73.0	74.9	73.0	0	---	0.0	S	0.00	3.0	S	73.0	67.7	67.7	30.008	0.00	0.00	0.000	0.083
10/24/24	6:30p	72.1	72.9	72.1	0	---	0.0	S	0.00	1.0	S	72.1	66.6	66.6	30.008	0.00	0.00	0.000	0.074
10/24/24	6:45p	71.1	72.1	71.1	0	---	0.0	---	0.00	0.0	---	71.1	65.3	65.3	30.009	0.00	0.00	0.000	0.064
10/24/24	7:00p	69.9	71.1	69.9	0	---	0.0	SSE	0.00	2.0	SSE	69.9	63.8	63.8	30.016	0.00	0.00	0.000	0.051
10/24/24	7:15p	68.4	70.0	68.4	0	---	0.0	---	0.00	0.0	---	68.4	61.4	61.4	30.016	0.00	0.00	0.000	0.035
10/24/24	7:30p	67.3	68.4	67.3	2	-24.2	0.0	---	0.00	0.0	---	67.3	60.4	60.4	30.021	0.00	0.00	0.000	0.024
10/24/24	7:45p	66.7	67.3	66.7	3	-16.8	0.0	---	0.00	0.0	---	66.7	59.9	59.9	30.025	0.00	0.00	0.000	0.018
10/24/24	8:00p	65.8	66.7	65.8	5	-7.2	0.0	---	0.00	0.0	---	65.8	59.3	59.3	30.027	0.00	0.00	0.000	0.008
10/24/24	8:15p	65.6	66.0	65.6	6	-3.5	0.0	---	0.00	0.0	---	65.6	59.4	59.4	30.028	0.00	0.00	0.000	0.006
10/24/24	8:30p	64.9	65.6	64.9	7	-0.8	0.0	---	0.00	0.0	---	64.9	59.0	59.0	30.026	0.00	0.00	0.001	0.000
10/24/24	8:45p	64.1	64.8	64.1	8	1.5	0.0	---	0.00	0.0	---	64.1	58.5	58.5	30.031	0.00	0.00	0.009	0.000
10/24/24	9:00p	63.0	64.1	63.0	7	-2.2	0.0	---	0.00	0.0	---	63.0	57.3	57.3	30.036	0.00	0.00	0.021	0.000
10/24/24	9:15p	62.8	63.0	62.8	7	-2.3	0.0	---	0.00	0.0	---	62.8	57.1	57.1	30.035	0.00	0.00	0.023	0.000
10/24/24	9:30p	61.9	62.8	61.9	10	4.6	0.0	---	0.00	0.0	---	61.9	56.9	56.9	30.043	0.00	0.00	0.032	0.000
10/24/24	9:45p	60.9	61.8	60.9	14	11.3	1.0	ESE	0.25	3.0	E	60.9	56.0	56.0	30.046	0.00	0.00	0.043	0.000
10/24/24	10:00p	60.0	60.9	60.0	15	12.1	1.0	E	0.25	3.0	E	60.0	55.3	55.3	30.050	0.00	0.00	0.052	0.000
10/24/24	10:15p	58.7	60.1	58.6	16	12.6	2.0	E	0.50	4.0	E	58.7	54.2	54.2	30.050	0.00	0.00	0.066	0.000
10/24/24	10:30p	57.7	58.6	57.6	18	14.4	1.0	E	0.25	2.0	E	57.7	53.5	53.5	30.051	0.00	0.00	0.076	0.000
10/24/24	10:45p	56.5	57.7	56.5	19	14.7	1.0	E	0.25	2.0	E	56.5	52.6	52.6	30.053	0.00	0.00	0.089	0.000
10/24/24	11:00p	55.9	56.5	55.9	19	14.2	1.0	E	0.25	3.0	E	55.9	52.1	52.1	30.053	0.00	0.00	0.095	0.000
10/24/24	11:15p	55.6	56.0	55.6	19	13.9	2.0	ESE	0.50	4.0	ESE	55.6	51.9	51.9	30.059	0.00	0.00	0.098	0.000
10/24/24	11:30p	54.9	55.5	54.9	19	13.3	2.0	ESE	0.50	4.0	ESE	54.9	51.4	51.4	30.060	0.00	0.00	0.105	0.000
10/24/24	11:45p	54.8	55.0	54.7	21	15.6	2.0	SE	0.50	4.0	SE	54.8	51.4	51.4	30.059	0.00	0.00	0.106	0.000
10/25/24	12:00a	53.6	54.8	53.6	22	15.6	1.0	SE	0.25	4.0	SE	53.6	50.5	50.5	30.063	0.00	0.00	0.119	0.000

NKSP 10/25/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/25/24	12:15a	52.8	53.7	52.8	24	16.9	1.0	S	0.25	3.0	S	52.8	49.9	49.9	30.062	0.00	0.00	0.127	0.000
10/25/24	12:30a	53.0	53.0	52.7	26	19.0	0.0	SSW	0.00	2.0	SSW	53.0	50.2	50.2	30.063	0.00	0.00	0.125	0.000
10/25/24	12:45a	53.1	53.1	53.0	27	20.0	0.0	S	0.00	2.0	SSW	53.1	50.3	50.3	30.063	0.00	0.00	0.124	0.000
10/25/24	1:00a	52.7	53.1	52.6	26	18.7	0.0	---	0.00	0.0	---	52.7	50.0	50.0	30.066	0.00	0.00	0.128	0.000
10/25/24	1:15a	52.0	52.7	52.0	28	19.9	0.0	---	0.00	0.0	---	52.0	49.6	49.6	30.069	0.00	0.00	0.135	0.000
10/25/24	1:30a	51.5	52.0	51.4	28	19.4	2.0	SE	0.50	4.0	SE	51.5	49.2	49.2	30.066	0.00	0.00	0.141	0.000
10/25/24	1:45a	51.1	51.5	51.1	28	19.1	2.0	SE	0.50	4.0	SE	51.1	48.9	48.9	30.070	0.00	0.00	0.145	0.000
10/25/24	2:00a	50.6	51.1	50.6	28	18.6	2.0	SE	0.50	4.0	ESE	50.6	48.5	48.5	30.067	0.00	0.00	0.150	0.000
10/25/24	2:15a	50.7	50.8	50.5	28	18.7	2.0	SE	0.50	4.0	SE	50.7	48.6	48.6	30.068	0.00	0.00	0.149	0.000
10/25/24	2:30a	50.5	50.9	50.5	28	18.6	1.0	SE	0.25	4.0	SE	50.5	48.4	48.4	30.064	0.00	0.00	0.151	0.000
10/25/24	2:45a	51.1	51.1	50.5	26	17.4	2.0	SE	0.50	4.0	SE	51.1	48.7	48.7	30.065	0.00	0.00	0.145	0.000
10/25/24	3:00a	50.6	51.1	50.6	26	16.9	2.0	SE	0.50	5.0	SE	50.6	48.4	48.4	30.066	0.00	0.00	0.150	0.000
10/25/24	3:15a	49.9	50.6	49.8	26	16.3	1.0	SE	0.25	3.0	SE	49.9	47.8	47.8	30.066	0.00	0.00	0.157	0.000
10/25/24	3:30a	49.6	49.9	49.6	27	16.9	1.0	SE	0.25	4.0	SE	49.6	47.6	47.6	30.062	0.00	0.00	0.160	0.000
10/25/24	3:45a	49.2	49.6	49.1	27	16.6	0.0	SE	0.00	2.0	SE	49.2	47.2	47.2	30.057	0.00	0.00	0.165	0.000
10/25/24	4:00a	48.9	49.1	48.9	28	17.2	0.0	---	0.00	0.0	---	48.9	46.9	46.9	30.054	0.00	0.00	0.168	0.000
10/25/24	4:15a	49.1	49.2	48.9	28	17.3	0.0	---	0.00	0.0	---	49.1	47.1	47.1	30.052	0.00	0.00	0.166	0.000
10/25/24	4:30a	49.2	49.2	49.1	28	17.4	0.0	---	0.00	0.0	---	49.2	47.2	47.2	30.054	0.00	0.00	0.165	0.000
10/25/24	4:45a	48.9	49.2	48.9	29	18.0	0.0	---	0.00	0.0	---	48.9	47.0	47.0	30.053	0.00	0.00	0.168	0.000
10/25/24	5:00a	48.9	49.1	48.9	29	18.0	0.0	---	0.00	0.0	---	48.9	47.0	47.0	30.056	0.00	0.00	0.168	0.000
10/25/24	5:15a	48.3	49.0	48.3	29	17.5	0.0	---	0.00	0.0	---	48.3	46.4	46.4	30.060	0.00	0.00	0.174	0.000
10/25/24	5:30a	48.1	48.3	48.1	30	18.1	0.0	---	0.00	0.0	---	48.1	46.2	46.2	30.060	0.00	0.00	0.176	0.000
10/25/24	5:45a	47.8	48.1	47.8	31	18.6	0.0	---	0.00	0.0	---	47.8	46.0	46.0	30.062	0.00	0.00	0.179	0.000
10/25/24	6:00a	47.3	47.8	47.3	31	18.1	0.0	---	0.00	0.0	---	47.3	45.5	45.5	30.065	0.00	0.00	0.184	0.000
10/25/24	6:15a	47.2	47.3	47.1	31	18.1	0.0	---	0.00	0.0	---	47.2	45.4	45.4	30.066	0.00	0.00	0.185	0.000
10/25/24	6:30a	47.2	47.3	47.1	31	18.1	0.0	---	0.00	0.0	---	47.2	45.4	45.4	30.063	0.00	0.00	0.185	0.000
10/25/24	6:45a	47.0	47.2	47.0	31	17.9	0.0	---	0.00	0.0	---	47.0	45.2	45.2	30.069	0.00	0.00	0.188	0.000
10/25/24	7:00a	46.9	47.1	46.9	30	17.0	1.0	SE	0.25	4.0	SE	46.9	45.1	45.1	30.072	0.00	0.00	0.189	0.000
10/25/24	7:15a	46.5	46.9	46.5	30	16.7	1.0	SE	0.25	4.0	SE	46.5	44.7	44.7	30.077	0.00	0.00	0.193	0.000
10/25/24	7:30a	46.4	46.5	46.3	30	16.6	1.0	SE	0.25	4.0	SE	46.4	44.6	44.6	30.074	0.00	0.00	0.194	0.000
10/25/24	7:45a	47.5	47.5	46.4	31	18.3	1.0	ESE	0.25	4.0	ESE	47.5	45.7	45.7	30.079	0.00	0.00	0.182	0.000
10/25/24	8:00a	49.0	49.0	47.5	30	18.9	1.0	ESE	0.25	3.0	ESE	49.0	47.1	47.1	30.081	0.00	0.00	0.167	0.000
10/25/24	8:15a	50.5	50.5	49.1	28	18.6	1.0	ESE	0.25	3.0	ESE	50.5	48.4	48.4	30.091	0.00	0.00	0.151	0.000
10/25/24	8:30a	51.2	51.3	50.5	25	16.5	1.0	SSE	0.25	3.0	ESE	51.2	48.8	48.8	30.097	0.00	0.00	0.144	0.000
10/25/24	8:45a	52.4	52.4	51.2	24	16.6	1.0	SE	0.25	3.0	SSE	52.4	49.6	49.6	30.101	0.00	0.00	0.131	0.000
10/25/24	9:00a	54.3	54.3	52.4	21	15.1	1.0	SE	0.25	4.0	SE	54.3	51.0	51.0	30.103	0.00	0.00	0.111	0.000
10/25/24	9:15a	56.8	56.8	54.3	15	9.6	1.0	SSE	0.25	3.0	SE	56.8	52.6	52.6	30.106	0.00	0.00	0.085	0.000
10/25/24	9:30a	59.0	59.0	56.9	10	2.4	1.0	SE	0.25	4.0	SE	59.0	54.4	54.4	30.108	0.00	0.00	0.063	0.000
10/25/24	9:45a	61.0	61.0	59.0	7	-3.7	1.0	SE	0.25	4.0	SSE	61.0	55.6	55.6	30.104	0.00	0.00	0.042	0.000
10/25/24	10:00a	63.4	63.4	61.0	4	-13.4	1.0	SSE	0.25	3.0	S	63.4	57.1	57.1	30.106	0.00	0.00	0.017	0.000
10/25/24	10:15a	64.5	64.5	63.4	3	-18.3	1.0	SE	0.25	4.0	SE	64.5	58.0	58.0	30.109	0.00	0.00	0.005	0.000
10/25/24	10:30a	65.7	65.7	64.5	1	-37.8	1.0	SE	0.25	4.0	SE	65.7	58.8	58.8	30.105	0.00	0.00	0.000	0.007
10/25/24	10:45a	67.7	67.7	65.7	0	---	1.0	SE	0.25	3.0	SE	67.7	60.5	60.5	30.105	0.00	0.00	0.000	0.028
10/25/24	11:00a	69.0	69.0	67.7	0	---	0.0	E	0.00	2.0	E	69.0	62.4	62.4	30.103	0.00	0.00	0.000	0.042
10/25/24	11:15a	69.2	69.2	68.8	0	---	1.0	WNW	0.25	3.0	NNW	69.2	62.7	62.7	30.105	0.00	0.00	0.000	0.044
10/25/24	11:30a	70.7	70.7	69.2	0	---	1.0	NW	0.25	2.0	NNE	70.7	64.8	64.8	30.106	0.00	0.00	0.000	0.059
10/25/24	11:45a	73.7	73.7	70.7	0	---	1.0	SE	0.25	3.0	SE	73.7	68.7	68.7	30.101	0.00	0.00	0.000	0.091
10/25/24	12:00p	75.0	75.0	73.7	0	---	1.0	SE	0.25	4.0	S	75.0	70.3	70.3	30.095	0.00	0.00	0.000	0.104
10/25/24	12:15p	76.3	76.5	75.0	0	---	0.0	NNE	0.00	3.0	E	76.3	71.8	71.8	30.093	0.00	0.00	0.000	0.118
10/25/24	12:30p	75.6	76.4	75.5	0	---	2.0	NNE	0.50	7.0	NNE	75.6	71.0	71.0	30.091	0.00	0.00	0.000	0.110

NKSP 10/25/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/25/24	12:45p	75.7	75.8	75.5	0	---	3.0	NNE	0.75	8.0	NW	75.7	71.1	71.1	30.087	0.00	0.00	0.000	0.111
10/25/24	1:00p	76.2	76.2	75.6	0	---	3.0	NE	0.75	8.0	NNE	76.2	71.6	71.6	30.080	0.00	0.00	0.000	0.117
10/25/24	1:15p	77.7	77.7	76.2	0	---	2.0	NE	0.50	8.0	E	77.7	73.2	73.2	30.070	0.00	0.00	0.000	0.132
10/25/24	1:30p	78.7	78.7	77.7	0	---	2.0	NNE	0.50	5.0	NNE	78.7	74.2	74.2	30.064	0.00	0.00	0.000	0.143
10/25/24	1:45p	79.3	79.3	78.7	0	---	2.0	NNE	0.50	6.0	W	79.3	74.8	74.8	30.059	0.00	0.00	0.000	0.149
10/25/24	2:00p	80.1	80.1	79.3	0	---	2.0	W	0.50	8.0	WNW	80.1	75.6	75.6	30.049	0.00	0.00	0.000	0.157
10/25/24	2:15p	80.3	80.3	80.1	0	---	3.0	NE	0.75	8.0	NNE	80.3	75.8	75.8	30.044	0.00	0.00	0.000	0.159
10/25/24	2:30p	80.7	80.8	80.2	0	---	3.0	NE	0.75	6.0	NNW	80.7	76.1	76.1	30.043	0.00	0.00	0.000	0.164
10/25/24	2:45p	81.4	81.4	80.6	0	---	2.0	NE	0.50	8.0	NNW	81.4	76.8	76.8	30.042	0.00	0.00	0.000	0.171
10/25/24	3:00p	82.2	82.2	81.4	0	---	4.0	N	1.00	9.0	N	82.2	77.6	77.6	30.041	0.00	0.00	0.000	0.179
10/25/24	3:15p	82.3	82.3	82.2	0	---	3.0	NNW	0.75	8.0	NNW	82.3	77.7	77.7	30.045	0.00	0.00	0.000	0.180
10/25/24	3:30p	82.8	82.9	82.3	0	---	3.0	NE	0.75	9.0	NNE	82.8	78.1	78.1	30.040	0.00	0.00	0.000	0.185
10/25/24	3:45p	82.9	82.9	82.6	0	---	3.0	NE	0.75	7.0	ENE	82.9	78.2	78.2	30.044	0.00	0.00	0.000	0.186
10/25/24	4:00p	83.4	83.4	82.9	0	---	4.0	NNE	1.00	10.0	NNE	83.4	78.6	78.6	30.046	0.00	0.00	0.000	0.192
10/25/24	4:15p	83.6	83.7	83.4	0	---	3.0	NNE	0.75	7.0	NW	83.6	78.8	78.8	30.051	0.00	0.00	0.000	0.194
10/25/24	4:30p	83.6	83.7	83.6	0	---	3.0	NNE	0.75	7.0	NW	83.6	78.8	78.8	30.048	0.00	0.00	0.000	0.194
10/25/24	4:45p	83.3	83.6	83.3	0	---	3.0	NNW	0.75	7.0	NW	83.3	78.5	78.5	30.045	0.00	0.00	0.000	0.191
10/25/24	5:00p	83.3	83.4	83.2	0	---	2.0	N	0.50	5.0	NNE	83.3	78.5	78.5	30.050	0.00	0.00	0.000	0.191
10/25/24	5:15p	83.0	83.3	82.9	0	---	2.0	NW	0.50	4.0	N	83.0	78.3	78.3	30.050	0.00	0.00	0.000	0.188
10/25/24	5:30p	82.8	83.0	82.7	0	---	2.0	WNW	0.50	5.0	WNW	82.8	78.1	78.1	30.053	0.00	0.00	0.000	0.185
10/25/24	5:45p	81.9	82.7	81.9	0	---	1.0	WNW	0.25	3.0	WNW	81.9	77.3	77.3	30.053	0.00	0.00	0.000	0.176
10/25/24	6:00p	81.1	81.9	81.1	0	---	1.0	WNW	0.25	2.0	WNW	81.1	76.5	76.5	30.061	0.00	0.00	0.000	0.168
10/25/24	6:15p	80.1	81.1	80.1	0	---	0.0	---	0.00	0.0	---	80.1	75.6	75.6	30.063	0.00	0.00	0.000	0.157
10/25/24	6:30p	79.3	80.1	79.3	0	---	0.0	---	0.00	0.0	---	79.3	74.8	74.8	30.066	0.00	0.00	0.000	0.149
10/25/24	6:45p	78.2	79.3	78.2	0	---	1.0	NNW	0.25	3.0	NNW	78.2	73.7	73.7	30.073	0.00	0.00	0.000	0.137
10/25/24	7:00p	77.7	78.3	77.7	0	---	1.0	NNW	0.25	3.0	NNW	77.7	73.2	73.2	30.078	0.00	0.00	0.000	0.132
10/25/24	7:15p	75.5	77.7	75.4	0	---	0.0	NNE	0.00	4.0	NNE	75.5	70.9	70.9	30.096	0.00	0.00	0.000	0.109
10/25/24	7:30p	73.7	75.4	73.7	0	---	0.0	NNE	0.00	3.0	NNE	73.7	68.7	68.7	30.100	0.00	0.00	0.000	0.091
10/25/24	7:45p	73.1	73.7	73.1	0	---	0.0	---	0.00	0.0	---	73.1	67.8	67.8	30.104	0.00	0.00	0.000	0.084
10/25/24	8:00p	73.0	73.3	73.0	0	---	0.0	NNE	0.00	1.0	NNE	73.0	67.7	67.7	30.104	0.00	0.00	0.000	0.083
10/25/24	8:15p	71.8	73.1	71.8	0	---	0.0	NNE	0.00	1.0	NNE	71.8	66.2	66.2	30.115	0.00	0.00	0.000	0.071
10/25/24	8:30p	69.0	71.8	69.0	---	---	0.0	NNE	0.00	2.0	NNE	69.0	---	---	30.119	0.00	0.00	0.000	0.042
10/25/24	8:45p	68.9	69.3	68.9	3	-15.3	1.0	NNE	0.25	3.0	NNE	68.9	62.5	62.5	30.125	0.00	0.00	0.000	0.041
10/25/24	9:00p	68.8	68.9	68.4	1	-35.9	0.0	NE	0.00	3.0	NE	68.8	62.2	62.2	30.134	0.00	0.00	0.000	0.040
10/25/24	9:15p	69.6	69.7	68.9	---	---	0.0	NE	0.00	1.0	NE	69.6	---	---	30.136	0.00	0.00	0.000	0.048
10/25/24	9:30p	68.7	69.6	68.7	0	---	1.0	NE	0.25	2.0	NE	68.7	61.9	61.9	30.141	0.00	0.00	0.000	0.039
10/25/24	9:45p	65.5	68.8	65.5	7	-0.3	2.0	NE	0.50	4.0	ESE	65.5	59.5	59.5	30.145	0.00	0.00	0.000	0.005
10/25/24	10:00p	62.2	65.5	62.2	13	10.7	2.0	SE	0.50	4.0	SE	62.2	57.2	57.2	30.153	0.00	0.00	0.029	0.000
10/25/24	10:15p	62.8	62.8	61.6	13	11.1	2.0	SE	0.50	4.0	SE	62.8	57.7	57.7	30.160	0.00	0.00	0.023	0.000
10/25/24	10:30p	63.1	63.1	62.7	12	9.6	0.0	ESE	0.00	1.0	ESE	63.1	58.0	58.0	30.164	0.00	0.00	0.020	0.000
10/25/24	10:45p	63.1	63.4	63.1	11	7.7	0.0	SE	0.00	2.0	SE	63.1	58.0	58.0	30.165	0.00	0.00	0.020	0.000
10/25/24	11:00p	62.7	63.1	62.7	12	9.3	0.0	SE	0.00	1.0	SE	62.7	57.6	57.6	30.169	0.00	0.00	0.024	0.000
10/25/24	11:15p	62.4	62.9	62.4	9	2.7	0.0	SE	0.00	1.0	SE	62.4	57.2	57.2	30.172	0.00	0.00	0.027	0.000
10/25/24	11:30p	60.0	62.4	60.0	15	12.1	1.0	WNW	0.25	3.0	WNW	60.0	55.3	55.3	30.170	0.00	0.00	0.052	0.000
10/25/24	11:45p	59.6	60.0	59.5	18	16.0	1.0	WNW	0.25	3.0	WNW	59.6	55.1	55.1	30.172	0.00	0.00	0.056	0.000
10/26/24	12:00a	59.6	59.8	59.6	17	14.7	1.0	W	0.25	3.0	W	59.6	55.1	55.1	30.171	0.00	0.00	0.056	0.000

NKSP 10/24/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/24/24	12:15a	74.4	44	51.1	73.6	8.26	.0739	351	1	100.0	15
10/24/24	12:30a	75.0	44	51.6	74.3	8.25	.0738	351	1	100.0	15
10/24/24	12:45a	74.6	44	51.2	73.9	8.26	.0739	351	1	100.0	15
10/24/24	1:00a	75.0	44	51.6	74.3	8.25	.0738	351	1	100.0	15
10/24/24	1:15a	75.2	42	50.5	74.3	7.95	.0738	352	1	100.0	15
10/24/24	1:30a	74.9	44	51.5	74.2	8.25	.0738	351	1	100.0	15
10/24/24	1:45a	75.2	43	51.2	74.4	8.05	.0738	351	1	100.0	15
10/24/24	2:00a	75.1	43	51.1	74.3	8.05	.0738	351	1	100.0	15
10/24/24	2:15a	74.9	43	50.9	74.1	8.05	.0738	351	1	100.0	15
10/24/24	2:30a	75.1	43	51.1	74.3	8.05	.0738	352	1	100.0	15
10/24/24	2:45a	75.1	42	50.4	74.2	7.95	.0738	351	1	100.0	15
10/24/24	3:00a	74.7	43	50.7	73.9	8.06	.0739	351	1	100.0	15
10/24/24	3:15a	74.9	43	50.9	74.1	8.05	.0738	351	1	100.0	15
10/24/24	3:30a	75.0	43	51.0	74.2	8.05	.0738	352	1	100.0	15
10/24/24	3:45a	75.1	43	51.1	74.3	8.05	.0738	351	1	100.0	15
10/24/24	4:00a	75.2	42	50.5	74.3	7.95	.0738	351	1	100.0	15
10/24/24	4:15a	75.2	42	50.5	74.3	7.95	.0738	351	1	100.0	15
10/24/24	4:30a	75.2	42	50.5	74.3	7.95	.0738	352	1	100.0	15
10/24/24	4:45a	75.1	42	50.4	74.2	7.95	.0738	351	1	100.0	15
10/24/24	5:00a	75.1	42	50.4	74.2	7.95	.0738	351	1	100.0	15
10/24/24	5:15a	75.0	42	50.3	74.1	7.95	.0738	351	1	100.0	15
10/24/24	5:30a	75.0	41	49.7	74.0	7.75	.0739	351	1	100.0	15
10/24/24	5:45a	74.9	42	50.3	74.0	7.95	.0739	352	1	100.0	15
10/24/24	6:00a	74.9	42	50.3	74.0	7.95	.0739	351	1	100.0	15
10/24/24	6:15a	75.0	42	50.3	74.1	7.95	.0739	324	1	94.7	15
10/24/24	6:30a	74.9	41	49.6	73.9	7.75	.0739	351	1	100.0	15
10/24/24	6:45a	74.9	41	49.6	73.9	7.75	.0739	352	1	100.0	15
10/24/24	7:00a	74.8	41	49.5	73.8	7.76	.0739	351	1	100.0	15
10/24/24	7:15a	74.6	41	49.3	73.6	7.77	.0739	351	1	100.0	15
10/24/24	7:30a	74.5	41	49.2	73.4	7.77	.0740	351	1	100.0	15
10/24/24	7:45a	74.4	41	49.2	73.3	7.77	.0740	351	1	100.0	15
10/24/24	8:00a	74.4	41	49.2	73.3	7.77	.0740	352	1	100.0	15
10/24/24	8:15a	74.5	41	49.2	73.4	7.77	.0740	351	1	100.0	15
10/24/24	8:30a	74.5	41	49.2	73.4	7.77	.0740	351	1	100.0	15
10/24/24	8:45a	74.3	41	49.1	73.2	7.78	.0740	351	1	100.0	15
10/24/24	9:00a	74.4	40	48.5	73.2	7.66	.0741	352	1	100.0	15
10/24/24	9:15a	74.6	40	48.7	73.5	7.66	.0740	351	1	100.0	15
10/24/24	9:30a	74.9	40	48.9	73.8	7.65	.0740	351	1	100.0	15
10/24/24	9:45a	75.4	39	48.7	74.2	7.54	.0739	351	1	100.0	15
10/24/24	10:00a	75.7	39	49.0	74.5	7.54	.0739	352	1	100.0	15
10/24/24	10:15a	76.2	38	48.7	75.0	7.33	.0738	351	1	100.0	15
10/24/24	10:30a	76.2	38	48.7	75.0	7.33	.0738	351	1	100.0	15
10/24/24	10:45a	76.6	38	49.1	75.4	7.32	.0737	351	1	100.0	15
10/24/24	11:00a	76.8	37	48.6	75.5	7.21	.0737	351	1	100.0	15
10/24/24	11:15a	77.1	37	48.8	75.8	7.21	.0736	352	1	100.0	15
10/24/24	11:30a	77.1	37	48.8	75.8	7.21	.0736	351	1	100.0	15
10/24/24	11:45a	77.7	36	48.6	76.2	7.00	.0736	351	1	100.0	15
10/24/24	12:00p	77.4	37	49.1	76.0	7.20	.0736	352	1	100.0	15
10/24/24	12:15p	77.7	36	48.6	76.2	7.00	.0735	351	1	100.0	15
10/24/24	12:30p	77.9	36	48.8	76.4	6.99	.0735	351	1	100.0	15

NKSP 10/24/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/24/24	12:45p	77.9	36	48.8	76.4	6.99	.0735	351	1	100.0	15
10/24/24	1:00p	78.3	35	48.4	76.7	6.88	.0734	351	1	100.0	15
10/24/24	1:15p	78.6	35	48.7	77.0	6.88	.0733	352	1	100.0	15
10/24/24	1:30p	78.6	36	49.4	77.1	6.98	.0733	351	1	100.0	15
10/24/24	1:45p	78.6	35	48.7	77.0	6.88	.0733	351	1	100.0	15
10/24/24	2:00p	78.9	35	48.9	77.3	6.87	.0732	351	1	100.0	15
10/24/24	2:15p	79.1	34	48.3	77.4	6.67	.0732	351	1	100.0	15
10/24/24	2:30p	79.2	35	49.2	77.6	6.87	.0731	352	1	100.0	15
10/24/24	2:45p	79.1	36	49.8	77.6	6.97	.0731	351	1	100.0	15
10/24/24	3:00p	79.0	36	49.8	77.5	6.97	.0731	351	1	100.0	15
10/24/24	3:15p	79.1	36	49.8	77.6	6.97	.0731	351	1	100.0	15
10/24/24	3:30p	79.2	35	49.2	77.6	6.87	.0731	352	1	100.0	15
10/24/24	3:45p	79.2	35	49.2	77.6	6.87	.0731	351	1	100.0	15
10/24/24	4:00p	79.2	36	49.9	77.7	6.97	.0730	351	1	100.0	15
10/24/24	4:15p	79.0	36	49.8	77.5	6.97	.0731	351	1	100.0	15
10/24/24	4:30p	78.9	36	49.7	77.4	6.97	.0731	352	1	100.0	15
10/24/24	4:45p	78.7	36	49.5	77.2	6.98	.0731	351	1	100.0	15
10/24/24	5:00p	78.8	36	49.6	77.3	6.97	.0731	351	1	100.0	15
10/24/24	5:15p	78.7	37	50.2	77.3	7.18	.0730	351	1	100.0	15
10/24/24	5:30p	78.4	38	50.7	77.0	7.28	.0731	351	1	100.0	15
10/24/24	5:45p	78.2	38	50.5	76.8	7.29	.0731	352	1	100.0	15
10/24/24	6:00p	78.1	37	49.7	76.7	7.19	.0731	351	1	100.0	15
10/24/24	6:15p	77.9	38	50.2	76.6	7.29	.0731	351	1	100.0	15
10/24/24	6:30p	77.6	38	50.0	76.3	7.30	.0732	351	1	100.0	15
10/24/24	6:45p	77.7	38	50.1	76.4	7.30	.0732	352	1	100.0	15
10/24/24	7:00p	77.9	37	49.5	76.5	7.19	.0732	351	1	100.0	15
10/24/24	7:15p	77.8	39	50.9	76.5	7.49	.0731	351	1	100.0	15
10/24/24	7:30p	77.5	39	50.6	76.3	7.50	.0732	351	1	100.0	15
10/24/24	7:45p	77.6	38	50.0	76.3	7.30	.0732	352	1	100.0	15
10/24/24	8:00p	77.5	39	50.6	76.3	7.50	.0732	351	1	100.0	15
10/24/24	8:15p	77.2	40	51.0	76.1	7.61	.0733	351	1	100.0	15
10/24/24	8:30p	77.2	39	50.3	76.0	7.51	.0733	351	1	100.0	15
10/24/24	8:45p	77.2	40	51.0	76.1	7.61	.0733	351	1	100.0	15
10/24/24	9:00p	76.9	40	50.7	75.8	7.61	.0733	352	1	100.0	15
10/24/24	9:15p	77.0	38	49.4	75.7	7.31	.0734	351	1	100.0	15
10/24/24	9:30p	76.8	40	50.6	75.7	7.61	.0734	351	1	100.0	15
10/24/24	9:45p	76.7	40	50.6	75.6	7.62	.0734	351	1	100.0	15
10/24/24	10:00p	76.8	41	51.3	75.8	7.75	.0734	352	1	100.0	15
10/24/24	10:15p	76.5	41	51.0	75.5	7.75	.0734	351	1	100.0	15
10/24/24	10:30p	76.6	40	50.5	75.5	7.62	.0734	351	1	100.0	15
10/24/24	10:45p	76.1	41	50.7	75.1	7.75	.0735	351	1	100.0	15
10/24/24	11:00p	76.1	41	50.7	75.1	7.75	.0735	351	1	100.0	15
10/24/24	11:15p	75.6	41	50.2	74.6	7.75	.0736	352	1	100.0	15
10/24/24	11:30p	75.6	41	50.2	74.6	7.75	.0736	351	1	100.0	15
10/24/24	11:45p	75.8	41	50.4	74.8	7.75	.0735	351	1	100.0	15
10/25/24	12:00a	75.4	41	50.1	74.4	7.75	.0736	351	1	100.0	15

NKSP 10/25/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/25/24	12:15a	75.4	41	50.1	74.4	7.75	.0736	350	1	100.0	15
10/25/24	12:30a	75.5	41	50.1	74.5	7.75	.0736	351	1	100.0	15
10/25/24	12:45a	75.7	41	50.3	74.7	7.75	.0736	351	1	100.0	15
10/25/24	1:00a	75.7	41	50.3	74.7	7.75	.0736	352	1	100.0	15
10/25/24	1:15a	75.7	41	50.3	74.7	7.75	.0736	351	1	100.0	15
10/25/24	1:30a	75.6	41	50.2	74.6	7.75	.0736	351	1	100.0	15
10/25/24	1:45a	75.6	40	49.6	74.5	7.64	.0736	351	1	100.0	15
10/25/24	2:00a	75.5	40	49.5	74.4	7.64	.0736	351	1	100.0	15
10/25/24	2:15a	75.4	40	49.4	74.3	7.64	.0737	352	1	100.0	15
10/25/24	2:30a	75.3	40	49.3	74.2	7.64	.0737	351	1	100.0	15
10/25/24	2:45a	75.1	40	49.1	74.0	7.65	.0737	351	1	100.0	15
10/25/24	3:00a	75.0	40	49.0	73.9	7.65	.0737	351	1	100.0	15
10/25/24	3:15a	74.9	40	48.9	73.8	7.65	.0737	352	1	100.0	15
10/25/24	3:30a	74.8	39	48.2	73.6	7.55	.0738	351	1	100.0	15
10/25/24	3:45a	74.7	39	48.1	73.5	7.56	.0738	351	1	100.0	15
10/25/24	4:00a	74.8	40	48.9	73.7	7.65	.0737	351	1	100.0	15
10/25/24	4:15a	74.8	39	48.2	73.6	7.55	.0737	351	1	100.0	15
10/25/24	4:30a	74.7	39	48.1	73.5	7.56	.0738	352	1	100.0	15
10/25/24	4:45a	74.6	39	48.0	73.4	7.56	.0738	351	1	100.0	15
10/25/24	5:00a	74.6	40	48.7	73.5	7.66	.0738	351	1	100.0	15
10/25/24	5:15a	74.5	40	48.6	73.4	7.66	.0738	351	1	100.0	15
10/25/24	5:30a	74.4	40	48.5	73.2	7.66	.0738	352	1	100.0	15
10/25/24	5:45a	74.2	40	48.3	73.0	7.67	.0738	351	1	100.0	15
10/25/24	6:00a	74.1	40	48.2	72.9	7.67	.0739	351	1	100.0	15
10/25/24	6:15a	74.0	40	48.1	72.8	7.67	.0739	351	1	100.0	15
10/25/24	6:30a	73.9	40	48.1	72.7	7.67	.0739	351	1	100.0	15
10/25/24	6:45a	73.8	40	48.0	72.6	7.67	.0739	352	1	100.0	15
10/25/24	7:00a	73.7	40	47.9	72.5	7.68	.0739	351	1	100.0	15
10/25/24	7:15a	73.6	39	47.1	72.3	7.58	.0740	351	1	100.0	15
10/25/24	7:30a	73.5	39	47.0	72.2	7.58	.0740	351	1	100.0	15
10/25/24	7:45a	73.3	39	46.8	72.0	7.58	.0741	352	1	100.0	15
10/25/24	8:00a	73.3	40	47.5	72.0	7.68	.0740	351	1	100.0	15
10/25/24	8:15a	73.3	40	47.5	72.0	7.68	.0741	351	1	100.0	15
10/25/24	8:30a	73.5	40	47.7	72.3	7.68	.0740	351	1	100.0	15
10/25/24	8:45a	73.7	40	47.9	72.5	7.68	.0740	352	1	100.0	15
10/25/24	9:00a	73.7	40	47.9	72.5	7.68	.0740	351	1	100.0	15
10/25/24	9:15a	73.9	40	48.1	72.7	7.67	.0740	351	1	100.0	15
10/25/24	9:30a	74.1	40	48.2	72.9	7.67	.0740	351	1	100.0	15
10/25/24	9:45a	74.4	39	47.8	73.2	7.56	.0739	351	1	100.0	15
10/25/24	10:00a	74.6	39	48.0	73.4	7.56	.0739	352	1	100.0	15
10/25/24	10:15a	75.0	39	48.4	73.8	7.55	.0738	351	1	100.0	15
10/25/24	10:30a	75.3	39	48.6	74.1	7.54	.0738	351	1	100.0	15
10/25/24	10:45a	75.9	39	49.2	74.7	7.53	.0737	351	1	100.0	15
10/25/24	11:00a	75.7	39	49.0	74.5	7.54	.0737	352	1	100.0	15
10/25/24	11:15a	76.2	39	49.4	75.0	7.53	.0736	351	1	100.0	15
10/25/24	11:30a	76.4	39	49.6	75.2	7.52	.0736	351	1	100.0	15
10/25/24	11:45a	77.1	37	48.8	75.8	7.21	.0735	351	1	100.0	15
10/25/24	12:00p	77.2	38	49.6	75.9	7.31	.0735	352	1	100.0	15
10/25/24	12:15p	77.3	38	49.7	76.0	7.30	.0734	351	1	100.0	15
10/25/24	12:30p	77.6	37	49.3	76.2	7.20	.0734	351	1	100.0	15

NKSP 10/25/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/25/24	12:45p	77.9	38	50.2	76.6	7.29	.0733	351	1	100.0	15
10/25/24	1:00p	77.8	38	50.2	76.5	7.29	.0733	351	1	100.0	15
10/25/24	1:15p	77.9	38	50.2	76.6	7.29	.0733	352	1	100.0	15
10/25/24	1:30p	78.0	38	50.3	76.6	7.29	.0733	351	1	100.0	15
10/25/24	1:45p	78.3	38	50.6	76.9	7.28	.0732	351	1	100.0	15
10/25/24	2:00p	78.4	38	50.7	77.0	7.28	.0732	351	1	100.0	15
10/25/24	2:15p	78.3	39	51.3	77.0	7.48	.0731	352	1	100.0	15
10/25/24	2:30p	78.2	39	51.2	76.9	7.49	.0731	351	1	100.0	15
10/25/24	2:45p	78.3	37	49.9	76.9	7.18	.0732	351	1	100.0	15
10/25/24	3:00p	78.4	38	50.7	77.0	7.28	.0731	351	1	100.0	15
10/25/24	3:15p	78.1	39	51.1	76.8	7.49	.0732	351	1	100.0	15
10/25/24	3:30p	78.1	38	50.4	76.7	7.29	.0732	352	1	100.0	15
10/25/24	3:45p	78.4	37	50.0	77.0	7.18	.0732	351	1	100.0	15
10/25/24	4:00p	78.4	38	50.7	77.0	7.28	.0731	351	1	100.0	15
10/25/24	4:15p	78.3	39	51.3	77.0	7.48	.0732	351	1	100.0	15
10/25/24	4:30p	78.2	38	50.5	76.8	7.29	.0732	352	1	100.0	15
10/25/24	4:45p	78.3	37	49.9	76.9	7.18	.0732	351	1	100.0	15
10/25/24	5:00p	78.6	38	50.9	77.2	7.28	.0731	351	1	100.0	15
10/25/24	5:15p	78.5	38	50.8	77.1	7.28	.0731	351	1	100.0	15
10/25/24	5:30p	78.6	37	50.1	77.2	7.18	.0732	352	1	100.0	15
10/25/24	5:45p	78.6	36	49.4	77.1	6.98	.0732	351	1	100.0	15
10/25/24	6:00p	78.4	38	50.7	77.0	7.28	.0732	351	1	100.0	15
10/25/24	6:15p	78.3	39	51.3	77.0	7.48	.0732	351	1	100.0	15
10/25/24	6:30p	78.2	38	50.5	76.8	7.29	.0732	351	1	100.0	15
10/25/24	6:45p	78.3	37	49.9	76.9	7.18	.0733	352	1	100.0	15
10/25/24	7:00p	78.2	39	51.2	76.9	7.49	.0732	351	1	100.0	15
10/25/24	7:15p	77.7	39	50.8	76.4	7.50	.0734	351	1	100.0	15
10/25/24	7:30p	77.6	38	50.0	76.3	7.30	.0734	351	1	100.0	15
10/25/24	7:45p	77.7	39	50.8	76.4	7.50	.0734	352	1	100.0	15
10/25/24	8:00p	77.4	40	51.2	76.3	7.60	.0734	351	1	100.0	15
10/25/24	8:15p	77.2	40	51.0	76.1	7.61	.0735	351	1	100.0	15
10/25/24	8:30p	77.3	40	51.1	76.2	7.60	.0735	351	1	100.0	15
10/25/24	8:45p	76.9	41	51.4	75.9	7.75	.0735	352	1	100.0	15
10/25/24	9:00p	77.0	39	50.1	75.8	7.51	.0736	351	1	100.0	15
10/25/24	9:15p	77.1	41	51.6	76.1	7.75	.0735	351	1	100.0	15
10/25/24	9:30p	76.8	42	52.0	75.9	7.91	.0736	351	1	100.0	15
10/25/24	9:45p	77.0	39	50.1	75.8	7.51	.0736	351	1	100.0	15
10/25/24	10:00p	76.7	42	51.9	75.8	7.92	.0736	352	1	100.0	15
10/25/24	10:15p	76.6	41	51.1	75.6	7.75	.0737	351	1	100.0	15
10/25/24	10:30p	76.4	42	51.6	75.5	7.92	.0737	351	1	100.0	15
10/25/24	10:45p	76.3	41	50.9	75.3	7.75	.0737	351	1	100.0	15
10/25/24	11:00p	76.0	43	51.9	75.2	8.05	.0737	352	1	100.0	15
10/25/24	11:15p	76.0	42	51.2	75.1	7.93	.0738	351	1	100.0	15
10/25/24	11:30p	76.0	40	49.9	74.9	7.63	.0738	351	1	100.0	15
10/25/24	11:45p	75.5	42	50.8	74.6	7.94	.0739	351	1	100.0	15
10/26/24	12:00a	75.6	42	50.9	74.7	7.94	.0738	352	1	100.0	15

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

OUTSIDE TEMPERATURE RECORD
CDCR 2030 (04/18)

INSTITUTION: NORTH KERN STATE PRISON

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the OUTSIDE ambient air temperature.

Using an accurate thermometer located in a central, heat neutral location, the outside air temperature is to be taken every hour, seven (7) days a week.

Thermometer Location: Central Control

Immediately notify the Watch Commander at extension 314 when the air temperature reaches 90 degrees.

Date	Time	Temp.	Printed Name
10/26/2024	0100	58	J. FIERRO
	0200	54	J. FIERRO
	0300	58	J. FIERRO
	0400	51	J FIERRO
	0500	53	J. FIERRO
	0600	53	Gonzalez
	0700	51	Gonzalez
	0800	50	Gonzalez
	0900	57	Gonzalez
	1000	65	Gonzalez
	1100	69	Gonzalez
	1200	71	Gonzalez
	1300	75	Gonzalez
	1400	76	Gonzalez
	1500	77	Gonzalez
	1600	79	Gonzalez
	1700	78	Gonzalez
	1800	77	Gonzalez
	1900	72	Gonzalez
	2000	69	Gonzalez
	2100	66	Gonzalez
	2200	62.9	M. Maldonado
	2300	59.0	M. Maldonado
	2400	57.8	M. Maldonado

Date	Time	Temp.	Printed Name
10/27/2024	0100	56.5	M. Maldonado
	0200	55.2	M. Maldonado
	0300	54.4	G. Ramirez
	0400	54.3	M. Maldonado
	0500	56.2	M. Maldonado
	0600	56	Gonzalez
	0700	55	Gonzalez
	0800	56	Gonzalez
	0900	58	Gonzalez
	1000	61	Gonzalez
	1100	65	Gonzalez
	1200	69	Gonzalez
	1300	71	Gonzalez
	1400	73	VALENCIA
	1500	74	VALENCIA
	1600	74	VALENCIA
	1700	72	VALENCIA
	1800	71	VALENCIA
	1900	67	VALENCIA
	2000	66	VALENCIA
	2100	64	VALENCIA
	2200	63	DUNN
	2300	62	DUNN
	2400	61	DUNN

DISTRIBUTION: Original: Institution Heat Plan Coordinator

NKSP 10/26/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/26/24	12:15a	59.6	59.7	59.5	17	14.7	0.0	W	0.00	1.0	W	59.6	55.1	55.1	30.171	0.00	0.00	0.056	0.000
10/26/24	12:30a	59.7	59.9	59.6	17	14.8	0.0	W	0.00	1.0	W	59.7	55.1	55.1	30.174	0.00	0.00	0.055	0.000
10/26/24	12:45a	58.9	59.8	58.9	17	14.1	0.0	W	0.00	3.0	W	58.9	54.4	54.4	30.173	0.00	0.00	0.064	0.000
10/26/24	1:00a	57.6	58.9	57.6	19	15.6	0.0	W	0.00	1.0	W	57.6	53.5	53.5	30.175	0.00	0.00	0.077	0.000
10/26/24	1:15a	56.8	57.6	56.8	20	16.1	0.0	W	0.00	1.0	W	56.8	52.9	52.9	30.175	0.00	0.00	0.085	0.000
10/26/24	1:30a	56.6	56.8	56.5	19	14.8	1.0	WSW	0.25	3.0	SW	56.6	52.7	52.7	30.175	0.00	0.00	0.088	0.000
10/26/24	1:45a	55.2	56.6	55.2	20	14.8	0.0	S	0.00	4.0	S	55.2	51.6	51.6	30.176	0.00	0.00	0.102	0.000
10/26/24	2:00a	54.2	55.1	54.2	23	17.1	1.0	SSE	0.25	4.0	SSE	54.2	51.0	51.0	30.174	0.00	0.00	0.112	0.000
10/26/24	2:15a	53.8	54.2	53.8	24	17.8	3.0	SE	0.75	5.0	SSE	53.8	50.7	50.7	30.176	0.00	0.00	0.117	0.000
10/26/24	2:30a	53.8	53.9	53.7	24	17.8	1.0	SE	0.25	4.0	SE	53.8	50.7	50.7	30.174	0.00	0.00	0.117	0.000
10/26/24	2:45a	53.0	53.8	53.0	24	17.1	0.0	SE	0.00	2.0	SE	53.0	50.1	50.1	30.175	0.00	0.00	0.125	0.000
10/26/24	3:00a	52.6	53.1	52.5	25	17.7	0.0	SE	0.00	2.0	SE	52.6	49.8	49.8	30.175	0.00	0.00	0.129	0.000
10/26/24	3:15a	52.3	52.6	52.3	25	17.5	1.0	SE	0.25	4.0	SE	52.3	49.6	49.6	30.174	0.00	0.00	0.132	0.000
10/26/24	3:30a	51.9	52.3	51.9	26	18.0	2.0	SE	0.50	4.0	SE	51.9	49.4	49.4	30.177	0.00	0.00	0.136	0.000
10/26/24	3:45a	52.2	52.3	52.0	26	18.3	1.0	SE	0.25	4.0	SE	52.2	49.6	49.6	30.177	0.00	0.00	0.133	0.000
10/26/24	4:00a	51.9	52.3	51.8	26	18.0	3.0	ESE	0.75	6.0	ESE	51.8	49.4	49.3	30.176	0.00	0.00	0.136	0.000
10/26/24	4:15a	52.4	52.4	51.8	27	19.3	3.0	ESE	0.75	4.0	ESE	52.3	49.8	49.7	30.176	0.00	0.00	0.131	0.000
10/26/24	4:30a	53.1	53.2	52.4	29	21.6	2.0	ESE	0.50	3.0	ESE	53.1	50.5	50.5	30.176	0.00	0.00	0.124	0.000
10/26/24	4:45a	53.1	53.2	53.1	29	21.6	1.0	ESE	0.25	3.0	ESE	53.1	50.5	50.5	30.178	0.00	0.00	0.124	0.000
10/26/24	5:00a	53.3	53.4	53.0	27	20.1	0.0	ESE	0.00	2.0	ESE	53.3	50.5	50.5	30.175	0.00	0.00	0.122	0.000
10/26/24	5:15a	54.1	54.1	53.3	25	19.0	2.0	ESE	0.50	3.0	ESE	54.1	51.0	51.0	30.180	0.00	0.00	0.114	0.000
10/26/24	5:30a	54.0	54.1	53.9	25	18.9	0.0	ESE	0.00	1.0	ESE	54.0	50.9	50.9	30.180	0.00	0.00	0.115	0.000
10/26/24	5:45a	54.0	54.2	54.0	27	20.7	0.0	ESE	0.00	2.0	ESE	54.0	51.1	51.1	30.186	0.00	0.00	0.115	0.000
10/26/24	6:00a	53.0	54.1	53.0	26	19.0	1.0	ESE	0.25	4.0	ESE	53.0	50.2	50.2	30.186	0.00	0.00	0.125	0.000
10/26/24	6:15a	52.9	53.0	52.6	26	18.9	2.0	ESE	0.50	3.0	ESE	52.9	50.1	50.1	30.189	0.00	0.00	0.126	0.000
10/26/24	6:30a	52.3	52.9	52.2	26	18.4	0.0	ESE	0.00	2.0	ESE	52.3	49.7	49.7	30.192	0.00	0.00	0.132	0.000
10/26/24	6:45a	52.0	52.2	52.0	27	19.0	1.0	ESE	0.25	3.0	ESE	52.0	49.5	49.5	30.188	0.00	0.00	0.135	0.000
10/26/24	7:00a	51.7	52.1	51.7	27	18.7	1.0	ESE	0.25	3.0	ESE	51.7	49.3	49.3	30.195	0.00	0.00	0.139	0.000
10/26/24	7:15a	51.1	51.6	51.0	27	18.2	2.0	SE	0.50	4.0	SE	51.1	48.8	48.8	30.200	0.00	0.00	0.145	0.000
10/26/24	7:30a	50.8	51.1	50.7	28	18.8	2.0	SE	0.50	4.0	SE	50.8	48.6	48.6	30.209	0.00	0.00	0.148	0.000
10/26/24	7:45a	50.7	50.7	50.5	29	19.6	1.0	SE	0.25	3.0	SE	50.7	48.6	48.6	30.214	0.00	0.00	0.149	0.000
10/26/24	8:00a	50.9	51.0	50.7	29	19.7	0.0	SE	0.00	2.0	SE	50.9	48.8	48.8	30.219	0.00	0.00	0.147	0.000
10/26/24	8:15a	52.4	52.4	51.0	28	20.2	0.0	SE	0.00	1.0	SE	52.4	49.9	49.9	30.226	0.00	0.00	0.131	0.000
10/26/24	8:30a	53.6	53.8	52.4	26	19.7	1.0	SE	0.25	3.0	SE	53.8	50.8	50.8	30.239	0.00	0.00	0.117	0.000
10/26/24	8:45a	55.2	55.2	53.8	25	19.9	1.0	SE	0.25	3.0	SE	55.2	51.9	51.9	30.244	0.00	0.00	0.102	0.000
10/26/24	9:00a	57.3	57.3	55.3	21	17.6	1.0	SE	0.25	4.0	SE	57.3	53.4	53.4	30.245	0.00	0.00	0.080	0.000
10/26/24	9:15a	59.7	59.7	57.3	16	13.4	0.0	SSE	0.00	2.0	SSE	59.7	55.1	55.1	30.249	0.00	0.00	0.055	0.000
10/26/24	9:30a	61.4	61.4	59.8	11	6.3	0.0	---	0.00	0.0	---	61.4	56.5	56.5	30.249	0.00	0.00	0.037	0.000
10/26/24	9:45a	62.9	62.9	61.4	8	0.6	0.0	---	0.00	0.0	---	62.9	57.4	57.4	30.245	0.00	0.00	0.022	0.000
10/26/24	10:00a	65.1	65.1	62.9	5	-7.7	0.0	SSE	0.00	3.0	SSE	65.1	58.7	58.7	30.245	0.00	0.00	0.000	0.001
10/26/24	10:15a	66.0	66.0	65.1	3	-17.3	0.0	SSE	0.00	3.0	S	66.0	59.3	59.3	30.246	0.00	0.00	0.000	0.010
10/26/24	10:30a	67.3	67.3	65.9	3	-16.4	1.0	S	0.25	5.0	S	67.3	60.5	60.5	30.245	0.00	0.00	0.000	0.024
10/26/24	10:45a	67.2	67.5	67.2	2	-24.3	2.0	WSW	0.50	5.0	WSW	67.2	60.3	60.3	30.241	0.00	0.00	0.000	0.023
10/26/24	11:00a	69.1	69.1	67.2	0	---	1.0	WNW	0.25	3.0	WSW	69.1	62.5	62.5	30.237	0.00	0.00	0.000	0.043
10/26/24	11:15a	70.5	70.5	69.1	0	---	1.0	SW	0.25	4.0	SW	70.5	64.6	64.6	30.230	0.00	0.00	0.000	0.057
10/26/24	11:30a	71.3	71.3	70.5	0	---	2.0	SW	0.50	7.0	WSW	71.3	65.6	65.6	30.229	0.00	0.00	0.000	0.066
10/26/24	11:45a	71.7	71.7	71.3	0	---	1.0	WNW	0.25	5.0	WNW	71.7	66.1	66.1	30.225	0.00	0.00	0.000	0.070
10/26/24	12:00p	71.9	72.0	71.7	0	---	2.0	W	0.50	6.0	W	71.9	66.4	66.4	30.223	0.00	0.00	0.000	0.072
10/26/24	12:15p	73.4	73.4	72.0	0	---	3.0	SW	0.75	7.0	SW	73.4	68.3	68.3	30.220	0.00	0.00	0.000	0.088
10/26/24	12:30p	74.0	74.1	73.4	0	---	2.0	SSW	0.50	7.0	WSW	74.0	69.1	69.1	30.214	0.00	0.00	0.000	0.094

NKSP 10/26/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/26/24	12:45p	74.9	74.9	74.0	0	---	3.0	WSW	0.75	9.0	W	74.9	70.2	70.2	30.208	0.00	0.00	0.000	0.103
10/26/24	1:00p	75.1	75.1	74.9	0	---	3.0	NW	0.75	8.0	NW	75.1	70.4	70.4	30.201	0.00	0.00	0.000	0.105
10/26/24	1:15p	75.9	76.0	75.1	0	---	3.0	NNW	0.75	7.0	NW	75.9	71.3	71.3	30.195	0.00	0.00	0.000	0.114
10/26/24	1:30p	76.4	76.4	75.9	0	---	3.0	NNW	0.75	8.0	NW	76.4	71.9	71.9	30.185	0.00	0.00	0.000	0.119
10/26/24	1:45p	76.6	76.6	76.2	0	---	3.0	NNW	0.75	7.0	NW	76.6	72.1	72.1	30.182	0.00	0.00	0.000	0.121
10/26/24	2:00p	76.9	77.0	76.6	0	---	3.0	NW	0.75	7.0	NW	76.9	72.5	72.5	30.174	0.00	0.00	0.000	0.124
10/26/24	2:15p	77.2	77.2	76.9	0	---	3.0	W	0.75	9.0	W	77.2	72.8	72.8	30.172	0.00	0.00	0.000	0.127
10/26/24	2:30p	77.8	77.9	77.1	0	---	3.0	WNW	0.75	8.0	WNW	77.8	73.3	73.3	30.171	0.00	0.00	0.000	0.133
10/26/24	2:45p	78.1	78.1	77.8	0	---	3.0	W	0.75	7.0	WNW	78.1	73.6	73.6	30.168	0.00	0.00	0.000	0.136
10/26/24	3:00p	77.9	78.1	77.9	0	---	3.0	NW	0.75	8.0	WNW	77.9	73.4	73.4	30.164	0.00	0.00	0.000	0.134
10/26/24	3:15p	78.2	78.3	78.0	0	---	2.0	NW	0.50	6.0	W	78.2	73.7	73.7	30.164	0.00	0.00	0.000	0.137
10/26/24	3:30p	78.6	78.6	78.2	0	---	2.0	NW	0.50	6.0	W	78.6	74.1	74.1	30.161	0.00	0.00	0.000	0.142
10/26/24	3:45p	79.1	79.1	78.6	0	---	2.0	WNW	0.50	6.0	W	79.1	74.6	74.6	30.164	0.00	0.00	0.000	0.147
10/26/24	4:00p	79.1	79.4	79.1	0	---	2.0	NW	0.50	7.0	WNW	79.1	74.6	74.6	30.160	0.00	0.00	0.000	0.147
10/26/24	4:15p	78.9	79.1	78.8	0	---	2.0	WNW	0.50	7.0	WNW	78.9	74.4	74.4	30.155	0.00	0.00	0.000	0.145
10/26/24	4:30p	79.6	79.6	78.9	0	---	1.0	WSW	0.25	3.0	WSW	79.6	75.1	75.1	30.158	0.00	0.00	0.000	0.152
10/26/24	4:45p	79.2	79.6	79.1	0	---	2.0	W	0.50	4.0	WNW	79.2	74.7	74.7	30.156	0.00	0.00	0.000	0.148
10/26/24	5:00p	78.9	79.3	78.9	0	---	2.0	NW	0.50	4.0	WNW	78.9	74.4	74.4	30.155	0.00	0.00	0.000	0.145
10/26/24	5:15p	78.8	79.0	78.7	0	---	1.0	WNW	0.25	3.0	WNW	78.8	74.3	74.3	30.149	0.00	0.00	0.000	0.144
10/26/24	5:30p	78.6	78.8	78.5	0	---	1.0	WNW	0.25	3.0	WNW	78.6	74.1	74.1	30.150	0.00	0.00	0.000	0.142
10/26/24	5:45p	78.5	78.6	78.4	0	---	0.0	WNW	0.00	2.0	WNW	78.5	74.0	74.0	30.155	0.00	0.00	0.000	0.141
10/26/24	6:00p	77.0	78.5	77.0	0	---	2.0	S	0.50	4.0	SSW	77.0	72.6	72.6	30.156	0.00	0.00	0.000	0.125
10/26/24	6:15p	75.6	76.9	75.6	0	---	0.0	S	0.00	2.0	S	75.6	71.0	71.0	30.146	0.00	0.00	0.000	0.110
10/26/24	6:30p	74.3	75.6	74.3	0	---	0.0	S	0.00	2.0	SSE	74.3	69.5	69.5	30.157	0.00	0.00	0.000	0.097
10/26/24	6:45p	73.7	74.5	73.7	0	---	0.0	SSE	0.00	2.0	SSE	73.7	68.7	68.7	30.166	0.00	0.00	0.000	0.091
10/26/24	7:00p	72.3	73.7	72.3	0	---	0.0	---	0.00	0.0	---	72.3	66.9	66.9	30.174	0.00	0.00	0.000	0.076
10/26/24	7:15p	71.7	72.3	71.6	0	---	0.0	---	0.00	0.0	---	71.7	66.1	66.1	30.169	0.00	0.00	0.000	0.070
10/26/24	7:30p	70.3	71.7	70.3	0	---	0.0	---	0.00	0.0	---	70.3	64.3	64.3	30.166	0.00	0.00	0.000	0.055
10/26/24	7:45p	69.0	70.3	69.0	0	---	0.0	---	0.00	0.0	---	69.0	62.4	62.4	30.172	0.00	0.00	0.000	0.042
10/26/24	8:00p	69.7	69.7	69.0	0	---	2.0	E	0.50	4.0	E	69.7	63.4	63.4	30.179	0.00	0.00	0.000	0.049
10/26/24	8:15p	69.0	69.9	69.0	4	-9.5	1.0	ESE	0.25	3.0	ESE	69.0	62.8	62.8	30.186	0.00	0.00	0.000	0.042
10/26/24	8:30p	67.4	69.0	67.4	6	-2.2	2.0	ESE	0.50	4.0	ESE	67.4	61.0	61.0	30.181	0.00	0.00	0.000	0.025
10/26/24	8:45p	66.4	67.4	66.4	7	0.3	3.0	E	0.75	4.0	ESE	66.4	60.4	60.4	30.185	0.00	0.00	0.000	0.015
10/26/24	9:00p	66.1	66.4	66.1	8	3.0	2.0	E	0.50	4.0	E	66.1	60.3	60.3	30.191	0.00	0.00	0.000	0.011
10/26/24	9:15p	65.0	66.1	65.0	10	7.0	2.0	ESE	0.50	3.0	ESE	65.0	59.8	59.8	30.192	0.00	0.00	0.000	0.000
10/26/24	9:30p	64.2	65.0	64.2	12	10.5	2.0	ESE	0.50	3.0	ESE	64.2	59.0	59.0	30.197	0.00	0.00	0.008	0.000
10/26/24	9:45p	63.4	64.2	63.4	12	9.8	2.0	ESE	0.50	3.0	ESE	63.4	58.3	58.3	30.198	0.00	0.00	0.017	0.000
10/26/24	10:00p	62.9	63.4	62.9	11	7.5	0.0	ESE	0.00	2.0	ESE	62.9	57.8	57.8	30.201	0.00	0.00	0.022	0.000
10/26/24	10:15p	62.3	62.9	62.3	12	9.0	0.0	---	0.00	0.0	---	62.3	57.3	57.3	30.202	0.00	0.00	0.028	0.000
10/26/24	10:30p	61.5	62.3	61.5	13	10.1	0.0	---	0.00	0.0	---	61.5	56.5	56.5	30.200	0.00	0.00	0.036	0.000
10/26/24	10:45p	60.4	61.6	60.4	15	12.5	0.0	ESE	0.00	1.0	ESE	60.4	55.6	55.6	30.200	0.00	0.00	0.048	0.000
10/26/24	11:00p	59.0	60.4	59.0	17	14.2	2.0	S	0.50	7.0	S	59.0	54.5	54.5	30.204	0.00	0.00	0.063	0.000
10/26/24	11:15p	58.0	59.0	58.0	21	18.2	2.0	S	0.50	6.0	S	58.0	54.0	54.0	30.197	0.00	0.00	0.073	0.000
10/26/24	11:30p	58.9	58.9	57.8	23	21.1	2.0	SSE	0.50	4.0	SSE	58.9	54.8	54.8	30.201	0.00	0.00	0.064	0.000
10/26/24	11:45p	58.9	59.1	58.8	21	19.0	0.0	SSE	0.00	3.0	SSE	58.9	54.7	54.7	30.200	0.00	0.00	0.064	0.000
10/27/24	12:00a	57.8	58.9	57.8	22	19.1	0.0	SSE	0.00	3.0	SSE	57.8	53.9	53.9	30.193	0.00	0.00	0.075	0.000

NKSP 10/27/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/27/24	12:15a	57.4	57.8	57.4	24	20.9	3.0	SE	0.75	5.0	SE	57.4	53.6	53.6	30.194	0.00	0.00	0.079	0.000
10/27/24	12:30a	57.7	57.7	57.4	24	21.1	2.0	SE	0.50	3.0	SE	57.7	53.9	53.9	30.188	0.00	0.00	0.076	0.000
10/27/24	12:45a	57.6	57.9	57.6	23	20.0	2.0	SE	0.50	6.0	ESE	57.6	53.7	53.7	30.188	0.00	0.00	0.077	0.000
10/27/24	1:00a	56.5	57.7	56.5	25	21.1	2.0	ESE	0.50	4.0	ESE	56.5	52.9	52.9	30.188	0.00	0.00	0.089	0.000
10/27/24	1:15a	55.4	56.6	55.4	24	19.2	1.0	ESE	0.25	3.0	ESE	55.4	52.0	52.0	30.183	0.00	0.00	0.100	0.000
10/27/24	1:30a	55.3	55.4	55.1	25	20.0	1.0	ENE	0.25	3.0	E	55.3	51.9	51.9	30.161	0.00	0.00	0.101	0.000
10/27/24	1:45a	55.8	55.8	55.3	25	20.5	0.0	SSE	0.00	2.0	ENE	55.8	52.3	52.3	30.185	0.00	0.00	0.096	0.000
10/27/24	2:00a	55.2	55.9	55.2	23	18.0	1.0	SSE	0.25	4.0	SSE	55.2	51.8	51.8	30.186	0.00	0.00	0.102	0.000
10/27/24	2:15a	54.7	55.2	54.7	24	18.6	1.0	S	0.25	5.0	S	54.7	51.4	51.4	30.186	0.00	0.00	0.107	0.000
10/27/24	2:30a	54.2	54.8	54.2	25	19.1	2.0	S	0.50	5.0	S	54.2	51.1	51.1	30.188	0.00	0.00	0.112	0.000
10/27/24	2:45a	54.5	54.5	54.2	26	20.3	1.0	SSW	0.25	5.0	SSW	54.5	51.4	51.4	30.183	0.00	0.00	0.109	0.000
10/27/24	3:00a	54.4	54.5	54.4	26	20.2	0.0	---	0.00	0.0	---	54.4	51.3	51.3	30.179	0.00	0.00	0.110	0.000
10/27/24	3:15a	54.6	54.6	54.4	26	20.4	0.0	S	0.00	2.0	S	54.6	51.5	51.5	30.167	0.00	0.00	0.108	0.000
10/27/24	3:30a	54.3	54.6	54.3	25	19.2	0.0	E	0.00	3.0	E	54.3	51.1	51.1	30.157	0.00	0.00	0.111	0.000
10/27/24	3:45a	54.3	54.3	54.1	26	20.1	1.0	ENE	0.25	4.0	SE	54.3	51.2	51.2	30.190	0.00	0.00	0.111	0.000
10/27/24	4:00a	54.3	54.4	54.2	26	20.1	2.0	SSE	0.50	7.0	SSE	54.3	51.2	51.2	30.186	0.00	0.00	0.111	0.000
10/27/24	4:15a	54.6	54.6	54.3	25	19.4	1.0	ESE	0.25	4.0	ESE	54.6	51.4	51.4	30.176	0.00	0.00	0.108	0.000
10/27/24	4:30a	54.9	54.9	54.6	25	19.7	1.0	ENE	0.25	4.0	E	54.9	51.6	51.6	30.164	0.00	0.00	0.105	0.000
10/27/24	4:45a	55.4	55.4	54.8	24	19.2	2.0	ENE	0.50	4.0	ENE	55.4	52.0	52.0	30.180	0.00	0.00	0.100	0.000
10/27/24	5:00a	56.2	56.2	55.4	23	18.6	0.0	ESE	0.00	2.0	E	56.2	52.5	52.5	30.194	0.00	0.00	0.092	0.000
10/27/24	5:15a	55.6	56.2	55.6	22	17.3	1.0	SE	0.25	3.0	SE	55.6	52.0	52.0	30.190	0.00	0.00	0.098	0.000
10/27/24	5:30a	55.2	55.6	55.2	23	18.0	0.0	SSE	0.00	2.0	SSE	55.2	51.8	51.8	30.183	0.00	0.00	0.102	0.000
10/27/24	5:45a	55.8	55.9	55.2	24	19.5	0.0	SSE	0.00	2.0	SSE	55.8	52.3	52.3	30.177	0.00	0.00	0.096	0.000
10/27/24	6:00a	56.0	56.0	55.9	23	18.7	0.0	WNW	0.00	1.0	WNW	56.0	52.4	52.4	30.178	0.00	0.00	0.094	0.000
10/27/24	6:15a	55.8	56.2	55.8	23	18.5	2.0	SSE	0.50	5.0	SSE	55.8	52.2	52.2	30.188	0.00	0.00	0.096	0.000
10/27/24	6:30a	55.2	55.8	55.2	24	19.0	2.0	S	0.50	6.0	SSE	55.2	51.8	51.8	30.181	0.00	0.00	0.102	0.000
10/27/24	6:45a	55.4	55.5	55.2	24	19.2	1.0	SSW	0.25	4.0	SSW	55.4	52.0	52.0	30.167	0.00	0.00	0.100	0.000
10/27/24	7:00a	55.7	55.7	55.4	24	19.4	1.0	SSE	0.25	5.0	SE	55.7	52.2	52.2	30.173	0.00	0.00	0.097	0.000
10/27/24	7:15a	55.3	55.7	55.3	25	20.0	1.0	SE	0.25	4.0	SE	55.3	51.9	51.9	30.180	0.00	0.00	0.101	0.000
10/27/24	7:30a	55.2	55.3	55.2	24	19.0	1.0	S	0.25	4.0	SSE	55.2	51.8	51.8	30.199	0.00	0.00	0.102	0.000
10/27/24	7:45a	55.4	55.5	55.2	23	18.2	1.0	SE	0.25	4.0	SSE	55.4	51.9	51.9	30.205	0.00	0.00	0.100	0.000
10/27/24	8:00a	55.6	55.6	55.4	23	18.3	2.0	ESE	0.50	6.0	ESE	55.6	52.1	52.1	30.201	0.00	0.00	0.098	0.000
10/27/24	8:15a	55.9	55.9	55.5	21	16.5	2.0	SSE	0.50	7.0	SE	55.9	52.2	52.2	30.202	0.00	0.00	0.095	0.000
10/27/24	8:30a	56.5	56.5	55.9	18	13.4	0.0	SSW	0.00	3.0	SSW	56.5	52.5	52.5	30.231	0.00	0.00	0.089	0.000
10/27/24	8:45a	58.2	58.2	56.5	12	5.7	3.0	SSW	0.75	8.0	SSW	58.2	53.8	53.8	30.240	0.00	0.00	0.071	0.000
10/27/24	9:00a	58.9	58.9	58.2	10	2.3	1.0	SSW	0.25	8.0	S	58.9	54.3	54.3	30.228	0.00	0.00	0.064	0.000
10/27/24	9:15a	60.2	60.2	58.9	7	-4.3	4.0	NW	1.00	11.0	NNW	60.2	54.9	54.9	30.204	0.00	0.00	0.050	0.000
10/27/24	9:30a	61.3	61.4	60.2	4	-14.9	5.0	WNW	1.25	11.0	NW	61.3	55.4	55.4	30.221	0.00	0.00	0.039	0.000
10/27/24	9:45a	62.1	62.1	61.4	3	-19.9	3.0	WNW	0.75	8.0	NW	62.1	55.9	55.9	30.230	0.00	0.00	0.030	0.000
10/27/24	10:00a	61.9	62.6	61.9	6	-6.2	5.0	SE	1.25	10.0	SE	61.9	56.1	56.1	30.229	0.00	0.00	0.032	0.000
10/27/24	10:15a	62.4	62.4	62.0	4	-14.1	2.0	SSE	0.50	10.0	SSE	62.4	56.3	56.3	30.226	0.00	0.00	0.027	0.000
10/27/24	10:30a	63.7	63.8	62.4	2	-26.6	2.0	S	0.50	6.0	SSE	63.7	57.2	57.2	30.225	0.00	0.00	0.014	0.000
10/27/24	10:45a	64.6	64.6	63.7	1	-38.5	2.0	SW	0.50	5.0	SW	64.6	57.9	57.9	30.223	0.00	0.00	0.004	0.000
10/27/24	11:00a	65.6	65.6	64.5	1	-37.9	1.0	SW	0.25	5.0	SW	65.6	58.7	58.7	30.208	0.00	0.00	0.000	0.006
10/27/24	11:15a	66.8	66.8	65.6	---	---	1.0	SE	0.25	6.0	ESE	66.8	---	---	30.212	0.00	0.00	0.000	0.019
10/27/24	11:30a	67.7	67.7	66.7	0	---	1.0	E	0.25	5.0	ESE	67.7	60.5	60.5	30.207	0.00	0.00	0.000	0.028
10/27/24	11:45a	68.4	68.4	67.7	0	---	3.0	SE	0.75	9.0	SE	68.4	61.4	61.4	30.220	0.00	0.00	0.000	0.035
10/27/24	12:00p	69.1	69.1	68.4	0	---	2.0	SSW	0.50	6.0	S	69.1	62.5	62.5	30.219	0.00	0.00	0.000	0.043
10/27/24	12:15p	69.7	69.7	69.1	0	---	1.0	W	0.25	6.0	W	69.7	63.4	63.4	30.207	0.00	0.00	0.000	0.049
10/27/24	12:30p	70.3	70.4	69.7	0	---	2.0	W	0.50	6.0	W	70.3	64.3	64.3	30.199	0.00	0.00	0.000	0.055

NKSP 10/27/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/27/24	12:45p	70.8	70.9	70.3	0	---	2.0	NW	0.50	7.0	WNW	70.8	64.9	64.9	30.193	0.00	0.00	0.000	0.060
10/27/24	1:00p	71.5	71.5	70.9	0	---	1.0	NW	0.25	5.0	NNW	71.5	65.8	65.8	30.192	0.00	0.00	0.000	0.068
10/27/24	1:15p	72.6	72.6	71.5	0	---	0.0	W	0.00	1.0	W	72.6	67.2	67.2	30.188	0.00	0.00	0.000	0.079
10/27/24	1:30p	72.6	72.7	72.4	0	---	1.0	ENE	0.25	4.0	ENE	72.6	67.2	67.2	30.172	0.00	0.00	0.000	0.079
10/27/24	1:45p	73.8	73.8	72.5	0	---	1.0	E	0.25	3.0	E	73.8	68.8	68.8	30.155	0.00	0.00	0.000	0.092
10/27/24	2:00p	73.7	74.0	73.5	0	---	2.0	SE	0.50	6.0	ESE	73.7	68.7	68.7	30.153	0.00	0.00	0.000	0.091
10/27/24	2:15p	73.9	74.2	73.7	0	---	1.0	SE	0.25	3.0	SE	73.9	69.0	69.0	30.150	0.00	0.00	0.000	0.093
10/27/24	2:30p	74.4	74.4	73.9	0	---	1.0	SE	0.25	3.0	SE	74.4	69.6	69.6	30.143	0.00	0.00	0.000	0.098
10/27/24	2:45p	74.2	74.6	74.2	0	---	2.0	SE	0.50	6.0	ESE	74.2	69.3	69.3	30.141	0.00	0.00	0.000	0.096
10/27/24	3:00p	74.4	74.6	74.2	0	---	2.0	SSW	0.50	5.0	SSE	74.4	69.6	69.6	30.135	0.00	0.00	0.000	0.098
10/27/24	3:15p	74.8	74.9	74.4	0	---	1.0	S	0.25	3.0	S	74.8	70.1	70.1	30.130	0.00	0.00	0.000	0.102
10/27/24	3:30p	74.4	74.9	74.3	0	---	3.0	S	0.75	7.0	SSW	74.4	69.6	69.6	30.129	0.00	0.00	0.000	0.098
10/27/24	3:45p	74.1	74.5	74.1	0	---	2.0	S	0.50	5.0	S	74.1	69.2	69.2	30.122	0.00	0.00	0.000	0.095
10/27/24	4:00p	74.4	74.5	74.0	0	---	2.0	S	0.50	6.0	SSW	74.4	69.6	69.6	30.124	0.00	0.00	0.000	0.098
10/27/24	4:15p	73.8	74.4	73.8	0	---	3.0	SSW	0.75	6.0	SSW	73.8	68.8	68.8	30.114	0.00	0.00	0.000	0.092
10/27/24	4:30p	73.5	73.8	73.5	0	---	3.0	SSW	0.75	7.0	SSW	73.5	68.4	68.4	30.118	0.00	0.00	0.000	0.089
10/27/24	4:45p	73.3	73.5	73.3	0	---	4.0	SSW	1.00	10.0	S	73.3	68.1	68.1	30.117	0.00	0.00	0.000	0.086
10/27/24	5:00p	72.8	73.3	72.8	0	---	3.0	S	0.75	8.0	S	72.8	67.5	67.5	30.114	0.00	0.00	0.000	0.081
10/27/24	5:15p	72.5	72.8	72.5	0	---	3.0	S	0.75	6.0	S	72.5	67.1	67.1	30.120	0.00	0.00	0.000	0.078
10/27/24	5:30p	71.9	72.5	71.9	0	---	2.0	SSE	0.50	4.0	S	71.9	66.4	66.4	30.121	0.00	0.00	0.000	0.072
10/27/24	5:45p	71.4	72.0	71.4	---	---	1.0	S	0.25	5.0	S	71.4	---	---	30.119	0.00	0.00	0.000	0.067
10/27/24	6:00p	71.0	71.4	70.9	---	---	0.0	SSE	0.00	2.0	S	71.0	---	---	30.106	0.00	0.00	0.000	0.063
10/27/24	6:15p	69.7	71.0	69.7	4	-9.0	3.0	ESE	0.75	6.0	ESE	69.7	63.6	63.6	30.113	0.00	0.00	0.000	0.049
10/27/24	6:30p	69.2	69.7	69.2	4	-9.3	3.0	SE	0.75	7.0	SE	69.2	63.0	63.0	30.115	0.00	0.00	0.000	0.044
10/27/24	6:45p	68.0	69.2	68.0	5	-5.6	2.0	SE	0.50	7.0	SE	68.0	61.4	61.4	30.110	0.00	0.00	0.000	0.031
10/27/24	7:00p	67.8	68.0	67.7	5	-5.7	1.0	ESE	0.25	4.0	SE	67.8	61.2	61.2	30.112	0.00	0.00	0.000	0.029
10/27/24	7:15p	67.4	67.8	67.4	7	1.1	0.0	ESE	0.00	2.0	ESE	67.4	61.2	61.2	30.115	0.00	0.00	0.000	0.025
10/27/24	7:30p	67.5	67.6	67.4	6	-2.1	0.0	ESE	0.00	2.0	ESE	67.5	61.1	61.1	30.110	0.00	0.00	0.000	0.026
10/27/24	7:45p	67.0	67.5	67.0	7	0.8	0.0	---	0.00	0.0	---	67.0	60.9	60.9	30.112	0.00	0.00	0.000	0.021
10/27/24	8:00p	66.9	67.0	66.8	9	6.1	0.0	SE	0.00	3.0	SE	66.9	61.3	61.3	30.111	0.00	0.00	0.000	0.020
10/27/24	8:15p	65.7	66.9	65.7	11	9.7	2.0	SE	0.50	5.0	SE	65.7	60.4	60.4	30.111	0.00	0.00	0.000	0.007
10/27/24	8:30p	64.7	65.6	64.7	11	8.9	3.0	SE	0.75	6.0	ESE	64.7	59.5	59.5	30.108	0.00	0.00	0.003	0.000
10/27/24	8:45p	64.5	64.7	64.4	12	10.7	4.0	ESE	1.00	7.0	SE	64.5	59.3	59.3	30.113	0.00	0.00	0.005	0.000
10/27/24	9:00p	64.7	64.8	64.5	11	8.9	2.0	SE	0.50	6.0	ESE	64.7	59.5	59.5	30.111	0.00	0.00	0.003	0.000
10/27/24	9:15p	63.9	64.7	63.9	14	13.7	2.0	SE	0.50	4.0	SE	63.9	58.7	58.7	30.110	0.00	0.00	0.011	0.000
10/27/24	9:30p	63.8	64.0	63.7	14	13.6	0.0	SE	0.00	2.0	SE	63.8	58.6	58.6	30.103	0.00	0.00	0.013	0.000
10/27/24	9:45p	63.8	63.8	63.6	13	11.9	0.0	SE	0.00	2.0	SE	63.8	58.6	58.6	30.105	0.00	0.00	0.013	0.000
10/27/24	10:00p	63.9	64.1	63.7	13	12.0	1.0	SE	0.25	4.0	SE	63.9	58.7	58.7	30.102	0.00	0.00	0.011	0.000
10/27/24	10:15p	63.1	63.9	63.1	14	13.1	2.0	SE	0.50	5.0	SE	63.1	58.0	58.0	30.100	0.00	0.00	0.020	0.000
10/27/24	10:30p	63.4	63.5	63.0	13	11.6	1.0	SE	0.25	3.0	SE	63.4	58.3	58.3	30.099	0.00	0.00	0.017	0.000
10/27/24	10:45p	62.8	63.5	62.8	13	11.1	1.0	ESE	0.25	3.0	SE	62.8	57.7	57.7	30.095	0.00	0.00	0.023	0.000
10/27/24	11:00p	62.3	62.8	62.3	15	14.0	0.0	ESE	0.00	3.0	ESE	62.3	57.3	57.3	30.095	0.00	0.00	0.028	0.000
10/27/24	11:15p	62.3	62.4	62.2	14	12.4	0.0	---	0.00	0.0	---	62.3	57.3	57.3	30.095	0.00	0.00	0.028	0.000
10/27/24	11:30p	62.3	62.3	62.3	14	12.4	0.0	---	0.00	0.0	---	62.3	57.3	57.3	30.092	0.00	0.00	0.028	0.000
10/27/24	11:45p	62.1	62.3	62.0	15	13.8	0.0	ESE	0.00	1.0	ESE	62.1	57.1	57.1	30.092	0.00	0.00	0.030	0.000
10/28/24	12:00a	61.5	62.1	61.5	15	13.4	0.0	---	0.00	0.0	---	61.5	56.5	56.5	30.096	0.00	0.00	0.036	0.000

NKSP 10/26/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/26/24	12:15a	75.7	42	51.0	74.8	7.94	.0738	350	1	100.0	15
10/26/24	12:30a	75.8	42	51.1	74.9	7.93	.0738	351	1	100.0	15
10/26/24	12:45a	75.3	42	50.6	74.4	7.94	.0739	351	1	100.0	15
10/26/24	1:00a	75.3	42	50.6	74.4	7.94	.0739	352	1	100.0	15
10/26/24	1:15a	75.4	42	50.7	74.5	7.94	.0739	351	1	100.0	15
10/26/24	1:30a	75.3	40	49.3	74.2	7.64	.0739	351	1	100.0	15
10/26/24	1:45a	74.7	43	50.7	73.9	8.06	.0740	351	1	100.0	15
10/26/24	2:00a	75.1	42	50.4	74.2	7.95	.0739	352	1	100.0	15
10/26/24	2:15a	74.8	42	50.2	73.9	7.95	.0740	351	1	100.0	15
10/26/24	2:30a	74.8	42	50.2	73.9	7.95	.0740	351	1	100.0	15
10/26/24	2:45a	75.1	42	50.4	74.2	7.95	.0739	351	1	100.0	15
10/26/24	3:00a	75.3	42	50.6	74.4	7.94	.0739	351	1	100.0	15
10/26/24	3:15a	75.5	41	50.1	74.5	7.75	.0739	352	1	100.0	15
10/26/24	3:30a	75.6	41	50.2	74.6	7.75	.0739	351	1	100.0	15
10/26/24	3:45a	75.7	41	50.3	74.7	7.75	.0739	351	1	100.0	15
10/26/24	4:00a	75.7	40	49.7	74.6	7.64	.0739	351	1	100.0	15
10/26/24	4:15a	75.8	40	49.8	74.7	7.63	.0739	352	1	100.0	15
10/26/24	4:30a	75.7	40	49.7	74.6	7.64	.0739	351	1	100.0	15
10/26/24	4:45a	75.7	40	49.7	74.6	7.64	.0739	351	1	100.0	15
10/26/24	5:00a	75.6	41	50.2	74.6	7.75	.0739	351	1	100.0	15
10/26/24	5:15a	75.7	41	50.3	74.7	7.75	.0739	352	1	100.0	15
10/26/24	5:30a	75.5	40	49.5	74.4	7.64	.0739	351	1	100.0	15
10/26/24	5:45a	75.5	41	50.1	74.5	7.75	.0739	351	1	100.0	15
10/26/24	6:00a	75.4	41	50.1	74.4	7.75	.0739	351	1	100.0	15
10/26/24	6:15a	75.3	41	50.0	74.3	7.75	.0739	351	1	100.0	15
10/26/24	6:30a	75.2	41	49.9	74.2	7.75	.0740	352	1	100.0	15
10/26/24	6:45a	75.1	41	49.8	74.1	7.75	.0740	351	1	100.0	15
10/26/24	7:00a	75.0	41	49.7	74.0	7.75	.0740	351	1	100.0	15
10/26/24	7:15a	74.9	41	49.6	73.9	7.75	.0740	351	1	100.0	15
10/26/24	7:30a	75.0	41	49.7	74.0	7.75	.0740	352	1	100.0	15
10/26/24	7:45a	75.0	41	49.7	74.0	7.75	.0741	351	1	100.0	15
10/26/24	8:00a	75.0	41	49.7	74.0	7.75	.0741	351	1	100.0	15
10/26/24	8:15a	75.0	40	49.0	73.9	7.65	.0741	351	1	100.0	15
10/26/24	8:30a	74.6	41	49.3	73.6	7.77	.0742	352	1	100.0	15
10/26/24	8:45a	74.9	41	49.6	73.9	7.75	.0742	351	1	100.0	15
10/26/24	9:00a	75.3	41	50.0	74.3	7.75	.0741	351	1	100.0	15
10/26/24	9:15a	75.6	41	50.2	74.6	7.75	.0740	351	1	100.0	15
10/26/24	9:30a	75.8	39	49.1	74.6	7.53	.0741	351	1	100.0	15
10/26/24	9:45a	75.7	40	49.7	74.6	7.64	.0740	352	1	100.0	15
10/26/24	10:00a	75.7	40	49.7	74.6	7.64	.0740	351	1	100.0	15
10/26/24	10:15a	76.2	40	50.1	75.1	7.63	.0740	351	1	100.0	15
10/26/24	10:30a	76.3	40	50.2	75.2	7.62	.0739	351	1	100.0	15
10/26/24	10:45a	76.8	39	50.0	75.6	7.51	.0739	352	1	100.0	15
10/26/24	11:00a	76.9	40	50.7	75.8	7.61	.0738	351	1	100.0	15
10/26/24	11:15a	77.1	40	50.9	76.0	7.61	.0738	351	1	100.0	15
10/26/24	11:30a	77.6	39	50.7	76.4	7.50	.0737	351	1	100.0	15
10/26/24	11:45a	77.7	39	50.8	76.4	7.50	.0737	351	1	100.0	15
10/26/24	12:00p	77.8	39	50.9	76.5	7.49	.0737	352	1	100.0	15
10/26/24	12:15p	78.0	38	50.3	76.6	7.29	.0736	351	1	100.0	15
10/26/24	12:30p	78.3	37	49.9	76.9	7.18	.0736	351	1	100.0	15

NKSP 10/26/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/26/24	12:45p	78.5	37	50.1	77.1	7.18	.0736	351	1	100.0	15
10/26/24	1:00p	78.7	37	50.2	77.3	7.18	.0735	352	1	100.0	15
10/26/24	1:15p	78.7	38	51.0	77.3	7.28	.0735	351	1	100.0	15
10/26/24	1:30p	78.7	38	51.0	77.3	7.28	.0734	351	1	100.0	15
10/26/24	1:45p	78.6	37	50.1	77.2	7.18	.0735	351	1	100.0	15
10/26/24	2:00p	78.9	37	50.4	77.5	7.17	.0734	352	1	100.0	15
10/26/24	2:15p	79.1	36	49.8	77.6	6.97	.0734	351	1	100.0	15
10/26/24	2:30p	79.2	36	49.9	77.7	6.97	.0734	351	1	100.0	15
10/26/24	2:45p	78.7	37	50.2	77.3	7.18	.0734	351	1	100.0	15
10/26/24	3:00p	78.4	37	50.0	77.0	7.18	.0735	351	1	100.0	15
10/26/24	3:15p	78.6	36	49.4	77.1	6.98	.0735	352	1	100.0	15
10/26/24	3:30p	79.1	35	49.1	77.5	6.87	.0734	351	1	100.0	15
10/26/24	3:45p	79.1	37	50.6	77.7	7.17	.0733	351	1	100.0	15
10/26/24	4:00p	78.9	37	50.4	77.5	7.17	.0734	351	1	100.0	15
10/26/24	4:15p	78.6	37	50.1	77.2	7.18	.0734	352	1	100.0	15
10/26/24	4:30p	78.8	36	49.6	77.3	6.97	.0734	351	1	100.0	15
10/26/24	4:45p	78.8	37	50.3	77.4	7.17	.0734	351	1	100.0	15
10/26/24	5:00p	78.5	37	50.1	77.1	7.18	.0734	351	1	100.0	15
10/26/24	5:15p	78.6	36	49.4	77.1	6.98	.0734	352	1	100.0	15
10/26/24	5:30p	78.6	36	49.4	77.1	6.98	.0734	351	1	100.0	15
10/26/24	5:45p	78.4	37	50.0	77.0	7.18	.0734	351	1	100.0	15
10/26/24	6:00p	78.1	37	49.7	76.7	7.19	.0735	351	1	100.0	15
10/26/24	6:15p	78.1	36	49.0	76.6	6.99	.0735	351	1	100.0	15
10/26/24	6:30p	78.0	38	50.3	76.6	7.29	.0735	352	1	100.0	15
10/26/24	6:45p	77.6	39	50.7	76.4	7.50	.0736	351	1	100.0	15
10/26/24	7:00p	77.5	38	49.9	76.2	7.30	.0736	351	1	100.0	15
10/26/24	7:15p	77.5	39	50.6	76.3	7.50	.0736	351	1	100.0	15
10/26/24	7:30p	77.1	39	50.2	75.9	7.51	.0736	352	1	100.0	15
10/26/24	7:45p	77.1	38	49.5	75.8	7.31	.0737	351	1	100.0	15
10/26/24	8:00p	77.1	40	50.9	76.0	7.61	.0736	351	1	100.0	15
10/26/24	8:15p	76.6	40	50.5	75.5	7.62	.0737	351	1	100.0	15
10/26/24	8:30p	76.9	39	50.1	75.7	7.51	.0737	352	1	100.0	15
10/26/24	8:45p	76.6	41	51.1	75.6	7.75	.0737	351	1	100.0	15
10/26/24	9:00p	76.6	39	49.8	75.4	7.52	.0738	351	1	100.0	15
10/26/24	9:15p	76.5	41	51.0	75.5	7.75	.0738	351	1	100.0	15
10/26/24	9:30p	76.3	41	50.9	75.3	7.75	.0738	351	1	100.0	15
10/26/24	9:45p	76.4	42	51.6	75.5	7.92	.0738	352	1	100.0	15
10/26/24	10:00p	76.1	42	51.3	75.2	7.93	.0738	351	1	100.0	15
10/26/24	10:15p	76.3	43	52.2	75.5	8.05	.0738	351	1	100.0	15
10/26/24	10:30p	76.0	42	51.2	75.1	7.93	.0738	351	1	100.0	15
10/26/24	10:45p	76.2	43	52.1	75.4	8.05	.0738	352	1	100.0	15
10/26/24	11:00p	75.8	42	51.1	74.9	7.93	.0739	351	1	100.0	15
10/26/24	11:15p	75.8	43	51.7	75.0	8.05	.0738	351	1	100.0	15
10/26/24	11:30p	76.0	41	50.6	75.0	7.75	.0739	351	1	100.0	15
10/26/24	11:45p	75.6	43	51.5	74.8	8.05	.0739	351	1	100.0	15
10/27/24	12:00a	75.7	43	51.6	74.9	8.05	.0738	352	1	100.0	15

NKSP 10/27/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/27/24	12:15a	75.8	43	51.7	75.0	8.05	.0738	350	1	100.0	15
10/27/24	12:30a	75.3	43	51.3	74.5	8.05	.0739	351	1	100.0	15
10/27/24	12:45a	75.3	43	51.3	74.5	8.05	.0739	352	1	100.0	15
10/27/24	1:00a	75.4	43	51.3	74.6	8.05	.0739	351	1	100.0	15
10/27/24	1:15a	75.5	43	51.4	74.7	8.05	.0739	351	1	100.0	15
10/27/24	1:30a	75.5	43	51.4	74.7	8.05	.0738	351	1	100.0	15
10/27/24	1:45a	75.5	43	51.4	74.7	8.05	.0739	352	1	100.0	15
10/27/24	2:00a	75.5	43	51.4	74.7	8.05	.0739	351	1	100.0	15
10/27/24	2:15a	75.6	42	50.9	74.7	7.94	.0739	351	1	100.0	15
10/27/24	2:30a	75.5	42	50.8	74.6	7.94	.0739	351	1	100.0	15
10/27/24	2:45a	75.5	42	50.8	74.6	7.94	.0739	351	1	100.0	15
10/27/24	3:00a	75.5	42	50.8	74.6	7.94	.0739	352	1	100.0	15
10/27/24	3:15a	75.5	42	50.8	74.6	7.94	.0738	351	1	100.0	15
10/27/24	3:30a	75.5	42	50.8	74.6	7.94	.0738	351	1	100.0	15
10/27/24	3:45a	75.5	42	50.8	74.6	7.94	.0739	351	1	100.0	15
10/27/24	4:00a	75.5	42	50.8	74.6	7.94	.0739	352	1	100.0	15
10/27/24	4:15a	75.5	42	50.8	74.6	7.94	.0739	351	1	100.0	15
10/27/24	4:30a	75.5	42	50.8	74.6	7.94	.0738	351	1	100.0	15
10/27/24	4:45a	75.5	42	50.8	74.6	7.94	.0739	351	1	100.0	15
10/27/24	5:00a	75.5	42	50.8	74.6	7.94	.0739	352	1	100.0	15
10/27/24	5:15a	75.5	42	50.8	74.6	7.94	.0739	351	1	100.0	15
10/27/24	5:30a	75.5	42	50.8	74.6	7.94	.0739	351	1	100.0	15
10/27/24	5:45a	75.5	42	50.8	74.6	7.94	.0739	351	1	100.0	15
10/27/24	6:00a	75.7	42	51.0	74.8	7.94	.0738	351	1	100.0	15
10/27/24	6:15a	75.5	41	50.1	74.5	7.75	.0739	352	1	100.0	15
10/27/24	6:30a	75.1	42	50.4	74.2	7.95	.0739	351	1	100.0	15
10/27/24	6:45a	75.0	43	51.0	74.2	8.05	.0739	351	1	100.0	15
10/27/24	7:00a	75.1	42	50.4	74.2	7.95	.0739	351	1	100.0	15
10/27/24	7:15a	75.2	42	50.5	74.3	7.95	.0739	352	1	100.0	15
10/27/24	7:30a	74.4	43	50.4	73.5	8.07	.0741	351	1	100.0	15
10/27/24	7:45a	74.6	43	50.6	73.8	8.07	.0741	351	1	100.0	15
10/27/24	8:00a	74.6	41	49.3	73.6	7.77	.0741	351	1	100.0	15
10/27/24	8:15a	74.2	43	50.3	73.3	8.08	.0741	351	1	100.0	15
10/27/24	8:30a	74.9	43	50.9	74.1	8.05	.0741	352	1	100.0	15
10/27/24	8:45a	74.3	43	50.4	73.4	8.08	.0742	351	1	100.0	15
10/27/24	9:00a	75.0	42	50.3	74.1	7.95	.0741	351	1	100.0	15
10/27/24	9:15a	74.8	41	49.5	73.8	7.76	.0741	351	1	100.0	15
10/27/24	9:30a	74.9	41	49.6	73.9	7.75	.0741	352	1	100.0	15
10/27/24	9:45a	75.5	39	48.8	74.3	7.54	.0741	351	1	100.0	15
10/27/24	10:00a	75.1	41	49.8	74.1	7.75	.0741	351	1	100.0	15
10/27/24	10:15a	75.9	40	49.8	74.8	7.63	.0740	351	1	100.0	15
10/27/24	10:30a	76.5	39	49.7	75.3	7.52	.0739	352	1	100.0	15
10/27/24	10:45a	76.6	39	49.8	75.4	7.52	.0739	351	1	100.0	15
10/27/24	11:00a	76.4	39	49.6	75.2	7.52	.0739	351	1	100.0	15
10/27/24	11:15a	77.3	39	50.4	76.1	7.50	.0737	351	1	100.0	15
10/27/24	11:30a	76.8	39	50.0	75.6	7.51	.0738	351	1	100.0	15
10/27/24	11:45a	77.6	38	50.0	76.3	7.30	.0737	352	1	100.0	15
10/27/24	12:00p	77.2	39	50.3	76.0	7.51	.0738	351	1	100.0	15
10/27/24	12:15p	77.9	36	48.8	76.4	6.99	.0737	351	1	100.0	15
10/27/24	12:30p	78.0	38	50.3	76.6	7.29	.0736	351	1	100.0	15

NKSP 10/27/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/27/24	12:45p	77.9	38	50.2	76.6	7.29	.0736	352	1	100.0	15
10/27/24	1:00p	78.0	38	50.3	76.6	7.29	.0736	351	1	100.0	15
10/27/24	1:15p	78.5	37	50.1	77.1	7.18	.0735	351	1	100.0	15
10/27/24	1:30p	78.3	38	50.6	76.9	7.28	.0735	351	1	100.0	15
10/27/24	1:45p	78.2	38	50.5	76.8	7.29	.0734	352	1	100.0	15
10/27/24	2:00p	78.8	38	51.0	77.4	7.27	.0733	351	1	100.0	15
10/27/24	2:15p	79.0	38	51.2	77.6	7.27	.0733	351	1	100.0	15
10/27/24	2:30p	79.1	37	50.6	77.7	7.17	.0733	351	1	100.0	15
10/27/24	2:45p	79.4	37	50.9	77.9	7.16	.0732	351	1	100.0	15
10/27/24	3:00p	79.2	38	51.4	77.8	7.27	.0732	352	1	100.0	15
10/27/24	3:15p	79.2	37	50.7	77.7	7.17	.0732	351	1	100.0	15
10/27/24	3:30p	79.5	36	50.2	77.9	6.96	.0732	351	1	100.0	15
10/27/24	3:45p	79.2	38	51.4	77.8	7.27	.0732	351	1	100.0	15
10/27/24	4:00p	79.0	37	50.5	77.6	7.17	.0733	352	1	100.0	15
10/27/24	4:15p	79.2	37	50.7	77.7	7.17	.0732	351	1	100.0	15
10/27/24	4:30p	78.8	38	51.0	77.4	7.27	.0733	351	1	100.0	15
10/27/24	4:45p	78.8	37	50.3	77.4	7.17	.0733	351	1	100.0	15
10/27/24	5:00p	78.7	39	51.7	77.4	7.48	.0732	351	1	100.0	15
10/27/24	5:15p	78.3	39	51.3	77.0	7.48	.0733	352	1	100.0	15
10/27/24	5:30p	78.6	38	50.9	77.2	7.28	.0733	351	1	100.0	15
10/27/24	5:45p	77.8	40	51.5	76.6	7.59	.0734	351	1	100.0	15
10/27/24	6:00p	78.1	38	50.4	76.7	7.29	.0733	351	1	100.0	15
10/27/24	6:15p	77.6	40	51.4	76.4	7.60	.0734	352	1	100.0	15
10/27/24	6:30p	77.7	38	50.1	76.4	7.30	.0734	351	1	100.0	15
10/27/24	6:45p	77.3	41	51.8	76.3	7.75	.0734	351	1	100.0	15
10/27/24	7:00p	77.4	39	50.5	76.2	7.50	.0735	351	1	100.0	15
10/27/24	7:15p	77.2	41	51.7	76.2	7.75	.0734	352	1	100.0	15
10/27/24	7:30p	77.4	39	50.5	76.2	7.50	.0734	351	1	100.0	15
10/27/24	7:45p	76.8	42	52.0	75.9	7.91	.0735	351	1	100.0	15
10/27/24	8:00p	77.2	41	51.7	76.2	7.75	.0734	351	1	100.0	15
10/27/24	8:15p	76.6	42	51.8	75.7	7.92	.0735	352	1	100.0	15
10/27/24	8:30p	76.9	42	52.1	76.0	7.91	.0735	351	1	100.0	15
10/27/24	8:45p	76.6	42	51.8	75.7	7.92	.0735	351	1	100.0	15
10/27/24	9:00p	76.6	43	52.4	75.8	8.05	.0735	351	1	100.0	15
10/27/24	9:15p	76.8	43	52.6	76.0	8.05	.0735	351	1	100.0	15
10/27/24	9:30p	76.3	43	52.2	75.5	8.05	.0735	352	1	100.0	15
10/27/24	9:45p	76.6	43	52.4	75.8	8.05	.0735	351	1	100.0	15
10/27/24	10:00p	76.4	43	52.2	75.6	8.05	.0735	351	1	100.0	15
10/27/24	10:15p	76.5	44	53.0	75.8	8.22	.0735	351	1	100.0	15
10/27/24	10:30p	76.7	41	51.2	75.7	7.75	.0735	352	1	100.0	15
10/27/24	10:45p	76.3	44	52.8	75.6	8.22	.0735	351	1	100.0	15
10/27/24	11:00p	76.5	43	52.3	75.7	8.05	.0735	351	1	100.0	15
10/27/24	11:15p	76.4	41	51.0	75.4	7.75	.0735	351	1	100.0	15
10/27/24	11:30p	75.8	44	52.3	75.1	8.23	.0736	351	1	100.0	15
10/27/24	11:45p	76.0	44	52.5	75.3	8.23	.0735	352	1	100.0	15
10/28/24	12:00a	76.4	44	52.9	75.7	8.22	.0735	351	1	100.0	15

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB-1 A Temp. Reading Location: 2ND TIER B-SECTION
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-28-24	0300	61	A. CASABAY
	0600	63	E. Andrade
	0900	64	E. Andrade
	1200	66	E. Andrade
	1500	64	R. Knight
	1800	64	R. Knight
	2100	62	R. Knight
	2400	61	D. Hill

Tuesday

Date	Time	Temp.	Name (Print)
10-29-24	0300	[illegible]	D. Hill
	0600	62°	E. Andrade
	0900	65	E. Andrade
	1200	66	E. Andrade
	1500	66	M. Lopez
	1800	64	M. Lopez
	2100	63	M. Lopez
	2400	62	D. Hill

Wednesday

Date	Time	Temp.	Name (Print)
10-30-24	0300	60	D. Hill
	0600	62	R. Suarez
	0900	64	R. Suarez
	1200	66	R. Suarez
	1500	67	D. Castrejon
	1800	67	D. Castrejon
	2100	67	D. Castrejon
	2400	61	D. Hill

Thursday

Date	Time	Temp.	Name (Print)
10-31-24	0300	62	D. Hill
	0600	65	E. Andrade
	0900	66	E. Andrade
	1200	68	E. Andrade
	1500	68	D. Castrejon
	1800	68	D. Castrejon
	2100	68	D. Castrejon
	2400	61	D. Hill

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB- 1 B side Temp. Reading Location: 2ND TIER A-SECTION
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-28-24	0300	61	A. CASABAY
	0600	63	E. Andrade
	0900	64	E. Andrade
	1200	64	E. Andrade
	1500	64	R. Knight
	1800	64	R. Knight
	2100	62	R. Knight
	2400	61	D Hill

Tuesday

Date	Time	Temp.	Name (Print)
10-29-24	0300	60	D. Hill
	0600	62	E. Andrade
	0900	65	E. Andrade
	1200	66	E. Andrade
	1500	66	M. Lopez
	1800	64	M. Lopez
	2100	63	M. Lopez
	2400	62	D Hill

Wednesday

Date	Time	Temp.	Name (Print)
10-30-24	0300	60	D. Hill
	0600	62	R. Gaines
	0900	64	R. Gaines
	1200	66	R. Gaines
	1500	67	D. Castrejon
	1800	67	D. Castrejon
	2100	67	D. Castrejon
	2400	64	D Hill

Thursday

Date	Time	Temp.	Name (Print)
10-31-24	0300	62	D Hill
	0600	64	E. Andrade
	0900	65	E. Andrade
	1200	66	E. Andrade
	1500	68	D. Castrejon
	1800	68	D. Castrejon
	2100	68	D. Castrejon
	2400	61	D. Hill

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: MKSP Housing Unit: FAB-2 Temp. Reading Location: Second Tier - B section
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/28	0300	66	J Blanco
	0600	65	R-Lima
	0900	65	R-Lima
	1200	66	R-Lima
	1500	68	O Rbo
	1800	69	O Rbo
	2100	67	O Rbo
	2400	67	J Blanco

Tuesday

Date	Time	Temp.	Name (Print)
10/29	0300	66	J Blanco
	0600	65	R-Lima
	0900	66	R-Lima
	1200	67	R-Lima
	1500	68	O Rbo
	1800	66	O Rbo
	2100	65	O Rbo
	2400	65	J Blanco

Wednesday

Date	Time	Temp.	Name (Print)
10/30	0300	63	J Blanco
	0600	62	R-Lima
	0900	63	R-Lima
	1200	64	R-Lima
	1500	66	O Rbo
	1800	63	O Rbo
	2100	63	O Rbo
	2400	63	GRios

Thursday

Date	Time	Temp.	Name (Print)
10/31	0300	62	G. Rios
	0600	63	R-Lima
	0900	64	R-Lima
	1200	65	R-Lima
	1500	68	Fosan
	1800	68	Fosan
	2100	68	Fosan
	2400	62	G. Rios

Friday

Date	Time	Temp.	Name (Print)
11/01	0300	62	G. Rios
	0600	62	CHAN
	0900	62	CHAN
	1200	64	CHAN
	1500		
	1800		
	2100		
	2400		G. Rios

Saturday

Date	Time	Temp.	Name (Print)
11/02	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
11/03	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB-2 Temp. Reading Location: 2nd Tier - A section
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/28	0300	66	J Blanco
	0600	65	R-Lira
	0900	65	R-Lira
	1200	66	R-Lira
	1500	68	O Rho
	1800	69	O Rho
	2100	69	O Rho
	2400	69	J Blanco

Tuesday

Date	Time	Temp.	Name (Print)
10/29	0300	66	J Blanco
	0600	65	R-Lira
	0900	66	R-Lira
	1200	67	R-Lira
	1500	69	O Rho
	1800	67	O Rho
	2100	66	O Rho
	2400	65	J Blanco

Wednesday

Date	Time	Temp.	Name (Print)
10/30	0300	63	J Blanco
	0600	62	R-Lira
	0900	63	R-Lira
	1200	64	R-Lira
	1500	66	O Rho
	1800	67	O Rho
	2100	64	O Rho
	2400	63	G Rios

Thursday

Date	Time	Temp.	Name (Print)
10/31	0300	62	G. Rios
	0600	63	R-Lira
	0900	64	R-Lira
	1200	65	R-Lira
	1500	68	Fosan
	1800	68	Fosan
	2100	68	Fosan
	2400	62	G. Rios

Friday

Date	Time	Temp.	Name (Print)
11/01	0300	62	G. Rios
	0600	62	Chan
	0900	62	Chan
	1200	69	Chan
	1500		
	1800		
	2100		
	2400		G. Rios

Saturday

Date	Time	Temp.	Name (Print)
11/02	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
11/03	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB-3 Temp. Reading Location: A-Section 2nd Tier
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-28-24	0300	59	Gill
	0600	59	Saldana
	0900	60	Saldana
	1200	60	Saldana
	1500	60	HANUTOSA
	1800	60	HANUTOSA
	2100	59	HANUTOSA
	2400	59	Revelos

Tuesday

Date	Time	Temp.	Name (Print)
10-29-2024	0300	59	Reveles
	0600	60	CHAN
	0900	60	CHAN
	1200	64	CHAN
	1500	64	R. Borquez
	1800	63	R. Borquez
	2100	61	R. Borquez
	2400	59	LANE

Wednesday

Date	Time	Temp.	Name (Print)
10-30-24	0300	59°	LANE
	0600	59	Pompa
	0900	59	Pompa
	1200	59	Pompa
	1500	60°	Z. JONES
	1800	62°	Z. JONES
	2100	62	Z. JONES
	2400	60°	LANE

Thursday

Date	Time	Temp.	Name (Print)
10-31-24	0300	59°	LANE
	0600	55°	J GALLEGOS
	0900	55°	J GALLEGOS
	1200	60°	J GALLEGOS
	1500	60°	U. Corren
	1800	60°	U. Corren
	2100	59°	U. Corren
	2400	60°	LANE

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB-J Temp. Reading Location: B-Section 2nd (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-28-24	0300	59	Gill
	0600	59	Saldana
	0900	60	Saldana
	1200	60	Saldana
	1500	60	Huitron
	1800	60	Huitron
	2100	59	Huitron
	2400	59	Revelo

Tuesday

Date	Time	Temp.	Name (Print)
10-29-2024	0300	59	Revelo
	0600	60	CHAN
	0900	60	CHAN
	1200	64	CHAN
	1500	64	R. Borquez
	1800	63	R. Borquez
	2100	61	R. Borquez
	2400	60	LANE

Wednesday

Date	Time	Temp.	Name (Print)
10-30-24	0300	59°	LANE
	0600	59	Pompa
	0900	59	Pompa
	1200	59	Pompa
	1500	60	Z Jones
	1800	62	Z Jones
	2100	61	Z Jones
	2400	60°	LANE

Thursday

Date	Time	Temp.	Name (Print)
10-31-24	0300	59°	LANE
	0600	55°	J GALLEGOS
	0900	55°	J GALLEGOS
	1200	60°	J GALLEGOS
	1500	60	V Correa
	1800	60	V Correa
	2100	60	V Correa
	2400	60°	LANE

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NRSP Housing Unit: A4-A Temp. Reading Location: dayroom
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-28-2024	0300	64	Revelos
	0600	64	CHAN
	0900	64	CHAN
	1200	66	CHAN
	1500	66	Baeza
	1800	65	Baeza
	2100	64	Baeza
	2400	63	Baeza

Tuesday

Date	Time	Temp.	Name (Print)
10-29-2024	0300	64	G. ZAMORA
	0600	64	O.Montoya
	0900	66	O.Montoya
	1200	66	O.Montoya
	1500	65	Baeza
	1800	65	Baeza
	2100	64	Baeza
	2400	62	G. ZAMORA

Wednesday

Date	Time	Temp.	Name (Print)
10/30/24	0300	61	G. ZAMORA
	0600	64	O.Montoya
	0900	64	O.Montoya
	1200	64	O.Montoya
	1500	65	Baeza
	1800	64	Baeza
	2100	62	Baeza
	2400	62	Price

Thursday

Date	Time	Temp.	Name (Print)
10/31/24	0300	62	Price
	0600	62	O.Montoya
	0900	64	O.Montoya
	1200	66	O.Montoya
	1500	64	O.Montoya
	1800	64	O.Montoya
	2100	62	O.Montoya
	2400	62	Price

Friday

Date	Time	Temp.	Name (Print)
	0300	62	Price
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: A4-B Temp. Reading Location: dayroom (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-28 2024	0300	64	Reveles
	0600	64	CHAN
	0900	64	CHAN
	1200	66	CHAN
	1500	66	Baeza
	1800	65	Baeza
	2100	65	Baeza
	2400	63	Baeza

Tuesday

Date	Time	Temp.	Name (Print)
10-29 2024	0300	64	G. ZAMORA
	0600	64	O. Montoya
	0900	66	O. Montoya
	1200	66	O. Montoya
	1500	65	Baeza
	1800	65	Baeza
	2100	64	Baeza
	2400	62	G. ZAMORA

Wednesday

Date	Time	Temp.	Name (Print)
10/30/24	0300	61	G. ZAMORA
	0600	64	O. Montoya
	0900	64	O. Montoya
	1200	64	O. Montoya
	1500	65	Baeza
	1800	64	Baeza
	2100	62	Baeza
	2400	62	PRICE

Thursday

Date	Time	Temp.	Name (Print)
10/31/24	0300	62	PRICE
	0600	62	O. Montoya
	0900	64	O. Montoya
	1200	66	O. Montoya
	1500	64	O. Montoya
	1800	64	O. Montoya
	2100	62	O. Montoya
	2400	62	PRICE

Friday

Date	Time	Temp.	Name (Print)
	0300	62	PRICE
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB 5 Temp. Reading Location: 2nd Tier, B Sec
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10	0300	64	P. PENO J
	0600	64	Reveles
	0900	64	Reveles
28	1200	64	Reveles
	1500	64°	C. GRAUSON
	1800	64°	C. GRAUSON
24	2100	64°	C. GRAUSON
	2400	64	P. PENO J

Tuesday

Date	Time	Temp.	Name (Print)
10	0300	64	P. PENO J
	0600	65	M. Pompa
	0900	65	M. Pompa
29	1200	65	M. Pompa
	1500	65	J. Lule
	1800	64	J. Lule
24	2100	64	J. Lule
	2400	64	P. PENO J

Wednesday

Date	Time	Temp.	Name (Print)
10-30-24	0300	64	P. PENO J
	0600	62°	J. SCHULTZ
	0900	62°	J. SCHULTZ
	1200	66°	J. SCHULTZ
	1500	66	G. Rios
	1800	66	G. Rios
	2100	66	G. Rios
	2400	65	P. PENO J

Thursday

Date	Time	Temp.	Name (Print)
10-31-24	0300	64	P. PENO J
	0600	61°	J. SCHULTZ
	0900	62°	J. SCHULTZ
	1200	67°	J. SCHULTZ
	1500	68	G. Rios
	1800	66	G. Rios
	2100	66	G. Rios
	2400	64	C. Ramiscal

Friday

Date	Time	Temp.	Name (Print)
	0300	62	C. Ramiscal
11	0600	61°	J. SCHULTZ
	0900	62°	J. SCHULTZ
1	1200	65°	J. SCHULTZ
	1500		
	1800		
24	2100		
	2400	64	C. Ramiscal

Saturday

Date	Time	Temp.	Name (Print)
	0300	62	C. Ramiscal
11	0600		
	0900		
	1200		
2	1500		
	1800		
24	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB5 Temp. Reading Location: 2nd Tier, A Sec
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10	0300	64	D. Pinson
	0600	64	Reyes
28	0900	64	Reyes
	1200	64	Reyes
	1500	64	G Grayson
24	1800	64	G Grayson
	2100	64	G Grayson
	2400	64	D Pinson

Tuesday

Date	Time	Temp.	Name (Print)
10	0300	64	D. Pinson
	0600	65	M. Pompa
29	0900	65	M. Pompa
	1200	65	M Pompa
	1500	64	J Luke
24	1800	64	J Luke
	2100	64	J Luke
	2400	64	D. Pinson

Wednesday

Date	Time	Temp.	Name (Print)
10-30-24	0300	64	D Pinson
	0600	62°	J. Schultz
	0900	62°	J. Schultz
	1200	66°	J. Schultz
	1500	66	G Rios
	1800	66	G Rios
	2100	66	G Rios
	2400	65	D Pinson

Thursday

Date	Time	Temp.	Name (Print)
	0300	64	D. Pinson
	0600	61°	J. Schultz
10	0900	62°	J. Schultz
	1200	64	J. Schultz
31	1500	68	G Rios
	1800	66	G Rios
24	2100	66	G Rios
	2400	64	C Ramirez

Friday

Date	Time	Temp.	Name (Print)
	0300	62	C. Ramirez
11	0600	61°	J. Schultz
	0900	62°	J. Schultz
1	1200	65°	J. Schultz
	1500		
	1800		
24	2100		
	2400	64	C. Ramirez

Saturday

Date	Time	Temp.	Name (Print)
	0300	62	C. Ramirez
11	0600		
	0900		
	1200		
2	1500		
	1800		
24	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITAT

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 1 (A) or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-28-24	0300	69	RMATA
	0600	69	R Ramirez
	0900	69	R Ramirez
	1200	70	R Ramirez
	1500	70	J Soto
	1800	69	J Soto
	2100	69	J Soto
	2400	69	RMATA

Tuesday

Date	Time	Temp.	Name (Print)
10-29-24	0300	69	RMATA
	0600	69	R Ramirez
	0900	69	R Ramirez
	1200	70	R Ramirez
	1500	70	J. SOTO
	1800	69	J. SOTO
	2100	69	J. SOTO
	2400	69	R. MATA

Wednesday

Date	Time	Temp.	Name (Print)
10-30-24	0300	69	RMATA
	0600	69	R Ramirez
	0900	69	R Ramirez
	1200	70	R Ramirez
	1500	70	J Soto
	1800	70	J Soto
	2100	70	J Soto
	2400	70	RMATA

Thursday

Date	Time	Temp.	Name (Print)
10-31-24	0300	70	RMATA
	0600	70	R Ramirez
	0900	70	R Ramirez
	1200	70	R Ramirez
	1500	70	LOGAN
	1800	70	LOGAN
	2100	69	LOGAN
	2400	68	A. Ramos

Friday

Date	Time	Temp.	Name (Print)
11-1-24	0300	68	A. Ramos
	0600	68	R Ramirez
	0900	69	R Ramirez
	1200	70	R Ramirez
	1500		
	1800		
	2100		
	2400	68	A. Ramos

Saturday

Date	Time	Temp.	Name (Print)
11-2-24	0300	68	A. Ramos
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITAT

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 1 A or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-28-24	0300	69	RMATA
	0600	69	R Ramirez
	0900	69	R Rami
	1200	70	R Ramirez
	1500	70	J Soto
	1800	70	J Soto
	2100	69	J Soto
	2400	69	RMATA

Tuesday

Date	Time	Temp.	Name (Print)
10-29-24	0300	70	RMATA
	0600	69	R. Ramirez
	0900	69	R Ramirez
	1200	70	R Ramirez
	1500	70	R Ramirez
	1800	~~70~~	J. SOTO
	2100	70	J. SOTO
	2400	69	RMATA

Wednesday

Date	Time	Temp.	Name (Print)
10-30-24	0300	69	RMATA
	0600	69	R Ramirez
	0900	69	R Ramirez
	1200	70	R Ramirez
	1500	70	J SOTO
	1800	70	J SOTO
	2100	70	J SOTO
	2400	70	RMATA

Thursday

Date	Time	Temp.	Name (Print)
10-31-24	0300	70	RMATA
	0600	70	R Ramirez
	0900	70	R Ramirez
	1200	70	R Ramirez
	1500	70	LOGAN
	1800	70	LOGAN
	2100	69	LOGAN
	2400	68	Ramos

Friday

Date	Time	Temp.	Name (Print)
11/1/24	0300	68	Ramos
	0600	68	R Ramirez
	0900	69	R Ramirez
	1200	70	R. Ramirez
	1500		
	1800		
	2100		
	2400	68	A. Ramos

Saturday

Date	Time	Temp.	Name (Print)
11/2/24	0300	68	A Ramos
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITATI

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # ~~B~~ 2 A or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-28-24	0300	74	G. Linares
	0600	75	A. ORTIZ
	0900	75	A. ORTIZ
	1200	76	A. ORTIZ
	1500	76	R. SALAZAR
	1800	76	R. SALAZAR
	2100	76	R. SALAZAR
	2400	75	J. Villareal

Tuesday

Date	Time	Temp.	Name (Print)
10-29-24	0300	75	J. Villareal
	0600	75	J. ORTIZ
	0900	75	J. ORTIZ
	1200	76	J. ORTIZ
	1500	76	R. SALAZAR
	1800	76	R. SALAZAR
	2100	76	R. SALAZAR
	2400	75	Earnest

Wednesday

Date	Time	Temp.	Name (Print)
10-30-24	0300	75	Earnest
	0600	75	J. SMAL
	0900	75	J. SMAL
	1200	76	J. SMAL
	1500	76	R. SALAZAR
	1800	76	R. SALAZAR
	2100	76	R. SALAZAR
	2400	75	M. Raquido

Thursday

Date	Time	Temp.	Name (Print)
10-31-24	0300	74	M. Raquido
	0600	74	King
	0900	74	King
	1200	74	King
	1500	76	R. SALAZAR
	1800	76	R. SALAZAR
	2100	76	R. SALAZAR
	2400	75	E. Dodson

Friday

Date	Time	Temp.	Name (Print)
11-01-24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
11-02-24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
11-03-24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATI

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # ~~B~~ 2 A or (B) Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-28-24	0300	74	G. Linares
	0600	74	A. ORTIZ
	0900	75	A. ORTIZ
	1200	75	A. ORTIZ
	1500	76	R. SALAZAR
	1800	76	R. SALAZAR
	2100	76	R. SALAZAR
	2400	75	J. Villareal

Tuesday

Date	Time	Temp.	Name (Print)
10-29-24	0300	75	J. Villareal
	0600	75	A. ORTIZ
	0900	75	A. ORTIZ
	1200	76	A. ORTIZ
	1500	76	R. SALAZAR
	1800	76	R. SALAZAR
	2100	76	R. SALAZAR
	2400	75	Earnest

Wednesday

Date	Time	Temp.	Name (Print)
10-30-24	0300	74	Earnest
	0600	75	ORTIZ
	0900	75	ORTIZ
	1200	76	ORTIZ
	1500	76	R. Salazar
	1800	76	R. Salazar
	2100	76	R. Salazar
	2400	76	Raymondo

Thursday

Date	Time	Temp.	Name (Print)
10-31-24	0300	75	Raymondo
	0600	75	King
	0900	75	King
	1200	75	King
	1500	76	R. SALAZAR
	1800	76	R. SALAZAR
	2100	76	R. SALAZAR
	2400	75	E. Dodson

Friday

Date	Time	Temp.	Name (Print)
11-01-24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
11-02-24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
11-03-24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITAT

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 3 A or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-28-24	0300	78	P. Cerda
	0600	78	V. [illegible]
	0900	78	V. [illegible]
	1200	78	V. [illegible]
	1500	70	PASUMBAL
	1800	72	PASUMBAL
	2100	70	PASUMBAL
	2400	69	LOGAN

Tuesday

Date	Time	Temp.	Name (Print)
10-29-24	0300	69	LOGAN
	0600	69	J. Hernandez
	0900	69	J. Hernandez
	1200	69	J. Hernandez
	1500	70	SOLORIO
	1800	70	SOLORIO
	2100	70	SOLORIO
	2400	70	CHAPMAN

Wednesday

Date	Time	Temp.	Name (Print)
10-30-24	0300	70	CHAPMAN
	0600	70	CHAPMAN
	0900	70	J. Hernandez
	1200	70	J. Hernandez
	1500	70	SOLORIO
	1800	70	SOLORIO
	2100	70	SOLORIO
	2400	68	P. Cerda

Thursday

Date	Time	Temp.	Name (Print)
10-31-24	0300	68	P. Cerda
	0600	68	J. Hernandez
	0900	68	J. Hernandez
	1200	68	J. Hernandez
	1500	70	SOLORIO
	1800	70	SOLORIO
	2100	70	SOLORIO
	2400	68	P. Cerda

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITAT

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 3 A or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-28-24	0300	78	Picerda
	0600	78	V. [illegible]
	0900	78	V. [illegible]
	1200	78	V. [illegible]
	1500	70	PASUMBAL
	1800	72	PASUMBAL
	2100	70	PASUMBAL
	2400	69	LOGAN

Tuesday

Date	Time	Temp.	Name (Print)
10-29-24	0300	69	LOGAN
	0600	69	J. Hernandez
	0900	69	J. Hernandez
	1200	69	J. Hernandez
	1500	70	SOLORIO
	1800	72	SOLORIO
	2100	70	SOLORIO
	2400	70	CHAPIN

Wednesday

Date	Time	Temp.	Name (Print)
10-30-24	0300	70	CHAPIN
	0600	70	CHAPIN
	0900	70	J. Hernandez
	1200	70	J. Hernandez
	1500	72	SOLORIO
	1800	72	SOLORIO
	2100	70	SOLORIO
	2400	68	Picerda

Thursday

Date	Time	Temp.	Name (Print)
10-31-24	0300	68	Picerda
	0600	68	J. Hernandez
	0900	68	J. Hernandez
	1200	68	J. Hernandez
	1500	70	SOLORIO
	1800	70	SOLORIO
	2100	70	SOLORIO
	2400	68	Picerda

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATI

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 4 or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/28/24	0300	68	LOGAN
	0600	68	King
	0900	68	King
	1200	68	King
	1500	68	H. [illegible]
	1800	67	H. [illegible]
	2100	67	H. [illegible]
	2400	66	Z. Green

Tuesday

Date	Time	Temp.	Name (Print)
10/29/24	0300	65	Z. Green
	0600	63	APEREZ
	0900	63	APEREZ
	1200	63	APEREZ
	1500	69	PASUMBAL
	1800	70	PASUMBAL
	2100	69	PASUMBAL
	2400	69	A. [illegible]

Wednesday

Date	Time	Temp.	Name (Print)
10/30/24	0300	68	A. Martin
	0600	63	APEREZ
	0900	63	APEREZ
	1200	63	APEREZ
	1500	68	Rains
	1800	68	Rains
	2100	68	Rains
	2400	68	R. Cisneros

Thursday

Date	Time	Temp.	Name (Print)
10-31-24	0300	67	R. Cisneros
	0600	66	C. Ponce
	0900	67	C. Ponce
	1200	67	C. Ponce
	1500	68	H. [illegible]
	1800	68	H. [illegible]
	2100	68	H. [illegible]
	2400	67	R. Cisneros

Friday

Date	Time	Temp.	Name (Print)
11-1-24	0300	66	R. Cisneros
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITATI

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 4 A or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/28/24	0300	68	LOGAN
	0600	68	King
	0900	68	King
	1200	68	King
	1500	68	H. Mammoux
	1800	68	H. Mammoux
	2100	67	H. Mammoux
	2400	67	Z. Green

Tuesday

Date	Time	Temp.	Name (Print)
10/29/24	0300	67	Z. Green
	0600	63	APEREZ
	0900	63	APEREZ
	1200	63	APEREZ
	1500	69	PASUMBAL
	1800	70	PASUMBAL
	2100	69	PASUMBAL
	2400	69	A. Martin

Wednesday

Date	Time	Temp.	Name (Print)
10/30/24	0300	68	A. Martin
	0600	63	APEREZ
	0900	63	APEREZ
	1200	63	APEREZ
	1500	69	Rains
	1800	68	Rains
	2100	68	Rains
	2400	68	R. Cisneros

Thursday

Date	Time	Temp.	Name (Print)
10-31-24	0300	67	R. Cisneros
	0600	66	C. Ponce
	0900	67	C. Ponce
	1200	67	C. Ponce
	1500	68	H. Mammoux
	1800	67	H. Mammoux
	2100	67	H. Mammoux
	2400	67	R. Cisneros

Friday

Date	Time	Temp.	Name (Print)
11-1-24	0300	66	R. Cisneros
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B5-A Temp. Reading Location: TIER 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10	0300	67	[illegible]
	0600	68	R. Ramirez
	0900	68	R. Ramirez
28	1200	69	R. Ramirez
	1500	70	C. Vejar
24	1800	70	C. Vejar
	2100	68	C. Vejar
	2400	66	[illegible]

Tuesday

Date	Time	Temp.	Name (Print)
10	0300	67	[illegible]
	0600	68	R. Ramirez
	0900	68	R. Ramirez
29	1200	69	R. Ramirez
	1500	70	C. Vejar
24	1800	70	C. Vejar
	2100	68	C. Vejar
	2400	66	[illegible]

Wednesday

Date	Time	Temp.	Name (Print)
10/30/24	0300	66	[illegible]
	0600	66	[illegible]
	0900	70	E. Cruz
	1200	70	E. Cruz
	1500	70	J. Ortega
	1800	70	J. Ortega
	2100	68	J. Ortega
	2400	66	[illegible]

Thursday

Date	Time	Temp.	Name (Print)
10/31/24	0300	66	[illegible]
	0600	67	E. Cruz
	0900	70	E. Cruz
	1200	70	E. Cruz
	1500	—	C. Campos
	1800	70	C. Campos
	2100	70	C. Campos
	2400	69	[illegible]

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B-5 B Temp. Reading Location: 1 TIER 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/28/24	0300	67	[illegible]
	0600	68	R. Ramirez
	0900	68	R. Ramirez
	1200	69	R. Ramirez
	1500	70	C. Vejar
	1800	70	C. Vejar
	2100	68	C. Vejar
	2400	66	[illegible]

Tuesday

Date	Time	Temp.	Name (Print)
10/29/24	0300	66	[illegible]
	0600	67	R. Ramirez
	0900	68	R. Ramirez
	1200	68	R. Ramirez
	1500	70	C. Vejar
	1800	70	C. Vejar
	2100	68	C. Vejar
	2400	66	[illegible]

Wednesday

Date	Time	Temp.	Name (Print)
10/30/24	0300	66	[illegible]
	0600	67	E. Cruz
	0900	70	E. Cruz
	1200	70	E. Cruz
	1500	70	J. Ortega
	1800	70	J. Ortega
	2100	68	J. Ortega
	2400	66	[illegible]

Thursday

Date	Time	Temp.	Name (Print)
10/31	0300	66	[illegible]
	0600	69	E. Cruz
	0900	71	E. Cruz
	1200	71	E. Cruz
	1500	70	G. Campos
	1800	70	G. Campos
	2100	70	G. Campos
	2400	69	Logan

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B-6 Temp. Reading Location: TIER 2
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/28/24	0300	70	ROSS
	0600	71	LOPEZ
	0900	72	LOPEZ
	1200	72	LOPEZ
	1500	71	Navarro
	1800	71	Navarro
	2100	71	Navarro
	2400	70	D SIS

Tuesday

Date	Time	Temp.	Name (Print)
10/29/24	0300	70	D. SIS
	0600	71	LOPEZ
	0900	71	LOPEZ
	1200	71	LOPEZ
	1500	71	ORTIZ
	1800	71	ORTIZ
	2100	70	ORTIZ
	2400	70	D SIS

Wednesday

Date	Time	Temp.	Name (Print)
10/30/24	0300	70	D SIS
	0600	70	LOPEZ
	0900	70	LOPEZ
	1200	70	LOPEZ
	1500	70	M. Romero
	1800	70	M. Romero
	2100	70	M. Romero
	2400	69	M. Romero

Thursday

Date	Time	Temp.	Name (Print)
10/31/24	0300	69	M. Romero
	0600	70	LOPEZ
	0900	70	LOPEZ
	1200	70	LOPEZ
	1500	68	S Mejia
	1800	68	S Mejia
	2100	68	S Mejia
	2400	67	H. Martinez

Friday

Date	Time	Temp.	Name (Print)
11/1/24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
11/2/24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
11/3/24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B-4 Temp. Reading Location: TIER 2
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension B 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-28-24	0300	70	ROSS
	0600	71	Lopez
	0900	71	Lopez
	1200	71	Lopez
	1500	71	Navarro
	1800	71	Navarro
	2100	71	Navarro
	2400	70	DSIS

Tuesday

Date	Time	Temp.	Name (Print)
10-29-24	0300	70	D. SIS
	0600	71	Lopez
	0900	71	Lopez
	1200	71	Lopez
	1500	71	ORTIZ
	1800	71	ORTIZ
	2100	71	ORTIZ
	2400	70	DSIS

Wednesday

Date	Time	Temp.	Name (Print)
10-30-24	0300	70	DSIS
	0600	70	Lopez
	0900	70	Lopez
	1200	70	Lopez
	1500	70	M. Romero
	1800	70	M. Romero
	2100	70	M. Romero
	2400	69	M. Romero

Thursday

Date	Time	Temp.	Name (Print)
10/31/24	0300	69	M. Romero
	0600	70	Lopez
	0900	70	Lopez
	1200	70	Lopez
	1500	68	Day
	1800	68	Shiju
	2100	68	Shiju
	2400	67	Hernandez

Friday

Date	Time	Temp.	Name (Print)
11/1/24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
11/2/24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
11/3/24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: 6 2A Temp. Reading Location: Day Room Above T.V.
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/28/24	0300	650	S. Pennell
	0600	69	McIntosh
	0900	70	McIntosh
	1200	70	McIntosh
	1500	70°	M. Franklin
	1800	70°	M. Franklin
	2100	70°	M. Franklin
	2400	70	L. Manco

Tuesday

Date	Time	Temp.	Name (Print)
10-29-24	0300	70	L. Manco
	0600	70	McIntosh
	0900	70	McIntosh
	1200	71	McIntosh
	1500	70°	M. Rains
	1800	70°	M. Rains
	2100	70°	M. Rains
	2400	68	Ellison

Wednesday

Date	Time	Temp.	Name (Print)
10/30/24	0300	68	Ellison
	0600	68	McIntosh
	0900	69	McIntosh
	1200	70	McIntosh
	1500	70	M. Serrato
	1800	70	M. Serrato
	2100	69	M. Serrato
	2400	68	Ellison

Thursday

Date	Time	Temp.	Name (Print)
10/31/24	0300	68	Ellison
	0600	68	McIntosh
	0900	68	McIntosh
	1200	69	McIntosh
	1500	70	D. Alvarado
	1800	70	D. Alvarado
	2100	69	D. Alvarado
	2400	68	Ellison

Friday

Date	Time	Temp.	Name (Print)
11/1/24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
11/2/24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
11/3/24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C2B SIDC Temp. Reading Location: 2nd TIER
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension _____ when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-28-24	0300	70	C. Nano
	0600	71	A Castillas
	0900	71	A Castillas
	1200	71	A Castillas
	1500	71	D. Alvarado
	1800	71	D. Alvarado
	2100	70	D. Alvarado
	2400	70	A. Walters

Tuesday

Date	Time	Temp.	Name (Print)
10-29-24	0300	70	A. Walters
	0600	70	A Castillas
	0900	71	A Castillas
	1200	71	A Castillas
	1500	71	A. Walter
	1800	70	A. Walter
	2100	70	A. Walter
	2400	70	A. Walter

Wednesday

Date	Time	Temp.	Name (Print)
10-30-24	0300	70	A. Walters
	0600	71	R. Anaya
	0900	71	Cotton
	1200	71	Co
	1500	70	Cotton
	1800	70	Cotton
	2100	70	Cotton
	2400	70	A. Walter

Thursday

Date	Time	Temp.	Name (Print)
10-31-24	0300	70	A. Walter
	0600	72	R. Anaya
	0900	72	R. Anaya
	1200	72	R. Anaya
	1500	72	Riley
	1800	71	Riley
	2100	71	Riley
	2400	70	A. Walters

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Name (Print)

Institution: WSP Housing Unit: Q3A Temp. Reading Location: Tier 2 Above IV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3741 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/28/24	0300	69	Camacho
	0600	68	J. Enriquez
	0900	68	J. Enriquez
	1200	69	J. Enriquez
	1500	70	A. Suarez
	1800	70	A. Suarez
	2100	69	A. Suarez
	2400	68	

Tuesday

Date	Time	Temp.	Name (Print)
10/29/24	0300	66	Camacho
	0600	66	M. Ruiz
	0900	67	M. Ruiz
	1200	69	M. Ruiz
	1500	70	A. Suarez
	1800	68	A. Suarez
	2100	67	A. Suarez
	2400	67	Camacho

Wednesday

Date	Time	Temp.	Name (Print)
10/30/24	0300	66	Camacho
	0600	66	M. Ruiz
	0900	67	M. Ruiz
	1200	68	M. Ruiz
	1500	68	A. Suarez
	1800	69	A. Suarez
	2100	67	A. Suarez
	2400	67	G. Zamora

Thursday

Date	Time	Temp.	Name (Print)
10/31/24	0300	66	G. Zamora
	0600	67	M. Ruiz
	0900	68	M. Ruiz
	1200	68	M. Ruiz
	1500	67	A. Suarez
	1800	67	A. Suarez
	2100	67	A. Suarez
	2400	66	Montes

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C3B Temp. Reading Location: Tier 2 Above TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/28/24	0300	68	E TORRES
	0600	69	D. Valencia
	0900	68	D. Valencia
	1200	69	D. Valencia
	1500	69	J ACOSTA
	1800	69	J ACOSTA
	2100	68	J ACOSTA
	2400	68	E TORRES

Tuesday

Date	Time	Temp.	Name (Print)
10/29/24	0300	66	E TORRES
	0600	66	D. Valencia
	0900	69	D. Valencia
	1200	69	D. Valencia
	1500	69	J ACOSTA
	1800	67	J ACOSTA
	2100	67	J ACOSTA
	2400	66	E TORRES

Wednesday

Date	Time	Temp.	Name (Print)
10/30/24	0300	64	E TORRES
	0600	64	D. Valencia
	0900	66	D. VALENCIA
	1200	67	D. VALENCIA
	1500	69	J ACOSTA
	1800	69	J ACOSTA
	2100	68	J ACOSTA
	2400	66	E TORRES

Thursday

Date	Time	Temp.	Name (Print)
10/31/24	0300	66	E TORRES
	0600	67	J. JONES
	0900	68	J. JONES
	1200	69	J. JONES
	1500	67	J. Berto
	1800	67	J. Berto
	2100	67	J. Berto
	2400	68	RAMIREZ

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C4A Temp. Reading Location: DAYROOM ABOVE T.V
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/28/24	0300	64°	S.Rau
	0600	65	E.Torres
	0900	65	E.Torres
	1200	66	E.Torres
	1500	67	Vielmas
	1800	67	Vielmas
	2100	65	Vielmas
	2400	64°	S.Rau

Tuesday

Date	Time	Temp.	Name (Print)
10/29/24	0300	63°	S.Rau
	0600	63	J.Padilla
	0900	63	J.Padilla
	1200	64	J.Padilla
	1500	68	Vielmas
	1800	68	Vielmas
	2100	67	Vielmas
	2400	67°	S.Rau

Wednesday

Date	Time	Temp.	Name (Print)
10/30/24	0300	65°	S.Rau
	0600	65°	Z. Jones
	0900	68°	Z. Jones
	1200	68°	Z. Jones
	1500	70	Vielmas
	1800	68	Vielmas
	2100	65	Vielmas
	2400	63	C.WITCHER

Thursday

Date	Time	Temp.	Name (Print)
10/31/24	0300	63	C.WITCHER
	0600	63	E.Torres
	0900	63	E.Torres
	1200	64	E.Torres
	1500	65	R. Casnesa
	1800	66	R. Casnesa
	2100	65	R. Casnesa
	2400	64	V. NDUKWU

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C4-B Temp. Reading Location: left side of TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/28/24	0300	68	Witmer
	0600	68	J. Padilla
	0900	68	J. Padilla
	1200	67°	J. Padilla
	1500	67°	H. Tovar
	1800	67	H. Tovar
	2100	67	H. Tovar
	2400	67	H. Gil

Tuesday

Date	Time	Temp.	Name (Print)
10/29/24	0300	67	H. Gil
	0600	67	A. Herrera
	0900	68	A. Herrera
	1200	68	A. Herrera
	1500	68	M. Franklin
	1800	68	M. Franklin
	2100	67	M. Franklin
	2400	67	P. Ramos

Wednesday

Date	Time	Temp.	Name (Print)
10/30/24	0300	66	P. Ramos
	0600	66	A. Herrera
	0900	67	A. Herrera
	1200	67	A. Herrera
	1500	67	J. Beato
	1800	67	J. Beato
	2100	67	J. Beato
	2400	65	P. Ramos

Thursday

Date	Time	Temp.	Name (Print)
10/31/24	0300	65	P. Ramos
	0600	65	A. Herrera
	0900	65	A. Herrera
	1200	67	A. Herrera
	1500	68	Tovar
	1800	68	Tovar
	2100	67	Tovar
	2400	65	Raguado

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D1 (B-SIDE) Temp. Reading Location: 2ND TIER ABOVE DAYROOM TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/28	0300	69	W. Colbert
	0600	69	M. Aguirre
	0900	70	M. Aguirre
	1200	71	M. Aguirre
	1500	70	S. Moreno
	1800	70	S. Moreno
	2100	70	S. Moreno
	2400	68	W. Colbert

Tuesday

Date	Time	Temp.	Name (Print)
10/29	0300	68	W Colbert
	0600	69	D. Cranny
	0900	69	Cranny
	1200	69	Cranny
	1500	70	J. Nieto
	1800	70	J. Nieto
	2100	70	J. Nieto
	2400	70	W. Colbert

Wednesday

Date	Time	Temp.	Name (Print)
10/30	0300	65	W. Colbert
	0600	68	A ANAYA
	0900	69	A ANAYA
	1200	73	A ANAYA
	1500	73	M. Lopez
	1800	72	M. Lopez
	2100	71	M. Lopez
	2400	71	Reyes

Thursday

Date	Time	Temp.	Name (Print)
10/31	0300	70	Reyes
	0600	69	J. Thompson
	0900	69	J. Thompson
	1200	71	J. Thompson
	1500	71	J. Nieto
	1800	70	J. Nieto
	2100	70	J. Nieto
	2400	70	REYES

Friday

Date	Time	Temp.	Name (Print)
11/1	0300	71	REYES
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400	69	W. Colbert

Saturday

Date	Time	Temp.	Name (Print)
11/2	0300	65	[illegible]
	0600		
	0900		
	1200		
	1500	64	P. Hess
	1800	65	P. Hess
	2100	64	P. Hess
	2400	65	W. Colbert

Sunday

Date	Time	Temp.	Name (Print)
11/3	0300	65	W. Colbert
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400	68	W. Colbert

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. D - 1 (A) Side Temp. Reading Location: Tier 2 - Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/28	0300	69	W. Colbert
	0600	69	M. AGUILAR
	0900	70	M. AGUILAR
	1200	71	M. AGUILAR
	1500	68	S. MORENO
	1800	68	S. MORENO
	2100	65	S. MORENO
	2400	68	W. Colbert

Tuesday

Date	Time	Temp.	Name (Print)
10/29	0300	68	W. Colbert
	0600	69	D. Cunny
	0900	69	Cunny
	1200	69	Cunny
	1500	70	J. NIETO
	1800	70	J. NIETO
	2100	70	J. NIETO
	2400	70	W. Colbert

Wednesday

Date	Time	Temp.	Name (Print)
10/30	0300	65	W. Colbert
	0600	68	A A NAYA
	0900	69	A A ANAYA
	1200	73	A A ANAYA
	1500	73	M. Lopez
	1800	72	M. Lopez
	2100	71	M. Lopez
	2400	71	[illegible]

Thursday

Date	Time	Temp.	Name (Print)
10/31	0300	71	[illegible]
	0600	68	J Moulder
	0900	69	J. Moulder
	1200	71	J. Moulder
	1500	71	J. NIETO
	1800	70	J. NIETO
	2100	70	J. NIETO
	2400	70	J. REYES

Friday

Date	Time	Temp.	Name (Print)
11/1	0300	71	REYES
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400	69	W. COLBERT

Saturday

Date	Time	Temp.	Name (Print)
11/2	0300		
	0600		
	0900		
	1200		
	1500	64	P. Henry
	1800	65	P. Henry
	2100	63	P. Henry
	2400	65	W. Colbert

Sunday

Date	Time	Temp.	Name (Print)
11/3	0300	65	W Colbert
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400	68	W. Colbert

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D2 (A) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/28	0300	70	A. MALDONADO
	0600	71	[illegible]
	0900	71	[illegible]
	1200	72	[illegible]
	1500	72	J. VALENCIA
	1800	70	J. VALENCIA
	2100	69	J. VALENCIA
	2400	68	[illegible]

Tuesday

Date	Time	Temp.	Name (Print)
10/29/24	0300	68	[illegible]
	0600	68	[illegible]
	0900	69	[illegible]
	1200	69	[illegible]
	1500	70	J ESQUIVEL
	1800	71	J ESQUIVEL
	2100	71	J ESQUIVEL
	2400	69	R Roberts

Wednesday

Date	Time	Temp.	Name (Print)
10/30/24	0300	69	R Roberts
	0600	68	[illegible]
	0900	68	[illegible]
	1200	69	[illegible]
	1500	69	[illegible]
	1800	69	[illegible]
	2100	69	[illegible]
	2400	69	[illegible]

Thursday

Date	Time	Temp.	Name (Print)
10/31/24	0300	68	[illegible]
	0600	68	[illegible]
	0900	69	[illegible]
	1200	69	[illegible]
	1500	70	B PRECIADO
	1800	70	PRECIADO
	2100	69	PRECIADO
	2400	69	R Roberts

Friday

Date	Time	Temp.	Name (Print)
11/1/24	0300	69	R Roberts
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
11/2/24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
11/3/24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D2 (B) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/28	0300	70	A-MACOSAN
	0600	71	Belton
	0900	71	Belton
	1200	72	Belton
	1500	72	J. VALENCIA
	1800	70	J. VALENCIA
	2100	69	J. VALENCIA
	2400	68	S. Gill

Tuesday

Date	Time	Temp.	Name (Print)
10/29/24	0300	67	S. Gill
	0600	68	Belton
	0900	69	Belton
	1200	69	Belton
	1500	70	J. ESQUIVEL
	1800	71	J. ESQUIVEL
	2100	72	J. ESQUIVEL
	2400	70	R Roberts

Wednesday

Date	Time	Temp.	Name (Print)
10/30/24	0300	70	R Roberts
	0600	68	Belton
	0900	68	Belton
	1200	69	Belton
	1500	69	Armer
	1800	69	Armer
	2100	69	Armer
	2400	66	[illegible]

Thursday

Date	Time	Temp.	Name (Print)
10/31/24	0300	68	Belton
	0600	68	Belton
	0900	69	Belton
	1200	69	[illegible]
	1500	70	RECLAW
	1800	70	RECLAW
	2100	69	RECLAW
	2400	70	R Roberts

Friday

Date	Time	Temp.	Name (Print)
11/1/24	0300	70	R Roberts
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
11/2/24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
11/3/24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. D - 3 (A) Side Temp. Reading Location: Tier 2 - Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/28/24	0300	70	REYES.
	0600	70	J. ESQUIVEL
	0900	71	J. ESQUIVEL
	1200	73	J. ESQUIVEL
	1500	72	GIBBS
	1800	71	GIBBS
	2100	70	GIBBS
	2400	70	Bmendoza

Tuesday

Date	Time	Temp.	Name (Print)
10-29-24	0300	70	Bmendoza
	0600	70	J. ESQUIVEL
	0900	71	J. ESQUIVEL
	1200	72	J. ESQUIVEL
	1500	72	B. CORRAL
	1800	71	B. CORRAL
	2100	70	B. CORRAL
	2400	69	Bmendoza

Wednesday

Date	Time	Temp.	Name (Print)
10-30-24	0300	70	Bmendoza
	0600	70	Castenon
	0900	70	Castenon
	1200	71	Castenon
	1500	71	Martinez
	1800	70	Martinez
	2100	69	Martinez
	2400	69	Bmendoza

Thursday

Date	Time	Temp.	Name (Print)
10/31/24	0300	69	Bmendoza
	0600	69	M. Sepeda
	0900	70	M. Jerkato
	1200	70	M. Jerkato
	1500	70	[illegible]
	1800	70	[illegible]
	2100	70	[illegible]
	2400	69	Bmendoza

Friday

Date	Time	Temp.	Name (Print)
11-1-24	0300	69	Bmendoza
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D3 (B) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/28/24	0300	71	R. REYES
	0600	71	J. ESQUIVEL
	0900	72	J. ESQUIVEL
	1200	73	J. ESQUIVEL
	1500	72	GIBBS
	1800	71	GIBBS
	2100	70	GIBBS
	2400	70	Bhendoza

Tuesday

Date	Time	Temp.	Name (Print)
10-29-24	0300	70	Bhendoza
	0600	70	J. ESQUIVEL
	0900	71	J. ESQUIVEL
	1200	72	J. ESQUIVEL
	1500	72	B. CORRAL
	1800	71	B. CORRAL
	2100	70	B. CORRAL
	2400	69	Bhendoza

Wednesday

Date	Time	Temp.	Name (Print)
10-30-24	0300	70	Bhendoza
	0600	70	Castenon
	0900	71	Castenon
	1200	71	Castenon
	1500	71	Martinez
	1800	70	Martinez
	2100	69	Martinez
	2400	69	Bhendoza

Thursday

Date	Time	Temp.	Name (Print)
10-31-24	0300	69	Bhendoza
	0600	69	M Serrato
	0900	70	M Serrato
	1200	70	M Serrato
	1500	70	Guzman
	1800	70	Guzman
	2100	70	Guzman
	2400	69	Bhendoza

Friday

Date	Time	Temp.	Name (Print)
11-1-24	0300	69	Bhendoza
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D-4 Temp. Reading Location: A
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3741 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/28/24	0300	70	S. Baez
	0600	70	A Lopez
	0900	70	A Lopez
	1200	70	A Lopez
	1500	71	Aguiola
	1800	69	Arvizu
	2100	69	Arvizu
	2400	70	S. Baez

Tuesday

Date	Time	Temp.	Name (Print)
10/29/24	0300	70	S. Baez
	0600	70	A Lopez
	0900	70	A Lopez
	1200	70	A Lopez
	1500	70	Aguiola
	1800	70	Arvizu
	2100	70	Arvizu
	2400	70	S. Baez

Wednesday

Date	Time	Temp.	Name (Print)
10/30/24	0300	68	S. Baez
	0600	70	A Lopez
	0900	70	A Lopez
	1200	70	A Lopez
	1500	70	R. PASCUA
	1800	70	R. PASCUA
	2100	70	R. PASCUA
	2400	70	[illegible]

Thursday

Date	Time	Temp.	Name (Print)
10/31/24	0300	70	[illegible]
	0600	70	A. Castrejon
	0900	70	A. Castrejon
	1200	70	A. Castrejon
	1500	70	R. PASCUA
	1800	70	R. PASCUA
	2100	70	R. PASCUA
	2400	70	[illegible]

Friday

Date	Time	Temp.	Name (Print)
	0300	67	J. ALCALA
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D-4 Temp. Reading Location: B
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 **when the inside air temperature reaches 90 degrees and again at 95 degrees.**

Monday

Date	Time	Temp.	Name (Print)
10/28/24	0300	70	S. Baez
	0600	70	A Lopez
	0900	70	A Lopez
	1200	70	A Lopez
	1500	71	Arreola
	1800	69	Arreola
	2100	69	Arreola
	2400	70	S. Baez

Tuesday

Date	Time	Temp.	Name (Print)
10/29/24	0300	70	S. Baez
	0600	70	A Lopez
	0900	70	A Lopez
	1200	70	A Lopez
	1500	70	Arreola
	1800	70	Arreola
	2100	70	Arreola
	2400	70	S. Baez

Wednesday

Date	Time	Temp.	Name (Print)
10/30/24	0300	68	S. Baez
	0600	68	A Lopez
	0900	70	A Lopez
	1200	70	A Lopez
	1500	70	R. PASCUA
	1800	70	R. PASCUA
	2100	70	R. PASCUA
	2400	70	[illegible]

Thursday

Date	Time	Temp.	Name (Print)
10/31/24	0300	70	[illegible]
	0600	70	[illegible]
	0900	70	[illegible]
	1200	70	[illegible]
	1500	70	R. PASCUA
	1800	70	R. PASCUA
	2100	70	R. PASCUA
	2400	70	[illegible]

Friday

Date	Time	Temp.	Name (Print)
	0300	67	[illegible]
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D5 (A) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/23/24	0300	65	J. Sanchez
	0600	68	N. TOVAR
	0900	68	N. TOVAR
	1200	69	N. TOVAR
	1500	69	N. TOVAR
	1800	68	N. TOVAR
	2100	67	N. TOVAR
	2400	67	J. Sanchez

Tuesday

Date	Time	Temp.	Name (Print)
10/24/24	0300	66	J. Sanchez
	0600	66	R. Guerrero
	0900	67	R. Guerrero
	1200	67	R. Guerrero
	1500	66	N. TOVAR
	1800	67	N. TOVAR
	2100	66	N. TOVAR
	2400	66	M. NAVARRETE

Wednesday

Date	Time	Temp.	Name (Print)
10/30/24	0300	68	M. NAVARRETE
	0600	66	R. Guerrero
	0900	66	R. Guerrero
	1200	67	R. Guerrero
	1500	68	G. MALDONADO
	1800	68	G. MALDONADO
	2100	67	G. MALDONADO
	2400	66	Jackson

Thursday

Date	Time	Temp.	Name (Print)
10/31/24	0300	64	Jackson
	0600	64	Jackson
	0900	64	R. Guerrero
	1200	66	R. Guerrero
	1500	66	R. Guerrero
	1800	67	A. Martinez
	2100	67	A. Martinez
	2400	68	[illegible]

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D5 (B) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/28/24	0300	65	J.Sanchez
	0600	68	N. Tovar
	0900	68	N. Tovar
	1200	69	N. Tovar
	1500	69	N. Tovar
	1800	68	N. Tovar
	2100	67	N. Tovar
	2400	67	J.Sanchez

Tuesday

Date	Time	Temp.	Name (Print)
10/29/24	0300	66	J.Sanchez
	0600	66	R.Guerrero
	0900	67	R.Guerrero
	1200	67	R.Guerrero
	1500	66	N. Tovar
	1800	67	N. Tovar
	2100	66	N. Tovar
	2400	66	M. Navarrete

Wednesday

Date	Time	Temp.	Name (Print)
10/30/24	0300	66	M. Navarrete
	0600	66	R.Guerrero
	0900	66	R.Guerrero
	1200	67	R.Guerrero
	1500	68	G. Macdonald
	1800	68	G. Macdonald
	2100	68	G. Macdonald
	2400	66	Jackson

Thursday

Date	Time	Temp.	Name (Print)
10/31/24	0300	64	Jackson
	0600	64	Jackson
	0900	64	R.Guerrero
	1200	66	R.Guerrero
	1500	66	R.Guerrero
	1800	67	A. Martinez
	2100	67	A. Martinez
	2400	68	[illegible]

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D-6 (A) Side Temp. Reading Location: Tier 2 - Above Dayroom TV (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-28-24	0300	68	D. SANTOYO
	0600	68	P.D. Solis
	0900	68	P.D. Solis
	1200	70	P.D. Solis
	1500	69	R. Aguilar
	1800	69	R. Aguilar
	2100	69	R. Aguilar
	2400	68	D SANTOYO

Tuesday

Date	Time	Temp.	Name (Print)
10-29-24	0300	67	D. SANTOYO
	0600	70	Medina
	0900	70	Medina
	1200	71	Medina
	1500	69	R. Aguilar
	1800	69	R. Aguilar
	2100	69	R. Aguilar
	2400	67	D SANTOYO

Wednesday

Date	Time	Temp.	Name (Print)
10-30-24	0300	67	D. SANTOYO
	0600	68	Medina
	0900	69	Medina
	1200	70	Medina
	1500	70°	M. VASQUEZ
	1800	70°	M. VASQUEZ
	2100	70°	M. VASQUEZ
	2400	69°	M. VASQUEZ

Thursday

Date	Time	Temp.	Name (Print)
10-31-24	0300	69	M. VASQUEZ
	0600	69	Medina
	0900	70	Medina
	1200	71	Medina
	1500	70°	M. VASQUEZ
	1800	70°	M. VASQUEZ
	2100	70°	M. VASQUEZ
	2400		

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D-6 (B) Side Temp. Reading Location: Tier 2 - Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-28-24	0300	69	D SANTOYO
	0600	68	D. Santoyo
	0900	68	D. Santoyo
	1200	70	D. Santoyo
	1500	70	R Aguilar
	1800	70	R Aguilar
	2100	70	R. Aguilar
	2400	70	D. SANTOYO

Tuesday

Date	Time	Temp.	Name (Print)
10-29-24	0300	69	D SANTOYO
	0600	70	Medina
	0900	71	Medina
	1200	71	Medina
	1500	70	R. Aguilar
	1800	70	R. Aguilar
	2100	70	R. Aguilar
	2400	69	D. SANTOYO

Wednesday

Date	Time	Temp.	Name (Print)
10-30-24	0300	69	D. SANTOYO
	0600	69	Medina
	0900	70	Medina
	1200	71	Medina
	1500	70	M. VASQUEZ
	1800	70	M. VASQUEZ
	2100	70	M. VASQUEZ
	2400	69	M. VASQUEZ

Thursday

Date	Time	Temp.	Name (Print)
10-31-24	0300	69	M. VASQUEZ
	0600	69	Medina
	0900	70	Medina
	1200	71	Medina
	1500	70	M. VASQUEZ
	1800	70	M. VASQUEZ
	2100	70	M. VASQUEZ
	2400		

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: MSF DORM 1 A-Side Temp. Reading Location: 1st Tier (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-28-24	0300	69	Montoya
	0600	69	J. Landeros
	0900	69	J. Landeros
	1200	69	J. Landeros
	1500	68°	I. Berrons
	1800	68°	I. Berrons
	2100	68°	I. Berrons
	2400	67°	A. Martinez

Tuesday

Date	Time	Temp.	Name (Print)
10-29-24	0300	66°	A. Martinez
	0600	65	J. Landeros
	0900	65	J. Landeros
	1200	65	J. Landeros
	1500	66	R. DURAN
	1800	67	R. DURAN
	2100	67	R. DURAN
	2400	66	D. Vasquez

Wednesday

Date	Time	Temp.	Name (Print)
10-30-24	0300	65°	D. Vazquez
	0600	65°	M. VEGA
	0900	65°	M. VEGA
	1200	66°	M. VEGA
	1500	66°	I. FRITZ
	1800	66°	I. FRITZ
	2100	66°	I. FRITZ
	2400	67°	J. Lopez

Thursday

Date	Time	Temp.	Name (Print)
10-31-24	0300	66°	J. Lopez
	0600	67°	M. VEGA
	0900	68°	M. VEGA
	1200	68°	M. VEGA
	1500	69	E. TOLBERT
	1800	68°	E. Tolbert
	2100	68°	E. Tolbert
	2400	68°	R. Mata

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DATE	ACTIVATED	DEACTIVATED

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: MSF DORM 1 B-Side Temp. Reading Location: 1st Tier (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/28/24	0300	69	Montoya
	0600	69	J. Lanuenos
	0900	69	J. Lanuenos
	1200	69	J. Lanuenos
	1500	68°	I. Berrone
	1800	68°	I. Berrone
	2100	67°	I. Berrone
	2400	67°	A Martinez

Tuesday

Date	Time	Temp.	Name (Print)
10/29/24	0300	66°	A Martinez
	0600	65	J. Lanuenos
	0900	65	J. Lanuenos
	1200	65	J. Lanuenos
	1500	66	R. DURAN
	1800	67	R. DURAN
	2100	67	R. DURAN
	2400	66°	D. Vasquez

Wednesday

Date	Time	Temp.	Name (Print)
10/30/24	0300	65°	D. Vasquez
	0600	65°	M. VEGA
	0900	65°	M. VEGA
	1200	66°	M. VEGA
	1500	66°	I. FNYZ
	1800	66°	I. FNYZ
	2100	66°	I. FNYZ
	2400	67°	J. Lopez

Thursday

Date	Time	Temp.	Name (Print)
10/31/24	0300	66°	J. Lopez
	0600	67°	M. VEGA
	0900	68°	M. VEGA
	1200	68°	M. VEGA
	1500	69	[illegible]
	1800	68	[illegible]
	2100	68	[illegible]
	2400	68°	R. Mata

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DATE	ACTIVATED	DEACTIVATED

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: M-DORM-2 A-SIDE Temp. Reading Location: BEHIND PODIUM (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/29	0300	68	C. HOUSE
	0600	65	VARGAS
	0900	65	VARGAS
	1200	65	VARGAS
	1500	68	Fritz
	1800	68	Fritz
	2100	68	Fritz
	2400	67	R. DURAN

Tuesday

Date	Time	Temp.	Name (Print)
10/29	0300	66	R. DURAN
	0600	66	Gonzalez
	0900	64	Gonzalez
	1200	64	Gonzalez
	1500	65	Fritz
	1800	65	Fritz
	2100	65	Fritz
	2400	64	R. DURAN

Wednesday

Date	Time	Temp.	Name (Print)
10/30	0300	63	R. DURAN
	0600	63	CRUZ
	0900	64	CRUZ
	1200	65	CRUZ
	1500	68	J. Medina
	1800	68	J. Medina
	2100	68	J. Medina
	2400	68°	K. MADRIGAL

Thursday

Date	Time	Temp.	Name (Print)
10/31	0300	66°	K. MADRIGAL
	0600	65	VARGAS
	0900	65	VARGAS
	1200	67	VARGAS
	1500	68	J. Medina
	1800	68	J. Medina
	2100	68	J. Medina
	2400	68	A. Martinez

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: M-DORM-2 B-SIDE Temp. Reading Location: BEHIND PODIUM (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/20/24	0300	66	C. HOUSE
	0600	65	VARGAS
	0900	65	VARGAS
	1200	65	VARGAS
	1500	68	FRITZ
	1800	68	FRITZ
	2100	68	FRITZ
	2400	67	R. DURAN

Tuesday

Date	Time	Temp.	Name (Print)
10/29/24	0300	66	R. DURAN
	0600	66	Gonzalez
	0900	64	Gonzalez
	1200	64	Gonzalez
	1500	65	FRITZ
	1800	65	FRITZ
	2100	65	FRITZ
	2400	64	R. DURAN

Wednesday

Date	Time	Temp.	Name (Print)
10/30/24	0300	63	R. DURAN
	0600	63	CRUZ
	0900	64	CRUZ
	1200	65	CRUZ
	1500	68	J. Medina
	1800	68	J. Medina
	2100	68	J. Medina
	2400	68°	K. MADRIGAL

Thursday

Date	Time	Temp.	Name (Print)
10/31/24	0300	66°	K. MADRIGAL
	0600	65	VARGAS
	0900	65	VARGAS
	1200	67	VARGAS
	1500	68	J. Medina
	1800	68	J. Medina
	2100	68	J. Medina
	2400	68	A. Martinez

Friday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: CTC | INP Temp. Reading Location: Above | Solution Key
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-28-24	0300	73.9	Y. Fernandez
	0600	73.0	Brown
	0900	73.0	Brown
	1200	73.0	Brown
	1500	73.8	Pineda
	1800	73.2	Pineda
	2100	73.6	Pineda
	2400	73.4	Y. Fernandez

Tuesday

Date	Time	Temp.	Name (Print)
10-29-24	0300	72.9	Y. Fernandez
	0600	73.0	Brown
	0900	73.0	Brown
	1200	73.0	Brown
	1500	72.9	I. Alvarez
	1800	72.9	I. Alvarez
	2100	72.9	I. Alvarez
	2400	72.8	Y. Fernandez

Wednesday

Date	Time	Temp.	Name (Print)
10-30-24	0300	72.8	Y. Fernandez
	0600	71.4	Y. Fernandez
	0900	71.4	Brown
	1200	71.4	Brown
	1500	73.0	I. Alvarez
	1800	73.0	I. Alvarez
	2100	73.0	I. Alvarez
	2400	73	[illegible]

Thursday

Date	Time	Temp.	Name (Print)
10-31-24	0300	72.9	[illegible]
	0600	71.2	H. Sanz
	0900	72.1	H. Sanz
	1200	73	H. Sanz
	1500	73	V. Fernandez
	1800	73	[illegible]
	2100	73	[illegible]
	2400		

Friday

Date	Time	Temp.	Name (Print)
11-1-24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Saturday

Date	Time	Temp.	Name (Print)
11-2-24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Sunday

Date	Time	Temp.	Name (Print)
11-3-24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

OUTSIDE TEMPERATURE RECORD

CDCR 2030 (04/18)

INSTITUTION: NKSP

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the OUTSIDE ambient air temperature.

Using an accurate thermometer located in a central, heat neutral location, the outside air temperature is to be taken every hour, seven (7) days a week.

Thermometer Location: Control

Immediately notify the Watch Commander at extension 3141 **when the air temperature reaches 90 degrees.**

Date	Time	Temp.	Printed Name
10-28	0100	58	DUNN
	0200	58	DUNN
	0300	56	DUNN
	0400	55	DUNN
	0500	54	DUNN
	0600	56	Gonzalez
	0700	56	Gonzalez
	0800	58	Gonzalez
	0900	61	Gonzalez
	1000	61	Gonzalez
	1100	63	Gonzalez
	1200	63	Gonzalez
	1300	63	Gonzalez
	1400	66	PADILLA
	1500	67	PADILLA
	1600	68	PADILLA
	1700	67	PADILLA
	1800	65	PADILLA
	1900	61	PADILLA
	2000	61	PADILLA
	2100	58	PADILLA
	2200	55	PADILLA
	2300	54	DUNN
	2400	53	DUNN

Date	Time	Temp.	Printed Name
10-29	0100	52	DUNN
	0200	51	DUNN
	0300	51	DUNN
	0400	52	DUNN
	0500	51	DUNN
	0600	50	C. VALENCIA
	0700	49	C. VALENCIA
	0800	50	C. VALENCIA
	0900	53	C. VALENCIA
	1000	57	C. VALENCIA
	1100	58	C. VALENCIA
	1200	60	C. VALENCIA
	1300	61	C. VALENCIA
	1400	64	PADILLA
	1500	65	PADILLA
	1600	65	PADILLA
	1700	65	PADILLA
	1800	63	PADILLA
	1900	60	PADILLA
	2000	58	PADILLA
	2100	54	PADILLA
	2200	49	PADILLA
	2300	48	PADILLA
	2400	49	PADILLA

DISTRIBUTION: Original: Institution Heat Plan Coordinator

NKSP 10/28/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/28/24	12:15a	61.3	61.5	61.3	16	14.7	0.0	---	0.00	0.0	---	61.3	56.5	56.5	30.091	0.00	0.00	0.039	0.000
10/28/24	12:30a	61.0	61.4	61.0	16	14.4	0.0	---	0.00	0.0	---	61.0	56.2	56.2	30.091	0.00	0.00	0.042	0.000
10/28/24	12:45a	59.7	61.1	59.7	19	17.3	1.0	WNW	0.25	3.0	ESE	59.7	55.3	55.3	30.091	0.00	0.00	0.055	0.000
10/28/24	1:00a	58.5	59.6	58.4	23	20.8	2.0	WNW	0.50	7.0	WNW	58.5	54.5	54.5	30.095	0.00	0.00	0.068	0.000
10/28/24	1:15a	58.3	58.7	58.3	22	19.6	0.0	N	0.00	2.0	N	58.3	54.3	54.3	30.086	0.00	0.00	0.070	0.000
10/28/24	1:30a	58.2	58.3	58.1	24	21.5	0.0	N	0.00	2.0	N	58.2	54.3	54.3	30.089	0.00	0.00	0.071	0.000
10/28/24	1:45a	58.5	58.5	58.2	23	20.8	0.0	N	0.00	1.0	NNE	58.5	54.5	54.5	30.093	0.00	0.00	0.068	0.000
10/28/24	2:00a	58.7	58.8	58.4	22	19.9	0.0	N	0.00	1.0	N	58.7	54.6	54.6	30.092	0.00	0.00	0.066	0.000
10/28/24	2:15a	58.6	58.8	58.5	22	19.8	2.0	WNW	0.50	6.0	WNW	58.6	54.5	54.5	30.090	0.00	0.00	0.067	0.000
10/28/24	2:30a	57.8	58.5	57.8	22	19.1	1.0	WNW	0.25	4.0	NW	57.8	53.9	53.9	30.088	0.00	0.00	0.075	0.000
10/28/24	2:45a	57.0	57.8	57.0	23	19.5	2.0	NW	0.50	8.0	NW	57.0	53.2	53.2	30.085	0.00	0.00	0.083	0.000
10/28/24	3:00a	56.2	57.0	56.1	24	19.8	3.0	NW	0.75	6.0	NNW	56.2	52.6	52.6	30.083	0.00	0.00	0.092	0.000
10/28/24	3:15a	55.5	56.1	55.4	26	21.1	1.0	NW	0.25	4.0	N	55.5	52.2	52.2	30.080	0.00	0.00	0.099	0.000
10/28/24	3:30a	55.3	55.5	55.2	27	21.8	0.0	NNW	0.00	2.0	NNW	55.3	52.1	52.1	30.078	0.00	0.00	0.101	0.000
10/28/24	3:45a	55.7	55.7	55.3	28	23.1	0.0	NNW	0.00	1.0	NNW	55.7	52.5	52.5	30.079	0.00	0.00	0.097	0.000
10/28/24	4:00a	55.9	55.9	55.7	28	23.2	1.0	NNW	0.25	3.0	NNW	55.9	52.7	52.7	30.076	0.00	0.00	0.095	0.000
10/28/24	4:15a	55.7	55.9	55.7	28	23.1	0.0	N	0.00	2.0	N	55.7	52.5	52.5	30.076	0.00	0.00	0.097	0.000
10/28/24	4:30a	55.7	55.8	55.7	29	23.9	0.0	N	0.00	2.0	N	55.7	52.6	52.6	30.075	0.00	0.00	0.097	0.000
10/28/24	4:45a	55.5	55.8	55.5	29	23.7	0.0	N	0.00	2.0	N	55.5	52.5	52.5	30.073	0.00	0.00	0.099	0.000
10/28/24	5:00a	54.7	55.5	54.7	29	23.0	0.0	ENE	0.00	2.0	N	54.7	51.8	51.8	30.077	0.00	0.00	0.107	0.000
10/28/24	5:15a	54.6	54.7	54.4	29	22.9	0.0	ESE	0.00	4.0	S	54.6	51.7	51.7	30.085	0.00	0.00	0.108	0.000
10/28/24	5:30a	55.4	55.4	54.6	31	25.2	2.0	S	0.50	6.0	S	55.4	52.5	52.5	30.082	0.00	0.00	0.100	0.000
10/28/24	5:45a	55.9	55.9	55.3	32	26.4	1.0	SSE	0.25	4.0	SSE	55.9	53.0	53.0	30.086	0.00	0.00	0.095	0.000
10/28/24	6:00a	56.1	56.3	55.9	31	25.8	1.0	SSE	0.25	3.0	SSE	56.1	53.2	53.2	30.084	0.00	0.00	0.093	0.000
10/28/24	6:15a	56.1	56.2	56.0	31	25.8	0.0	SSE	0.00	2.0	SSE	56.1	53.2	53.2	30.089	0.00	0.00	0.093	0.000
10/28/24	6:30a	56.1	56.2	56.0	31	25.8	0.0	SSE	0.00	1.0	SSE	56.1	53.2	53.2	30.090	0.00	0.00	0.093	0.000
10/28/24	6:45a	56.3	56.3	56.1	32	26.8	0.0	SSE	0.00	2.0	SSE	56.3	53.4	53.4	30.091	0.00	0.00	0.091	0.000
10/28/24	7:00a	56.9	57.0	56.4	32	27.3	0.0	S	0.00	2.0	S	56.9	53.9	53.9	30.089	0.00	0.00	0.084	0.000
10/28/24	7:15a	57.2	57.2	56.9	32	27.6	0.0	SSW	0.00	3.0	SSW	57.2	54.2	54.2	30.094	0.00	0.00	0.081	0.000
10/28/24	7:30a	57.4	57.4	57.1	31	27.0	0.0	SSW	0.00	1.0	SSW	57.4	54.3	54.3	30.100	0.00	0.00	0.079	0.000
10/28/24	7:45a	57.7	57.7	57.4	31	27.2	0.0	SSW	0.00	3.0	SW	57.7	54.6	54.6	30.099	0.00	0.00	0.076	0.000
10/28/24	8:00a	58.7	58.7	57.7	27	24.8	3.0	WNW	0.75	8.0	W	58.7	55.0	55.0	30.107	0.00	0.00	0.066	0.000
10/28/24	8:15a	59.3	59.3	58.7	23	21.5	3.0	NW	0.75	7.0	NW	59.3	55.2	55.2	30.113	0.00	0.00	0.059	0.000
10/28/24	8:30a	59.9	59.9	59.3	18	16.2	3.0	NW	0.75	10.0	WNW	59.9	55.4	55.4	30.121	0.00	0.00	0.053	0.000
10/28/24	8:45a	60.5	60.5	59.9	11	5.6	5.0	NW	1.25	10.0	NW	60.5	55.7	55.7	30.125	0.00	0.00	0.047	0.000
10/28/24	9:00a	61.2	61.2	60.5	5	-10.5	7.0	NW	1.75	12.0	NW	60.7	55.4	54.9	30.134	0.00	0.00	0.040	0.000
10/28/24	9:15a	62.0	62.0	61.2	2	-27.7	8.0	NW	2.00	14.0	WNW	60.9	55.8	54.7	30.133	0.00	0.00	0.031	0.000
10/28/24	9:30a	62.0	62.2	61.9	---	---	8.0	NW	2.00	15.0	NW	60.9	---	---	30.138	0.00	0.00	0.031	0.000
10/28/24	9:45a	62.1	62.1	62.0	0	---	12.0	NW	3.00	21.0	N	58.1	55.7	51.7	30.133	0.00	0.00	0.030	0.000
10/28/24	10:00a	61.9	62.1	61.9	0	---	9.0	NW	2.25	17.0	NW	59.9	55.5	53.5	30.134	0.00	0.00	0.032	0.000
10/28/24	10:15a	62.4	62.5	61.9	0	---	9.0	NW	2.25	16.0	WNW	60.5	55.9	54.0	30.134	0.00	0.00	0.027	0.000
10/28/24	10:30a	62.5	62.6	62.3	0	---	12.0	NW	3.00	20.0	NW	58.6	56.0	52.1	30.135	0.00	0.00	0.026	0.000
10/28/24	10:45a	62.4	62.6	62.3	0	---	12.0	NW	3.00	19.0	NW	58.5	55.9	52.0	30.131	0.00	0.00	0.027	0.000
10/28/24	11:00a	63.0	63.0	62.3	0	---	10.0	WNW	2.50	20.0	NW	60.5	56.4	53.9	30.131	0.00	0.00	0.021	0.000
10/28/24	11:15a	62.9	63.0	62.7	0	---	11.0	WNW	2.75	17.0	WNW	59.7	56.3	53.1	30.132	0.00	0.00	0.022	0.000
10/28/24	11:30a	63.0	63.1	62.8	0	---	12.0	WNW	3.00	18.0	WNW	59.2	56.4	52.6	30.128	0.00	0.00	0.021	0.000
10/28/24	11:45a	63.3	63.4	63.0	0	---	11.0	NW	2.75	20.0	NW	60.1	56.7	53.5	30.122	0.00	0.00	0.018	0.000
10/28/24	12:00p	63.3	63.5	63.3	0	---	11.0	NW	2.75	17.0	NNW	60.1	56.7	53.5	30.118	0.00	0.00	0.018	0.000
10/28/24	12:15p	62.3	63.3	62.3	0	---	12.0	NW	3.00	20.0	NW	58.4	55.8	51.9	30.121	0.00	0.00	0.028	0.000
10/28/24	12:30p	62.6	62.6	62.2	0	---	8.0	NW	2.00	16.0	NNW	61.6	56.1	55.1	30.115	0.00	0.00	0.025	0.000

NKSP 10/28/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/28/24	12:45p	62.9	62.9	62.6	---	---	10.0	NW	2.50	15.0	NNW	60.4	---	---	30.110	0.00	0.00	0.022	0.000
10/28/24	1:00p	63.6	63.6	62.9	0	---	5.0	NW	1.25	11.0	NW	63.6	56.9	56.9	30.099	0.00	0.00	0.015	0.000
10/28/24	1:15p	64.2	64.2	63.6	0	---	8.0	NNW	2.00	14.0	NNW	63.4	57.5	56.7	30.082	0.00	0.00	0.008	0.000
10/28/24	1:30p	65.4	65.4	64.2	0	---	7.0	NNW	1.75	14.0	NNW	65.4	58.5	58.5	30.080	0.00	0.00	0.000	0.004
10/28/24	1:45p	66.3	66.3	65.4	0	---	8.0	WNW	2.00	15.0	WNW	65.7	59.3	58.7	30.071	0.00	0.00	0.000	0.014
10/28/24	2:00p	66.5	66.7	66.3	0	---	8.0	NW	2.00	15.0	NNW	65.9	59.5	58.9	30.061	0.00	0.00	0.000	0.016
10/28/24	2:15p	67.2	67.2	66.5	0	---	8.0	NW	2.00	15.0	WNW	66.6	60.1	59.5	30.056	0.00	0.00	0.000	0.023
10/28/24	2:30p	67.3	67.4	67.0	0	---	9.0	NW	2.25	17.0	WNW	66.0	60.2	58.9	30.048	0.00	0.00	0.000	0.024
10/28/24	2:45p	67.3	67.5	67.1	0	---	9.0	WNW	2.25	16.0	NNW	66.0	60.2	58.9	30.043	0.00	0.00	0.000	0.024
10/28/24	3:00p	67.6	67.7	67.2	0	---	10.0	NW	2.50	19.0	NNW	65.5	60.4	58.3	30.040	0.00	0.00	0.000	0.027
10/28/24	3:15p	67.9	68.0	67.5	0	---	8.0	NW	2.00	19.0	NNE	67.2	60.7	60.0	30.035	0.00	0.00	0.000	0.030
10/28/24	3:30p	68.0	68.0	67.6	0	---	6.0	NW	1.50	13.0	NNW	68.0	60.8	60.8	30.031	0.00	0.00	0.000	0.031
10/28/24	3:45p	68.1	68.1	67.8	0	---	8.0	NNW	2.00	14.0	NW	67.4	61.0	60.3	30.020	0.00	0.00	0.000	0.032
10/28/24	4:00p	68.3	68.3	68.0	0	---	9.0	NW	2.25	17.0	NNW	66.9	61.3	59.9	30.021	0.00	0.00	0.000	0.034
10/28/24	4:15p	68.4	68.4	68.1	0	---	7.0	NW	1.75	13.0	WNW	68.4	61.4	61.4	30.016	0.00	0.00	0.000	0.035
10/28/24	4:30p	68.0	68.4	67.9	0	---	7.0	NW	1.75	15.0	NNW	68.0	60.8	60.8	30.016	0.00	0.00	0.000	0.031
10/28/24	4:45p	67.7	68.1	67.7	0	---	9.0	NW	2.25	15.0	NNW	66.3	60.5	59.1	30.015	0.00	0.00	0.000	0.028
10/28/24	5:00p	67.6	67.8	67.5	0	---	8.0	NNW	2.00	13.0	NNW	66.9	60.4	59.7	30.009	0.00	0.00	0.000	0.027
10/28/24	5:15p	67.2	67.6	67.1	0	---	8.0	NW	2.00	14.0	NNW	66.6	60.1	59.5	30.005	0.00	0.00	0.000	0.023
10/28/24	5:30p	66.4	67.2	66.4	0	---	6.0	NW	1.50	14.0	NNW	66.4	59.4	59.4	30.003	0.00	0.00	0.000	0.015
10/28/24	5:45p	65.8	66.4	65.8	0	---	4.0	NW	1.00	11.0	NW	65.8	58.8	58.8	30.002	0.00	0.00	0.000	0.008
10/28/24	6:00p	65.1	65.8	65.1	0	---	4.0	NW	1.00	9.0	WNW	65.1	58.2	58.2	30.001	0.00	0.00	0.000	0.001
10/28/24	6:15p	63.7	65.1	63.7	0	---	4.0	NW	1.00	8.0	NW	63.7	57.0	57.0	29.999	0.00	0.00	0.014	0.000
10/28/24	6:30p	63.0	63.7	63.0	0	---	2.0	NW	0.50	8.0	NNW	63.0	56.4	56.4	30.004	0.00	0.00	0.021	0.000
10/28/24	6:45p	62.2	63.0	62.2	---	---	1.0	NW	0.25	4.0	NW	62.2	---	---	30.005	0.00	0.00	0.029	0.000
10/28/24	7:00p	61.3	62.3	61.3	1	-40.5	1.0	WNW	0.25	3.0	NW	61.3	55.1	55.1	30.009	0.00	0.00	0.039	0.000
10/28/24	7:15p	61.5	61.5	61.2	1	-40.4	1.0	NW	0.25	4.0	NW	61.5	55.3	55.3	30.012	0.00	0.00	0.036	0.000
10/28/24	7:30p	61.7	61.7	61.3	0	---	2.0	NW	0.50	5.0	NW	61.7	55.4	55.4	30.014	0.00	0.00	0.034	0.000
10/28/24	7:45p	61.8	61.9	61.7	0	---	2.0	NW	0.50	5.0	NW	61.8	55.4	55.4	30.019	0.00	0.00	0.033	0.000
10/28/24	8:00p	61.2	61.8	61.2	1	-40.6	1.0	NW	0.25	4.0	NW	61.2	55.0	55.0	30.015	0.00	0.00	0.040	0.000
10/28/24	8:15p	60.2	61.3	60.2	3	-21.2	0.0	NW	0.00	2.0	NW	60.2	54.4	54.4	30.017	0.00	0.00	0.050	0.000
10/28/24	8:30p	59.8	60.2	59.8	4	-15.9	0.0	WNW	0.00	2.0	WNW	59.8	54.2	54.2	30.019	0.00	0.00	0.054	0.000
10/28/24	8:45p	59.2	59.8	59.2	4	-16.3	1.0	WNW	0.25	3.0	WNW	59.2	53.7	53.7	30.019	0.00	0.00	0.060	0.000
10/28/24	9:00p	58.2	59.2	58.1	6	-8.9	2.0	W	0.50	7.0	W	58.2	53.1	53.1	30.024	0.00	0.00	0.071	0.000
10/28/24	9:15p	56.9	58.1	56.9	8	-4.0	5.0	W	1.25	9.0	W	56.3	52.4	51.8	30.026	0.00	0.00	0.084	0.000
10/28/24	9:30p	56.5	56.8	56.3	10	0.5	4.0	WNW	1.00	8.0	W	56.4	52.4	52.3	30.032	0.00	0.00	0.089	0.000
10/28/24	9:45p	56.0	56.5	56.0	11	2.1	3.0	WNW	0.75	7.0	NW	56.0	52.0	52.0	30.034	0.00	0.00	0.094	0.000
10/28/24	10:00p	55.3	56.0	55.3	13	5.2	4.0	WNW	1.00	8.0	WNW	55.0	51.4	51.1	30.039	0.00	0.00	0.101	0.000
10/28/24	10:15p	55.5	55.5	55.3	14	7.0	5.0	WNW	1.25	10.0	WNW	54.7	51.6	50.8	30.041	0.00	0.00	0.099	0.000
10/28/24	10:30p	55.4	55.6	55.4	14	6.9	4.0	WNW	1.00	8.0	WNW	55.1	51.5	51.2	30.043	0.00	0.00	0.100	0.000
10/28/24	10:45p	54.9	55.4	54.9	15	8.0	2.0	WNW	0.50	7.0	WNW	54.9	51.1	51.1	30.041	0.00	0.00	0.105	0.000
10/28/24	11:00p	54.3	54.9	54.2	16	9.0	2.0	WNW	0.50	6.0	W	54.3	50.7	50.7	30.042	0.00	0.00	0.111	0.000
10/28/24	11:15p	54.4	54.5	54.2	16	9.1	2.0	WNW	0.50	7.0	NW	54.4	50.8	50.8	30.040	0.00	0.00	0.110	0.000
10/28/24	11:30p	54.1	54.5	54.1	16	8.8	2.0	W	0.50	7.0	W	54.1	50.5	50.5	30.040	0.00	0.00	0.114	0.000
10/28/24	11:45p	53.8	54.1	53.7	17	9.9	2.0	W	0.50	4.0	W	53.8	50.4	50.4	30.042	0.00	0.00	0.117	0.000
10/29/24	12:00a	53.9	54.0	53.8	17	10.0	2.0	WNW	0.50	6.0	WNW	53.9	50.4	50.4	30.038	0.00	0.00	0.116	0.000

NKSP 10/29/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/29/24	12:15a	53.7	53.9	53.7	17	9.8	2.0	W	0.50	6.0	WNW	53.7	50.3	50.3	30.036	0.00	0.00	0.118	0.000
10/29/24	12:30a	53.8	53.8	53.7	17	9.9	2.0	WNW	0.50	6.0	WNW	53.8	50.4	50.4	30.038	0.00	0.00	0.117	0.000
10/29/24	12:45a	53.3	53.8	53.3	17	9.5	3.0	WNW	0.75	6.0	WNW	53.3	50.0	50.0	30.037	0.00	0.00	0.122	0.000
10/29/24	1:00a	52.9	53.3	52.9	17	9.2	1.0	NW	0.25	4.0	WNW	52.9	49.7	49.7	30.036	0.00	0.00	0.126	0.000
10/29/24	1:15a	52.4	53.0	52.3	18	10.1	3.0	W	0.75	8.0	WSW	52.3	49.4	49.3	30.038	0.00	0.00	0.131	0.000
10/29/24	1:30a	52.4	52.5	52.3	18	10.1	2.0	WSW	0.50	5.0	WSW	52.4	49.4	49.4	30.043	0.00	0.00	0.131	0.000
10/29/24	1:45a	52.2	52.4	52.2	18	9.9	1.0	WSW	0.25	4.0	WSW	52.2	49.3	49.3	30.043	0.00	0.00	0.133	0.000
10/29/24	2:00a	51.9	52.3	51.9	18	9.6	0.0	W	0.00	3.0	W	51.9	49.0	49.0	30.045	0.00	0.00	0.136	0.000
10/29/24	2:15a	51.8	51.9	51.8	19	10.8	0.0	WSW	0.00	1.0	WSW	51.8	49.0	49.0	30.047	0.00	0.00	0.138	0.000
10/29/24	2:30a	51.9	52.1	51.8	18	9.6	0.0	ENE	0.00	3.0	WSW	51.9	49.0	49.0	30.054	0.00	0.00	0.136	0.000
10/29/24	2:45a	51.3	51.9	51.3	19	10.4	0.0	ENE	0.00	1.0	ENE	51.3	48.6	48.6	30.051	0.00	0.00	0.143	0.000
10/29/24	3:00a	51.7	51.7	51.3	20	11.9	0.0	---	0.00	0.0	---	51.7	49.0	49.0	30.053	0.00	0.00	0.139	0.000
10/29/24	3:15a	51.9	52.0	51.6	19	10.9	0.0	---	0.00	0.0	---	51.9	49.1	49.1	30.054	0.00	0.00	0.136	0.000
10/29/24	3:30a	52.2	52.2	51.9	19	11.1	0.0	ENE	0.00	1.0	ENE	52.2	49.3	49.3	30.059	0.00	0.00	0.133	0.000
10/29/24	3:45a	52.0	52.2	52.0	19	10.9	0.0	ENE	0.00	1.0	ENE	52.0	49.2	49.2	30.061	0.00	0.00	0.135	0.000
10/29/24	4:00a	52.0	52.1	52.0	19	10.9	0.0	---	0.00	0.0	---	52.0	49.2	49.2	30.062	0.00	0.00	0.135	0.000
10/29/24	4:15a	52.0	52.1	52.0	19	10.9	0.0	---	0.00	0.0	---	52.0	49.2	49.2	30.064	0.00	0.00	0.135	0.000
10/29/24	4:30a	51.9	52.1	51.8	20	12.0	0.0	ENE	0.00	1.0	ENE	51.9	49.1	49.1	30.067	0.00	0.00	0.136	0.000
10/29/24	4:45a	51.8	51.9	51.7	21	13.0	0.0	---	0.00	0.0	---	51.8	49.1	49.1	30.066	0.00	0.00	0.138	0.000
10/29/24	5:00a	51.3	51.7	51.3	21	12.6	0.0	ENE	0.00	1.0	ENE	51.3	48.7	48.7	30.067	0.00	0.00	0.143	0.000
10/29/24	5:15a	50.8	51.3	50.8	22	13.3	0.0	ENE	0.00	1.0	ENE	50.8	48.3	48.3	30.065	0.00	0.00	0.148	0.000
10/29/24	5:30a	50.5	50.9	50.5	23	14.0	0.0	---	0.00	0.0	---	50.5	48.2	48.2	30.068	0.00	0.00	0.151	0.000
10/29/24	5:45a	50.4	50.5	50.3	24	14.9	0.0	ENE	0.00	1.0	ENE	50.4	48.1	48.1	30.069	0.00	0.00	0.152	0.000
10/29/24	6:00a	50.5	50.6	50.4	24	15.0	0.0	ENE	0.00	1.0	ENE	50.5	48.2	48.2	30.074	0.00	0.00	0.151	0.000
10/29/24	6:15a	50.7	50.7	50.6	24	15.2	0.0	ENE	0.00	1.0	ENE	50.7	48.3	48.3	30.077	0.00	0.00	0.149	0.000
10/29/24	6:30a	50.2	50.6	50.1	24	14.7	0.0	E	0.00	1.0	E	50.2	48.0	48.0	30.076	0.00	0.00	0.154	0.000
10/29/24	6:45a	50.0	50.2	50.0	24	14.6	0.0	E	0.00	1.0	E	50.0	47.9	47.9	30.076	0.00	0.00	0.156	0.000
10/29/24	7:00a	49.6	50.0	49.6	25	15.2	0.0	E	0.00	1.0	E	49.6	47.5	47.5	30.076	0.00	0.00	0.160	0.000
10/29/24	7:15a	49.6	49.6	49.4	26	16.1	0.0	E	0.00	1.0	E	49.6	47.5	47.5	30.080	0.00	0.00	0.160	0.000
10/29/24	7:30a	50.0	50.0	49.6	26	16.4	0.0	SSE	0.00	1.0	SSE	50.0	47.9	47.9	30.088	0.00	0.00	0.156	0.000
10/29/24	7:45a	50.3	50.3	50.0	26	16.7	0.0	SSE	0.00	3.0	S	50.3	48.2	48.2	30.097	0.00	0.00	0.153	0.000
10/29/24	8:00a	50.8	50.8	50.2	25	16.2	0.0	S	0.00	2.0	S	50.8	48.5	48.5	30.106	0.00	0.00	0.148	0.000
10/29/24	8:15a	51.2	51.2	50.8	24	15.6	0.0	S	0.00	1.0	S	51.2	48.7	48.7	30.116	0.00	0.00	0.144	0.000
10/29/24	8:30a	51.6	51.6	51.1	24	15.9	0.0	---	0.00	0.0	---	51.6	49.0	49.0	30.126	0.00	0.00	0.140	0.000
10/29/24	8:45a	52.8	52.8	51.6	23	16.0	0.0	---	0.00	0.0	---	52.8	49.9	49.9	30.135	0.00	0.00	0.127	0.000
10/29/24	9:00a	53.7	53.7	52.8	20	13.5	0.0	WSW	0.00	3.0	WSW	53.7	50.5	50.5	30.141	0.00	0.00	0.118	0.000
10/29/24	9:15a	54.8	54.9	53.7	19	13.3	0.0	WSW	0.00	2.0	WSW	54.8	51.3	51.3	30.145	0.00	0.00	0.106	0.000
10/29/24	9:30a	56.2	56.2	54.9	16	10.5	0.0	WSW	0.00	3.0	WSW	56.2	52.2	52.2	30.146	0.00	0.00	0.092	0.000
10/29/24	9:45a	57.3	57.6	56.3	12	5.0	1.0	W	0.25	6.0	WNW	57.3	53.0	53.0	30.150	0.00	0.00	0.080	0.000
10/29/24	10:00a	57.0	57.3	57.0	13	6.5	1.0	NW	0.25	8.0	NW	57.0	52.8	52.8	30.151	0.00	0.00	0.083	0.000
10/29/24	10:15a	57.1	57.1	56.9	12	4.9	5.0	NNW	1.25	13.0	NW	56.5	52.9	52.3	30.152	0.00	0.00	0.082	0.000
10/29/24	10:30a	57.5	57.6	57.0	10	1.2	5.0	WNW	1.25	12.0	NW	57.0	53.2	52.7	30.154	0.00	0.00	0.078	0.000
10/29/24	10:45a	58.1	58.1	57.5	8	-3.0	7.0	WNW	1.75	14.0	W	56.9	53.4	52.2	30.154	0.00	0.00	0.072	0.000
10/29/24	11:00a	58.5	58.5	58.0	7	-5.5	6.0	WNW	1.50	12.0	W	57.8	53.5	52.8	30.154	0.00	0.00	0.068	0.000
10/29/24	11:15a	59.2	59.2	58.5	5	-11.9	5.0	W	1.25	11.0	NW	59.0	53.8	53.6	30.154	0.00	0.00	0.060	0.000
10/29/24	11:30a	59.7	59.7	59.2	3	-21.6	5.0	NW	1.25	13.0	NW	59.6	54.0	53.9	30.150	0.00	0.00	0.055	0.000
10/29/24	11:45a	60.0	60.0	59.6	3	-21.4	6.0	NW	1.50	12.0	NW	59.6	54.2	53.8	30.153	0.00	0.00	0.052	0.000
10/29/24	12:00p	60.3	60.3	59.9	2	-28.8	4.0	NW	1.00	13.0	NW	60.3	54.4	54.4	30.147	0.00	0.00	0.049	0.000
10/29/24	12:15p	60.6	60.6	60.1	1	-40.9	4.0	WNW	1.00	13.0	W	60.6	54.6	54.6	30.142	0.00	0.00	0.046	0.000
10/29/24	12:30p	61.1	61.1	60.5	1	-40.6	5.0	W	1.25	12.0	W	61.1	55.0	55.0	30.139	0.00	0.00	0.041	0.000

NKSP 10/29/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/29/24	12:45p	61.8	61.8	61.1	0	---	3.0	NW	0.75	10.0	NW	61.8	55.4	55.4	30.130	0.00	0.00	0.033	0.000
10/29/24	1:00p	61.8	61.9	61.7	---	---	4.0	WNW	1.00	10.0	WNW	61.8	---	---	30.126	0.00	0.00	0.033	0.000
10/29/24	1:15p	62.2	62.2	61.8	---	---	2.0	NNW	0.50	10.0	NNW	62.2	---	---	30.120	0.00	0.00	0.029	0.000
10/29/24	1:30p	63.1	63.2	62.2	0	---	2.0	WNW	0.50	8.0	W	63.1	56.5	56.5	30.113	0.00	0.00	0.020	0.000
10/29/24	1:45p	63.6	63.7	63.1	0	---	2.0	W	0.50	9.0	WNW	63.6	56.9	56.9	30.106	0.00	0.00	0.015	0.000
10/29/24	2:00p	64.1	64.1	63.6	0	---	3.0	NW	0.75	11.0	NW	64.1	57.4	57.4	30.106	0.00	0.00	0.009	0.000
10/29/24	2:15p	65.3	65.3	64.0	0	---	1.0	NNE	0.25	8.0	NNE	65.3	58.4	58.4	30.099	0.00	0.00	0.000	0.003
10/29/24	2:30p	65.3	65.5	64.9	0	---	4.0	NW	1.00	12.0	NW	65.3	58.4	58.4	30.101	0.00	0.00	0.000	0.003
10/29/24	2:45p	65.7	65.7	65.1	0	---	5.0	W	1.25	11.0	WNW	65.7	58.7	58.7	30.098	0.00	0.00	0.000	0.007
10/29/24	3:00p	65.9	66.3	65.7	0	---	6.0	NW	1.50	16.0	WSW	65.9	58.9	58.9	30.098	0.00	0.00	0.000	0.009
10/29/24	3:15p	65.9	66.0	65.8	0	---	5.0	W	1.25	12.0	WSW	65.9	58.9	58.9	30.097	0.00	0.00	0.000	0.009
10/29/24	3:30p	66.3	66.3	65.9	0	---	4.0	WNW	1.00	13.0	WNW	66.3	59.3	59.3	30.097	0.00	0.00	0.000	0.014
10/29/24	3:45p	66.1	66.3	65.8	0	---	5.0	NNW	1.25	12.0	NW	66.1	59.1	59.1	30.097	0.00	0.00	0.000	0.011
10/29/24	4:00p	66.3	66.4	66.1	0	---	5.0	NW	1.25	10.0	N	66.3	59.3	59.3	30.100	0.00	0.00	0.000	0.014
10/29/24	4:15p	66.0	66.3	66.0	0	---	5.0	NNW	1.25	13.0	NNW	66.0	59.0	59.0	30.101	0.00	0.00	0.000	0.010
10/29/24	4:30p	66.1	66.1	65.9	0	---	4.0	NNW	1.00	9.0	NNW	66.1	59.1	59.1	30.100	0.00	0.00	0.000	0.011
10/29/24	4:45p	65.8	66.2	65.8	0	---	5.0	NNW	1.25	10.0	N	65.8	58.8	58.8	30.105	0.00	0.00	0.000	0.008
10/29/24	5:00p	65.2	65.8	65.1	0	---	6.0	NW	1.50	12.0	NNW	65.2	58.3	58.3	30.106	0.00	0.00	0.000	0.002
10/29/24	5:15p	65.0	65.2	65.0	0	---	4.0	NW	1.00	10.0	NW	65.0	58.1	58.1	30.109	0.00	0.00	0.000	0.000
10/29/24	5:30p	64.9	65.1	64.8	0	---	4.0	NNW	1.00	10.0	N	64.9	58.0	58.0	30.108	0.00	0.00	0.001	0.000
10/29/24	5:45p	64.5	64.9	64.5	0	---	1.0	N	0.25	5.0	NW	64.5	57.7	57.7	30.116	0.00	0.00	0.005	0.000
10/29/24	6:00p	63.9	64.5	63.9	0	---	1.0	N	0.25	3.0	NNW	63.9	57.2	57.2	30.114	0.00	0.00	0.011	0.000
10/29/24	6:15p	63.1	63.9	63.1	0	---	1.0	N	0.25	3.0	N	63.1	56.5	56.5	30.115	0.00	0.00	0.020	0.000
10/29/24	6:30p	61.7	63.1	61.7	0	---	1.0	N	0.25	3.0	N	61.7	55.4	55.4	30.115	0.00	0.00	0.034	0.000
10/29/24	6:45p	61.4	61.7	61.2	0	---	0.0	N	0.00	1.0	N	61.4	55.1	55.1	30.122	0.00	0.00	0.037	0.000
10/29/24	7:00p	60.4	61.4	60.4	---	---	0.0	ENE	0.00	2.0	ENE	60.4	---	---	30.124	0.00	0.00	0.048	0.000
10/29/24	7:15p	59.6	60.5	59.6	1	-41.6	1.0	ENE	0.25	3.0	ENE	59.6	53.8	53.8	30.130	0.00	0.00	0.056	0.000
10/29/24	7:30p	59.3	59.6	59.3	1	-41.7	2.0	ENE	0.50	3.0	ENE	59.3	53.5	53.5	30.126	0.00	0.00	0.059	0.000
10/29/24	7:45p	58.7	59.3	58.7	2	-29.8	0.0	ENE	0.00	2.0	ENE	58.7	53.1	53.1	30.126	0.00	0.00	0.066	0.000
10/29/24	8:00p	58.4	58.7	58.3	2	-30.0	0.0	ENE	0.00	1.0	ENE	58.4	52.9	52.9	30.126	0.00	0.00	0.069	0.000
10/29/24	8:15p	57.9	58.4	57.9	5	-12.8	0.0	ENE	0.00	1.0	ENE	57.9	52.7	52.7	30.126	0.00	0.00	0.074	0.000
10/29/24	8:30p	56.9	58.0	56.8	9	-1.5	1.0	ENE	0.25	2.0	ENE	56.9	52.6	52.6	30.127	0.00	0.00	0.084	0.000
10/29/24	8:45p	55.9	56.9	55.9	10	-0.0	1.0	ENE	0.25	4.0	E	55.9	51.9	51.9	30.127	0.00	0.00	0.095	0.000
10/29/24	9:00p	54.1	55.9	54.1	11	0.6	2.0	ESE	0.50	3.0	ESE	54.1	50.5	50.5	30.129	0.00	0.00	0.114	0.000
10/29/24	9:15p	53.1	54.1	53.0	14	5.1	1.0	SE	0.25	3.0	SE	53.1	49.8	49.8	30.132	0.00	0.00	0.124	0.000
10/29/24	9:30p	52.1	53.1	52.1	15	5.8	1.0	SE	0.25	3.0	SE	52.1	49.1	49.1	30.138	0.00	0.00	0.134	0.000
10/29/24	9:45p	50.6	52.1	50.6	16	6.0	1.0	SE	0.25	4.0	SE	50.6	48.0	48.0	30.146	0.00	0.00	0.150	0.000
10/29/24	10:00p	49.8	50.6	49.7	20	10.3	2.0	SE	0.50	5.0	SE	49.8	47.5	47.5	30.157	0.00	0.00	0.158	0.000
10/29/24	10:15p	49.1	49.8	49.1	20	9.7	2.0	SE	0.50	6.0	SSW	49.1	46.9	46.9	30.166	0.00	0.00	0.166	0.000
10/29/24	10:30p	48.6	49.1	48.5	22	11.4	0.0	SSW	0.00	3.0	SW	48.6	46.5	46.5	30.167	0.00	0.00	0.171	0.000
10/29/24	10:45p	48.6	48.7	48.5	23	12.4	1.0	SSE	0.25	3.0	S	48.6	46.5	46.5	30.168	0.00	0.00	0.171	0.000
10/29/24	11:00p	48.1	48.6	48.1	23	12.0	1.0	SSE	0.25	6.0	SSW	48.1	46.0	46.0	30.172	0.00	0.00	0.176	0.000
10/29/24	11:15p	47.3	48.1	47.3	24	12.3	2.0	SE	0.50	5.0	S	47.3	45.3	45.3	30.179	0.00	0.00	0.184	0.000
10/29/24	11:30p	46.8	47.3	46.7	26	13.7	0.0	SSW	0.00	3.0	SSW	46.8	44.9	44.9	30.183	0.00	0.00	0.190	0.000
10/29/24	11:45p	47.2	47.2	46.7	26	14.0	1.0	SE	0.25	4.0	SE	47.2	45.2	45.2	30.179	0.00	0.00	0.185	0.000
10/30/24	12:00a	49.3	49.3	47.2	22	12.0	2.0	SE	0.50	5.0	SE	49.3	47.1	47.1	30.177	0.00	0.00	0.164	0.000

NKSP 10/28/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/28/24	12:15a	75.9	43	51.8	75.1	8.05	.0736	350	1	100.0	15
10/28/24	12:30a	75.7	44	52.2	75.0	8.24	.0736	352	1	100.0	15
10/28/24	12:45a	75.8	44	52.3	75.1	8.23	.0736	351	1	100.0	15
10/28/24	1:00a	75.8	44	52.3	75.1	8.23	.0736	351	1	100.0	15
10/28/24	1:15a	75.8	44	52.3	75.1	8.23	.0735	351	1	100.0	15
10/28/24	1:30a	75.8	44	52.3	75.1	8.23	.0736	352	1	100.0	15
10/28/24	1:45a	75.8	44	52.3	75.1	8.23	.0736	351	1	100.0	15
10/28/24	2:00a	75.7	44	52.2	75.0	8.24	.0736	351	1	100.0	15
10/28/24	2:15a	75.7	44	52.2	75.0	8.24	.0736	351	1	100.0	15
10/28/24	2:30a	75.6	44	52.1	74.9	8.24	.0736	351	1	100.0	15
10/28/24	2:45a	75.5	44	52.1	74.8	8.24	.0736	352	1	100.0	15
10/28/24	3:00a	75.5	44	52.1	74.8	8.24	.0736	351	1	100.0	15
10/28/24	3:15a	75.4	43	51.3	74.6	8.05	.0736	351	1	100.0	15
10/28/24	3:30a	75.4	44	52.0	74.7	8.24	.0736	351	1	100.0	15
10/28/24	3:45a	75.3	44	51.9	74.6	8.24	.0736	352	1	100.0	15
10/28/24	4:00a	75.3	44	51.9	74.6	8.24	.0736	351	1	100.0	15
10/28/24	4:15a	75.4	44	52.0	74.7	8.24	.0736	351	1	100.0	15
10/28/24	4:30a	75.3	44	51.9	74.6	8.24	.0736	351	1	100.0	15
10/28/24	4:45a	75.2	44	51.8	74.5	8.25	.0736	352	1	100.0	15
10/28/24	5:00a	75.2	44	51.8	74.5	8.25	.0736	351	1	100.0	15
10/28/24	5:15a	75.2	44	51.8	74.5	8.25	.0736	351	1	100.0	15
10/28/24	5:30a	75.2	45	52.4	74.6	8.45	.0736	351	1	100.0	15
10/28/24	5:45a	75.2	43	51.2	74.4	8.05	.0737	351	1	100.0	15
10/28/24	6:00a	74.7	46	52.5	74.2	8.56	.0737	352	1	100.0	15
10/28/24	6:15a	74.8	46	52.6	74.3	8.55	.0737	351	1	100.0	15
10/28/24	6:30a	75.1	47	53.5	74.7	8.75	.0736	351	1	100.0	15
10/28/24	6:45a	75.2	46	53.0	74.7	8.55	.0736	351	1	100.0	15
10/28/24	7:00a	75.4	47	53.8	75.0	8.74	.0736	352	1	100.0	15
10/28/24	7:15a	75.5	46	53.3	75.0	8.54	.0736	351	1	100.0	15
10/28/24	7:30a	75.7	46	53.4	75.2	8.54	.0736	351	1	100.0	15
10/28/24	7:45a	75.4	46	53.2	74.9	8.54	.0736	351	1	100.0	15
10/28/24	8:00a	75.4	47	53.8	75.0	8.74	.0736	351	1	100.0	15
10/28/24	8:15a	75.6	46	53.4	75.1	8.54	.0736	352	1	100.0	15
10/28/24	8:30a	75.9	46	53.6	75.4	8.53	.0736	351	1	100.0	15
10/28/24	8:45a	76.0	45	53.1	75.4	8.43	.0736	351	1	100.0	15
10/28/24	9:00a	76.2	44	52.7	75.5	8.23	.0736	351	1	100.0	15
10/28/24	9:15a	76.4	42	51.6	75.5	7.92	.0736	352	1	100.0	15
10/28/24	9:30a	76.6	40	50.5	75.5	7.62	.0736	351	1	100.0	15
10/28/24	9:45a	76.3	40	50.2	75.2	7.62	.0737	351	1	100.0	15
10/28/24	10:00a	76.6	39	49.8	75.4	7.52	.0736	351	1	100.0	15
10/28/24	10:15a	76.9	38	49.4	75.6	7.31	.0736	351	1	100.0	15
10/28/24	10:30a	77.1	36	48.1	75.7	7.01	.0736	352	1	100.0	15
10/28/24	10:45a	77.0	37	48.7	75.7	7.21	.0736	351	1	100.0	15
10/28/24	11:00a	77.4	35	47.6	75.9	6.90	.0736	351	1	100.0	15
10/28/24	11:15a	77.3	37	49.0	75.9	7.20	.0736	351	1	100.0	15
10/28/24	11:30a	77.6	36	48.5	76.1	7.00	.0735	352	1	100.0	15
10/28/24	11:45a	77.8	36	48.7	76.3	6.99	.0735	351	1	100.0	15
10/28/24	12:00p	77.6	36	48.5	76.1	7.00	.0735	351	1	100.0	15
10/28/24	12:15p	77.9	36	48.8	76.4	6.99	.0735	351	1	100.0	15
10/28/24	12:30p	77.9	36	48.8	76.4	6.99	.0734	352	1	100.0	15

NKSP 10/28/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/28/24	12:45p	78.1	36	49.0	76.6	6.99	.0734	351	1	100.0	15
10/28/24	1:00p	77.9	36	48.8	76.4	6.99	.0734	351	1	100.0	15
10/28/24	1:15p	78.3	35	48.4	76.7	6.88	.0733	351	1	100.0	15
10/28/24	1:30p	77.9	36	48.8	76.4	6.99	.0734	352	1	100.0	15
10/28/24	1:45p	77.7	36	48.6	76.2	7.00	.0734	351	1	100.0	15
10/28/24	2:00p	77.9	36	48.8	76.4	6.99	.0733	351	1	100.0	15
10/28/24	2:15p	77.5	36	48.4	76.0	7.00	.0734	351	1	100.0	15
10/28/24	2:30p	77.4	35	47.6	75.9	6.90	.0734	351	1	100.0	15
10/28/24	2:45p	77.5	37	49.2	76.1	7.20	.0733	352	1	100.0	15
10/28/24	3:00p	77.0	37	48.7	75.7	7.21	.0734	351	1	100.0	15
10/28/24	3:15p	77.2	35	47.4	75.7	6.91	.0734	351	1	100.0	15
10/28/24	3:30p	77.6	37	49.3	76.2	7.20	.0733	351	1	100.0	15
10/28/24	3:45p	77.3	38	49.7	76.0	7.30	.0733	352	1	100.0	15
10/28/24	4:00p	77.3	36	48.3	75.9	7.00	.0733	351	1	100.0	15
10/28/24	4:15p	77.6	38	50.0	76.3	7.30	.0732	351	1	100.0	15
10/28/24	4:30p	77.3	38	49.7	76.0	7.30	.0733	351	1	100.0	15
10/28/24	4:45p	77.3	36	48.3	75.9	7.00	.0733	351	1	100.0	15
10/28/24	5:00p	77.4	38	49.8	76.1	7.30	.0732	352	1	100.0	15
10/28/24	5:15p	77.0	38	49.4	75.7	7.31	.0733	351	1	100.0	15
10/28/24	5:30p	77.2	36	48.2	75.8	7.01	.0733	351	1	100.0	15
10/28/24	5:45p	76.8	38	49.3	75.5	7.31	.0733	351	1	100.0	15
10/28/24	6:00p	76.7	37	48.5	75.4	7.22	.0733	352	1	100.0	15
10/28/24	6:15p	76.6	38	49.1	75.4	7.32	.0733	351	1	100.0	15
10/28/24	6:30p	76.3	38	48.8	75.1	7.32	.0734	351	1	100.0	15
10/28/24	6:45p	76.5	38	49.0	75.3	7.32	.0734	351	1	100.0	15
10/28/24	7:00p	76.0	39	49.2	74.8	7.53	.0734	352	1	100.0	15
10/28/24	7:15p	76.2	39	49.4	75.0	7.53	.0734	351	1	100.0	15
10/28/24	7:30p	75.8	39	49.1	74.6	7.53	.0735	351	1	100.0	15
10/28/24	7:45p	76.0	39	49.2	74.8	7.53	.0735	351	1	100.0	15
10/28/24	8:00p	75.7	39	49.0	74.5	7.54	.0735	351	1	100.0	15
10/28/24	8:15p	75.9	39	49.2	74.7	7.53	.0735	352	1	100.0	15
10/28/24	8:30p	75.6	39	48.9	74.4	7.54	.0735	351	1	100.0	15
10/28/24	8:45p	75.7	39	49.0	74.5	7.54	.0735	351	1	100.0	15
10/28/24	9:00p	75.8	38	48.4	74.6	7.33	.0735	351	1	100.0	15
10/28/24	9:15p	75.3	39	48.6	74.1	7.54	.0736	352	1	100.0	15
10/28/24	9:30p	75.4	39	48.7	74.2	7.54	.0736	351	1	100.0	15
10/28/24	9:45p	75.6	39	48.9	74.4	7.54	.0736	351	1	100.0	15
10/28/24	10:00p	75.1	40	49.1	74.0	7.65	.0736	351	1	100.0	15
10/28/24	10:15p	75.0	40	49.0	73.9	7.65	.0737	352	1	100.0	15
10/28/24	10:30p	75.1	40	49.1	74.0	7.65	.0736	351	1	100.0	15
10/28/24	10:45p	75.2	39	48.5	74.0	7.55	.0736	351	1	100.0	15
10/28/24	11:00p	75.1	39	48.4	73.9	7.55	.0737	351	1	100.0	15
10/28/24	11:15p	75.1	39	48.4	73.9	7.55	.0737	351	1	100.0	15
10/28/24	11:30p	75.1	39	48.4	73.9	7.55	.0737	352	1	100.0	15
10/28/24	11:45p	75.0	39	48.4	73.8	7.55	.0737	351	1	100.0	15
10/29/24	12:00a	75.0	39	48.4	73.8	7.55	.0737	351	1	100.0	15

NKSP 10/29/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/29/24	12:15a	75.0	39	48.4	73.8	7.55	.0737	351	1	100.0	15
10/29/24	12:30a	74.9	39	48.3	73.7	7.55	.0737	351	1	100.0	15
10/29/24	12:45a	74.8	39	48.2	73.6	7.55	.0737	351	1	100.0	15
10/29/24	1:00a	74.7	39	48.1	73.5	7.56	.0737	351	1	100.0	15
10/29/24	1:15a	74.7	39	48.1	73.5	7.56	.0737	351	1	100.0	15
10/29/24	1:30a	74.6	38	47.3	73.3	7.37	.0738	352	1	100.0	15
10/29/24	1:45a	74.7	38	47.4	73.4	7.36	.0738	351	1	100.0	15
10/29/24	2:00a	74.9	38	47.6	73.7	7.35	.0737	351	1	100.0	15
10/29/24	2:15a	74.9	38	47.6	73.7	7.35	.0737	351	1	100.0	15
10/29/24	2:30a	74.9	38	47.6	73.7	7.35	.0737	352	1	100.0	15
10/29/24	2:45a	75.1	38	47.8	73.9	7.35	.0737	351	1	100.0	15
10/29/24	3:00a	75.1	38	47.8	73.9	7.35	.0737	351	1	100.0	15
10/29/24	3:15a	75.2	38	47.8	74.0	7.35	.0737	351	1	100.0	15
10/29/24	3:30a	75.2	38	47.8	74.0	7.35	.0737	351	1	100.0	15
10/29/24	3:45a	75.3	38	47.9	74.1	7.34	.0737	352	1	100.0	15
10/29/24	4:00a	75.3	38	47.9	74.1	7.34	.0737	351	1	100.0	15
10/29/24	4:15a	75.3	38	47.9	74.1	7.34	.0737	351	1	100.0	15
10/29/24	4:30a	75.4	38	48.0	74.2	7.34	.0737	351	1	100.0	15
10/29/24	4:45a	75.3	38	47.9	74.1	7.34	.0737	352	1	100.0	15
10/29/24	5:00a	75.3	38	47.9	74.1	7.34	.0737	351	1	100.0	15
10/29/24	5:15a	75.3	38	47.9	74.1	7.34	.0737	351	1	100.0	15
10/29/24	5:30a	75.2	38	47.8	74.0	7.35	.0737	351	1	100.0	15
10/29/24	5:45a	75.2	38	47.8	74.0	7.35	.0737	352	1	100.0	15
10/29/24	6:00a	75.3	39	48.6	74.1	7.54	.0737	351	1	100.0	15
10/29/24	6:15a	75.3	39	48.6	74.1	7.54	.0737	351	1	100.0	15
10/29/24	6:30a	75.1	39	48.4	73.9	7.55	.0737	351	1	100.0	15
10/29/24	6:45a	74.8	39	48.2	73.6	7.55	.0738	351	1	100.0	15
10/29/24	7:00a	74.6	39	48.0	73.4	7.56	.0738	352	1	100.0	15
10/29/24	7:15a	74.5	39	47.9	73.3	7.56	.0739	351	1	100.0	15
10/29/24	7:30a	74.4	39	47.8	73.2	7.56	.0739	351	1	100.0	15
10/29/24	7:45a	74.4	40	48.5	73.2	7.66	.0739	351	1	100.0	15
10/29/24	8:00a	74.3	40	48.4	73.1	7.66	.0739	352	1	100.0	15
10/29/24	8:15a	74.3	40	48.4	73.1	7.66	.0740	351	1	100.0	15
10/29/24	8:30a	74.4	40	48.5	73.2	7.66	.0740	351	1	100.0	15
10/29/24	8:45a	74.5	40	48.6	73.4	7.66	.0740	351	1	100.0	15
10/29/24	9:00a	74.6	40	48.7	73.5	7.66	.0740	351	1	100.0	15
10/29/24	9:15a	74.6	40	48.7	73.5	7.66	.0740	352	1	100.0	15
10/29/24	9:30a	74.8	39	48.2	73.6	7.55	.0740	351	1	100.0	15
10/29/24	9:45a	74.9	39	48.3	73.7	7.55	.0740	351	1	100.0	15
10/29/24	10:00a	75.0	39	48.4	73.8	7.55	.0739	351	1	100.0	15
10/29/24	10:15a	75.2	39	48.5	74.0	7.55	.0739	352	1	100.0	15
10/29/24	10:30a	75.3	39	48.6	74.1	7.54	.0739	351	1	100.0	15
10/29/24	10:45a	75.5	38	48.1	74.3	7.34	.0739	351	1	100.0	15
10/29/24	11:00a	75.7	38	48.3	74.5	7.34	.0739	351	1	100.0	15
10/29/24	11:15a	75.9	38	48.5	74.7	7.33	.0738	352	1	100.0	15
10/29/24	11:30a	76.1	38	48.6	74.9	7.33	.0738	351	1	100.0	15
10/29/24	11:45a	75.5	38	48.1	74.3	7.34	.0739	351	1	100.0	15
10/29/24	12:00p	75.7	37	47.6	74.4	7.24	.0739	351	1	100.0	15
10/29/24	12:15p	75.8	37	47.7	74.5	7.23	.0738	351	1	100.0	15
10/29/24	12:30p	75.6	37	47.5	74.3	7.24	.0739	352	1	100.0	15

NKSP 10/29/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/29/24	12:45p	75.8	37	47.7	74.5	7.23	.0738	351	1	100.0	15
10/29/24	1:00p	75.8	37	47.7	74.5	7.23	.0738	351	1	100.0	15
10/29/24	1:15p	75.5	37	47.4	74.2	7.24	.0738	351	1	100.0	15
10/29/24	1:30p	75.8	36	46.9	74.5	7.03	.0738	352	1	100.0	15
10/29/24	1:45p	75.7	38	48.3	74.5	7.34	.0737	351	1	100.0	15
10/29/24	2:00p	75.6	38	48.2	74.4	7.34	.0738	351	1	100.0	15
10/29/24	2:15p	75.9	36	47.0	74.6	7.03	.0737	351	1	100.0	15
10/29/24	2:30p	75.7	38	48.3	74.5	7.34	.0737	351	1	100.0	15
10/29/24	2:45p	75.7	37	47.6	74.4	7.24	.0737	352	1	100.0	15
10/29/24	3:00p	75.7	36	46.8	74.4	7.04	.0738	351	1	100.0	15
10/29/24	3:15p	76.0	35	46.4	74.6	6.93	.0737	351	1	100.0	15
10/29/24	3:30p	75.9	37	47.8	74.6	7.23	.0737	351	1	100.0	15
10/29/24	3:45p	75.6	36	46.8	74.3	7.04	.0738	352	1	100.0	15
10/29/24	4:00p	75.9	35	46.3	74.5	6.93	.0738	351	1	100.0	15
10/29/24	4:15p	76.1	36	47.2	74.8	7.03	.0737	351	1	100.0	15
10/29/24	4:30p	75.8	37	47.7	74.5	7.23	.0737	351	1	100.0	15
10/29/24	4:45p	75.9	36	47.0	74.6	7.03	.0738	352	1	100.0	15
10/29/24	5:00p	76.0	36	47.1	74.7	7.03	.0737	351	1	100.0	15
10/29/24	5:15p	75.8	37	47.7	74.5	7.23	.0738	351	1	100.0	15
10/29/24	5:30p	75.5	37	47.4	74.2	7.24	.0738	351	1	100.0	15
10/29/24	5:45p	75.7	37	47.6	74.4	7.24	.0738	351	1	100.0	15
10/29/24	6:00p	75.6	37	47.5	74.3	7.24	.0738	352	1	100.0	15
10/29/24	6:15p	75.7	37	47.6	74.4	7.24	.0738	351	1	100.0	15
10/29/24	6:30p	75.5	37	47.4	74.2	7.24	.0738	351	1	100.0	15
10/29/24	6:45p	75.6	37	47.5	74.3	7.24	.0738	351	1	100.0	15
10/29/24	7:00p	75.3	37	47.2	74.0	7.24	.0739	352	1	100.0	15
10/29/24	7:15p	75.5	37	47.4	74.2	7.24	.0739	351	1	100.0	15
10/29/24	7:30p	75.3	37	47.2	74.0	7.24	.0739	351	1	100.0	15
10/29/24	7:45p	75.2	38	47.8	74.0	7.35	.0739	351	1	100.0	15
10/29/24	8:00p	75.5	37	47.4	74.2	7.24	.0738	352	1	100.0	15
10/29/24	8:15p	75.0	38	47.7	73.8	7.35	.0739	351	1	100.0	15
10/29/24	8:30p	75.2	38	47.8	74.0	7.35	.0739	351	1	100.0	15
10/29/24	8:45p	75.3	36	46.5	74.0	7.04	.0739	351	1	100.0	15
10/29/24	9:00p	74.7	38	47.4	73.4	7.36	.0740	351	1	100.0	15
10/29/24	9:15p	74.9	38	47.6	73.7	7.35	.0739	352	1	100.0	15
10/29/24	9:30p	74.9	37	46.9	73.6	7.25	.0740	351	1	100.0	15
10/29/24	9:45p	74.9	37	46.9	73.6	7.25	.0740	351	1	100.0	15
10/29/24	10:00p	74.8	37	46.8	73.5	7.25	.0740	351	1	100.0	15
10/29/24	10:15p	74.7	37	46.7	73.4	7.26	.0741	352	1	100.0	15
10/29/24	10:30p	74.6	37	46.6	73.3	7.26	.0741	351	1	100.0	15
10/29/24	10:45p	74.4	37	46.4	73.1	7.26	.0741	351	1	100.0	15
10/29/24	11:00p	74.2	37	46.2	72.8	7.27	.0742	351	1	100.0	15
10/29/24	11:15p	74.0	37	46.1	72.6	7.27	.0742	352	1	100.0	15
10/29/24	11:30p	73.8	37	45.9	72.4	7.27	.0743	351	1	100.0	15
10/29/24	11:45p	73.7	39	46.5	72.3	7.40	.0743	351	1	100.0	15
10/30/24	12:00a	73.6	37	45.7	72.2	7.28	.0743	351	1	100.0	15

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

OUTSIDE TEMPERATURE RECORD

CDCR 2030 (04/18)

INSTITUTION: NKSP

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the OUTSIDE ambient air temperature.

Using an accurate thermometer located in a central, heat neutral location, the outside air temperature is to be taken every hour, seven (7) days a week.

Thermometer Location: CENTRAL CONTROL

Immediately notify the Watch Commander at extension 3141 when the air temperature reaches 90 degrees.

Date	Time	Temp.	Printed Name
10/30	0100	46	PADILLA
	0200	46	PADILLA
	0300	44	PADILLA
	0400	44	PADILLA
	0500	43	PADILLA
	0600	42	LMARTINEZ
	0700	41	LMARTINEZ
	0800	42	LMARTINEZ
	0900	47	LMARTINEZ
	1000	54	LMARTINEZ
	1100	60	LMARTINEZ
	1200	64	LMARTINEZ
	1300	66	LMARTINEZ
	1400	67	MONCIBAIZ
	1500	68	MONCIBAIZ
	1600	70	MONCIBAIZ
	1700	69	MONCIBAIZ
	1800	67	MONCIBAIZ
	1900	63	MONCIBAIZ
	2000	60	MONCIBAIZ
	2100	56	MONCIBAIZ
	2200	52	MONCIBAIZ
	2300	49	MONCIBAIZ
	2400	46	MONCIBAIZ

Date	Time	Temp.	Printed Name
10/31	0100	47	MONCIBAIZ
	0200	47	MONCIBAIZ
	0300	45	MONCIBAIZ
	0400	44	MONCIBAIZ
	0500	43	MONCIBAIZ
	0600	42	LMARTINEZ
	0700	41	LMARTINEZ
	0800	42	LMARTINEZ
	0900	46	LMARTINEZ
	1000	52	LMARTINEZ
	1100	59	LMARTINEZ
	1200	64	LMARTINEZ
	1300	66	LMARTINEZ
	1400	69	MONCIBAIZ
	1500	70	MONCIBAIZ
	1600	69	MONCIBAIZ
	1700	69	MONCIBAIZ
	1800	65	MONCIBAIZ
	1900	61	MONCIBAIZ
	2000	58	MONCIBAIZ
	2100	55	MONCIBAIZ
	2200	54	MONCIBAIZ
	2300	51	MONCIBAIZ
	2400	51	MONCIBAIZ

DISTRIBUTION: Original: Institution Heat Plan Coordinator

NKSP 10/30/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/30/24	12:15a	48.6	49.4	48.6	21	10.4	0.0	SE	0.00	3.0	SE	48.6	46.4	46.4	30.185	0.00	0.00	0.171	0.000
10/30/24	12:30a	48.0	48.6	48.0	21	9.9	0.0	SE	0.00	1.0	SE	48.0	45.8	45.8	30.190	0.00	0.00	0.177	0.000
10/30/24	12:45a	47.0	47.9	47.0	23	11.1	1.0	ESE	0.25	3.0	ESE	47.0	44.9	44.9	30.190	0.00	0.00	0.188	0.000
10/30/24	1:00a	46.8	47.0	46.7	23	10.9	2.0	E	0.50	4.0	E	46.8	44.7	44.7	30.190	0.00	0.00	0.190	0.000
10/30/24	1:15a	46.6	46.9	46.5	23	10.7	2.0	E	0.50	4.0	E	46.6	44.6	44.6	30.186	0.00	0.00	0.192	0.000
10/30/24	1:30a	46.3	46.6	46.3	24	11.4	3.0	ENE	0.75	7.0	E	45.5	44.3	43.5	30.188	0.00	0.00	0.195	0.000
10/30/24	1:45a	46.0	46.3	46.0	25	12.1	2.0	ENE	0.50	5.0	ENE	46.0	44.1	44.1	30.188	0.00	0.00	0.198	0.000
10/30/24	2:00a	46.0	46.1	45.9	24	11.2	0.0	ENE	0.00	3.0	ENE	46.0	44.1	44.1	30.186	0.00	0.00	0.198	0.000
10/30/24	2:15a	45.7	46.0	45.7	24	10.9	0.0	---	0.00	0.0	---	45.7	43.8	43.8	30.191	0.00	0.00	0.201	0.000
10/30/24	2:30a	44.3	45.7	44.3	25	10.6	0.0	ENE	0.00	1.0	ENE	44.3	42.4	42.4	30.190	0.00	0.00	0.216	0.000
10/30/24	2:45a	44.3	44.3	44.1	27	12.4	0.0	E	0.00	1.0	E	44.3	42.5	42.5	30.190	0.00	0.00	0.216	0.000
10/30/24	3:00a	44.0	44.5	44.0	27	12.1	0.0	SSE	0.00	2.0	SSE	44.0	42.2	42.2	30.191	0.00	0.00	0.219	0.000
10/30/24	3:15a	43.6	44.0	43.5	28	12.6	0.0	SSE	0.00	2.0	SSE	43.6	41.8	41.8	30.192	0.00	0.00	0.223	0.000
10/30/24	3:30a	43.5	43.6	43.4	28	12.5	0.0	SSE	0.00	2.0	SSE	43.5	41.7	41.7	30.194	0.00	0.00	0.224	0.000
10/30/24	3:45a	44.0	44.0	43.4	29	13.7	1.0	SSE	0.25	5.0	SSE	44.0	42.3	42.3	30.192	0.00	0.00	0.219	0.000
10/30/24	4:00a	44.1	44.1	43.9	28	13.0	2.0	SSE	0.50	5.0	SE	44.1	42.3	42.3	30.198	0.00	0.00	0.218	0.000
10/30/24	4:15a	43.5	44.2	43.5	27	11.7	2.0	SE	0.50	5.0	SE	43.5	41.7	41.7	30.199	0.00	0.00	0.224	0.000
10/30/24	4:30a	43.3	43.6	43.1	28	12.3	1.0	SE	0.25	3.0	SE	43.3	41.5	41.5	30.204	0.00	0.00	0.226	0.000
10/30/24	4:45a	43.2	43.3	43.0	28	12.2	1.0	SE	0.25	3.0	SE	43.2	41.5	41.5	30.205	0.00	0.00	0.227	0.000
10/30/24	5:00a	43.3	43.3	43.0	29	13.1	1.0	SE	0.25	3.0	SE	43.3	41.6	41.6	30.206	0.00	0.00	0.226	0.000
10/30/24	5:15a	43.4	43.4	43.2	30	14.0	0.0	ESE	0.00	2.0	ESE	43.4	41.7	41.7	30.211	0.00	0.00	0.225	0.000
10/30/24	5:30a	43.5	43.6	43.4	29	13.3	0.0	ESE	0.00	1.0	ESE	43.5	41.8	41.8	30.219	0.00	0.00	0.224	0.000
10/30/24	5:45a	43.1	43.5	43.1	28	12.2	0.0	---	0.00	0.0	---	43.1	41.4	41.4	30.221	0.00	0.00	0.228	0.000
10/30/24	6:00a	42.8	43.1	42.6	29	12.7	0.0	ESE	0.00	1.0	ESE	42.8	41.1	41.1	30.226	0.00	0.00	0.231	0.000
10/30/24	6:15a	42.7	42.8	42.7	29	12.6	0.0	---	0.00	0.0	---	42.7	41.0	41.0	30.232	0.00	0.00	0.232	0.000
10/30/24	6:30a	41.9	42.7	41.9	28	11.1	0.0	ESE	0.00	1.0	ESE	41.9	40.2	40.2	30.235	0.00	0.00	0.241	0.000
10/30/24	6:45a	41.3	41.9	41.3	29	11.4	0.0	---	0.00	0.0	---	41.3	39.7	39.7	30.241	0.00	0.00	0.247	0.000
10/30/24	7:00a	41.2	41.3	41.1	30	12.1	0.0	ESE	0.00	1.0	ESE	41.2	39.6	39.6	30.236	0.00	0.00	0.248	0.000
10/30/24	7:15a	41.4	41.5	41.3	30	12.2	0.0	ESE	0.00	2.0	ESE	41.4	39.8	39.8	30.242	0.00	0.00	0.246	0.000
10/30/24	7:30a	41.1	41.4	41.1	30	12.0	0.0	---	0.00	0.0	---	41.1	39.5	39.5	30.250	0.00	0.00	0.249	0.000
10/30/24	7:45a	41.4	41.4	41.1	31	13.0	0.0	---	0.00	0.0	---	41.4	39.8	39.8	30.256	0.00	0.00	0.246	0.000
10/30/24	8:00a	42.2	42.2	41.4	31	13.7	0.0	ESE	0.00	1.0	ESE	42.2	40.5	40.5	30.257	0.00	0.00	0.237	0.000
10/30/24	8:15a	43.7	43.7	42.2	30	14.2	0.0	ESE	0.00	3.0	ESE	43.7	42.0	42.0	30.263	0.00	0.00	0.222	0.000
10/30/24	8:30a	45.2	45.2	43.7	29	14.8	1.0	SE	0.25	4.0	SE	45.2	43.4	43.4	30.267	0.00	0.00	0.206	0.000
10/30/24	8:45a	46.5	46.5	45.2	26	13.4	1.0	SE	0.25	4.0	ESE	46.5	44.6	44.6	30.266	0.00	0.00	0.193	0.000
10/30/24	9:00a	47.9	47.9	46.5	25	13.7	0.0	ESE	0.00	3.0	ESE	47.9	45.9	45.9	30.266	0.00	0.00	0.178	0.000
10/30/24	9:15a	49.1	49.1	47.9	23	12.8	0.0	SE	0.00	4.0	ESE	49.1	47.0	47.0	30.279	0.00	0.00	0.166	0.000
10/30/24	9:30a	51.0	51.0	49.1	19	10.1	0.0	SE	0.00	2.0	SSE	51.0	48.4	48.4	30.288	0.00	0.00	0.146	0.000
10/30/24	9:45a	53.2	53.2	51.0	14	5.1	0.0	SSE	0.00	2.0	SSE	53.2	49.8	49.8	30.284	0.00	0.00	0.123	0.000
10/30/24	10:00a	54.7	54.7	53.2	11	1.1	0.0	S	0.00	1.0	S	54.7	51.0	51.0	30.282	0.00	0.00	0.107	0.000
10/30/24	10:15a	56.5	56.6	54.8	8	-4.3	0.0	S	0.00	1.0	S	56.5	52.1	52.1	30.276	0.00	0.00	0.089	0.000
10/30/24	10:30a	57.5	57.5	56.5	7	-6.3	0.0	WSW	0.00	2.0	WSW	57.5	52.8	52.8	30.278	0.00	0.00	0.078	0.000
10/30/24	10:45a	59.4	59.4	57.5	4	-16.2	0.0	SW	0.00	3.0	SW	59.4	53.8	53.8	30.275	0.00	0.00	0.058	0.000
10/30/24	11:00a	60.5	60.5	59.4	2	-28.6	1.0	SSW	0.25	4.0	WSW	60.5	54.6	54.6	30.281	0.00	0.00	0.047	0.000
10/30/24	11:15a	61.3	61.3	60.5	0	---	1.0	SW	0.25	5.0	SW	61.3	55.0	55.0	30.278	0.00	0.00	0.039	0.000
10/30/24	11:30a	62.3	62.3	61.3	0	---	1.0	SSW	0.25	7.0	SSW	62.3	55.8	55.8	30.278	0.00	0.00	0.028	0.000
10/30/24	11:45a	63.2	63.2	62.3	0	---	1.0	SE	0.25	3.0	SE	63.2	56.6	56.6	30.273	0.00	0.00	0.019	0.000
10/30/24	12:00p	64.1	64.1	63.2	0	---	1.0	E	0.25	4.0	E	64.1	57.4	57.4	30.271	0.00	0.00	0.009	0.000
10/30/24	12:15p	64.4	64.5	64.0	0	---	1.0	ESE	0.25	6.0	ESE	64.4	57.6	57.6	30.259	0.00	0.00	0.006	0.000
10/30/24	12:30p	65.1	65.1	64.4	0	---	1.0	ESE	0.25	6.0	E	65.1	58.2	58.2	30.255	0.00	0.00	0.000	0.001

NKSP 10/30/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/30/24	12:45p	66.3	66.4	65.0	0	---	1.0	SSW	0.25	6.0	SSW	66.3	59.3	59.3	30.248	0.00	0.00	0.000	0.014
10/30/24	1:00p	66.7	67.0	66.3	0	---	2.0	SE	0.50	5.0	SE	66.7	59.6	59.6	30.244	0.00	0.00	0.000	0.018
10/30/24	1:15p	67.0	67.0	66.6	0	---	1.0	SE	0.25	7.0	SE	67.0	59.9	59.9	30.238	0.00	0.00	0.000	0.021
10/30/24	1:30p	67.9	67.9	67.0	0	---	1.0	SSW	0.25	5.0	SE	67.9	60.7	60.7	30.233	0.00	0.00	0.000	0.030
10/30/24	1:45p	67.4	68.0	67.4	0	---	1.0	NW	0.25	4.0	SE	67.4	60.3	60.3	30.230	0.00	0.00	0.000	0.025
10/30/24	2:00p	67.6	67.7	67.4	0	---	3.0	NW	0.75	9.0	NNW	67.6	60.4	60.4	30.229	0.00	0.00	0.000	0.027
10/30/24	2:15p	67.6	67.6	67.1	0	---	2.0	NE	0.50	8.0	NNE	67.6	60.4	60.4	30.223	0.00	0.00	0.000	0.027
10/30/24	2:30p	68.6	68.6	67.7	0	---	2.0	NE	0.50	8.0	ENE	68.6	61.8	61.8	30.215	0.00	0.00	0.000	0.037
10/30/24	2:45p	68.4	68.6	68.2	0	---	2.0	NW	0.50	7.0	NW	68.4	61.4	61.4	30.210	0.00	0.00	0.000	0.035
10/30/24	3:00p	68.8	68.8	68.3	0	---	4.0	W	1.00	8.0	WSW	68.8	62.1	62.1	30.207	0.00	0.00	0.000	0.040
10/30/24	3:15p	69.5	69.7	68.8	0	---	1.0	NE	0.25	4.0	NE	69.5	63.2	63.2	30.205	0.00	0.00	0.000	0.047
10/30/24	3:30p	69.8	69.8	69.4	0	---	1.0	ENE	0.25	4.0	ENE	69.8	63.6	63.6	30.200	0.00	0.00	0.000	0.050
10/30/24	3:45p	70.5	70.5	69.8	0	---	1.0	WSW	0.25	7.0	W	70.5	64.6	64.6	30.203	0.00	0.00	0.000	0.057
10/30/24	4:00p	70.2	70.5	70.1	0	---	2.0	NNE	0.50	4.0	WSW	70.2	64.2	64.2	30.195	0.00	0.00	0.000	0.054
10/30/24	4:15p	69.5	70.3	69.4	0	---	3.0	NE	0.75	7.0	NNE	69.5	63.2	63.2	30.193	0.00	0.00	0.000	0.047
10/30/24	4:30p	69.7	69.8	69.5	0	---	1.0	ENE	0.25	5.0	NE	69.7	63.4	63.4	30.186	0.00	0.00	0.000	0.049
10/30/24	4:45p	69.8	69.9	69.7	0	---	1.0	NNW	0.25	4.0	NNW	69.8	63.6	63.6	30.185	0.00	0.00	0.000	0.050
10/30/24	5:00p	69.8	70.0	69.7	0	---	1.0	NE	0.25	4.0	NE	69.8	63.6	63.6	30.183	0.00	0.00	0.000	0.050
10/30/24	5:15p	69.5	69.8	69.5	0	---	2.0	NW	0.50	5.0	NW	69.5	63.2	63.2	30.186	0.00	0.00	0.000	0.047
10/30/24	5:30p	69.5	69.6	69.4	0	---	1.0	NW	0.25	2.0	NW	69.5	63.2	63.2	30.183	0.00	0.00	0.000	0.047
10/30/24	5:45p	68.7	69.5	68.7	0	---	1.0	NNE	0.25	3.0	NNE	68.7	61.9	61.9	30.174	0.00	0.00	0.000	0.039
10/30/24	6:00p	67.4	68.7	67.4	0	---	1.0	NNE	0.25	3.0	NNE	67.4	60.3	60.3	30.160	0.00	0.00	0.000	0.025
10/30/24	6:15p	66.4	67.4	66.4	0	---	0.0	NNE	0.00	2.0	NNE	66.4	59.4	59.4	30.182	0.00	0.00	0.000	0.015
10/30/24	6:30p	65.4	66.4	65.4	0	---	0.0	NNE	0.00	2.0	NNE	65.4	58.5	58.5	30.186	0.00	0.00	0.000	0.004
10/30/24	6:45p	63.9	65.3	63.9	0	---	0.0	NNE	0.00	2.0	NNE	63.9	57.2	57.2	30.190	0.00	0.00	0.011	0.000
10/30/24	7:00p	63.3	64.0	63.3	0	---	1.0	NNE	0.25	3.0	NNE	63.3	56.7	56.7	30.194	0.00	0.00	0.018	0.000
10/30/24	7:15p	62.2	63.3	62.2	0	---	1.0	NNE	0.25	3.0	NNE	62.2	55.8	55.8	30.196	0.00	0.00	0.029	0.000
10/30/24	7:30p	60.5	62.2	60.5	4	-15.4	0.0	NNE	0.00	2.0	NNE	60.5	54.7	54.7	30.197	0.00	0.00	0.047	0.000
10/30/24	7:45p	60.8	60.8	60.5	3	-20.8	0.0	---	0.00	0.0	---	60.8	54.9	54.9	30.193	0.00	0.00	0.044	0.000
10/30/24	8:00p	60.7	60.8	60.5	4	-15.3	0.0	---	0.00	0.0	---	60.7	54.9	54.9	30.193	0.00	0.00	0.045	0.000
10/30/24	8:15p	60.3	60.7	60.3	4	-15.6	0.0	---	0.00	0.0	---	60.3	54.6	54.6	30.194	0.00	0.00	0.049	0.000
10/30/24	8:30p	60.1	60.4	60.1	3	-21.3	0.0	---	0.00	0.0	---	60.1	54.3	54.3	30.193	0.00	0.00	0.051	0.000
10/30/24	8:45p	58.1	60.1	58.1	6	-9.0	0.0	ENE	0.00	1.0	ENE	58.1	53.0	53.0	30.192	0.00	0.00	0.072	0.000
10/30/24	9:00p	56.3	58.1	56.3	10	0.3	2.0	ESE	0.50	4.0	ESE	56.3	52.2	52.2	30.189	0.00	0.00	0.091	0.000
10/30/24	9:15p	54.9	56.3	54.9	11	1.3	3.0	ESE	0.75	7.0	ESE	54.9	51.1	51.1	30.195	0.00	0.00	0.105	0.000
10/30/24	9:30p	53.8	54.9	53.7	19	12.4	3.0	ESE	0.75	6.0	ESE	53.8	50.5	50.5	30.197	0.00	0.00	0.117	0.000
10/30/24	9:45p	53.3	53.8	53.3	20	13.2	2.0	ESE	0.50	6.0	ESE	53.3	50.1	50.1	30.198	0.00	0.00	0.122	0.000
10/30/24	10:00p	52.2	53.4	52.2	20	12.3	2.0	ESE	0.50	4.0	SE	52.2	49.3	49.3	30.208	0.00	0.00	0.133	0.000
10/30/24	10:15p	51.6	52.2	51.6	22	13.9	1.0	ESE	0.25	4.0	ESE	51.6	49.0	49.0	30.210	0.00	0.00	0.140	0.000
10/30/24	10:30p	51.5	51.7	51.4	22	13.8	2.0	ESE	0.50	4.0	ESE	51.5	48.9	48.9	30.211	0.00	0.00	0.141	0.000
10/30/24	10:45p	51.0	51.5	51.0	19	10.1	3.0	ESE	0.75	5.0	SE	50.8	48.4	48.2	30.211	0.00	0.00	0.146	0.000
10/30/24	11:00p	49.3	51.1	49.3	21	10.9	4.0	S	1.00	10.0	S	48.1	47.1	45.9	30.211	0.00	0.00	0.164	0.000
10/30/24	11:15p	48.9	49.3	48.9	22	11.7	1.0	SSE	0.25	4.0	SSE	48.9	46.7	46.7	30.215	0.00	0.00	0.168	0.000
10/30/24	11:30p	48.9	49.0	48.8	23	12.7	1.0	SSE	0.25	4.0	SSE	48.9	46.8	46.8	30.214	0.00	0.00	0.168	0.000
10/30/24	11:45p	48.4	48.9	48.3	24	13.2	2.0	ESE	0.50	4.0	SE	48.4	46.3	46.3	30.217	0.00	0.00	0.173	0.000
10/31/24	12:00a	48.2	48.4	48.1	24	13.0	2.0	ESE	0.50	4.0	ESE	48.2	46.1	46.1	30.209	0.00	0.00	0.175	0.000

NKSP 10/31/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/31/24	12:15a	47.9	48.2	47.8	23	11.8	2.0	SE	0.50	4.0	SE	47.9	45.8	45.8	30.205	0.00	0.00	0.178	0.000
10/31/24	12:30a	48.5	48.6	47.8	21	10.3	1.0	SE	0.25	3.0	SE	48.5	46.3	46.3	30.210	0.00	0.00	0.172	0.000
10/31/24	12:45a	48.3	48.5	48.1	24	13.1	2.0	SE	0.50	3.0	SE	48.3	46.2	46.2	30.207	0.00	0.00	0.174	0.000
10/31/24	1:00a	47.6	48.3	47.6	25	13.5	3.0	ESE	0.75	4.0	ESE	47.0	45.6	45.0	30.203	0.00	0.00	0.181	0.000
10/31/24	1:15a	47.1	47.6	47.1	26	13.9	3.0	ESE	0.75	6.0	ESE	46.4	45.1	44.4	30.200	0.00	0.00	0.186	0.000
10/31/24	1:30a	47.4	47.4	47.1	26	14.2	3.0	ESE	0.75	4.0	ESE	46.7	45.4	44.7	30.204	0.00	0.00	0.183	0.000
10/31/24	1:45a	47.6	47.7	47.4	25	13.5	2.0	ESE	0.50	4.0	ESE	47.6	45.6	45.6	30.203	0.00	0.00	0.181	0.000
10/31/24	2:00a	47.4	47.7	47.4	24	12.4	2.0	ESE	0.50	4.0	ESE	47.4	45.4	45.4	30.203	0.00	0.00	0.183	0.000
10/31/24	2:15a	46.5	47.4	46.5	24	11.6	2.0	ESE	0.50	4.0	SE	46.5	44.5	44.5	30.202	0.00	0.00	0.193	0.000
10/31/24	2:30a	46.3	46.5	46.3	25	12.3	3.0	ESE	0.75	6.0	ESE	45.5	44.4	43.6	30.202	0.00	0.00	0.195	0.000
10/31/24	2:45a	45.8	46.4	45.8	25	11.9	2.0	ESE	0.50	4.0	ESE	45.8	43.9	43.9	30.202	0.00	0.00	0.200	0.000
10/31/24	3:00a	45.4	45.9	45.4	26	12.5	1.0	ESE	0.25	3.0	ESE	45.4	43.5	43.5	30.205	0.00	0.00	0.204	0.000
10/31/24	3:15a	44.9	45.4	44.9	26	12.0	0.0	ESE	0.00	3.0	ESE	44.9	43.0	43.0	30.203	0.00	0.00	0.209	0.000
10/31/24	3:30a	44.5	44.9	44.5	26	11.7	2.0	ESE	0.50	6.0	ESE	44.5	42.6	42.6	30.200	0.00	0.00	0.214	0.000
10/31/24	3:45a	43.8	44.5	43.8	25	10.2	1.0	SE	0.25	4.0	ESE	43.8	41.9	41.9	30.193	0.00	0.00	0.221	0.000
10/31/24	4:00a	44.0	44.1	43.7	26	11.3	2.0	ESE	0.50	6.0	ESE	44.0	42.1	42.1	30.189	0.00	0.00	0.219	0.000
10/31/24	4:15a	44.3	44.3	43.9	26	11.5	3.0	ESE	0.75	7.0	ESE	43.2	42.4	41.3	30.185	0.00	0.00	0.216	0.000
10/31/24	4:30a	44.0	44.4	44.0	28	12.9	3.0	ESE	0.75	4.0	ESE	42.9	42.2	41.1	30.181	0.00	0.00	0.219	0.000
10/31/24	4:45a	43.6	44.1	43.6	28	12.6	1.0	ESE	0.25	3.0	ESE	43.6	41.8	41.8	30.180	0.00	0.00	0.223	0.000
10/31/24	5:00a	43.4	43.6	43.3	27	11.6	0.0	ESE	0.00	4.0	ESE	43.4	41.6	41.6	30.182	0.00	0.00	0.225	0.000
10/31/24	5:15a	43.1	43.3	42.9	28	12.2	2.0	ESE	0.50	4.0	ESE	43.1	41.4	41.4	30.181	0.00	0.00	0.228	0.000
10/31/24	5:30a	43.3	43.3	43.0	29	13.1	1.0	ESE	0.25	3.0	ESE	43.3	41.6	41.6	30.184	0.00	0.00	0.226	0.000
10/31/24	5:45a	43.2	43.6	43.2	28	12.2	0.0	ESE	0.00	2.0	ESE	43.2	41.5	41.5	30.187	0.00	0.00	0.227	0.000
10/31/24	6:00a	42.9	43.3	42.8	28	12.0	0.0	ESE	0.00	1.0	ESE	42.9	41.2	41.2	30.189	0.00	0.00	0.230	0.000
10/31/24	6:15a	42.8	43.0	42.8	27	11.1	0.0	ESE	0.00	1.0	ESE	42.8	41.0	41.0	30.198	0.00	0.00	0.231	0.000
10/31/24	6:30a	42.0	42.8	42.0	26	9.5	0.0	ESE	0.00	1.0	ESE	42.0	40.2	40.2	30.198	0.00	0.00	0.240	0.000
10/31/24	6:45a	41.6	42.0	41.5	28	10.9	0.0	---	0.00	0.0	---	41.6	39.9	39.9	30.197	0.00	0.00	0.244	0.000
10/31/24	7:00a	41.5	41.6	41.5	28	10.8	0.0	ESE	0.00	1.0	ESE	41.5	39.8	39.8	30.199	0.00	0.00	0.245	0.000
10/31/24	7:15a	41.5	41.6	41.4	29	11.6	0.0	SSW	0.00	1.0	SSW	41.5	39.8	39.8	30.205	0.00	0.00	0.245	0.000
10/31/24	7:30a	41.5	41.6	41.5	28	10.8	0.0	SSW	0.00	2.0	SSW	41.5	39.8	39.8	30.207	0.00	0.00	0.245	0.000
10/31/24	7:45a	41.5	41.6	41.3	29	11.6	0.0	SSW	0.00	1.0	SSW	41.5	39.8	39.8	30.213	0.00	0.00	0.245	0.000
10/31/24	8:00a	42.7	42.7	41.4	29	12.6	0.0	SSW	0.00	1.0	SSW	42.7	41.0	41.0	30.214	0.00	0.00	0.232	0.000
10/31/24	8:15a	43.9	43.9	42.7	27	12.0	0.0	S	0.00	2.0	S	43.9	42.1	42.1	30.223	0.00	0.00	0.220	0.000
10/31/24	8:30a	45.2	45.2	44.0	26	12.3	0.0	S	0.00	2.0	S	45.2	43.3	43.3	30.221	0.00	0.00	0.206	0.000
10/31/24	8:45a	45.3	45.4	45.1	27	13.2	1.0	SE	0.25	3.0	SE	45.3	43.5	43.5	30.219	0.00	0.00	0.205	0.000
10/31/24	9:00a	46.8	46.8	45.3	26	13.7	1.0	SE	0.25	3.0	SE	46.8	44.9	44.9	30.223	0.00	0.00	0.190	0.000
10/31/24	9:15a	49.0	49.0	46.8	22	11.7	0.0	SSE	0.00	5.0	S	49.0	46.8	46.8	30.230	0.00	0.00	0.167	0.000
10/31/24	9:30a	49.7	49.7	49.0	18	7.8	1.0	SSW	0.25	4.0	SSW	49.7	47.3	47.3	30.231	0.00	0.00	0.159	0.000
10/31/24	9:45a	51.6	51.6	49.7	17	8.1	0.0	SE	0.00	3.0	SE	51.6	48.8	48.8	30.229	0.00	0.00	0.140	0.000
10/31/24	10:00a	52.6	52.6	51.6	14	4.7	2.0	SE	0.50	5.0	SE	52.6	49.4	49.4	30.225	0.00	0.00	0.129	0.000
10/31/24	10:15a	54.7	54.7	52.5	10	-0.9	2.0	SE	0.50	7.0	SE	54.7	51.0	51.0	30.219	0.00	0.00	0.107	0.000
10/31/24	10:30a	57.2	57.2	54.7	3	-23.3	3.0	SE	0.75	8.0	SSW	57.2	52.1	52.1	30.219	0.00	0.00	0.081	0.000
10/31/24	10:45a	58.0	58.1	57.2	2	-30.3	2.0	SSW	0.50	7.0	S	58.0	52.6	52.6	30.220	0.00	0.00	0.073	0.000
10/31/24	11:00a	59.4	59.4	58.0	1	-41.7	1.0	ESE	0.25	5.0	S	59.4	53.6	53.6	30.221	0.00	0.00	0.058	0.000
10/31/24	11:15a	60.2	60.3	59.4	0	---	2.0	ESE	0.50	7.0	SE	60.2	54.2	54.2	30.216	0.00	0.00	0.050	0.000
10/31/24	11:30a	61.6	61.6	60.2	0	---	1.0	ESE	0.25	4.0	ESE	61.6	55.3	55.3	30.212	0.00	0.00	0.035	0.000
10/31/24	11:45a	62.9	62.9	61.7	0	---	2.0	W	0.50	6.0	W	62.9	56.3	56.3	30.211	0.00	0.00	0.022	0.000
10/31/24	12:00p	64.0	64.0	62.9	0	---	4.0	SW	1.00	11.0	WSW	64.0	57.3	57.3	30.206	0.00	0.00	0.010	0.000
10/31/24	12:15p	64.2	64.2	63.7	0	---	5.0	W	1.25	11.0	WSW	64.2	57.5	57.5	30.202	0.00	0.00	0.008	0.000
10/31/24	12:30p	65.7	65.7	64.1	0	---	4.0	WSW	1.00	10.0	WSW	65.7	58.7	58.7	30.194	0.00	0.00	0.000	0.007

NKSP 10/31/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/31/24	12:45p	66.2	66.2	65.6	0	---	5.0	WSW	1.25	10.0	SW	66.2	59.2	59.2	30.185	0.00	0.00	0.000	0.012
10/31/24	1:00p	66.9	66.9	66.2	0	---	5.0	WSW	1.25	10.0	WSW	66.9	59.8	59.8	30.179	0.00	0.00	0.000	0.020
10/31/24	1:15p	67.3	67.3	66.8	0	---	5.0	W	1.25	11.0	WSW	67.3	60.2	60.2	30.171	0.00	0.00	0.000	0.024
10/31/24	1:30p	68.7	68.7	67.3	0	---	5.0	WSW	1.25	10.0	SW	68.7	61.9	61.9	30.162	0.00	0.00	0.000	0.039
10/31/24	1:45p	68.7	69.2	68.6	0	---	5.0	W	1.25	10.0	W	68.7	61.9	61.9	30.156	0.00	0.00	0.000	0.039
10/31/24	2:00p	68.7	69.0	68.5	0	---	5.0	WSW	1.25	12.0	WSW	68.7	61.9	61.9	30.148	0.00	0.00	0.000	0.039
10/31/24	2:15p	69.4	69.5	68.7	0	---	3.0	WSW	0.75	11.0	WSW	69.4	63.0	63.0	30.139	0.00	0.00	0.000	0.046
10/31/24	2:30p	69.1	69.8	69.1	0	---	5.0	W	1.25	9.0	W	69.1	62.5	62.5	30.136	0.00	0.00	0.000	0.043
10/31/24	2:45p	69.9	70.0	69.1	0	---	5.0	WSW	1.25	12.0	WSW	69.9	63.8	63.8	30.130	0.00	0.00	0.000	0.051
10/31/24	3:00p	70.0	70.1	69.9	0	---	7.0	WSW	1.75	13.0	SSW	70.0	63.9	63.9	30.130	0.00	0.00	0.000	0.052
10/31/24	3:15p	69.7	70.1	69.7	0	---	5.0	W	1.25	13.0	WNW	69.7	63.4	63.4	30.127	0.00	0.00	0.000	0.049
10/31/24	3:30p	69.8	69.8	69.4	0	---	5.0	WNW	1.25	12.0	W	69.8	63.6	63.6	30.125	0.00	0.00	0.000	0.050
10/31/24	3:45p	69.7	69.9	69.6	0	---	6.0	WNW	1.50	14.0	WNW	69.7	63.4	63.4	30.121	0.00	0.00	0.000	0.049
10/31/24	4:00p	69.7	69.9	69.6	0	---	5.0	NW	1.25	11.0	WNW	69.7	63.4	63.4	30.123	0.00	0.00	0.000	0.049
10/31/24	4:15p	70.1	70.1	69.7	0	---	6.0	WNW	1.50	12.0	NW	70.1	64.0	64.0	30.120	0.00	0.00	0.000	0.053
10/31/24	4:30p	69.8	70.3	69.8	0	---	7.0	NW	1.75	12.0	NW	69.8	63.6	63.6	30.121	0.00	0.00	0.000	0.050
10/31/24	4:45p	69.2	69.9	69.2	0	---	8.0	NW	2.00	12.0	NW	68.5	62.7	62.0	30.119	0.00	0.00	0.000	0.044
10/31/24	5:00p	69.1	69.3	69.1	0	---	6.0	NW	1.50	11.0	NNW	69.1	62.5	62.5	30.119	0.00	0.00	0.000	0.043
10/31/24	5:15p	68.6	69.1	68.6	0	---	6.0	NNW	1.50	11.0	N	68.6	61.8	61.8	30.121	0.00	0.00	0.000	0.037
10/31/24	5:30p	67.8	68.6	67.8	0	---	6.0	NW	1.50	12.0	NW	67.8	60.6	60.6	30.118	0.00	0.00	0.000	0.029
10/31/24	5:45p	66.8	67.8	66.8	0	---	7.0	NW	1.75	13.0	WNW	66.8	59.7	59.7	30.123	0.00	0.00	0.000	0.019
10/31/24	6:00p	65.5	66.8	65.5	0	---	8.0	NW	2.00	14.0	NNW	64.9	58.5	57.9	30.121	0.00	0.00	0.000	0.005
10/31/24	6:15p	64.3	65.5	64.3	0	---	8.0	NW	2.00	15.0	NW	63.6	57.5	56.8	30.125	0.00	0.00	0.007	0.000
10/31/24	6:30p	63.4	64.3	63.4	0	---	6.0	NW	1.50	12.0	NW	63.4	56.8	56.8	30.129	0.00	0.00	0.017	0.000
10/31/24	6:45p	62.5	63.4	62.5	0	---	5.0	NW	1.25	9.0	WNW	62.5	56.0	56.0	30.136	0.00	0.00	0.026	0.000
10/31/24	7:00p	61.3	62.5	61.3	2	-28.1	4.0	NW	1.00	8.0	WNW	61.3	55.2	55.2	30.143	0.06	0.00	0.039	0.000
10/31/24	7:15p	60.4	61.3	60.4	5	-11.0	5.0	NW	1.25	9.0	WNW	60.4	54.7	54.7	30.147	0.00	0.00	0.048	0.000
10/31/24	7:30p	59.7	60.5	59.7	8	-1.8	5.0	NW	1.25	9.0	WNW	59.6	54.7	54.6	30.149	0.00	0.00	0.055	0.000
10/31/24	7:45p	58.9	59.7	58.9	11	4.4	5.0	NW	1.25	10.0	NW	58.7	54.3	54.1	30.152	0.00	0.00	0.064	0.000
10/31/24	8:00p	58.1	58.9	58.1	14	9.1	3.0	NW	0.75	9.0	NW	58.1	53.7	53.7	30.151	0.00	0.00	0.072	0.000
10/31/24	8:15p	57.5	58.1	57.5	15	10.1	3.0	NW	0.75	7.0	NW	57.5	53.2	53.2	30.155	0.00	0.00	0.078	0.000
10/31/24	8:30p	56.9	57.5	56.9	17	12.5	2.0	NW	0.50	5.0	NW	56.9	52.8	52.8	30.159	0.00	0.00	0.084	0.000
10/31/24	8:45p	56.5	56.9	56.4	17	12.1	1.0	WNW	0.25	4.0	NW	56.5	52.5	52.5	30.161	0.00	0.00	0.089	0.000
10/31/24	9:00p	55.8	56.5	55.8	17	11.6	1.0	WNW	0.25	4.0	NW	55.8	51.9	51.9	30.165	0.00	0.00	0.096	0.000
10/31/24	9:15p	55.5	55.8	55.5	17	11.3	0.0	WNW	0.00	2.0	WNW	55.5	51.7	51.7	30.165	0.00	0.00	0.099	0.000
10/31/24	9:30p	55.0	55.5	55.0	18	12.2	0.0	---	0.00	0.0	---	55.0	51.4	51.4	30.171	0.00	0.00	0.104	0.000
10/31/24	9:45p	54.8	55.0	54.8	18	12.0	0.0	---	0.00	0.0	---	54.8	51.2	51.2	30.175	0.00	0.00	0.106	0.000
10/31/24	10:00p	54.4	54.9	54.4	18	11.7	0.0	SSW	0.00	1.0	WNW	54.4	50.9	50.9	30.181	0.00	0.00	0.110	0.000
10/31/24	10:15p	53.2	54.4	53.2	20	13.1	0.0	SSW	0.00	2.0	SSW	53.2	50.1	50.1	30.185	0.00	0.00	0.123	0.000
10/31/24	10:30p	53.1	53.3	53.1	19	11.9	0.0	SSW	0.00	2.0	SSW	53.1	49.9	49.9	30.183	0.00	0.00	0.124	0.000
10/31/24	10:45p	52.5	53.1	52.5	20	12.5	0.0	SSE	0.00	4.0	SE	52.5	49.6	49.6	30.188	0.00	0.00	0.130	0.000
10/31/24	11:00p	51.7	52.5	51.7	22	14.0	0.0	SE	0.00	4.0	SE	51.7	49.0	49.0	30.185	0.00	0.00	0.139	0.000
10/31/24	11:15p	50.2	51.7	50.2	23	13.8	1.0	SW	0.25	4.0	S	50.2	48.0	48.0	30.191	0.00	0.00	0.154	0.000
10/31/24	11:30p	50.8	50.8	50.2	24	15.2	3.0	SW	0.75	5.0	SW	50.6	48.4	48.2	30.193	0.00	0.00	0.148	0.000
10/31/24	11:45p	51.1	51.1	50.7	22	13.5	2.0	WSW	0.50	4.0	SW	51.1	48.6	48.6	30.193	0.00	0.00	0.145	0.000
11/01/24	12:00a	51.8	51.8	51.1	20	11.9	2.0	WSW	0.50	5.0	WSW	51.8	49.0	49.0	30.193	0.00	0.00	0.138	0.000

NKSP 10/30/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/30/24	12:15a	73.4	37	45.5	71.9	7.28	.0743	351	1	100.0	15
10/30/24	12:30a	73.2	37	45.4	71.7	7.29	.0744	351	1	100.0	15
10/30/24	12:45a	73.2	37	45.4	71.7	7.29	.0744	351	1	100.0	15
10/30/24	1:00a	73.0	37	45.2	71.5	7.29	.0744	351	1	100.0	15
10/30/24	1:15a	73.1	37	45.3	71.6	7.29	.0744	352	1	100.0	15
10/30/24	1:30a	73.1	37	45.3	71.6	7.29	.0744	351	1	100.0	15
10/30/24	1:45a	73.3	37	45.4	71.8	7.28	.0744	351	1	100.0	15
10/30/24	2:00a	73.2	37	45.4	71.7	7.29	.0744	351	1	100.0	15
10/30/24	2:15a	73.3	37	45.4	71.8	7.28	.0744	351	1	100.0	15
10/30/24	2:30a	73.2	36	44.6	71.6	7.12	.0744	352	1	100.0	15
10/30/24	2:45a	73.1	36	44.5	71.5	7.13	.0744	351	1	100.0	15
10/30/24	3:00a	73.1	36	44.5	71.5	7.13	.0744	351	1	100.0	15
10/30/24	3:15a	72.9	36	44.4	71.2	7.13	.0745	351	1	100.0	15
10/30/24	3:30a	72.8	36	44.3	71.1	7.14	.0745	352	1	100.0	15
10/30/24	3:45a	72.7	36	44.2	70.9	7.14	.0745	351	1	100.0	15
10/30/24	4:00a	72.6	36	44.1	70.8	7.15	.0745	351	1	100.0	15
10/30/24	4:15a	72.6	36	44.1	70.8	7.15	.0745	351	1	100.0	15
10/30/24	4:30a	72.6	36	44.1	70.8	7.15	.0745	351	1	100.0	15
10/30/24	4:45a	72.6	36	44.1	70.8	7.15	.0745	352	1	100.0	15
10/30/24	5:00a	72.6	36	44.1	70.8	7.15	.0745	351	1	100.0	15
10/30/24	5:15a	72.5	36	44.0	70.6	7.15	.0746	351	1	100.0	15
10/30/24	5:30a	72.2	37	44.5	70.3	7.31	.0746	351	1	100.0	15
10/30/24	5:45a	72.1	37	44.4	70.1	7.31	.0746	352	1	100.0	15
10/30/24	6:00a	71.9	37	44.2	69.8	7.31	.0747	351	1	100.0	15
10/30/24	6:15a	71.6	37	43.9	69.4	7.32	.0748	351	1	100.0	15
10/30/24	6:30a	71.3	37	43.7	69.0	7.32	.0748	351	1	100.0	15
10/30/24	6:45a	71.2	37	43.6	68.8	7.33	.0748	351	1	100.0	15
10/30/24	7:00a	71.0	37	43.4	68.6	7.33	.0749	352	1	100.0	15
10/30/24	7:15a	70.9	37	43.3	68.4	7.33	.0749	351	1	100.0	15
10/30/24	7:30a	70.8	37	43.2	68.3	7.33	.0749	351	1	100.0	15
10/30/24	7:45a	70.6	37	43.1	68.0	7.34	.0750	351	1	100.0	15
10/30/24	8:00a	70.6	37	43.1	68.0	7.34	.0750	352	1	100.0	15
10/30/24	8:15a	70.6	37	43.1	68.0	7.34	.0750	351	1	100.0	15
10/30/24	8:30a	70.8	38	43.9	68.4	7.52	.0750	351	1	100.0	15
10/30/24	8:45a	71.1	38	44.2	68.8	7.51	.0749	351	1	100.0	15
10/30/24	9:00a	71.2	38	44.3	68.9	7.50	.0749	351	1	100.0	15
10/30/24	9:15a	71.4	38	44.5	69.2	7.49	.0749	352	1	100.0	15
10/30/24	9:30a	71.7	38	44.7	69.6	7.48	.0749	351	1	100.0	15
10/30/24	9:45a	71.9	37	44.2	69.8	7.31	.0748	351	1	100.0	15
10/30/24	10:00a	72.1	37	44.4	70.1	7.31	.0748	351	1	100.0	15
10/30/24	10:15a	72.4	37	44.6	70.6	7.30	.0747	352	1	100.0	15
10/30/24	10:30a	72.8	37	45.0	71.2	7.29	.0747	351	1	100.0	15
10/30/24	10:45a	73.1	37	45.3	71.6	7.29	.0746	351	1	100.0	15
10/30/24	11:00a	73.6	37	45.7	72.2	7.28	.0745	351	1	100.0	15
10/30/24	11:15a	74.0	37	46.1	72.6	7.27	.0745	352	1	100.0	15
10/30/24	11:30a	74.3	37	46.3	73.0	7.26	.0744	351	1	100.0	15
10/30/24	11:45a	74.7	37	46.7	73.4	7.26	.0743	351	1	100.0	15
10/30/24	12:00p	75.1	36	46.3	73.8	7.05	.0743	351	1	100.0	15
10/30/24	12:15p	75.5	36	46.7	74.2	7.04	.0742	351	1	100.0	15
10/30/24	12:30p	74.6	36	45.9	73.2	7.07	.0743	352	1	100.0	15

NKSP 10/30/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/30/24	12:45p	75.2	36	46.4	73.9	7.05	.0742	351	1	100.0	15
10/30/24	1:00p	74.7	36	46.0	73.3	7.06	.0743	351	1	100.0	15
10/30/24	1:15p	75.3	36	46.5	74.0	7.04	.0742	351	1	100.0	15
10/30/24	1:30p	75.0	37	47.0	73.7	7.25	.0742	352	1	100.0	15
10/30/24	1:45p	75.0	36	46.2	73.7	7.05	.0742	351	1	100.0	15
10/30/24	2:00p	75.4	36	46.6	74.1	7.04	.0741	351	1	100.0	15
10/30/24	2:15p	75.1	37	47.0	73.8	7.25	.0742	351	1	100.0	15
10/30/24	2:30p	75.1	36	46.3	73.8	7.05	.0742	352	1	100.0	15
10/30/24	2:45p	75.3	36	46.5	74.0	7.04	.0741	351	1	100.0	15
10/30/24	3:00p	74.8	37	46.8	73.5	7.25	.0742	351	1	100.0	15
10/30/24	3:15p	74.7	36	46.0	73.3	7.06	.0742	351	1	100.0	15
10/30/24	3:30p	75.1	35	45.6	73.7	6.95	.0741	351	1	100.0	15
10/30/24	3:45p	75.1	36	46.3	73.8	7.05	.0741	352	1	100.0	15
10/30/24	4:00p	74.9	37	46.9	73.6	7.25	.0741	351	1	100.0	15
10/30/24	4:15p	74.9	38	47.6	73.7	7.35	.0741	351	1	100.0	15
10/30/24	4:30p	75.3	36	46.5	74.0	7.04	.0741	351	1	100.0	15
10/30/24	4:45p	75.0	38	47.7	73.8	7.35	.0741	352	1	100.0	15
10/30/24	5:00p	74.8	38	47.5	73.6	7.36	.0741	351	1	100.0	15
10/30/24	5:15p	75.4	36	46.6	74.1	7.04	.0740	351	1	100.0	15
10/30/24	5:30p	75.6	38	48.2	74.4	7.34	.0740	351	1	100.0	15
10/30/24	5:45p	75.2	38	47.8	74.0	7.35	.0740	352	1	100.0	15
10/30/24	6:00p	75.2	38	47.8	74.0	7.35	.0740	351	1	100.0	15
10/30/24	6:15p	75.4	38	48.0	74.2	7.34	.0740	351	1	100.0	15
10/30/24	6:30p	74.7	38	47.4	73.4	7.36	.0741	351	1	100.0	15
10/30/24	6:45p	75.2	36	46.4	73.9	7.05	.0741	351	1	100.0	15
10/30/24	7:00p	75.0	38	47.7	73.8	7.35	.0741	352	1	100.0	15
10/30/24	7:15p	74.7	38	47.4	73.4	7.36	.0741	351	1	100.0	15
10/30/24	7:30p	74.9	39	48.3	73.7	7.55	.0741	351	1	100.0	15
10/30/24	7:45p	74.5	39	47.9	73.3	7.56	.0741	351	1	100.0	15
10/30/24	8:00p	74.8	39	48.2	73.6	7.55	.0741	352	1	100.0	15
10/30/24	8:15p	74.8	37	46.8	73.5	7.25	.0741	351	1	100.0	15
10/30/24	8:30p	74.5	39	47.9	73.3	7.56	.0741	351	1	100.0	15
10/30/24	8:45p	75.2	38	47.8	74.0	7.35	.0740	351	1	100.0	15
10/30/24	9:00p	74.3	39	47.7	73.1	7.56	.0742	351	1	100.0	15
10/30/24	9:15p	74.9	39	48.3	73.7	7.55	.0741	352	1	100.0	15
10/30/24	9:30p	75.2	38	47.8	74.0	7.35	.0741	351	1	100.0	15
10/30/24	9:45p	75.5	38	48.1	74.3	7.34	.0740	351	1	100.0	15
10/30/24	10:00p	75.6	38	48.2	74.4	7.34	.0740	351	1	100.0	15
10/30/24	10:15p	75.6	39	48.9	74.4	7.54	.0740	352	1	100.0	15
10/30/24	10:30p	75.7	39	49.0	74.5	7.54	.0740	351	1	100.0	15
10/30/24	10:45p	75.7	39	49.0	74.5	7.54	.0740	351	1	100.0	15
10/30/24	11:00p	75.7	38	48.3	74.5	7.34	.0740	351	1	100.0	15
10/30/24	11:15p	75.6	38	48.2	74.4	7.34	.0740	352	1	100.0	15
10/30/24	11:30p	75.4	38	48.0	74.2	7.34	.0741	351	1	100.0	15
10/30/24	11:45p	75.3	38	47.9	74.1	7.34	.0741	351	1	100.0	15
10/31/24	12:00a	75.0	38	47.7	73.8	7.35	.0741	351	1	100.0	15

NKSP 10/31/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/31/24	12:15a	74.7	38	47.4	73.4	7.36	.0742	351	1	100.0	15
10/31/24	12:30a	74.4	38	47.1	73.1	7.37	.0742	351	1	100.0	15
10/31/24	12:45a	74.1	37	46.2	72.7	7.27	.0743	351	1	100.0	15
10/31/24	1:00a	73.9	38	46.7	72.6	7.39	.0743	351	1	100.0	15
10/31/24	1:15a	73.7	38	46.5	72.3	7.40	.0743	352	1	100.0	15
10/31/24	1:30a	73.5	38	46.3	72.1	7.41	.0744	351	1	100.0	15
10/31/24	1:45a	73.4	38	46.2	72.0	7.41	.0744	351	1	100.0	15
10/31/24	2:00a	73.3	38	46.2	71.9	7.42	.0744	351	1	100.0	15
10/31/24	2:15a	73.2	38	46.1	71.8	7.42	.0744	351	1	100.0	15
10/31/24	2:30a	73.0	38	45.9	71.5	7.43	.0744	352	1	100.0	15
10/31/24	2:45a	72.8	38	45.7	71.2	7.44	.0745	351	1	100.0	15
10/31/24	3:00a	72.6	38	45.5	70.9	7.45	.0745	351	1	100.0	15
10/31/24	3:15a	72.4	37	44.6	70.6	7.30	.0746	351	1	100.0	15
10/31/24	3:30a	72.2	37	44.5	70.3	7.31	.0746	352	1	100.0	15
10/31/24	3:45a	72.1	37	44.4	70.1	7.31	.0746	351	1	100.0	15
10/31/24	4:00a	72.0	37	44.3	70.0	7.31	.0746	351	1	100.0	15
10/31/24	4:15a	71.9	37	44.2	69.8	7.31	.0746	351	1	100.0	15
10/31/24	4:30a	71.9	37	44.2	69.8	7.31	.0746	351	1	100.0	15
10/31/24	4:45a	71.6	37	43.9	69.4	7.32	.0746	352	1	100.0	15
10/31/24	5:00a	71.5	37	43.8	69.3	7.32	.0746	351	1	100.0	15
10/31/24	5:15a	71.5	37	43.8	69.3	7.32	.0746	351	1	100.0	15
10/31/24	5:30a	71.5	37	43.8	69.3	7.32	.0747	351	1	100.0	15
10/31/24	5:45a	71.6	38	44.6	69.5	7.49	.0746	352	1	100.0	15
10/31/24	6:00a	71.6	38	44.6	69.5	7.49	.0746	351	1	100.0	15
10/31/24	6:15a	71.6	37	43.9	69.4	7.32	.0747	351	1	100.0	15
10/31/24	6:30a	71.4	37	43.8	69.1	7.32	.0747	351	1	100.0	15
10/31/24	6:45a	71.3	37	43.7	69.0	7.32	.0747	351	1	100.0	15
10/31/24	7:00a	71.2	37	43.6	68.8	7.33	.0747	352	1	100.0	15
10/31/24	7:15a	71.1	37	43.5	68.7	7.33	.0748	351	1	100.0	15
10/31/24	7:30a	71.1	37	43.5	68.7	7.33	.0748	351	1	100.0	15
10/31/24	7:45a	70.9	37	43.3	68.4	7.33	.0748	351	1	100.0	15
10/31/24	8:00a	70.8	37	43.2	68.3	7.33	.0748	352	1	100.0	15
10/31/24	8:15a	70.8	37	43.2	68.3	7.33	.0749	351	1	100.0	15
10/31/24	8:30a	70.8	37	43.2	68.3	7.33	.0749	351	1	100.0	15
10/31/24	8:45a	71.1	37	43.5	68.7	7.33	.0748	351	1	100.0	15
10/31/24	9:00a	71.4	37	43.8	69.1	7.32	.0748	352	1	100.0	15
10/31/24	9:15a	71.7	37	44.0	69.5	7.32	.0747	351	1	100.0	15
10/31/24	9:30a	71.9	37	44.2	69.8	7.31	.0747	351	1	100.0	15
10/31/24	9:45a	72.3	37	44.6	70.4	7.30	.0746	351	1	100.0	15
10/31/24	10:00a	72.5	37	44.7	70.7	7.30	.0746	352	1	100.0	15
10/31/24	10:15a	72.7	37	44.9	71.0	7.30	.0745	351	1	100.0	15
10/31/24	10:30a	73.2	37	45.4	71.7	7.29	.0745	351	1	100.0	15
10/31/24	10:45a	73.6	37	45.7	72.2	7.28	.0744	351	1	100.0	15
10/31/24	11:00a	73.9	36	45.3	72.4	7.09	.0744	351	1	100.0	15
10/31/24	11:15a	74.3	36	45.6	72.9	7.08	.0743	352	1	100.0	15
10/31/24	11:30a	74.8	36	46.1	73.4	7.06	.0742	351	1	100.0	15
10/31/24	11:45a	75.2	36	46.4	73.9	7.05	.0741	351	1	100.0	15
10/31/24	12:00p	75.6	36	46.8	74.3	7.04	.0741	352	1	100.0	15
10/31/24	12:15p	76.0	35	46.4	74.6	6.93	.0740	350	1	100.0	15
10/31/24	12:30p	75.8	34	45.4	74.3	6.73	.0740	352	1	100.0	15

NKSP 10/31/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/31/24	12:45p	76.1	35	46.5	74.7	6.93	.0739	351	1	100.0	15
10/31/24	1:00p	76.4	33	45.2	74.9	6.55	.0739	351	1	100.0	15
10/31/24	1:15p	76.4	34	45.9	74.9	6.72	.0739	351	1	100.0	15
10/31/24	1:30p	76.2	34	45.8	74.7	6.73	.0739	352	1	100.0	15
10/31/24	1:45p	76.5	33	45.2	74.9	6.55	.0738	351	1	100.0	15
10/31/24	2:00p	76.3	34	45.9	74.8	6.72	.0738	351	1	100.0	15
10/31/24	2:15p	76.1	33	44.9	74.6	6.55	.0739	351	1	100.0	15
10/31/24	2:30p	76.0	32	44.0	74.4	6.43	.0739	352	1	100.0	15
10/31/24	2:45p	75.8	33	44.6	74.3	6.55	.0739	351	1	100.0	15
10/31/24	3:00p	75.5	32	43.6	73.9	6.44	.0740	351	1	100.0	15
10/31/24	3:15p	75.4	32	43.5	73.8	6.44	.0740	351	1	100.0	15
10/31/24	3:30p	75.8	32	43.8	74.2	6.43	.0739	351	1	100.0	15
10/31/24	3:45p	75.5	32	43.6	73.9	6.44	.0739	352	1	100.0	15
10/31/24	4:00p	75.4	33	44.3	73.9	6.55	.0739	351	1	100.0	15
10/31/24	4:15p	75.7	31	42.9	74.0	6.24	.0739	351	1	100.0	15
10/31/24	4:30p	75.5	33	44.4	74.0	6.55	.0739	351	1	100.0	15
10/31/24	4:45p	75.4	33	44.3	73.9	6.55	.0739	352	1	100.0	15
10/31/24	5:00p	75.7	32	43.7	74.1	6.44	.0739	351	1	100.0	15
10/31/24	5:15p	75.7	34	45.3	74.2	6.74	.0739	351	1	100.0	15
10/31/24	5:30p	75.3	34	45.0	73.8	6.74	.0739	351	1	100.0	15
10/31/24	5:45p	75.8	34	45.4	74.3	6.73	.0739	352	1	100.0	15
10/31/24	6:00p	75.4	34	45.1	73.9	6.74	.0739	351	1	100.0	15
10/31/24	6:15p	75.6	33	44.5	74.1	6.55	.0739	351	1	100.0	15
10/31/24	6:30p	75.3	35	45.7	73.9	6.94	.0739	351	1	100.0	15
10/31/24	6:45p	75.5	35	45.9	74.1	6.94	.0739	352	1	100.0	15
10/31/24	7:00p	75.6	36	46.8	74.3	7.04	.0739	351	1	100.0	15
10/31/24	7:15p	75.8	34	45.4	74.3	6.73	.0739	351	1	100.0	15
10/31/24	7:30p	75.1	36	46.3	73.8	7.05	.0740	351	1	100.0	15
10/31/24	7:45p	75.7	36	46.8	74.4	7.04	.0739	351	1	100.0	15
10/31/24	8:00p	75.9	35	46.3	74.5	6.93	.0739	352	1	100.0	15
10/31/24	8:15p	75.1	37	47.0	73.8	7.25	.0740	351	1	100.0	15
10/31/24	8:30p	75.4	37	47.3	74.1	7.24	.0739	351	1	100.0	15
10/31/24	8:45p	75.8	37	47.7	74.5	7.23	.0739	351	1	100.0	15
10/31/24	9:00p	75.9	37	47.8	74.6	7.23	.0739	352	1	100.0	15
10/31/24	9:15p	74.9	38	47.6	73.7	7.35	.0740	351	1	100.0	15
10/31/24	9:30p	75.1	39	48.4	73.9	7.55	.0740	351	1	100.0	15
10/31/24	9:45p	75.5	39	48.8	74.3	7.54	.0739	351	1	100.0	15
10/31/24	10:00p	75.7	38	48.3	74.5	7.34	.0739	351	1	100.0	15
10/31/24	10:15p	75.8	38	48.4	74.6	7.33	.0739	352	1	100.0	15
10/31/24	10:30p	75.8	38	48.4	74.6	7.33	.0739	351	1	100.0	15
10/31/24	10:45p	75.9	38	48.5	74.7	7.33	.0739	351	1	100.0	15
10/31/24	11:00p	75.7	38	48.3	74.5	7.34	.0739	352	1	100.0	15
10/31/24	11:15p	75.4	38	48.0	74.2	7.34	.0740	351	1	100.0	15
10/31/24	11:30p	75.2	38	47.8	74.0	7.35	.0740	351	1	100.0	15
10/31/24	11:45p	75.0	38	47.7	73.8	7.35	.0741	351	1	100.0	15
11/01/24	12:00a	74.7	38	47.4	73.4	7.36	.0741	351	1	100.0	15

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N KSP Housing Unit: A 1 Temp. Reading Location: A-Side
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10/11/24	0300	70	S. Hodson
	0600	71	E. Andrade
	0900	72	E. Andrade
	1200	72	E. Andrade
	1500	72	MANNING
	1800	72	MANNING
	2100	72	MANNING
	2400	70	D Hu

Wednesday

Date	Time	Temp.	Name (Print)
10-2-24	0300	69	D Hu
	0600	70	S.SANCHEZ
	0900	72	S.SANCHEZ
	1200	74	S.SANCHEZ
	1500	75	D. Castrejon
	1800	75	D. Castrejon
	2100	75	D. Castrejon
	2400	73	D. Hu

Thursday

Date	Time	Temp.	Name (Print)
10-3-24	0300	71	D. Hu
	0600	72	E. Andrade
	0900	73	E. Andrade
	1200	74	E. Andrade
	1500	75	D Castrejon
	1800	75	D. Castrejon
	2100	75	D. Castrejon
	2400	74	D. Hu

Friday

Date	Time	Temp.	Name (Print)
10-4-24	0300	72	D. Hu
	0600	74	[illegible]
	0900	74	[illegible]
	1200	74	[illegible]
	1500	74	E MENDEZ
	1800	74	E MENDEZ
	2100	76	E. MENDEZ
	2400	72	G Rios

Saturday

Date	Time	Temp.	Name (Print)
10-5-24	0300	70	G Rios
	0600	70	M Pompa
	0900	70	M Pompa
	1200	70	M. Pompa
	1500	72	E Mendez
	1800	72	E Mendez
	2100	72	E Mendez
	2400	70	G Rios

Sunday

Date	Time	Temp.	Name (Print)
10-6-24	0300	70	G. Rios
	0600	70	M. Pompa
	0900	70	M Pompa
	1200	70	M. Pompa
	1500	70	R. Knight
	1800	72	R. Knight
	2100	72	R. Knight
	2400	72	G. Rios

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: A1 Temp. Reading Location: B-Side
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10/1/24	0300	70	S. Hodson
	0600	71	E. Andrade
	0900	72	E. Andrade
	1200	73	E. Andrade
	1500	72	MANNING
	1800	72	MANNING
	2100	73	MANNING
	2400	70	D Hu

Wednesday

Date	Time	Temp.	Name (Print)
10-2-23	0300	69	D. Hill
	0600	70	S. SANCHEZ
	0900	72	S. SANCHEZ
	1200	74	S. SANCHEZ
	1500	75	D. Castrejon
	1800	75	D. Castrejon
	2100	75	D. Castrejon
	2400	73	D. Hu

Thursday

Date	Time	Temp.	Name (Print)
10-3-24	0300	71	D. Hu
	0600	72	E. Andrade
	0900	73	E. Andrade
	1200	74	E. Andrade
	1500	75	D. Castrejon
	1800	75	D. Castrejon
	2100	75	D. Castrejon
	2400	74	D Hu

Friday

Date	Time	Temp.	Name (Print)
10-4-24	0300	72	D. Hu
	0600	74	[illegible]
	0900	74	[illegible]
	1200	74	[illegible]
	1500	74	E MENDEZ
	1800	74	E MENDEZ
	2100	76	E MENDEZ
	2400	72	G Rios

Saturday

Date	Time	Temp.	Name (Print)
10-5-24	0300	70	G Rios
	0600	70	M. Lompa
	0900	70	M. Lompa
	1200	70	M. Lompa
	1500	72	E MENDEZ
	1800	72	E MENDEZ
	2100	72	E. MENDEZ
	2400	70	G Rios

Sunday

Date	Time	Temp.	Name (Print)
10-6-24	0300	70	G Rios
	0600	70	M. Lompa
	0900	70	M. Lompa
	1200	70	M. Lompa
	1500	76	R. Wright
	1800	72	R. Wright
	2100	72	R. Wright
	2400	72	G. Rios

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB-2 Temp. Reading Location: 2ND TIER A-SECTION
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9/30	0300	72	Z. Green
	0600	74	S. Ball
	0900	76	S. Ball
	1200	78	S. Ball
	1500	79	O Rubio
	1800	80	O Rubio
	2100	77	O Rubio
	2400	75	Z. Green

Tuesday

Date	Time	Temp.	Name (Print)
10/1	0300	75	Z. Green
	0600	75	J. MARTINEZ
	0900	75	J. MARTINEZ
	1200	75	J. MARTINEZ
	1500	79	O Rubio
	1800	81	O Rubio
	2100	79	O Rubio
	2400	76	Z. Green

Wednesday

Date	Time	Temp.	Name (Print)
10/2	0300	75	Z. Green
	0600	72.	Z. GARCIA
	0900	70	Z. Garcia
	1200	70	Z. Garcia
	1500	80	O Rubio
	1800	81	O Rubio
	2100	78	O Rubio
	2400	76	Gill

Thursday

Date	Time	Temp.	Name (Print)
10/3	0300	75	Gill
	0600	76	MURCHIE
	0900	77	MURCHIE
	1200	78	MURCHIE
	1500	80	Fosan
	1800	80	Fosan
	2100	80	Fosan
	2400	78	Gill

Friday

Date	Time	Temp.	Name (Print)
10/4	0300	75	Reyes
	0600	70	CHAN
	0900	70	CHAN
	1200	72	CHAN
	1500	74	R. Knight
	1800	76	R. Knight
	2100	80	R. Knight
	2400	79	Z. Green

Saturday

Date	Time	Temp.	Name (Print)
10/5	0300	78	Z. Green
	0600	78	CHAN
	0900	78	CHAN
	1200	78	CHAN
	1500	76	Jaramillo
	1800	76	Jaramillo
	2100	76	Jaramillo
	2400	78	C. Salas

Sunday

Date	Time	Temp.	Name (Print)
10/6	0300	78	C. Salas
	0600	71	C. Ramiscal
	0900	71	C. Ramiscal
	1200	72	C. Ramiscal
	1500	79	O Rubio
	1800	79	O Rubio
	2100	77	O Rubio
	2400	77	J. Blanco

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB-2 Temp. Reading Location: 2ND TIER B-SECTION
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9/30	0300	72	Z. Green
	0600	74	S. Hall
	0900	75	S. Hall
	1200	76	S. Hall
	1500	78	O Rubio
	1800	80	O Rubio
	2100	77	O Rubio
	2400	75	Z. Green

Tuesday

Date	Time	Temp.	Name (Print)
10/1	0300	75	Z. Green
	0600	75	J. MARTINEZ
	0900	75	J. MARTINEZ
	1200	75	J. MARTINEZ
	1500	79	O Rubio
	1800	80	O Rubio
	2100	78	O Rubio
	2400	76	Z. Green

Wednesday

Date	Time	Temp.	Name (Print)
10/2	0300	75	Z. Green
	0600	72	Z. GARCIA
	0900	70	Z. Garcia
	1200	70	Z. Garcia
	1500	79	O Rubio
	1800	80	O Rubio
	2100	77	O Rubio
	2400	75	Gill

Thursday

Date	Time	Temp.	Name (Print)
10/3	0300	75	Gill
	0600	76	Mulhall
	0900	77	Mulhall
	1200	78	Mulhall
	1500	80	Tijerina
	1800	80	Tijerina
	2100	80	Tijerina
	2400	78	Gill

Friday

Date	Time	Temp.	Name (Print)
10/4	0300	75	Reyes
	0600	70	CHAN
	0900	70	CHAN
	1200	72	CHAN
	1500	74	R. Knight
	1800	76	R. Knight
	2100	80	R. Knight
	2400	79	Z. Green

Saturday

Date	Time	Temp.	Name (Print)
10/5	0300	78	Z. Green
	0600	78	CHAN
	0900	78	CHAN
	1200	78	CHAN
	1500	78	Jaramillo
	1800	78	Jaramillo
	2100	76	Jaramillo
	2400	78	C. Solano

Sunday

Date	Time	Temp.	Name (Print)
10/6	0300	78	C. Solano
	0600	71	C. Kamiseal
	0900	77	C. Kamiseal
	1200	77	C. Kamiseal
	1500	79	O Rubio
	1800	78	O Rubio
	2100	78	O Rubio
	2400	77	S. Bennie

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB- A 3 Temp. Reading Location: 2ND TIER A-SECTION (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9-30-24	0300	68	G. Rios
	0600	68	Saldana
	0900	69	Saldana
	1200	70	Saldana
	1500	70	HINOJOSA
	1800	70	HINOJOSA
	2100	69	HINOJOSA
	2400	68	G. Rios

Tuesday

Date	Time	Temp.	Name (Print)
10-01-24	0300	68°	H. Franklin
	0600	70	CHAN
	0900	70	CHAN
	1200	72	CHAN
	1500	72	R. Borquez
	1800	72	R. Borquez
	2100	71	R. Borquez
	2400	68°	H. Franklin

Wednesday

Date	Time	Temp.	Name (Print)
10-02-24	0300	69°	LANE
	0600	69	Martinez
	0900	74	Martinez
	1200	74	Martinez
	1500	74	GRAYSON
	1800	74	GRAYSON
	2100	74	GRAYSON
	2400	71°	LANE

Thursday

Date	Time	Temp.	Name (Print)
10-03-24	0300	70°	LANE
	0600	70	Saldana
	0900	70	Saldana
	1200	71	Saldana
	1500	71	R. Knight
	1800	72	R. Knight
	2100	72	R. Knight
	2400	72°	LANE

Friday

Date	Time	Temp.	Name (Print)
10-04-24	0300	70°	LANE
	0600	70	Saldana
	0900	70	Saldana
	1200	72	Saldana
	1500	71	HINOJOSA
	1800	71	HINOJOSA
	2100	70	HINOJOSA
	2400	71°	LANE

Saturday

Date	Time	Temp.	Name (Print)
10-05-24	0300	70°	LANE
	0600	70	Saldana
	0900	70	Saldana
	1200	71	Saldana
	1500	74	HINOJOSA
	1800	74	HINOJOSA
	2100	72	HINOJOSA
	2400	70°	LANE

Sunday

Date	Time	Temp.	Name (Print)
10-06-24	0300	70°	LANE
	0600	70	Saldana
	0900	70	Saldana
	1200	71	Saldana
	1500	70	HINOJOSA
	1800	70	HINOJOSA
	2100	71	HINOJOSA
	2400	72°	LANE

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB-3 Temp. Reading Location: 2ND TIER B-SECTION
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9-30-24	0300	68	G. Rios
	0600	68	Saldana
	0900	69	Saldana
	1200	70	Saldana
	1500	69	HINOJOSA
	1800	69	HINOJOSA
	2100	68	HINOJOSA
	2400	68	G. Rios

Tuesday

Date	Time	Temp.	Name (Print)
10-1-24	0300	68	FRANKLIN
	0600	70	CHAN
	0900	70	CHAN
	1200	72	CHAN
	1500	72	R. Borquez
	1800	72	R. Borquez
	2100	71	R. Borquez
	2400	68°	M. Franklin

Wednesday

Date	Time	Temp.	Name (Print)
10-02-24	0300	69°	LANE
	0600	69	Martinez
	0900	70	Martinez
	1200	74	Martinez
	1500	74	GRAYSON
	1800	74	GRAYSON
	2100	74	GRAYSON
	2400	71°	LANE

Thursday

Date	Time	Temp.	Name (Print)
10-03-24	0300	70°	LANE
	0600	70	Saldana
	0900	70	Saldana
	1200	71	Saldana
	1500	71	R. Knight
	1800	72	R. Knight
	2100	72	R. Knight
	2400	72°	LANE

Friday

Date	Time	Temp.	Name (Print)
10-04-24	0300	70°	LANE
	0600	70	Saldana
	0900	70	Saldana
	1200	72	Saldana
	1500	72	HINOJOSA
	1800	72	HINOJOSA
	2100	71	HINOJOSA
	2400	71°	LANE

Saturday

Date	Time	Temp.	Name (Print)
10-05-24	0300	70°	LANE
	0600	70	Saldana
	0900	70	Saldana
	1200	71	Saldana
	1500	71	HINOJOSA
	1800	71	HINOJOSA
	2100	70	HINOJOSA
	2400	70°	LANE

Sunday

Date	Time	Temp.	Name (Print)
10-06-24	0300	70°	LANE
	0600	70	Saldana
	0900	70	Saldana
	1200	71	Saldana
	1500	71	HINOJOSA
	1800	71	HINOJOSA
	2100	71	HINOJOSA
	2400	72°	LANE

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: A4 Aside Temp. Reading Location: 1 Dayroom
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400	74	PRICE

Tuesday

Date	Time	Temp.	Name (Print)
10/1/24	0300	74	Price
	0600	74	O.Montoya
	0900	74	O.Montoya
	1200	76	O.Montoya
	1500	78	D.Batza
	1800	77	D.Batza
	2100	75	D.Batza
	2400	74	PRICE

Wednesday

Date	Time	Temp.	Name (Print)
10/2/24	0300	74	Price
	0600	74	O.Montoya
	0900	76	O.Montoya
	1200	78	O.Montoya
	1500	79	D.Batza
	1800	78	D.Batza
	2100	76	D.Batza
	2400	74	PRICE

Thursday

Date	Time	Temp.	Name (Print)
10/3/24	0300	74	PRICE
	0600	74	O.Montoya
	0900	76	O.Montoya
	1200	78	O.Montoya
	1500	75°	I. Gallardo
	1800	75°	I. Gallardo
	2100	75	I. Gallardo
	2400	76	PRICE

Friday

Date	Time	Temp.	Name (Print)
10/4/24	0300	76	PRICE
	0600	76	O.Montoya
	0900	76	O.Montoya
	1200	78	O.Montoya
	1500	78	O.Montoya
	1800	76	O.Montoya
	2100	76	O.Montoya
	2400	76	PRICE

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	76	PRICE
	0600	76	O.Montoya
	0900	76	O.Montoya
	1200	78	O.Montoya
	1500	76	GRAYSON
	1800	75	GRAYSON
	2100	75	GRAYSON
	2400	74°	M. Franklin

Sunday

Date	Time	Temp.	Name (Print)
10/6/24	0300	74°	M. Franklin
	0600	72	CHAN
	0900	72	CHAN
	1200	74	CHAN
	1500	74	Grayson
	1800	74	Grayson
	2100	74	Grayson
	2400	74°	M. Franklin

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: A4 Beside Temp. Reading Location: 1 Dayroom
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400	74	PRICE

Tuesday

Date	Time	Temp.	Name (Print)
10/1/24	0300	74	Price
	0600	74	O.Montoya
	0900	74	O.Montoya
	1200	76	O.Montoya
	1500	78	D. Baeza
	1800	77	D. Baeza
	2100	75	D. Baeza
	2400	74	PRICE

Wednesday

Date	Time	Temp.	Name (Print)
10/2/24	0300	74	Price
	0600	74	O.Montoya
	0900	76	O.Montoya
	1200	78	O.Montoya
	1500	79	D. Baeza
	1800	78	D. Baeza
	2100	76	D. Baeza
	2400	74	PRICE

Thursday

Date	Time	Temp.	Name (Print)
10/3/24	0300	74	PRICE
	0600	74	O.Montoya
	0900	76	O.Montoya
	1200	78	O.Montoya
	1500	75	E Gallardo
	1800	75	E Gallardo
	2100	75	E Gallardo
	2400	76	PRICE

Friday

Date	Time	Temp.	Name (Print)
10/4/24	0300	76	PRICE
	0600	76	O.Montoya
	0900	76	O.Montoya
	1200	78	O.Montoya
	1500	78	O.Montoya
	1800	76	O.Montoya
	2100	76	O.Montoya
	2400	76	PRICE

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	76	PRICE
	0600	76	O.Montoya
	0900	76	O.Montoya
	1200	78	O.Montoya
	1500	76	Grayson
	1800	75	Grayson
	2100	75	Grayson
	2400	74	M. Franklin

Sunday

Date	Time	Temp.	Name (Print)
10/6/24	0300	74	M. Franklin
	0600	72	CHAN
	0900	72	CHAN
	1200	74	CHAN
	1500	74	Grayson
	1800	74	Grayson
	2100	74	Grayson
	2400	74	M. Franklin

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB-5 Temp. Reading Location: 2ND TIER A-SECTION
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10-1-24	0300	74	D. Pinson
	0600	70	M. Pompa
	0900	70	M. Pompa
	1200	70	M. Pompa
	1500	75	GRAYSON
	1800	75	GRAYSON
	2100	75	GRAYSON
	2400	75	D. Pinson

Wednesday

Date	Time	Temp.	Name (Print)
10-2-24	0300	74	D. Pinson
	0600	74°	J. SCHULTZ
	0900	75°	J. SCHULTZ
	1200	77°	J. SCHULTZ
	1500	78	G. Gill
	1800	75	G. Gill
	2100	75	G. Gill
	2400	75	D. Pinson

Thursday

Date	Time	Temp.	Name (Print)
10-3-24	0300	74	D. Pinson
	0600	74°	J. SCHULTZ
	0900	76°	J. SCHULTZ
	1200	78°	J. SCHULTZ
	1500	78	Gill
	1800	77	Gill
	2100	77	Gill
	2400	75°	M. Franklin

Friday

Date	Time	Temp.	Name (Print)
10-4-24	0300	74°	M. Franklin
	0600	76°	J. SCHULTZ
	0900	78°	J. SCHULTZ
	1200	80°	J. SCHULTZ
	1500	80°	G. Rios
	1800	80°	G. Rios
	2100	80°	G. Rios
	2400	74	M. Franklin

Saturday

Date	Time	Temp.	Name (Print)
10-5-24	0300	74°	M. Franklin
	0600	74°	J. SCHULTZ
	0900	76°	J. SCHULTZ
	1200	79°	J. SCHULTZ
	1500	78	G. Rios
	1800	78	G. Rios
	2100	78	G. Rios
	2400	74	M. Franklin

Sunday

Date	Time	Temp.	Name (Print)
10-6-24	0300	73	M. Gonzalez
	0600	74°	J. SCHULTZ
	0900	76°	J. SCHULTZ
	1200	78°	J. SCHULTZ
	1500	80	G. Rios
	1800	80°	G. Rios
	2100	78°	G. Rios
	2400	78	RICE

Notes

10-2-24 UHT ACTIVATED @ 1100
10-3-24 UHT ACTIVATED @ 1104
11-5-24 UHT ACTIVATED @ 1149
11-6-24 UHT ACTIVATED @ 1155

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB-5 Temp. Reading Location: 2ND TIER B-SECTION (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10-1-24	0300	74	P. Pelson
	0600	70	M. Pompa
	0900	70	M. Pompa
	1200	70	M. Pompa
	1500	75	Grasson
	1800	75	Grasson
	2100	75	Grasson
	2400	75	P. Pelson

Wednesday

Date	Time	Temp.	Name (Print)
10-2-24	0300	74	P. Pelson
	0600	74°	J. Schultz
	0900	75°	J. Schultz
	1200	77°	J. Schultz
	1500	78	Gill
	1800	75	Gill
	2100	75	Gill
	2400	75	P. Pelson

Thursday

Date	Time	Temp.	Name (Print)
10-3-24	0300	74	P. Pelson
	0600	74°	J. Schultz
	0900	76°	J. Schultz
	1200	78°	J. Schultz
	1500	78	Gill
	1800	77	Gill
	2100	77	Gill
	2400	75°	M. Franklin

Friday

Date	Time	Temp.	Name (Print)
10.4.24	0300	74	M. Franklin
	0600	76°	J. Schultz
	0900	78°	J. Schultz
	1200	80°	J. Schultz
	1500	80°	G. Rios
	1800	80°	G. Rios
	2100	80°	G. Rios
	2400	74°	M. Franklin

Saturday

Date	Time	Temp.	Name (Print)
10.5.24	0300	74°	M. Franklin
	0600	74°	J. Schultz
	0900	76°	J. Schultz
	1200	79°	J. Schultz
	1500	78	G. Rios
	1800	78	G. Rios
	2100	78	G. Rios
	2400	74°	M. Franklin

Sunday

Date	Time	Temp.	Name (Print)
10.6.24	0300	73°	M. Gonzalez
	0600	74°	J. Schultz
	0900	76°	J. Schultz
	1200	78°	J. Schultz
	1500	80°	G. Rios
	1800	80°	G. Rios
	2100	78°	G. Rios
	2400	78	Price

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

Attachment 11

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B-1A Temp. Reading Location: Tier 2
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9-30-24	0300	76°	RMATA
	0600	75	C MURRAY
	0900	77	C MURRAY
	1200	78	C MURRAY
	1500	79	M. MODESTO
	1800	79	M. MODESTO
	2100	78	M. MODESTO
	2400	80	RMATA

Tuesday

Date	Time	Temp.	Name (Print)
10-01-24	0300	77°	RMATA
	0600	77	R Ramirez
	0900	77	R Ramirez
	1200	80	R Ramirez
	1500	79	M. MODESTO
	1800	78	M. MODESTO
	2100	77	M. MODESTO
	2400	77°	RMATA

Wednesday

Date	Time	Temp.	Name (Print)
10-2-24	0300	80	Mata
	0600	78	R Ramirez
	0900	78	R Ramirez
	1200	80	R Ramirez
	1500	80	M. MODESTO
	1800	80	M. MODESTO
	2100	79	M. MODESTO
	2400	78	MATA

Thursday

Date	Time	Temp.	Name (Print)
10-3-24	0300	78	Mata
	0600	77	R Ramirez
	0900	77	R Ramirez
	1200	78	R Ramirez
	1500	80	R. Cisneros
	1800	78	R. Cisneros
	2100	77	R. Cisneros
	2400	77	H. RAYA

Friday

Date	Time	Temp.	Name (Print)
10-4-24	0300	75	H. RAYA
	0600	77	R Ramirez
	0900	77	R Ramirez
	1200	80	R Ramirez
	1500	80	R. Cisneros
	1800	79	R. Cisneros
	2100	78	R. Cisneros
	2400	77	Rans

Saturday

Date	Time	Temp.	Name (Print)
10-5-24	0300	77	Ramos
	0600	77	Smoe
	0900	77	Smoe
	1200	77	Smoe
	1500	77	Lucamos
	1800	77	Lucamos
	2100	77	Lucamos
	2400	78	PRICE

Sunday

Date	Time	Temp.	Name (Print)
10-6-24	0300	78	PRICE
	0600	78	Smoe
	0900	78	Smoe
	1200	78	Smoe
	1500	77	CAMPOS
	1800	77	CAMPOS
	2100	77	CAMPOS
	2400	77	RAMOS

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B1-B Temp. Reading Location: Tier 2
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9-30-24	0300	780	R MATA
	0600	790	C-MURRAY
	0900	780	C MURRAY
	1200	780	C MURRAY
	1500	79	M- MODESTO
	1800	79	M. MODESTO
	2100	78	M. MODESTO
	2400	780	R MATA

Tuesday

Date	Time	Temp.	Name (Print)
10-01-24	0300	780	R MATA
	0600	78	R Ramirez
	0900	78	R Ramirez
	1200	80	R Ramirez
	1500	79	M MODESTO
	1800	78	M. MODESTO
	2100	77	M. MODESTO
	2400	79	R MATA

Wednesday

Date	Time	Temp.	Name (Print)
10-02-24	0300	77	R MATA
	0600	77	R Ramirez
	0900	79	R Ramirez
	1200	80	R Ramirez
	1500	80	M. MODESTO
	1800	80	M. MODESTO
	2100	79	M. MODESTO
	2400	77	Tayor

Thursday

Date	Time	Temp.	Name (Print)
10.3.24	0300	77	R Ramirez
	0600	78	Ramirez
	0900	78	R Ramirez
	1200	80	R Ramirez
	1500	80	R. Cisneros
	1800	78	R. Cisneros
	2100	77	R. Cisneros
	2400	77	Taylor

Friday

Date	Time	Temp.	Name (Print)
10-4-24	0300	75	H. RAMA
	0600	77	R Ramirez
	0900	77	R Ramirez
	1200	80	R Ramirez
	1500	80	R Cisneros
	1800	79	R. Cisneros
	2100	79	R. Cisneros
	2400	77	P. Tamas

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	77	P. Tamas
	0600	77	Smal
	0900	77	Smal
	1200	78	Smal
	1500	79	Cuampos
	1800	78	Cuampos
	2100	77	Cuampos
	2400	78	PRICE

Sunday

Date	Time	Temp.	Name (Print)
10.06.24	0300	78	PRICE
	0600	78	Smal
	0900	78	Smal
	1200	78	Smal
	1500	77	Cuampos
	1800	77	Cuampos
	2100	77	Cuampos
	2400	77	Palma

Notes

'STRIBUTION: Original: Institution Heat Plan Coordinator

Attachment 11

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITATION

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B2-A Temp. Reading Location: Tier 2
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10/1/24	0300	77	MEARNS
	0600	77	ORTIZ
	0900	77	ORTIZ
	1200	78	R ORTIZ
	1500	78	R. SALAZAR
	1800	79	R. SALAZAR
	2100	78	R. SALAZAR
	2400	77	DUNN

Wednesday

Date	Time	Temp.	Name (Print)
10/2/24	0300	77	DUNN
	0600	78	SMAL
	0900	78	SMAL
	1200	78	SMAL
	1500	79	R. SALAZAR
	1800	79	R. SALAZAR
	2100	78	R. SALAZAR
	2400	77	Earnest

Thursday

Date	Time	Temp.	Name (Print)
10/3/24	0300	76	Earnest
	0600	76	King
	0900	76	King
	1200	76	King
	1500	78	R. SALAZAR
	1800	79	R. SALAZAR
	2100	78	R. SALAZAR
	2400	77	Earnest

Friday

Date	Time	Temp.	Name (Print)
10/4/24	0300	76	Earnest
	0600	76	PRICE
	0900	76	PRICE
	1200	76	PRICE
	1500	76	PASUMBAL
	1800	76	PASUMBAL
	2100	75	PASUMBAL
	2400	75	Earnest

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	75	Earnest
	0600	75	H. [illegible]
	0900	75	H. [illegible]
	1200	75	H. [illegible]
	1500	78	PRICE
	1800	78	PRICE
	2100	78	PRICE
	2400	77	Earnest

Sunday

Date	Time	Temp.	Name (Print)
10/6/24	0300	76	Earnest
	0600	77	ORTIZ
	0900	77	ORTIZ
	1200	77	ORTIZ
	1500	78	R. SALAZAR
	1800	79	R. SALAZAR
	2100	78	R. SALAZAR
	2400	77	GAMBOA

Notes

	ACT	DEACT
10-3-24		2115

DISTRIBUTION: Original: Institution Heat Plan Coordinator

Attachment 11

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITATION

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B2-B Temp. Reading Location: Tier 2
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10/1/24	0300	77	ERNEST
	0600	77	ORTIZ
	0900	77	ORTIZ
	1200	77	ORTIZ
	1500	78	R-SALAZAR
	1800	79	R-SALAZAR
	2100	78	R-SALAZAR
	2400	77	DUNN

Wednesday

Date	Time	Temp.	Name (Print)
10/2/24	0300	78	DUNN
	0600	78	SMAL
	0900	78	SMAL
	1200	79	SMAL
	1500	79	R-SALAZAR
	1800	79	R-SALAZAR
	2100	78	R-SALAZAR
	2400	76	Earnest

Thursday

Date	Time	Temp.	Name (Print)
10/3/24	0300	75	Earnest
	0600	75	King
	0900	76	King
	1200	76	King
	1500	78	R-SALAZAR
	1800	79	R-SALAZAR
	2100	78	R-SALAZAR
	2400	77	Earnest

Friday

Date	Time	Temp.	Name (Print)
10/4/24	0300	76	Earnest
	0600	76	PRICE
	0900	76	PRICE
	1200	76	PRICE
	1500	76	PASUMBAL
	1800	76	PASUMBAL
	2100	75	PASUMBAL
	2400	75	Earnest

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	75	Earnest
	0600	75	Hernandez
	0900	75	Hernandez
	1200	76	Hernandez
	1500	78	PRICE
	1800	78	PRICE
	2100	78	PRICE
	2400	76	Earnest

Sunday

Date	Time	Temp.	Name (Print)
10/6/24	0300	76	Earnest
	0600	77	ORTIZ
	0900	76	ORTIZ
	1200	77	ORTIZ
	1500	78	R.SALAZAR
	1800	79	R.SALAZAR
	2100	78	R-SALAZAR
	2400	79	PAMBOA

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B3A Temp. Reading Location: Above T.V.
(e.g., 1st tier, 2nd tier, ~~3rd tier~~, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9-30-24	0300	72	P. Cerda
	0600	72	J. Hernandez
	0900	72	J. Hernandez
	1200	72	J. Hernandez
	1500	73	PASUMBAL
	1800	74	PASUMBAL
	2100	72	PASUMBAL
	2400	72	NAVADDETE

Tuesday

Date	Time	Temp.	Name (Print)
10/1/24	0300	72	NAVADDETE
	0600	72	VAZQUEZ
	0900	72	VAZQUEZ
	1200	72	VAZQUEZ
	1500	74	SOLORIO
	1800	76	SOLORIO
	2100	76	SOLORIO
	2400	75	CMURRAY

Wednesday

Date	Time	Temp.	Name (Print)
10/2/24	0300	72	CMURRAY
	0600	72	J. Hernandez
	0900	72	J. Hernandez
	1200	72	J. Hernandez
	1500	74	SOLORIO
	1800	76	SOLORIO
	2100	76	SOLORIO
	2400	74	P. Cerda

Thursday

Date	Time	Temp.	Name (Print)
10/3	0300	74	P. Cerda
	0600	74	RAMOS
	0900	74	RAMOS
	1200	74	RAMOS
	1500	76	SOLORIO
	1800	76	SOLORIO
	2100	76	SOLORIO
	2400	74	P. Cerda

Friday

Date	Time	Temp.	Name (Print)
10/4/24	0300	72	P. Cerda
	0600	72	King
	0900	74	King
	1200	74	King
	1500	74	SOLORIO
	1800	76	SOLORIO
	2100	76	SOLORIO
	2400	74	P. Cerda

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	74	P. Cerda
	0600	74	King
	0900	74	King
	1200	74	King
	1500	74	[illegible]
	1800	74	[illegible]
	2100	74	[illegible]
	2400	72	P. Cerda

Sunday

Date	Time	Temp.	Name (Print)
10/6/24	0300	72	P. Cerda
	0600	77	[illegible]
	0900	77	[illegible]
	1200	77	[illegible]
	1500	77	[illegible]
	1800	76	[illegible]
	2100	76	[illegible]
	2400	72	P. Cerda

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B 3 B Temp. Reading Location: Above T.V.
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9-30-24	0300	72	P. Cerda
	0600	72	J. Hernandez
	0900	72	J. Hernandez
	1200	72	J. Hernandez
	1500	73	P. Asumadal
	1800	74	P. Asumadal
	2100	72	P. Asumadal
	2400	72	Navarrete

Tuesday

Date	Time	Temp.	Name (Print)
10/1/24	0300	72	Navarrete
	0600	72	Vazquez
	0900	72	Vazquez
	1200	72	Vazquez
	1500	74	Solorio
	1800	76	Solorio
	2100	78	Solorio
	2400	76	C Murray

Wednesday

Date	Time	Temp.	Name (Print)
10/2/24	0300	72	C Murray
	0600	72	J. Hernandez
	0900	72	J. Hernandez
	1200	72	J. Hernandez
	1500	75	Solorio
	1800	78	Solorio
	2100	78	Solorio
	2400	74	P. Cerda

Thursday

Date	Time	Temp.	Name (Print)
10-3-24	0300	74	P. Cerda
	0600	74	Ramos
	0900	74	Ramos
	1200	74	Ramos
	1500	76	Solorio
	1800	78	Solorio
	2100	78	Solorio
	2400	74	P. Cerda

Friday

Date	Time	Temp.	Name (Print)
10-4-25	0300	72	P. Cerda
	0600	72	King
	0900	74	King
	1200	74	King
	1500	76	Solorio
	1800	78	Solorio
	2100	78	Solorio
	2400	74	P. Cerda

Saturday

Date	Time	Temp.	Name (Print)
10-5-25	0300	74	P. Cerda
	0600	74	King
	0900	74	King
	1200	74	King
	1500	74	Mejias
	1800	74	Mejias
	2100	74	Mejias
	2400	72	P. Cerda

Sunday

Date	Time	Temp.	Name (Print)
10-6-25	0300	72	P. Cerda
	0600	77	Gray
	0900	77	Gray
	1200	77	Gray
	1500	79	Gray
	1800	76	Gray
	2100	76	Gray
	2400	72	P. Cerda

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B4 A Temp. Reading Location: ABOVE TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9/30/24	0300	73	H. MODESTO
	0600	71	King
	0900	73	King
	1200	74	King
	1500	75	H. MARMOLEJO
	1800	74	H. MARMOLEJO
	2100	74	H. MARMOLEJO
	2400	73	H. MODESTO

Tuesday

Date	Time	Temp.	Name (Print)
10-1-24	0300	72	H. MODESTO
	0600	72	APEREZ
	0900	72	APEREZ
	1200	72	APEREZ
	1500	72	Pasumbal
	1800	72	Pasumbal
	2100	72	Pasumbal
	2400	71	H. MODESTO

Wednesday

Date	Time	Temp.	Name (Print)
10-2-24	0300	72	H. MODESTO
	0600	72	APEREZ
	0900	72	APEREZ
	1200	72	APEREZ
	1500	75	J. JORAMILLO
	1800	75	J. JORAMILLO
	2100	74	J. JORAMILLO
	2400	73	R. CISNEROS

Thursday

Date	Time	Temp.	Name (Print)
10-3-24	0300	72	R. CISNEROS
	0600	72	APEREZ
	0900	72	APEREZ
	1200	73	APEREZ
	1500	74	H. MARMOLEJO
	1800	74	H. MARMOLEJO
	2100	73	H. MARMOLEJO
	2400	73	CISNEROS

Friday

Date	Time	Temp.	Name (Print)
10-4-24	0300	73	CISNEROS
	0600	74	APEREZ
	0900	74	APEREZ
	1200	74	APEREZ
	1500	75	H. MARMOLEJO
	1800	74	H. MARMOLEJO
	2100	74	H. MARMOLEJO
	2400	74	R. CISNEROS

Saturday

Date	Time	Temp.	Name (Print)
10-5-24	0300	73	R. CISNEROS
	0600	74	APEREZ
	0900	74	APEREZ
	1200	75	APEREZ
	1500	75	H. MARMOLEJO
	1800	76	H. MARMOLEJO
	2100	74	H. MARMOLEJO
	2400	73	D. HILL

Sunday

Date	Time	Temp.	Name (Print)
10-6-24	0300	71	D. HILL
	0600	71	King
	0900	72	King
	1200	74	King
	1500	75	H. MARMOLEJO
	1800	74	H. MARMOLEJO
	2100	74	H. MARMOLEJO
	2400	74	[illegible]

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B4 B Temp. Reading Location: ABOVE TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9/30/24	0300	73	H. MODESTO
	0600	71	King
	0900	71	King
	1200	74	King
	1500	75	H. MARRAMUN
	1800	74	H. MARRAMUN
	2100	73	H. MARRAMUN
	2400	73	H. MODESTO

Tuesday

Date	Time	Temp.	Name (Print)
10-1-24	0300	72	H. MODESTO
	0600	72	APEREZ
	0900	72	APEREZ
	1200	72	APEREZ
	1500	73	Pasimbeal
	1800	73	Pasimbeal
	2100	72	Pasimbeal
	2400	71	H. MODESTO

Wednesday

Date	Time	Temp.	Name (Print)
10-2-24	0300	71	H. MODESTO
	0600	72	APEREZ
	0900	72	APEREZ
	1200	72	APEREZ
	1500	75	J. JORAMILLO
	1800	75	J. JORAMILLO
	2100	74	J. JORAMILLO
	2400	73	R. CISNEROS

Thursday

Date	Time	Temp.	Name (Print)
10-3-24	0300	72	R. Cisneros
	0600	72	APEREZ
	0900	72	APEREZ
	1200	73	APEREZ
	1500	74	H. MARRAMUN
	1800	74	H. MARRAMUN
	2100	74	H. MARRAMUN
	2400	72	CISNEROS

Friday

Date	Time	Temp.	Name (Print)
10-4-24	0300	72	Cisneros
	0600	72	APEREZ
	0900	72	APEREZ
	1200	72	APEREZ
	1500	73	H. MARRAMUN
	1800	74	H. MARRAMUN
	2100	73	H. MARRAMUN
	2400	73	R. Cisneros

Saturday

Date	Time	Temp.	Name (Print)
10-5-24	0300	73	R. Cisneros
	0600	72	APEREZ
	0900	72	APEREZ
	1200	73	APEREZ
	1500	74	H. MARRAMUN
	1800	75	H. MARRAMUN
	2100	75	H. MARRAMUN
	2400	73	[illegible]

Sunday

Date	Time	Temp.	Name (Print)
10-6-24	0300	71	[illegible]
	0600	71	King
	0900	72	King
	1200	74	King
	1500	75	H. MARRAMUN
	1800	74	H. MARRAMUN
	2100	74	H. MARRAMUN
	2400	74	[illegible]

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 5 (A or B) Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9/30/24	0300	76	[illegible]
	0600	76	[illegible]
	0900	75	T Smal
	1200	75	T Smal
	1500	74	G Gomes
	1800	74	G Ortega
	2100	74	J Ortega
	2400	76	[illegible]

Tuesday

Date	Time	Temp.	Name (Print)
10/1/24	0300	77	[illegible]
	0600	76	[illegible]
	0900	76	T Smal
	1200	74	T Smal
	1500	75	O Vega
	1800	75	O Vega
	2100	75	O Vega
	2400	76	[illegible]

Wednesday

Date	Time	Temp.	Name (Print)
10/2/24	0300	76	[illegible]
	0600	76	[illegible]
	0900	75	E Cruz
	1200	75	E Cruz
	1500	75	O Vega
	1800	74	O Vega
	2100	75	O Vega
	2400	76	[illegible]

Thursday

Date	Time	Temp.	Name (Print)
10/3/24	0300	77	[illegible]
	0600	76	[illegible]
	0900	75	E Cruz
	1200	75	E Cruz
	1500	76	R Ruiz
	1800	76	R Ruiz
	2100	75	R Ruiz
	2400	75	M. Lopez

Friday

Date	Time	Temp.	Name (Print)
10/4/24	0300	75	M. Lopez
	0600	75	[illegible]
	0900	75	E Cruz
	1200	75	E Cruz
	1500	75	G Campos
	1800	74	G Campos
	2100	74	G Campos
	2400	75	M. Lopez

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	75	M. Lopez
	0600	75	E Cruz
	0900	77	E Cruz
	1200	77	E Cruz
	1500	77	J. Ortega
	1800	76	J. Ortega
	2100	76	J. Ortega
	2400	77	[illegible]

Sunday

Date	Time	Temp.	Name (Print)
10/6/24	0300	77	[illegible]
	0600	74	[illegible]
	0900	77	E Cruz
	1200	77	E Cruz
	1500	78	J. Ortega
	1800	78	J. Ortega
	2100	77	J. Ortega
	2400	77	[illegible]

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITA

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 5 A or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9/30/24	0300	76	[illegible]
	0600	77	[illegible]
	0900	75	T Smith
	1200	75	T Smith
	1500	75	Garcia
	1800	74	Ortega
	2100	74	Ortega
	2400	76	[illegible]

Tuesday

Date	Time	Temp.	Name (Print)
10/1/24	0300	77	[illegible]
	0600	76	[illegible]
	0900	75	T Smith
	1200	75	T Smith
	1500	75	Ovaer
	1800	74	Ovaer
	2100	75	Ovaer
	2400	76	[illegible]

Wednesday

Date	Time	Temp.	Name (Print)
10/2/24	0300	76	[illegible]
	0600	77	[illegible]
	0900	75	E Cruz
	1200	76	E Cruz
	1500	75	Ovaer
	1800	75	Ovaer
	2100	75	Ovaer
	2400	76	[illegible]

Thursday

Date	Time	Temp.	Name (Print)
10/3/24	0300	77	[illegible]
	0600	76	[illegible]
	0900	75	E Cruz
	1200	75	E Cruz
	1500	74	Rios
	1800	74	Rios
	2100	76	Rios
	2400	75	M Lopez

Friday

Date	Time	Temp.	Name (Print)
10/4/24	0300	75	M. Lopez
	0600	75	M Lopez
	0900	74	E Cruz
	1200	75	E Cruz
	1500	75	E Cruz
	1800	75	E Cruz
	2100	75	E Cruz
	2400	75	M. Lopez

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	75	M Lopez
	0600	76	E Cruz
	0900	77	E Cruz
	1200	77	E Cruz
	1500	77	J. Ortega
	1800	76	J. Ortega
	2100	76	J. Ortega
	2400	77	[illegible]

Sunday

Date	Time	Temp.	Name (Print)
10/6/24	0300	77	[illegible]
	0600	75	[illegible]
	0900	77	E Cruz
	1200	77	[illegible]
	1500	78	J. Ortega
	1800	78	J. Ortega
	2100	77	J. Ortega
	2400	77	[illegible]

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B6-A Temp. Reading Location: A POD
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9/30/24	0300	76	M. Romero
	0600	77	Lopez
	0900	77	Lopez
	1200	77	Lopez
	1500	77	J. Navarro
	1800	77	J. Navarro
	2100	77	J. Navarro
	2400	76	D Sis

Tuesday

Date	Time	Temp.	Name (Print)
10-1-24	0300	76	D Sis
	0600	74	Lopez
	0900	74	Lopez
	1200	74	Lopez
	1500	75	A ORTIZ
	1800	75	A. ORTIZ
	2100	74	A. ORTIZ
	2400	73	SIS

Wednesday

Date	Time	Temp.	Name (Print)
10/2/24	0300	76	SIS
	0600	76	Lopez
	0900	76	Lopez
	1200	76	Lopez
	1500	78	Lyle
	1800	77	Lyle
	2100	76	Lyle
	2400	78	M. Romero

Thursday

Date	Time	Temp.	Name (Print)
10-3-24	0300	78	M. Romero
	0600	78	Lopez
	0900	77	Lopez
	1200	77	Lopez
	1500	78	Y. Carrasco
	1800	79	Y. Carrasco
	2100	78	Y. Carrasco
	2400	78	M Romero

Friday

Date	Time	Temp.	Name (Print)
10-4-24	0300	78	Mendoza
	0600	78	Lopez
	0900	78	Lopez
	1200	78	Lopez
	1500	78	Y. Carrasco
	1800	78	Y. Carrasco
	2100	78	Y. Carrasco
	2400	78	BARRIOS

Saturday

Date	Time	Temp.	Name (Print)
10-5-24	0300	78	BARRIOS
	0600	78	J. Sanchez
	0900	78	J. Sanchez
	1200	79	J. Sanchez
	1500	79	Y. Carrasco
	1800	79	Y. Carrasco
	2100	79	Y. Carrasco
	2400	79	M. Romero

Sunday

Date	Time	Temp.	Name (Print)
10-6-24	0300	78	M. Romero
	0600	78	J. Sanchez
	0900	78	J. Sanchez
	1200	79	J. Sanchez
	1500	79	J. Navarro
	1800	79	J. Navarro
	2100	78	J. Navarro
	2400	78	B. ROSS

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B6-B Temp. Reading Location: B POD
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9-30-24	0300	76	M.Romero
	0600	77	Lopez
	0900	77	Lopez
	1200	77	Lopez
	1500	77	J.Navarro
	1800	77	J.Navarro
	2100	77	J.Navarro
	2400	76	JSJ

Tuesday

Date	Time	Temp.	Name (Print)
10-1-24	0300	76	D SJS
	0600	76	Lopez
	0900	76	Lopez
	1200	76	Lopez
	1500	79	ORTIZ
	1800	78	ORTIZ
	2100	78	ORTIZ
	2400	75	SJS

Wednesday

Date	Time	Temp.	Name (Print)
10/2/24	0300	76	SJS
	0600	76	Lopez
	0900	76	Lopez
	1200	76	Lopez
	1500	77	Luke
	1800	77	Luke
	2100	77	Luke
	2400	78	M.Romero

Thursday

Date	Time	Temp.	Name (Print)
10/3/24	0300	78	M.Romero
	0600	78	Lopez
	0900	77	Lopez
	1200	77	Lopez
	1500	79	Y.Carrasco
	1800	79	Y.Carrasco
	2100	78	Y.Carrasco
	2400	78°	Morgan

Friday

Date	Time	Temp.	Name (Print)
10-4-24	0300	78	Morgan Y
	0600	78	Lopez
	0900	77	Lopez
	1200	77	Lopez
	1500	78	Y.Carrasco
	1800	78	Y.Carrasco
	2100	78	Y.Carrasco
	2400	78	Barrios

Saturday

Date	Time	Temp.	Name (Print)
10-5-24	0300	78	Barrios
	0600	78	J.Sanchez
	0900	78	J.Sanchez
	1200	79	J.Sanchez
	1500	79	Y.Carrasco
	1800	79	Y.Carrasco
	2100	78	Y.Carrasco
	2400	78	M.Romero

Sunday

Date	Time	Temp.	Name (Print)
10-6-24	0300	78	M.Romero
	0600	78	J.Sanchez
	0900	78	J.Sanchez
	1200	79	J.Sanchez
	1500	79	J.Navarro
	1800	79	J.Navarro
	2100	78	J.Navarro
	2400	78	B.ROSS

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C-2 A Temp. Reading Location: TIER 2
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 5141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
1 Oct	0300	77	Montes
	0600	77	McIntosh
	0900	79	McIntosh
	1200	79	McIntosh
	1500	80	M-Serrato
	1800	80	M-Serrato
	2100	80	M-Serrato
	2400	78	Ellison

Wednesday

Date	Time	Temp.	Name (Print)
2 Oct	0300	78	Ellison
	0600	79	McIntosh
	0900	80	McIntosh
	1200	81	McIntosh
	1500	81	Serrato
	1800	80	Serrato
	2100	79	Serrato
	2400	78	Ellison

Thursday

Date	Time	Temp.	Name (Print)
3 Oct	0300	79	Ellison
	0600	79	McIntosh
	0900	79	McIntosh
	1200	80	McIntosh
	1500	80	Ellison
	1800	79	Ellison
	2100	79	Ellison
	2400	78	Ellison

Friday

Date	Time	Temp.	Name (Print)
4 Oct	0300	76	Ellison
	0600	79	McIntosh
	0900	79	McIntosh
	1200	80	McIntosh
	1500	80	M. Rains
	1800	80	M. Rains
	2100	80	M. Rains
	2400	80	Ellison

Saturday

Date	Time	Temp.	Name (Print)
5 Oct	0300	78	Ellison
	0600	79	T. Deles Santos
	0900	79	T. Deles Santos
	1200	80	T. Deles Santos
	1500	80	G. Contreras
	1800	80	G. Contreras
	2100	80	G. Contreras
	2400	78	D. Alvarado

Sunday

Date	Time	Temp.	Name (Print)
6 Oct	0300	78	D. Alvarado
	0600	78	T. Deles Santos
	0900	78	T. Deles Santos
	1200	79	T. Deles Santos
	1500	79	G. Contreras
	1800	80	G. Contreras
	2100	80	G. Contreras
	2400	79	M. Ayala

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C2-B Temp. Reading Location: 2ND TIER
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10/1/24	0300	76	A. WALTERS
	0600	77°	A CASILLAS
	0900	77	A CASILLAS
	1200	78	A CASILLAS
	1500	78	A walters
	1800	79	A walters
	2100	78	A walters
	2400	76	A walters

Wednesday

Date	Time	Temp.	Name (Print)
10/2/24	0300	77	A walter
	0600	77	D. ZAMUDIO
	0900	78	D. ZAMUDIO
	1200	78	D. ZAMUDIO
	1500	80	COTTON
	1800	80	COTTON
	2100	80	COTTON
	2400	77	A walter

Thursday

Date	Time	Temp.	Name (Print)
10/3/24	0300	78	A walter
	0600	78	R. ANAYA
	0900	78	R. ANAYA
	1200	78	R. ANAYA
	1500	80	COTTON
	1800	80	COTTON
	2100	80	COTTON
	2400	[illegible]	A walters

Friday

Date	Time	Temp.	Name (Print)
10/4/24	0300	78	COTTON
	0600	78	A CASILLAS
	0900	78	A CASILLAS
	1200	78	A CASILLAS
	1500	80	COTTON
	1800	80	COTTON
	2100	78	COTTON
	2400	78	COTTON

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	78	A walter
	0600	78	A. CASILLAS
	0900	78°	A CASILLAS
	1200	78°	A CASILLAS
	1500	79	COTTON
	1800	79	COTTON
	2100	79	COTTON
	2400	79	A walters

Sunday

Date	Time	Temp.	Name (Print)
10/6/24	0300	80	A. martinez
	0600	79°	A CASILLAS
	0900	80	A CASILLAS
	1200	80	A CASILLAS
	1500	80	D. Alvarado
	1800	80	D. Alvarado
	2100	80	D. Alvarado
	2400	80	A. martinez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C3-A Temp. Reading Location: 2nd Tier (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9-30-24	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10-1-24	0300	80	J Ferrer
	0600	80	J Ferrer
	0900	79	J Ferrer
	1200	80	J Ferrer
	1500	81	Suarez
	1800	81	Suarez
	2100	80	Suarez
	2400	80	CANACHO

Wednesday

Date	Time	Temp.	Name (Print)
10-2-24	0300	80	CANACHO
	0600	80	J Ferrer
	0900	81	J Ferrer
	1200	81	J Ferrer
	1500	82	A Suarez
	1800	82	A Suarez
	2100	81	A. Suarez
	2400	80	CANACHO

Thursday

Date	Time	Temp.	Name (Print)
10-3-24	0300	80	CANACHO
	0600	80	J Ferrer
	0900	82	J Ferrer
	1200	82	J Ferrer
	1500	82	A. Suarez
	1800	82	A. Suarez
	2100	81	A Suarez
	2400	80	Morales

Friday

Date	Time	Temp.	Name (Print)
10-4-24	0300	80	Morales
	0600	81	J Ferrer
	0900	81	J Ferrer
	1200	81	J Ferrer
	1500	81	A Suarez
	1800	81	A Suarez
	2100	82	A Suarez
	2400	80	I. BERRONES

Saturday

Date	Time	Temp.	Name (Print)
10-5-24	0300	80	I. BERRONES
	0600	80	J Ferrer
	0900	81	J Ferrer
	1200	82	J Ferrer
	1500	82	Riley
	1800	81	Riley
	2100	81	Riley
	2400	80	CANACHO

Sunday

Date	Time	Temp.	Name (Print)
10-6-24	0300	80	CANACHO
	0600	80	Y. SANCHEZ
	0900	80	Y. SANCHEZ
	1200	80	Y. SANCHEZ
	1500	81	Riley
	1800	81	Riley
	2100	80	Riley
	2400	80	CANACHO

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C3B Temp. Reading Location: T2, Above TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10/1/24	0300	76°	E TORRES
	0600	77	D. Valencia
	0900	77	D. Valencia
	1200	77	D. Valencia
	1500	77	JACOSTA
	1800	77	JACOSTA
	2100	77	JACOSTA
	2400	76	E TORRES

Wednesday

Date	Time	Temp.	Name (Print)
10/2/24	0300	76	E TORRES
	0600	76	D. Valencia
	0900	76	D. Valencia
	1200	76	D. Valencia
	1500	76	JACOSTA
	1800	76	JACOSTA
	2100	76	JACOSTA
	2400	76	E TORRES

Thursday

Date	Time	Temp.	Name (Print)
10/3/24	0300	76	E TORRES
	0600	75	J. JONES
	0900	76	J. JONES
	1200	77	J. JONES
	1500	80	R. Aguilar
	1800	80	R. Aguilar
	2100	79	R. Aguilar
	2400	78	E. TORRES

Friday

Date	Time	Temp.	Name (Print)
10/4/24	0300	76	E TORRES
	0600	76	J. JONES
	0900	77	J. JONES
	1200	79	J. JONES
	1500	80	R. Aguilar
	1800	80	R. Aguilar
	2100	80	J. Navarro
	2400	76	J. Navarro

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	79	D. Valencia
	0600	79	D. Valencia
	0900	79	D. Valencia
	1200	79	D. Valencia
	1500	79	JACOSTA
	1800	79	JACOSTA
	2100	79	JACOSTA
	2400	79	Pennel

Sunday

Date	Time	Temp.	Name (Print)
10/6/24	0300	78	Pennel
	0600	79	D. Valencia
	0900	79	D. Valencia
	1200	79	D. Valencia
	1500	79	D. Valencia
	1800	78	E TORRES
	2100	78	E TORRES
	2400	78	E TORRES

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C4A Temp. Reading Location: right of T.V
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10/1/24	0300	75	Rall
	0600	75	J.Padilla
	0900	76	J.Padilla
	1200	77	J.Padilla
	1500	80	Vielmas
	1800	81	Vielmas
	2100	79	Vielmas
	2400	78°	S.Rau

Wednesday

Date	Time	Temp.	Name (Print)
10/2/24	0300	77°	S.Rau
	0600	78°	Z. Jones
	0900	78°	Z. Jones
	1200	80°	Z. Jones
	1500	82	Vielmas
	1800	81	Vielmas
	2100	80	Vielmas
	2400	76	Vielmas

Thursday

Date	Time	Temp.	Name (Print)
10/3/24	0300	76	Torres. E
	0600	79	Torres, E
	0900	79	Torres, E
	1200	79	Torres. E
	1500	82	Vielmas
	1800	82	Vielmas
	2100	80	Vielmas
	2400	78	C.WITCHER

Friday

Date	Time	Temp.	Name (Print)
10/4/24	0300	78	C.WITCHER
	0600	78	E.Torres
	0900	78	E.Torres
	1200	78	E.Torres
	1500	81	Vielmas
	1800	80	Vielmas
	2100	79	Vielmas
	2400	78	C.WITCHER

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	77°	S.Rau
	0600	77	Torres, E
	0900	78	Torres, E
	1200	78	Torres, E
	1500	78	R. Aguilar
	1800	77	R. Aguilar
	2100	77	R. Aguilar
	2400	76°	S.Rau

Sunday

Date	Time	Temp.	Name (Print)
10/6/24	0300	75°	S.Rau
	0600	76	Torres
	0900	77	Torres
	1200	78	[illegible]
	1500	79	R. Aguilar
	1800	78	R. Aguilar
	2100	77	R. Aguilar
	2400	76°	S.Rau

Notes

Tues UHT Activated 1235

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C4-B Temp. Reading Location: dayroom (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10-1-24	0300	78	CUTCHER
	0600	75	Zamudio
	0900	75	Zamudio
	1200	75	Zamudio
	1500	75	Dwelch
	1800	79	Dwelch
	2100	79	Dwelch
	2400	79	P. Ramos

Wednesday

Date	Time	Temp.	Name (Print)
10-2-2024	0300	79	P. Ramos
	0600	75°	J. Gonzalez
	0900	75°	J. Gonzalez
	1200	79	J. Gonzalez
	1500	80	R. Aguilar
	1800	80	R. Aguilar
	2100	79	R. Aguilar
	2400	79	P. Ramos

Thursday

Date	Time	Temp.	Name (Print)
10-3-2024	0300	78°	P. Ramos
	0600	76°	J. Gonzalez
	0900	77°	J. Gonzalez
	1200	78°	J. Gonzalez
	1500	78	K. MADRIGAL
	1800	78	K. MADRIGAL
	2100	78°	K. MADRIGAL
	2400	78°	P. Ramos

Friday

Date	Time	Temp.	Name (Print)
10-4-2024	0300	78°	P. Ramos
	0600	78°	S. Ramirez
	0900	79°	J. Ramirez
	1200	79°	J. Ramirez
	1500	79°	H. Tovar
	1800	81°	H. Tovar
	2100	78°	H. Tovar
	2400	79	J. Acuna

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	79	J. Acuna
	0600	74	P. Hom
	0900	76°	P. Hom
	1200	77	P. Hom
	1500	77°	H. Tovar
	1800	76°	H. Tovar
	2100	78°	I. BERRONES
	2400	80	I. BERRONES

Sunday

Date	Time	Temp.	Name (Print)
10-6-24	0300	78	I. BERRONES
	0600	77	J. Padilla
	0900	78	J. Padilla
	1200	78	J. Padilla
	1500	78	Tovar
	1800	78	Tovar
	2100	78	Tovar
	2400	78	A. Matos

Notes

Date	Activation	Deactivation
10-2-24	1100	

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. D - 1 (A) Side Temp. Reading Location: Tier 2 - Above Dayroom TV (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9/30	0300	69	LEGORETTA
	0600	69	LBAEZA
	0900	70	LBAEZA
	1200	71	LBAEZA
	1500	75°	M AVILA
	1800	74°	M AVILA
	2100	74	M AVILA
	2400	72	LEGORETTA

Tuesday

Date	Time	Temp.	Name (Print)
10/1/24	0300	70	P. MORALES
	0600	70	LBAEZA
	0900	71	LBAEZA
	1200	72	LBAEZA
	1500	74	L. Frias
	1800	73	L. Frias
	2100	73	L. Frias
	2400	73	LBAEZA

Wednesday

Date	Time	Temp.	Name (Print)
10/2/24	0300	73	LBAEZA
	0600	70	LBAEZA
	0900	71	LBAEZA
	1200	72	LBAEZA
	1500	75	L. Frias
	1800	75	L. Frias
	2100	74	L. Frias
	2400	74	P. MORALES

Thursday

Date	Time	Temp.	Name (Print)
10/3/24	0300	73	P. MORALES
	0600	73	LBAEZA
	0900	73	LBAEZA
	1200	74	LBAEZA
	1500	74	L. Frias
	1800	74	L. Frias
	2100	73	L. Frias
	2400	73	Y. Fernandez

Friday

Date	Time	Temp.	Name (Print)
10/4/24	0300	72	Y. Fernandez
	0600	72	LBAEZA
	0900	72	LBAEZA
	1200	72	LBAEZA
	1500	74	L. Frias
	1800	74	L. Frias
	2100	73	L. Frias
	2400	73	P. MORALES

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	73	P. MORALES
	0600	74	E MENDOZA
	0900	74	E MENDOZA
	1200	74	E MENDOZA
	1500	74	L. Frias
	1800	74	L. Frias
	2100	74	L. Frias
	2400	73	G. ZAMORA

Sunday

Date	Time	Temp.	Name (Print)
10/6/24	0300	72	G. ZAMORA
	0600	72	E MENDOZA
	0900	72	E MENDOZA
	1200	72	E MENDOZA
	1500	72	S. MORENO
	1800	72	S. MORENO
	2100	72	S. MORENO
	2400	73	G. ZAMORA

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

Type text here

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. D - 1 (B) Side Temp. Reading Location: Tier 2 - Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9/30	0300	72	LEGORETTA
	0600	72	LBAEZA
	0900	75	LBAEZA
	1200	74	LBAEZA
	1500	75°	M AVILA
	1800	74°	M AVILA
	2100	74	M AVILA
	2400	73	LEGORETTA

Tuesday

Date	Time	Temp.	Name (Print)
10/1/24	0300	72	P. MORALES
	0600	72	LBAEZA
	0900	72	LBAEZA
	1200	73	LBAEZA
	1500	74	LGÓMEZ
	1800	74	LGómez
	2100	73	LGómez
	2400	73	P. MORALES

Wednesday

Date	Time	Temp.	Name (Print)
10/2/24	0300	75	P. MORALES
	0600	75	LBAEZA
	0900	75	LBAEZA
	1200	74	LBAEZA
	1500	75	LGómez
	1800	75	LGómez
	2100	74	LGómez
	2400	75	P. MORALES

Thursday

Date	Time	Temp.	Name (Print)
10/3/24	0300	74	P. MORALES
	0600	74	LBAEZA
	0900	74	LBAEZA
	1200	75	LBAEZA
	1500	74	LGómez
	1800	74	LGómez
	2100	74	LGómez
	2400	73	Y. Fernandez

Friday

Date	Time	Temp.	Name (Print)
10/4/24	0300	72	Y. Fernandez
	0600	72	LBAEZA
	0900	72	LBAEZA
	1200	73	LBAEZA
	1500	74	LGómez
	1800	74	LGómez
	2100	73	LGómez
	2400	73	P. MORALES

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	74	G. ZAMORA
	0600	74	E MENDOZ
	0900	76	E MENDOZ
	1200	76	E MENDOZ
	1500	74	LGómez
	1800	74	LGómez
	2100	74	LGómez
	2400	74	G. ZAMORA

Sunday

Date	Time	Temp.	Name (Print)
10/6/24	0300	72	G. ZAMORA
	0600	72	E MENDOZ
	0900	72	E MENDOZ
	1200	72	E MENDOZ
	1500	75	S. MORENO
	1800	78	S. MORENO
	2100	78	S. MORENO
	2400	75	G. ZAMORA

Notes

ACTIVITED DEACTIVITED
1930 HRS

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D2 (A) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10-1-24	0300	76	D. Mancera
	0600	76	D. Mancera
	0900	78	H. Barber
	1200	80	H. Barber
	1500	80	J. ESQUIVEL
	1800	80	J. ESQUIVEL
	2100	76	J. ESQUIVEL
	2400	77	G. Martinez

Wednesday

Date	Time	Temp.	Name (Print)
10.2.24	0300	76	G. Martinez
	0600	77	G. Martinez
	0900	78	Goodell
	1200	79	Goodell
	1500	79	Amer
	1800	79	Amer
	2100	79	Amer
	2400	79	G. Martinez

Thursday

Date	Time	Temp.	Name (Print)
10.3.24	0300	77	G. Martinez
	0600	78	G. Martinez
	0900	79	Goodell
	1200	79	Goodell
	1500	79	C. Solano
	1800	79	C. Solano
	2100	79	C. Solano
	2400	78	G. Martinez

Friday

Date	Time	Temp.	Name (Print)
10.4.24	0300	76	G. Martinez
	0600	76	G. Martinez
	0900	77	G. Contreras
	1200	78	G. Contreras
	1500	78	C. Solano
	1800	79	C. Solano
	2100	78	C. Solano
	2400	77	G. Martinez

Saturday

Date	Time	Temp.	Name (Print)
10.5.24	0300	77	G. Martinez
	0600	78	G. Martinez
	0900	78	G. Contreras
	1200	79	G. Contreras
	1500	79	J. VALENCIA
	1800	79	J. VALENCIA
	2100	79	J. VALENCIA
	2400	79	D. Drake

Sunday

Date	Time	Temp.	Name (Print)
10/6/24	0300	78	D. Drake
	0600	78	[illegible]
	0900	78	[illegible]
	1200	78	[illegible]
	1500	78	[illegible]
	1800	78	[illegible]
	2100	78	[illegible]
	2400	75	A. MALDONADO

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D2 (B) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10-1-24	0300	76	D. Mancilla
	0600	76	D. Mancilla
	0900	78	H Bah
	1200	80	H Bah
	1500	80	J. ESQUIVEL
	1800	80	J. ESQUIVEL
	2100	76	J. ESQUIVEL
	2400	77	G. Martinez

Wednesday

Date	Time	Temp.	Name (Print)
10-2-24	0300	76	G Martinez
	0600	77	G Martinez
	0900	78	Goodell
	1200	79	Goodell
	1500	79	Ayala
	1800	79	Ayala
	2100	79	Ayala
	2400	77	G Martinez

Thursday

Date	Time	Temp.	Name (Print)
10-3-24	0300	77	G Martinez
	0600	78	G Martinez
	0900	79	Goodell
	1200	79	Goodell
	1500	79	C. Solano
	1800	79	C. Solano
	2100	79	C. Solano
	2400	78	G Martinez

Friday

Date	Time	Temp.	Name (Print)
10-4-24	0300	76	G Martinez
	0600	76	G Martinez
	0900	77	G. Contreras
	1200	78	G. Contreras
	1500	78	C. Solano
	1800	79	C. Solano
	2100	78	C. Solano
	2400	77	G Martinez

Saturday

Date	Time	Temp.	Name (Print)
10-5-24	0300	77	G Martinez
	0600	78	G Martinez
	0900	78	G. Contreras
	1200	78	G. Contreras
	1500	79	J. VALENCIA
	1800	79	J. VALENCIA
	2100	79	J. VALENCIA
	2400	79	D. Drake

Sunday

Date	Time	Temp.	Name (Print)
10-6-24	0300	78	D Drake
	0600	78	Murgia
	0900	78	Murgia
	1200	78	Murgia
	1500	78	Murgia
	1800	78	Murgia
	2100	77	Murgia
	2400	75	A Maldonado

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D3 (A) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9-30-24	0300	73	M. Gaete
	0600	75	J. ESQUIVEL
	0900	76	J. ESQUIVEL
	1200	78	J. ESQUIVEL
	1500	77	A. MARTINEZ
	1800	77	A. MARTINEZ
	2100	76	A. MARTINEZ
	2400	76	A. MARTINEZ

Tuesday

Date	Time	Temp.	Name (Print)
10-1-24	0300	70	A. MARTINEZ
	0600	76	J. ESQUIVEL
	0900	77	J. ESQUIVEL
	1200	78	J. ESQUIVEL
	1500	77	A. MARTINEZ
	1800	77	A. MARTINEZ
	2100	76	A. MARTINEZ
	2400	76	CHAVEZ

Wednesday

Date	Time	Temp.	Name (Print)
10-2-24	0300	74	CHAVEZ
	0600	74	A. Castrejon
	0900	74	A. Castrejon
	1200	74	A. Castrejon
	1500	77	A. MARTINEZ
	1800	77	A. MARTINEZ
	2100	76	A. MARTINEZ
	2400	73	M. Gaete

Thursday

Date	Time	Temp.	Name (Print)
10-3-24	0300	73	M. Gaete
	0600	73	M. Serrato
	0900	73	M. Serrato
	1200	73	M. Serrato
	1500	75	A. MARTINEZ
	1800	76	A. MARTINEZ
	2100	76	A. MARTINEZ
	2400	75	M. Gaete

Friday

Date	Time	Temp.	Name (Print)
10-4-24	0300	75	M. Gaete
	0600	75	J. ESQUIVEL
	0900	76	J. ESQUIVEL
	1200	78	J. ESQUIVEL
	1500	78	S. Moreno
	1800	78	S. Moreno
	2100	75	S. Moreno
	2400	75	S. Moreno

Saturday

Date	Time	Temp.	Name (Print)
10-5-24	0300	75	S. Moreno
	0600	75	J. ESQUIVEL
	0900	77	J. ESQUIVEL
	1200	78	J. ESQUIVEL
	1500	78	S. Moreno
	1800	78	S. Moreno
	2100	75	S. Moreno
	2400	75	M. Gaete

Sunday

Date	Time	Temp.	Name (Print)
10-6-24	0300	74	M. Gaete
	0600	74	S. Moreno
	0900	74	S. Moreno
	1200	75	S. Moreno
	1500	76	A. MARTINEZ
	1800	76	A. MARTINEZ
	2100	75	A. MARTINEZ
	2400	75	G. Linares

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D3 (B) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9-30-24	0300	78	M. Garcia
	0600	77	J. ESQUIVEL
	0900	77	J. ESQUIVEL
	1200	78	J. ESQUIVEL
	1500	77	A. MARTINEZ
	1800	76	A. MARTIN
	2100	76	A. MARTIN
	2400	75	A. MARTIN

Tuesday

Date	Time	Temp.	Name (Print)
10-1-24	0300	75	A. MARTINEZ
	0600	75	J. ESQUIVEL
	0900	76	J. ESQUIVEL
	1200	78	J. ESQUIVEL
	1500	77	A. MARTINEZ
	1800	76	A. MARTIN
	2100	76	A. MARTIN
	2400	76	A. MARTIN

Wednesday

Date	Time	Temp.	Name (Print)
10.2.24	0300	74	A. MARTIN
	0600	72	A. MARTIN
	0900	74	A. Castrejon
	1200	74	A. Castrejon
	1500	78	A. MARTINEZ
	1800	77	A. MARTINEZ
	2100	77	A. MARTINEZ
	2400	77	M. Garcia

Thursday

Date	Time	Temp.	Name (Print)
10-3-24	0300	77	M. Garcia
	0600	77	M. Serrano
	0900	77	M. Serrano
	1200	78	M. Serrano
	1500	77	A. MARTINEZ
	1800	77	A. MARTINEZ
	2100	76	A. MARTINEZ
	2400	76	M. Garcia

Friday

Date	Time	Temp.	Name (Print)
10-4-24	0300	75	M. Garcia
	0600	75	J. ESQUIVEL
	0900	76	J. ESQUIVEL
	1200	77	J. ESQUIVEL
	1500	77	S. MORENO
	1800	77	S. MORENO
	2100	75	S. MORENO
	2400	75	S. MORENO

Saturday

Date	Time	Temp.	Name (Print)
10-5-24	0300	75	S. MORENO
	0600	75	J. ESQUIVEL
	0900	76	J. ESQUIVEL
	1200	77	J. ESQUIVEL
	1500	77	MORENO
	1800	77	MORENO
	2100	77	MORENO
	2400	77	M. Garcia

Sunday

Date	Time	Temp.	Name (Print)
10-6-24	0300	77	M. Garcia
	0600	77	S. MORENO
	0900	77	S. MORENO
	1200	78	S. MORENO
	1500	77	A. MARTINEZ
	1800	77	A. MARTINEZ
	2100	77	A. MARTINEZ
	2400	77	A. Linares

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. D - 4 (A) Side Temp. Reading Location: Tier 2 - Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10/1/24	0300	79	S. Baez
	0600	79	Lopez
	0900	79	Lopez
	1200	79	Lopez
	1500	79	Arreola
	1800	79	Arreola
	2100	79	Arreola
	2400	79	S. Baez

Wednesday

Date	Time	Temp.	Name (Print)
10-2-24	0300	79	S. Baez
	0600	79	A Lopez
	0900	79	A Lopez
	1200	79	A Lopez
	1500	79	R. PASCUA
	1800	79	R. PASCUA
	2100	79	R. PASCUA
	2400	79	S. Baez

Thursday

Date	Time	Temp.	Name (Print)
10-3-24	0300	79	S. Baez
	0600	79	D Castrejon
	0900	79	D. Castrejon
	1200	79	D. Castrejon
	1500	79	R. PASCUA
	1800	79	R. PASCUA
	2100	79	R. PASCUA
	2400	79	REYES.

Friday

Date	Time	Temp.	Name (Print)
10-4-24	0300	79	REYES
	0600	79	MENDEZ
	0900	79	MENDEZ
	1200	79	MENDEZ
	1500	79	R. PASCUA
	1800	79	R. PASCUA
	2100	79	R. PASCUA
	2400	79	REYES.

Saturday

Date	Time	Temp.	Name (Print)
10-5-24	0300	79	REYES.
	0600	79	A Lopez
	0900	79	A lopez
	1200	79	A Lopez
	1500	79	R. PASCUA
	1800	79	R. PASCUA
	2100	79	R PASCUA
	2400	79	G. Linares

Sunday

Date	Time	Temp.	Name (Print)
10-6-24	0300	79	G. Linares
	0600	79	A Lopez
	0900	79	A Lopez
	1200	80	A Lopez
	1500	79	R. PASCUA
	1800	79	R. PASCUA
	2100	79	R. PASCUA
	2400	79	S. Baez

Notes

UHT ACTIVATED Oct 1, 24 1200
UHT ACTIVATED Oct 6, 24 1155

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. D - 4 (B) Side Temp. Reading Location: Tier 2 - Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10/1/24	0300	79	S. Baez
	0600	79	Lopez
	0900	79	Lopez
	1200	79	Lopez
	1500	79	Ayala
	1800	80	Ayala
	2100	80	Ayala
	2400	79	S. Baez

Wednesday

Date	Time	Temp.	Name (Print)
10-2-24	0300	79	S. Baez
	0600	79	A Lopez
	0900	79	A Lopez
	1200	79	A Lopez
	1500	79	R. PASCUA
	1800	79	R. PASCUA
	2100	79	R. PASCUA
	2400	79	S. Baez

Thursday

Date	Time	Temp.	Name (Print)
10-3-24	0300	79	S. Baez
	0600	80	D. Castrejon
	0900	80	D. Castrejon
	1200	80	D. Castrejon
	1500	79	R. PASCUA
	1800	79	R. PASCUA
	2100	79	R. PASCUA
	2400	79	REYES

Friday

Date	Time	Temp.	Name (Print)
10-4-24	0300	79	REYES
	0600	79	Mendez
	0900	79	Mendez
	1200	79	Mendez
	1500	79	R. PASCUA
	1800	79	R. PASCUA
	2100	79	R. PASCUA
	2400	79	REYES

Saturday

Date	Time	Temp.	Name (Print)
10-5-24	0300	79	REYES
	0600	79	A Lopez
	0900	79	A Lopez
	1200	79	A Lopez
	1500	79	R. PASCUA
	1800	79	R. PASCUA
	2100	79	R. PASCUA
	2400	79	G. Linares

Sunday

Date	Time	Temp.	Name (Print)
10-6-24	0300	79	G. Linares
	0600	79	A Lopez
	0900	79	A Lopez
	1200	80	A Lopez
	1500	79	R. PASCUA
	1800	79	R. PASCUA
	2100	79	R. PASCUA
	2400	79	S. Baez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. D - 5 (A) Side Temp. Reading Location: Tier 2 - Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday 10-1-24

Date	Time	Temp.	Name (Print)
10/1/24	0300	71	Malcda
	0600	70	A. Herrera
	0900	71	A. Herrera
	1200	71	A. Herrera
	1500	72	N. Tovar
	1800	73	N. Tovar
	2100	72	N. Tovar
	2400	71	J. Jackson

Wednesday

Date	Time	Temp.	Name (Print)
10-2-24	0300	71	J. Jackson
	0600	71	J. Jackson
	0900	70	A. Herrera
	1200	70	A Herrera
	1500	76	N. Tovar
	1800	76	N. Tovar
	2100	71	N. Tovar
	2400	70	J Jackson

Thursday

Date	Time	Temp.	Name (Print)
10-3-24	0300	70	JACKSON
	0600	70	Alterrera
	0900	71	A Herrera
	1200	70	A Herrera
	1500	71	N. Tovar
	1800	72	N. Tovar
	2100	72	N. Tovar
	2400	77	[illegible]

Friday

Date	Time	Temp.	Name (Print)
10/4/24	0300	71	[illegible]
	0600	70	Alterrera
	0900	71	A. Herrera
	1200	71	A Herrera
	1500	76	GAGE
	1800	72	GAGE
	2100	72	Gage
	2400	72	A-MACDONAD

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	70	A-MACDONAD
	0600	70	[illegible]
	0900	70	[illegible]
	1200	70	[illegible]
	1500	72	Sardahe
	1800	72	Sardahe
	2100	72	Sardahe
	2400	72	A-MACDONAD

Sunday

Date	Time	Temp.	Name (Print)
10/6/24	0300	70	A-MACDONAD
	0600	70	G. Contreras
	0900	71	G. Contreras
	1200	73	G. Contreras
	1500	74	CORREA
	1800	74	CORREA
	2100	72	CORREA
	2400	73	G-ZAMORA

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. D - 5 ~~(A)~~ B Side Temp. Reading Location: Tier 2 - Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday 10-1-24

Date	Time	Temp.	Name (Print)
10-1-24	0300	71	Maceda
	0600	70	A. Herrera
	0900	71	A Herrera
	1200	71	A. Herrera
	1500	72	N. Tovar
	1800	73	N. Tovar
	2100	72	N. Tovar
	2400	71	J. Jackson

Wednesday

Date	Time	Temp.	Name (Print)
10-2-24	0300	71	J. Jackson
	0600	71	J. Jackson
	0900	70	A Herrera
	1200	70	A. Herrera
	1500	70	N. Tovar
	1800	71	N. Tovar
	2100	71	N. Tovar
	2400	70	J Acksson

Thursday

Date	Time	Temp.	Name (Print)
10-3-24	0300	70	J Asson
	0600	70	A Herrera
	0900	71	A Herrera
	1200	70	A Herrera
	1500	71	N. Tovar
	1800	72	N. Tovar
	2100	72	N. Tovar
	2400	71	Gage

Friday

Date	Time	Temp.	Name (Print)
10/4/24	0300	77	Gage
	0600	76	A Herrera
	0900	71	A Herrera
	1200	71	A Herrera
	1500	76	GAGE
	1800	76	GAGE
	2100	74	GAGE
	2400	74	A MACDONALD

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	70	A MACDONALD
	0600	70	Gage
	0900	70	Gage
	1200	70	Gage
	1500	72	Sordinha
	1800	72	Sordinha
	2100	72	Sordinha
	2400	70	A MACDONALD

Sunday

Date	Time	Temp.	Name (Print)
10/6/24	0300	70	A MACDONALD
	0600	70	G. Contreras
	0900	70	G Contreras
	1200	73	G. Contreras
	1500	76	CORREA
	1800	78	CORREA
	2100	78	CORREA
	2400	78	G. ZAMORA

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. D - 6 (A) Side Temp. Reading Location: Tier 2 - Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10-1-24	0300	75	D. SANTOYO
	0600	75	B. COVERT
	0900	75	B. COVERT
	1200	76	B. COVERT
	1500	76	R. Aguilar
	1800	76	R. Aguilar
	2100	76	R Aguilar
	2400	75	D. SANTOYO

Wednesday

Date	Time	Temp.	Name (Print)
10-2-24	0300	74	D. SANTOYO
	0600	74	B. COVERT
	0900	75	B. COVERT
	1200	77	B. COVERT
	1500	77	M. VASQUEZ
	1800	75	M. VASQUEZ
	2100	74	M. VASQUEZ
	2400	74	M. VASQUEZ

Thursday

Date	Time	Temp.	Name (Print)
10-3-24	0300	73	M. VASQUEZ
	0600	73	E. Tolbert
	0900	74	E. Tolbert
	1200	76	E. Tolbert
	1500	76	M. VASQUEZ
	1800	76	M. VASQUEZ
	2100	76	M. VASQUEZ
	2400	75	K. Gibson

Friday

Date	Time	Temp.	Name (Print)
10-4-24	0300	75	K. Gibson
	0600	77	[illegible]
	0900	77	[illegible]
	1200	77	[illegible]
	1500	80.	M. VASQUEZ
	1800	77.	M. VASQUEZ
	2100	75	M. VASQUEZ
	2400	75	D. SANTOYO

Saturday

Date	Time	Temp.	Name (Print)
10-5-24	0300	74	D. SANTOYO
	0600	80	A. Gonzalez
	0900	80	A. Gonzalez
	1200	80	A. Gonzalez
	1500	80	A. Arreola
	1800	80	A. Arreola
	2100	79	A. Arreola
	2400	78	D. SANTOYO

Sunday

Date	Time	Temp.	Name (Print)
10-6-24	0300	77	D. SANTOYO
	0600	77	[illegible]
	0900	77	[illegible]
	1200	77	[illegible]
	1500	78	A. Arreola
	1800	78	A. Arreola
	2100	78	A. Arreola
	2400	78°	G. ZAMORA

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D6 (B) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10-1-24	0300	76	D. SANTOYO
	0600	76	B. COVERT
	0900	77	B. COVERT
	1200	77	B. COVERT
	1500	77	R. Aguilar
	1800	77	R. Aguilar
	2100	77	R Aguilar
	2400	77	D. SANTOYO

Wednesday

Date	Time	Temp.	Name (Print)
10-2-24	0300	77	D. SANTOYO
	0600	75	B. COVERT
	0900	76	B. COVERT
	1200	77	B. COVERT
	1500	76	M. VASQUEZ
	1800	76	M. VASQUEZ
	2100	75	M. VASQUEZ
	2400	74	M. VASQUEZ

Thursday

Date	Time	Temp.	Name (Print)
10-3-24	0300	73	M. VASQUEZ
	0600	73	E. Olivera
	0900	74	E. Olivera
	1200	76	E. Olivera
	1500	76	M. VASQUEZ
	1800	76	M. VASQUEZ
	2100	76	M. VASQUEZ
	2400	75	K. Gibson

Friday

Date	Time	Temp.	Name (Print)
10-4-24	0300	75	K. Gibson
	0600	77	[illegible]
	0900	77	[illegible]
	1200	77	[illegible]
	1500	78	M. VASQUEZ
	1800	79	M. VASQUEZ
	2100	78	M. VASQUEZ
	2400	78	D. SANTOYO

Saturday

Date	Time	Temp.	Name (Print)
10-5-24	0300	78	D. SANTOYO
	0600	80	[illegible]
	0900	80	[illegible]
	1200	80	[illegible]
	1500	80	A. Arreola
	1800	80	A. Arreola
	2100	79	A. Arreola
	2400	79	D. SANTOYO

Sunday

Date	Time	Temp.	Name (Print)
10-6-24	0300	79	D. SANTOYO
	0600	79	[illegible]
	0900	79	[illegible]
	1200	79	[illegible]
	1500	79	A. Arreola
	1800	79	A. Arreola
	2100	79	A. Arreola
	2400	78°	G. ZAMORA

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NASP Housing Unit: FAC. M DORM 1 A-SIDE Temp. Reading Location: 1st TIER - BEHIND C/O PODIUM (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10/1/24	0300	76°	J. Lopez
	0600	77	J. Landeros
	0900	77	J. Landeros
	1200	77	J. Landeros
	1500	78	R. Duran
	1800	79	R. Duran
	2100	79	R. Duran
	2400	78°	J. Lopez

Wednesday

Date	Time	Temp.	Name (Print)
10/2/24	0300	76°	J. Lopez
	0600	76°	M. Vega
	0900	77°	M. Vega
	1200	78°	M. Vega
	1500	79	I. Fritz
	1800	79	I. Fritz
	2100	80	I. Fritz
	2400	80	J. Lopez

Thursday

Date	Time	Temp.	Name (Print)
10/3/24	0300	80	J. Lopez
	0600	77°	M. Vega
	0900	78°	M. Vega
	1200	79°	M. Vega
	1500	78°	R. Lor
	1800	80°	R. Lor
	2100	78°	R. Lor
	2400	78	M. Racinero

Friday

Date	Time	Temp.	Name (Print)
10/4/24	0300	78	M. Racinero
	0600	78°	M. Vega
	0900	79°	M. Vega
	1200	79°	M. Vega
	1500	80	R. Duran
	1800	80	R. Duran
	2100	80	R. Duran
	2400	80°	J. Lopez

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	80	J. Lopez
	0600	78°	M. Vega
	0900	78°	M. Vega
	1200	79°	M. Vega
	1500	80	J. Montoya
	1800	80	J. Montoya
	2100	80	J. Montoya
	2400	79	J. Montoya

Sunday

Date	Time	Temp.	Name (Print)
10/6/24	0300	79	J. Montoya
	0600	78°	M. Vega
	0900	78°	M. Vega
	1200	79°	M. Vega
	1500	80	J. Montoya
	1800	80	J. Montoya
	2100	80	J. Montoya
	2400	80	J. Montoya

Notes

UHT ACTIVATED		UHT DEACTIVATED
10/1/24	1245	2030
10/2/24	1100	2130
10/3/24	1101	2115
10/4/24	1101	2045
10/5/24	1149	
10/6/24	1155	2015

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAC. M DORM 1 B-SIDE Temp. Reading Location: 1ST TIER-BEHIND C/O PODIUM (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10/1/24	0300	76	J. Lopez
	0600	77	J. Landeros
	0900	77	J. Landeros
	1200	77	J. Landeros
	1500	78	R. Duran
	1800	79	R. Duran
	2100	79	R. Duran
	2400	78°	J. Lopez

Wednesday

Date	Time	Temp.	Name (Print)
10/2/24	0300	76°	J. Lopez
	0600	76°	M. VEGA
	0900	77°	M. VEGA
	1200	78°	M. VEGA
	1500	79	I. Fritz
	1800	78	I. Fritz
	2100	80	I. Fritz
	2400	80	J. Lopez

Thursday

Date	Time	Temp.	Name (Print)
10/3/24	0300	80	J. LOPEZ
	0600	77°	M. VEGA
	0900	78°	M. VEGA
	1200	79°	M. VEGA
	1500	78°	R. LOR
	1800	80°	R. LOR
	2100	78°	R. LOR
	2400	78	RALLA

Friday

Date	Time	Temp.	Name (Print)
10/4/24	0300	78	RALLA
	0600	78°	M. VEGA
	0900	79°	M. VEGA
	1200	79°	M. VEGA
	1500	80	R. DURAN
	1800	80	R. DURAN
	2100	80	R. DURAN
	2400	80	J. LOPEZ

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	80	J. LOPEZ
	0600	78°	M. VEGA
	0900	78°	M. VEGA
	1200	79°	M. VEGA
	1500	80	J. MONTOYA
	1800	80	J. MONTOYA
	2100	80	J. MONTOYA
	2400	79	J. MONTOYA

Sunday

Date	Time	Temp.	Name (Print)
10/6/24	0300	79	J. MONTOYA
	0600	78°	M. VEGA
	0900	78°	M. VEGA
	1200	79°	M. VEGA
	1500	80	J. MONTOYA
	1800	80	J. MONTOYA
	2100	80	J. MONTOYA
	2400	80	J. MONTOYA

Notes

UHT ACTIVATED		UHT DEACTIVATED
10/1/24	1245	2030
10/2/24	1100	2130
10/3/24	1101	2115
10/4/24	1101	2045
10/5/24	1149	
10/6/24	1155	2015

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: M-2 A-SIDE Temp. Reading Location: BEHIND PODIUM (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10/1/24	0300	76	R. DURAN
	0600	76	GONZALEZ
	0900	78	GONZALEZ
	1200	78	GONZALEZ
	1500	78	I. FRITZ
	1800	78	I. FRITZ
	2100	77	I. FRITZ
	2400	77	R. DURAN

Wednesday

Date	Time	Temp.	Name (Print)
10/2/24	0300	77	R. DURAN
	0600	77	S. CROWELL
	0900	79	S. CROWELL
	1200	80	S. CROWELL
	1500	80	J. Medina
	1800	80	J. medina
	2100	80	J Medina
	2400	79°	K. MADRIGAL

Thursday

Date	Time	Temp.	Name (Print)
10/3/24	0300	77°	K. MADRIGAL
	0600	78	PRICE
	0900	78	PRICE
	1200	78	PRICE
	1500	79	J. Medina
	1800	79	J. medina
	2100	79	J. Medina
	2400	78°	K. MADRIGAL

Friday

Date	Time	Temp.	Name (Print)
10/4/24	0300	78	K. MADRIGAL
	0600	78	VARGAS
	0900	78	VARGAS
	1200	79	VARGAS
	1500	79	J. medina
	1800	80	J medina
	2100	80	J. medina
	2400	80°	K. MADRIGAL

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	78°	K. MADRIGAL
	0600	78	VARGAS
	0900	78	VARGAS
	1200	78	VARGAS
	1500	79	Medina
	1800	80	medina
	2100	79	medina
	2400	80°	H. Tran

Sunday

Date	Time	Temp.	Name (Print)
10/6/24	0300	79°	H. Tran
	0600	78	VARGAS
	0900	78	VARGAS
	1200	78	VARGAS
	1500	78	PRICE
	1800	78	PRICE
	2100	78	PRICE
	2400	78	C. House

Notes

UHT	ACTIVATED	DEACTIVATED
TUES. 10-1	1249	2020
WED. 10-2	1100	2130
THURS. 10-3	11:01	2115
FRI- 10-4	1101	2025
SAT. 10-5	1149	20:30
SUN- 10-6	1154	

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: M-2 B-SIDE Temp. Reading Location: BEHIND PODIUM (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
	0300		
	0600		
	0900		
	1200		
	1500		
	1800		
	2100		
	2400		

Tuesday

Date	Time	Temp.	Name (Print)
10/1/24	0300	76	R. DURAN
	0600	76	GONZALEZ
	0900	78	GONZALEZ
	1200	78	GONZALEZ
	1500	78	I. FRITZ
	1800	78	I. FRITZ
	2100	77	I. FRITZ
	2400	77	R. DURAN

Wednesday

Date	Time	Temp.	Name (Print)
10/2/24	0300	77	R. DURAN
	0600	77	S. CROWELL
	0900	79	S. CROWELL
	1200	80	S. CROWELL
	1500	80	J. Medina
	1800	80	J. Medina
	2100	80	J. Medina
	2400	79	K. MADRIGAL

Thursday

Date	Time	Temp.	Name (Print)
10/3/24	0300	77°	K. MADRIGAL
	0600	78	PRICE
	0900	78	PRICE
	1200	78	PRICE
	1500	79	J. Medina
	1800	79	J. Medina
	2100	79	J. Medina
	2400	78°	K. MADRIGAL

Friday

Date	Time	Temp.	Name (Print)
10/4/24	0300	78°	K. MADRIGAL
	0600	78	VARGAS
	0900	78	VARGAS
	1200	79	VARGAS
	1500	79	J. Medina
	1800	80	Medina
	2100	80	Medina
	2400	80°	K. MADRIGAL

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	78°	K. MADRIGAL
	0600	78	VARGAS
	0900	78	VARGAS
	1200	78	VARGAS
	1500	79	Medina
	1800	80	Medina
	2100	79	J. Medina
	2400	[illegible]	H. Tran

Sunday

Date	Time	Temp.	Name (Print)
10/6/24	0300	76	H. Tran
	0600	78	VARGAS
	0900	78	VARGAS
	1200	78	VARGAS
	1500	78	PRICE
	1800	78	PRICE
	2100	78	PRICE
	2400	78	C. HOUSE

Notes

UHT	ACTIVATED	DEACTIVATED
TUES. 10-1	1249	2030
WED. 10-2	1100	2130
THURS. 10-3	11:01	2115
FRI. 10-4	1101	2025
SAT. 10-5	1149	2030
SUN. 10-6	1154	

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: CTC/INF Temp. Reading Location: Above Isolation Lock
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
9-30-24	0300	71.8	J. MIRELES
	0600	71.8	Brown
	0900	71.8	Brown
	1200	71.8	Brown
	1500	71.8	[illegible]
	1800	71.8	[illegible]
	2100	72.0	[illegible]
	2400	72.1	W. Colbert

Tuesday

Date	Time	Temp.	Name (Print)
10-1-24	0300	72.1	W. Colbert
	0600	72.1	Brown
	0900	72.1	Brown
	1200	72.1	Brown
	1500	71.8	I. ALVAREZ
	1800	71.8	I. ALVAREZ
	2100	71.7	I. ALVAREZ
	2400	71.7	I. ALVAREZ

Wednesday

Date	Time	Temp.	Name (Print)
10-2-24	0300	71.8	Brown
	0600	71.8	Brown
	0900	71.8	Brown
	1200	71.8	Brown
	1500	71.2	I. ALVAREZ
	1800	71.2	I. ALVAREZ
	2100	71.2	I. ALVAREZ
	2400	71.2	[illegible]

Thursday

Date	Time	Temp.	Name (Print)
10-3-24	0300	72	[illegible]
	0600	72.3	[illegible]
	0900	72.1	[illegible]
	1200	71.2	[illegible]
	1500	71.1	I. ALVAREZ
	1800	71.1	I. ALVAREZ
	2100	71.1	I. ALVAREZ
	2400	71.3	J. Rodriguez

Friday

Date	Time	Temp.	Name (Print)
10/4/24	0300	71.8	J. Rodriguez
	0600	72.1	[illegible]
	0900	72.1	[illegible]
	1200	71.8	[illegible]
	1500	71.8	PENETTA
	1800	71.8	PENETTA
	2100	72.0	PENETTA
	2400	71.2	J. Rodriguez

Saturday

Date	Time	Temp.	Name (Print)
10/5/24	0300	72.0	J. Rodriguez
	0600	72.0	Brown
	0900	72.0	Brown
	1200	72.0	Brown
	1500	71.2	PENETTA
	1800	71.4	I. ALVAREZ
	2100	71.4	I. ALVAREZ
	2400	71.8	W. Colbert

Sunday

Date	Time	Temp.	Name (Print)
10-6-24	0300	71.2	W. Colbert
	0600	71.2	Brown
	0900	71.2	Brown
	1200	71.2	Brown
	1500	71.2	PENETTA
	1800	71.4	PENETTA
	2100	71.4	PENETTA
	2400	71.6	[illegible]

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

OUTSIDE TEMPERATURE RECORD

CDCR 2030 (04/18)

INSTITUTION: NORTH KERN STATE PRISON

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the OUTSIDE ambient air temperature.

Using an accurate thermometer located in a central, heat neutral location, the outside air temperature is to be taken every hour, seven (7) days a week.

Thermometer Location: CENTRAL CONTROL ROOF TOP

Immediately notify the Watch Commander at extension 3141 when the air temperature reaches 90 degrees.

Date	Time	Temp.	Printed Name
10/2	0100	73	C. [illegible]
	0200	71	C. [illegible]
	0300	71	C. [illegible]
	0400	68	C. [illegible]
	0500	68	C. [illegible]
	0600	67	C. VALENCIA
	0700	66	C. VALENCIA
	0800	69	C. VALENCIA
	0900	76	C. VALENCIA
	1000	84	C. VALENCIA
	1100	90	C. VALENCIA
	1200	93	C. VALENCIA
	1300	95	C. VALENCIA
	1400	97	MONCIBAIZ
	1500	99	MONCIBAIZ
	1600	97	MONCIBAIZ
	1700	99	MONCIBAIZ
	1800	97	MONCIBAIZ
	1900	93	MONCIBAIZ
	2000	91	MONCIBAIZ
	2100	85	MONCIBAIZ
	2200	79	PADILLA
	2300	75	PADILLA
	2400	75	PADILLA

UHT ACTIVATED: 1100 HRS

Date	Time	Temp.	Printed Name
10/3	0100	73	PADILLA
	0200	71	PADILLA
	0300	70	PADILLA
	0400	70	PADILLA
	0500	68	PADILLA
	0600	69	VALENCIA
	0700	67	VALENCIA
	0800	69	VALENCIA
	0900	77	VALENCIA
	1000	84	VALENCIA
	1100	89	VALENCIA
1101	1200	94	VALENCIA
	1300	98	VALENCIA
	1400	98.8	REHKOPF
	1500	101.1	REHKOPF
	1600	102.3	REHKOPF
	1700	101.8	REHKOPF
	1800	100	REHKOPF
	1900	96	REHKOPF
	2000	90.1	REHKOPF
	2100	84.1	REHKOPF
	2200	78	PADILLA
	2300	76	PADILLA
	2400	74	PADILLA

UHT ACTIVATED 1101 hrs

DISTRIBUTION: Original: Institution Heat Plan Coordinator

NKSP 10/02/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/02/24	12:15a	73.6	74.6	73.6	12	17.8	3.0	ESE	0.75	7.0	ESE	73.6	69.7	69.7	30.008	0.00	0.00	0.000	0.090
10/02/24	12:30a	72.8	73.5	72.8	13	19.0	4.0	E	1.00	6.0	ESE	72.8	68.8	68.8	30.008	0.00	0.00	0.000	0.081
10/02/24	12:45a	73.1	73.1	72.8	12	17.4	3.0	E	0.75	4.0	E	73.1	69.1	69.1	30.005	0.00	0.00	0.000	0.084
10/02/24	1:00a	73.1	73.3	73.1	14	21.0	3.0	ESE	0.75	4.0	ESE	73.1	69.3	69.3	30.002	0.00	0.00	0.000	0.084
10/02/24	1:15a	72.8	73.1	72.8	13	19.0	3.0	ESE	0.75	4.0	ESE	72.8	68.8	68.8	30.000	0.00	0.00	0.000	0.081
10/02/24	1:30a	72.0	72.8	72.0	13	18.4	3.0	ESE	0.75	6.0	ESE	72.0	67.7	67.7	29.998	0.00	0.00	0.000	0.073
10/02/24	1:45a	71.8	72.1	71.7	13	18.3	3.0	SE	0.75	6.0	ESE	71.8	67.4	67.4	30.000	0.00	0.00	0.000	0.071
10/02/24	2:00a	71.3	71.8	71.0	15	21.2	2.0	SE	0.50	4.0	SE	71.3	66.9	66.9	29.996	0.00	0.00	0.000	0.066
10/02/24	2:15a	71.0	71.5	71.0	15	21.0	3.0	ESE	0.75	5.0	ESE	71.0	66.5	66.5	29.996	0.00	0.00	0.000	0.063
10/02/24	2:30a	71.2	71.2	70.7	15	21.1	3.0	SE	0.75	5.0	ESE	71.2	66.8	66.8	29.996	0.00	0.00	0.000	0.065
10/02/24	2:45a	70.7	71.2	70.7	15	20.7	3.0	ESE	0.75	5.0	SE	70.7	66.0	66.0	29.991	0.00	0.00	0.000	0.059
10/02/24	3:00a	71.1	71.1	70.5	15	21.1	3.0	ESE	0.75	6.0	ESE	71.1	66.6	66.6	29.986	0.00	0.00	0.000	0.064
10/02/24	3:15a	70.1	71.1	70.1	17	23.2	3.0	ESE	0.75	6.0	ESE	70.1	65.3	65.3	29.985	0.00	0.00	0.000	0.053
10/02/24	3:30a	69.8	70.2	69.8	17	23.0	3.0	SE	0.75	6.0	ESE	69.8	65.0	65.0	29.982	0.00	0.00	0.000	0.050
10/02/24	3:45a	69.1	69.8	69.1	18	23.8	2.0	SE	0.50	4.0	SE	69.1	64.3	64.3	29.982	0.00	0.00	0.000	0.043
10/02/24	4:00a	68.8	69.2	68.8	20	26.1	2.0	SE	0.50	3.0	SE	68.8	64.2	64.2	29.982	0.00	0.00	0.000	0.040
10/02/24	4:15a	68.2	68.8	68.2	21	26.7	2.0	SE	0.50	3.0	SE	68.2	63.7	63.7	29.982	0.00	0.00	0.000	0.033
10/02/24	4:30a	68.4	68.5	68.2	21	26.9	2.0	SE	0.50	3.0	SE	68.4	63.9	63.9	29.982	0.00	0.00	0.000	0.035
10/02/24	4:45a	68.3	68.3	68.1	22	28.0	2.0	SE	0.50	3.0	SE	68.3	63.9	63.9	29.983	0.00	0.00	0.000	0.034
10/02/24	5:00a	68.7	68.8	68.3	20	26.0	1.0	SE	0.25	3.0	SE	68.7	64.1	64.1	29.978	0.00	0.00	0.000	0.039
10/02/24	5:15a	68.9	68.9	68.6	20	26.1	1.0	SE	0.25	4.0	SE	68.9	64.3	64.3	29.978	0.00	0.00	0.000	0.041
10/02/24	5:30a	68.8	69.1	68.8	19	24.8	3.0	SE	0.75	4.0	SE	68.8	64.1	64.1	29.978	0.00	0.00	0.000	0.040
10/02/24	5:45a	68.3	68.8	68.2	20	25.6	3.0	SE	0.75	4.0	SE	68.3	63.7	63.7	29.976	0.00	0.00	0.000	0.034
10/02/24	6:00a	67.8	68.3	67.8	22	27.5	4.0	ESE	1.00	6.0	ESE	67.8	63.4	63.4	29.980	0.00	0.00	0.000	0.029
10/02/24	6:15a	67.7	67.9	67.6	22	27.5	3.0	ESE	0.75	4.0	ESE	67.7	63.2	63.2	29.980	0.00	0.00	0.000	0.028
10/02/24	6:30a	67.2	67.7	67.1	24	29.2	3.0	ESE	0.75	4.0	ESE	67.2	62.7	62.7	29.985	0.00	0.00	0.000	0.023
10/02/24	6:45a	67.1	67.6	67.1	23	28.0	2.0	ESE	0.50	4.0	ESE	67.1	62.5	62.5	29.985	0.00	0.00	0.000	0.022
10/02/24	7:00a	66.7	67.1	66.7	22	26.6	3.0	ESE	0.75	6.0	ESE	66.7	62.0	62.0	29.986	0.00	0.00	0.000	0.018
10/02/24	7:15a	66.5	66.8	66.5	24	28.6	3.0	ESE	0.75	6.0	ESE	66.5	61.9	61.9	29.985	0.00	0.00	0.000	0.016
10/02/24	7:30a	67.5	67.5	66.5	24	29.4	3.0	ESE	0.75	6.0	ESE	67.5	63.2	63.2	29.988	0.00	0.00	0.000	0.026
10/02/24	7:45a	68.1	68.1	67.5	22	27.8	2.0	ESE	0.50	4.0	ESE	68.1	63.7	63.7	29.991	0.00	0.00	0.000	0.032
10/02/24	8:00a	69.4	69.4	68.1	19	25.3	1.0	ESE	0.25	4.0	ESE	69.4	64.7	64.7	29.995	0.00	0.00	0.000	0.046
10/02/24	8:15a	70.6	70.6	69.4	18	25.0	1.0	ESE	0.25	4.0	ESE	70.6	66.2	66.2	29.994	0.00	0.00	0.000	0.058
10/02/24	8:30a	72.2	72.2	70.6	15	21.9	1.0	SE	0.25	4.0	SE	72.2	68.2	68.2	29.997	0.00	0.00	0.000	0.075
10/02/24	8:45a	74.6	74.6	72.3	11	16.6	1.0	SE	0.25	3.0	SE	74.6	70.9	70.9	29.994	0.00	0.00	0.000	0.100
10/02/24	9:00a	76.9	76.9	74.6	6	4.7	0.0	SE	0.00	1.0	SE	76.9	72.8	72.8	29.998	0.00	0.00	0.000	0.124
10/02/24	9:15a	79.1	79.1	76.9	3	-8.4	1.0	SE	0.25	3.0	N	79.1	75.0	75.0	29.999	0.00	0.00	0.000	0.147
10/02/24	9:30a	81.2	81.2	79.1	0	---	1.0	SE	0.25	4.0	SE	81.2	76.6	76.6	29.999	0.00	0.00	0.000	0.169
10/02/24	9:45a	82.2	82.2	81.2	0	---	2.0	SE	0.50	4.0	SE	82.2	77.6	77.6	30.002	0.00	0.00	0.000	0.179
10/02/24	10:00a	84.2	84.2	82.2	0	---	2.0	SE	0.50	4.0	SE	84.2	79.3	79.3	30.003	0.00	0.00	0.000	0.200
10/02/24	10:15a	85.1	85.1	84.1	0	---	2.0	ESE	0.50	4.0	SE	85.1	80.1	80.1	30.005	0.00	0.00	0.000	0.209
10/02/24	10:30a	87.0	87.0	85.1	0	---	1.0	SE	0.25	4.0	SSE	87.0	81.6	81.6	30.001	0.00	0.00	0.000	0.229
10/02/24	10:45a	88.3	88.3	87.0	0	---	1.0	ESE	0.25	3.0	SE	88.3	82.6	82.6	29.997	0.00	0.00	0.000	0.243
10/02/24	11:00a	90.1	90.1	88.2	0	---	2.0	SSE	0.50	6.0	SSE	90.1	84.1	84.1	29.989	0.00	0.00	0.000	0.261
10/02/24	11:15a	91.1	91.1	90.1	0	---	2.0	SSE	0.50	7.0	SSE	91.1	84.8	84.8	29.979	0.00	0.00	0.000	0.272
10/02/24	11:30a	91.9	91.9	91.0	0	---	2.0	S	0.50	5.0	S	91.9	85.4	85.4	29.976	0.00	0.00	0.000	0.280
10/02/24	11:45a	93.5	93.5	91.9	0	---	2.0	SE	0.50	7.0	SE	93.5	86.6	86.6	29.973	0.00	0.00	0.000	0.297
10/02/24	12:00p	93.1	93.5	93.1	0	---	2.0	SE	0.50	5.0	SE	93.1	86.3	86.3	29.970	0.00	0.00	0.000	0.293
10/02/24	12:15p	94.3	94.3	93.1	0	---	2.0	SSW	0.50	7.0	W	94.3	87.2	87.2	29.960	0.00	0.00	0.000	0.305
10/02/24	12:30p	94.9	95.2	94.3	0	---	2.0	SW	0.50	6.0	SSW	94.9	87.6	87.6	29.953	0.00	0.00	0.000	0.311

NKSP 10/02/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/02/24	12:45p	95.1	95.1	94.3	0	---	3.0	NE	0.75	8.0	W	95.1	87.8	87.8	29.946	0.00	0.00	0.000	0.314
10/02/24	1:00p	95.8	96.3	95.1	0	---	3.0	SSW	0.75	7.0	NW	95.8	88.3	88.3	29.938	0.00	0.00	0.000	0.321
10/02/24	1:15p	96.9	96.9	95.8	0	---	2.0	SW	0.50	6.0	WSW	96.9	89.1	89.1	29.930	0.00	0.00	0.000	0.332
10/02/24	1:30p	96.6	97.2	96.5	0	---	3.0	W	0.75	8.0	NW	96.6	88.9	88.9	29.922	0.00	0.00	0.000	0.329
10/02/24	1:45p	96.4	96.6	96.0	0	---	4.0	N	1.00	9.0	WNW	96.4	88.7	88.7	29.911	0.00	0.00	0.000	0.327
10/02/24	2:00p	97.0	97.1	96.4	0	---	4.0	W	1.00	8.0	NW	97.0	89.2	89.2	29.904	0.00	0.00	0.000	0.333
10/02/24	2:15p	98.0	98.0	97.1	0	---	4.0	W	1.00	9.0	W	98.0	89.9	89.9	29.898	0.00	0.00	0.000	0.344
10/02/24	2:30p	98.1	98.1	97.8	0	---	3.0	SW	0.75	8.0	W	98.1	90.0	90.0	29.893	0.00	0.00	0.000	0.345
10/02/24	2:45p	99.2	99.3	98.1	0	---	4.0	W	1.00	10.0	W	99.2	90.7	90.7	29.887	0.00	0.00	0.000	0.356
10/02/24	3:00p	99.1	99.2	98.8	0	---	4.0	WNW	1.00	9.0	W	99.1	90.7	90.7	29.881	0.00	0.00	0.000	0.355
10/02/24	3:15p	99.5	99.5	98.8	0	---	4.0	W	1.00	8.0	NW	99.5	90.9	90.9	29.876	0.00	0.00	0.000	0.359
10/02/24	3:30p	99.9	99.9	99.4	0	---	3.0	WNW	0.75	9.0	WSW	99.9	91.2	91.2	29.873	0.00	0.00	0.000	0.364
10/02/24	3:45p	99.9	100.2	99.8	0	---	3.0	NW	0.75	8.0	W	99.9	91.2	91.2	29.869	0.00	0.00	0.000	0.364
10/02/24	4:00p	99.7	100.0	99.6	0	---	4.0	WNW	1.00	9.0	NW	99.7	91.1	91.1	29.866	0.00	0.00	0.000	0.361
10/02/24	4:15p	100.0	100.1	99.6	0	---	5.0	WNW	1.25	10.0	W	100.0	91.3	91.3	29.860	0.00	0.00	0.000	0.365
10/02/24	4:30p	100.1	100.1	99.9	0	---	5.0	WNW	1.25	9.0	WNW	100.1	91.4	91.4	29.857	0.00	0.00	0.000	0.366
10/02/24	4:45p	100.3	100.4	100.0	0	---	5.0	WNW	1.25	10.0	WNW	100.3	91.5	91.5	29.854	0.00	0.00	0.000	0.368
10/02/24	5:00p	99.9	100.3	99.8	0	---	6.0	WNW	1.50	10.0	W	99.9	91.2	91.2	29.850	0.00	0.00	0.000	0.364
10/02/24	5:15p	99.6	99.9	99.6	0	---	6.0	WNW	1.50	10.0	W	99.6	91.0	91.0	29.848	0.00	0.00	0.000	0.360
10/02/24	5:30p	99.2	99.6	99.2	0	---	4.0	WNW	1.00	9.0	WNW	99.2	90.7	90.7	29.850	0.00	0.00	0.000	0.356
10/02/24	5:45p	98.6	99.2	98.6	0	---	4.0	WNW	1.00	9.0	W	98.6	90.3	90.3	29.850	0.00	0.00	0.000	0.350
10/02/24	6:00p	97.7	98.7	97.7	0	---	3.0	WNW	0.75	6.0	W	97.7	89.7	89.7	29.847	0.00	0.00	0.000	0.341
10/02/24	6:15p	96.5	97.7	96.5	0	---	3.0	WNW	0.75	6.0	WNW	96.5	88.8	88.8	29.846	0.00	0.00	0.000	0.328
10/02/24	6:30p	95.1	96.5	95.1	0	---	3.0	W	0.75	6.0	W	95.1	87.8	87.8	29.846	0.00	0.00	0.000	0.314
10/02/24	6:45p	93.9	95.1	93.9	0	---	2.0	N	0.50	4.0	WNW	93.9	86.9	86.9	29.847	0.00	0.00	0.000	0.301
10/02/24	7:00p	93.5	93.9	93.5	0	---	2.0	N	0.50	3.0	WNW	93.5	86.6	86.6	29.850	0.00	0.00	0.000	0.297
10/02/24	7:15p	93.3	93.5	93.2	0	---	2.0	WNW	0.50	3.0	WNW	93.3	86.4	86.4	29.857	0.00	0.00	0.000	0.295
10/02/24	7:30p	92.7	93.6	92.7	0	---	1.0	WNW	0.25	4.0	WNW	92.7	86.0	86.0	29.859	0.00	0.00	0.000	0.289
10/02/24	7:45p	90.4	92.6	90.4	0	---	0.0	WNW	0.00	1.0	WNW	90.4	84.3	84.3	29.861	0.00	0.00	0.000	0.265
10/02/24	8:00p	91.0	91.0	90.4	0	---	2.0	N	0.50	3.0	N	91.0	84.7	84.7	29.862	0.00	0.00	0.000	0.271
10/02/24	8:15p	91.3	91.4	90.9	0	---	3.0	WNW	0.75	4.0	N	91.3	84.9	84.9	29.862	0.00	0.00	0.000	0.274
10/02/24	8:30p	87.6	91.2	87.5	0	---	3.0	ENE	0.75	4.0	ENE	87.6	82.1	82.1	29.865	0.00	0.00	0.000	0.235
10/02/24	8:45p	86.0	87.6	86.0	0	---	2.0	ENE	0.50	4.0	ENE	86.0	80.8	80.8	29.869	0.00	0.00	0.000	0.219
10/02/24	9:00p	85.1	86.0	85.0	0	---	3.0	ESE	0.75	6.0	ESE	85.1	80.1	80.1	29.873	0.00	0.00	0.000	0.209
10/02/24	9:15p	83.1	85.1	83.1	0	---	2.0	SE	0.50	4.0	SE	83.1	78.4	78.4	29.877	0.00	0.00	0.000	0.189
10/02/24	9:30p	81.9	83.1	81.9	1	-28.0	3.0	SE	0.75	5.0	SE	81.9	77.4	77.4	29.877	0.00	0.00	0.000	0.176
10/02/24	9:45p	80.3	81.9	80.3	5	3.1	4.0	SE	1.00	5.0	SE	80.3	76.2	76.2	29.879	0.00	0.00	0.000	0.159
10/02/24	10:00p	79.0	80.3	78.9	7	9.6	4.0	ESE	1.00	6.0	ESE	79.0	75.3	75.3	29.880	0.00	0.00	0.000	0.146
10/02/24	10:15p	77.7	79.0	77.6	10	16.7	4.0	SE	1.00	6.0	ESE	77.7	74.1	74.1	29.884	0.00	0.00	0.000	0.132
10/02/24	10:30p	77.0	77.6	76.9	12	20.5	3.0	SE	0.75	5.0	SE	77.0	73.8	73.8	29.888	0.00	0.00	0.000	0.125
10/02/24	10:45p	76.4	76.9	76.4	12	20.0	3.0	SE	0.75	6.0	ESE	76.4	73.1	73.1	29.886	0.00	0.00	0.000	0.119
10/02/24	11:00p	75.8	76.4	75.8	13	19.5	4.0	ESE	1.00	8.0	S	75.8	72.5	72.5	29.891	0.00	0.00	0.000	0.113
10/02/24	11:15p	74.1	75.8	74.0	17	26.5	3.0	SSE	0.75	7.0	S	74.1	71.1	71.1	29.893	0.00	0.00	0.000	0.095
10/02/24	11:30p	74.1	74.2	74.0	18	27.9	3.0	SE	0.75	5.0	SE	74.1	71.2	71.2	29.899	0.00	0.00	0.000	0.095
10/02/24	11:45p	74.3	74.3	73.8	16	25.2	4.0	ESE	1.00	7.0	ESE	74.3	71.2	71.2	29.894	0.00	0.00	0.000	0.097
10/03/24	12:00a	75.0	75.1	74.3	15	24.2	4.0	SE	1.00	7.0	SE	75.0	72.0	72.0	29.893	0.00	0.00	0.000	0.104

NKSP 10/03/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/03/24	12:15a	73.6	75.0	73.6	17	26.1	4.0	SE	1.00	7.0	SE	73.6	70.4	70.4	29.891	0.00	0.00	0.000	0.090
10/03/24	12:30a	73.3	73.7	73.3	17	25.8	6.0	ESE	1.50	8.0	SE	73.3	70.0	70.0	29.889	0.00	0.00	0.000	0.086
10/03/24	12:45a	73.0	73.3	73.0	15	22.6	5.0	ESE	1.25	8.0	SE	73.0	69.3	69.3	29.891	0.00	0.00	0.000	0.083
10/03/24	1:00a	73.0	73.1	72.9	13	19.2	3.0	ESE	0.75	6.0	ESE	73.0	69.1	69.1	29.887	0.00	0.00	0.000	0.083
10/03/24	1:15a	72.8	73.3	72.8	11	15.2	3.0	SE	0.75	5.0	SE	72.8	68.5	68.5	29.888	0.00	0.00	0.000	0.081
10/03/24	1:30a	72.8	72.8	72.5	12	17.2	2.0	SE	0.50	4.0	SE	72.8	68.7	68.7	29.886	0.00	0.00	0.000	0.081
10/03/24	1:45a	72.4	72.8	72.4	13	18.7	1.0	SE	0.25	3.0	SE	72.4	68.2	68.2	29.886	0.00	0.00	0.000	0.077
10/03/24	2:00a	71.9	72.5	71.8	13	18.3	2.0	SE	0.50	3.0	SE	71.9	67.5	67.5	29.885	0.00	0.00	0.000	0.072
10/03/24	2:15a	71.8	71.8	71.4	14	20.0	2.0	SE	0.50	3.0	SE	71.8	67.5	67.5	29.885	0.00	0.00	0.000	0.071
10/03/24	2:30a	71.8	71.9	71.7	13	18.3	3.0	SE	0.75	4.0	SE	71.8	67.4	67.4	29.885	0.00	0.00	0.000	0.071
10/03/24	2:45a	71.6	72.0	71.6	15	21.5	3.0	ESE	0.75	6.0	ESE	71.6	67.3	67.3	29.880	0.00	0.00	0.000	0.069
10/03/24	3:00a	70.6	71.6	70.6	17	23.6	2.0	ESE	0.50	4.0	ESE	70.6	66.1	66.1	29.881	0.00	0.00	0.000	0.058
10/03/24	3:15a	69.9	70.6	69.9	16	21.6	2.0	ESE	0.50	3.0	ESE	69.9	65.0	65.0	29.875	0.00	0.00	0.000	0.051
10/03/24	3:30a	69.9	69.9	69.6	16	21.6	2.0	ESE	0.50	3.0	ESE	69.9	65.0	65.0	29.876	0.00	0.00	0.000	0.051
10/03/24	3:45a	69.6	69.9	69.4	17	22.8	2.0	SE	0.50	3.0	SE	69.6	64.8	64.8	29.876	0.00	0.00	0.000	0.048
10/03/24	4:00a	70.0	70.3	69.5	16	21.7	2.0	SE	0.50	3.0	SE	70.0	65.1	65.1	29.871	0.00	0.00	0.000	0.052
10/03/24	4:15a	69.5	70.0	69.3	17	22.7	3.0	ESE	0.75	6.0	ESE	69.5	64.6	64.6	29.870	0.00	0.00	0.000	0.047
10/03/24	4:30a	69.5	69.7	69.5	16	21.3	3.0	ESE	0.75	6.0	ESE	69.5	64.6	64.6	29.868	0.00	0.00	0.000	0.047
10/03/24	4:45a	70.0	70.0	69.4	18	24.5	3.0	ESE	0.75	4.0	ESE	70.0	65.3	65.3	29.869	0.00	0.00	0.000	0.052
10/03/24	5:00a	68.9	70.1	68.9	19	24.9	3.0	ESE	0.75	4.0	ESE	68.9	64.2	64.2	29.873	0.00	0.00	0.000	0.041
10/03/24	5:15a	69.4	69.5	68.8	16	21.2	2.0	ESE	0.50	4.0	ESE	69.4	64.4	64.4	29.876	0.00	0.00	0.000	0.046
10/03/24	5:30a	69.8	69.8	69.4	15	20.0	2.0	ESE	0.50	3.0	ESE	69.8	64.8	64.8	29.874	0.00	0.00	0.000	0.050
10/03/24	5:45a	70.5	70.7	69.7	14	19.0	1.0	ESE	0.25	3.0	ESE	70.5	65.7	65.7	29.872	0.00	0.00	0.000	0.057
10/03/24	6:00a	69.6	70.6	69.6	16	21.4	0.0	ESE	0.00	2.0	ESE	69.6	64.7	64.7	29.875	0.00	0.00	0.000	0.048
10/03/24	6:15a	68.1	69.6	68.1	16	20.2	1.0	ESE	0.25	3.0	ESE	68.1	63.0	63.0	29.872	0.00	0.00	0.000	0.032
10/03/24	6:30a	67.9	68.1	67.6	18	22.8	1.0	ESE	0.25	3.0	ESE	67.9	63.0	63.0	29.879	0.00	0.00	0.000	0.030
10/03/24	6:45a	68.0	68.0	67.8	20	25.4	2.0	ESE	0.50	3.0	ESE	68.0	63.4	63.4	29.880	0.00	0.00	0.000	0.031
10/03/24	7:00a	67.5	68.0	67.4	20	25.0	1.0	ESE	0.25	3.0	ESE	67.5	62.8	62.8	29.885	0.00	0.00	0.000	0.026
10/03/24	7:15a	67.2	67.5	67.1	20	24.7	0.0	ESE	0.00	2.0	ESE	67.2	62.4	62.4	29.890	0.00	0.00	0.000	0.023
10/03/24	7:30a	67.7	67.7	67.2	20	25.1	0.0	ESE	0.00	2.0	ESE	67.7	63.0	63.0	29.892	0.00	0.00	0.000	0.028
10/03/24	7:45a	68.4	68.4	67.7	19	24.5	0.0	ESE	0.00	1.0	ESE	68.4	63.7	63.7	29.898	0.00	0.00	0.000	0.035
10/03/24	8:00a	69.4	69.4	68.3	18	24.0	0.0	ESE	0.00	1.0	ESE	69.4	64.6	64.6	29.899	0.00	0.00	0.000	0.046
10/03/24	8:15a	72.6	72.6	69.4	14	20.6	0.0	ESE	0.00	1.0	ESE	72.6	68.6	68.6	29.897	0.00	0.00	0.000	0.079
10/03/24	8:30a	74.6	74.6	72.6	9	12.0	0.0	ESE	0.00	1.0	ESE	74.6	70.7	70.7	29.902	0.00	0.00	0.000	0.100
10/03/24	8:45a	76.9	76.9	74.7	4	-4.0	0.0	ESE	0.00	2.0	ESE	76.9	72.6	72.6	29.905	0.00	0.00	0.000	0.124
10/03/24	9:00a	77.6	77.6	76.9	2	-17.5	0.0	ESE	0.00	2.0	SE	77.6	73.4	73.4	29.906	0.00	0.00	0.000	0.131
10/03/24	9:15a	79.8	79.8	77.6	---	---	0.0	ESE	0.00	2.0	ESE	79.8	---	---	29.908	0.00	0.00	0.000	0.154
10/03/24	9:30a	81.2	81.2	79.8	0	---	0.0	ESE	0.00	1.0	ESE	81.2	76.6	76.6	29.909	0.00	0.00	0.000	0.169
10/03/24	9:45a	83.2	83.2	81.2	0	---	0.0	SSW	0.00	3.0	SSW	83.2	78.5	78.5	29.907	0.00	0.00	0.000	0.190
10/03/24	10:00a	84.8	84.8	83.2	0	---	1.0	SSW	0.25	4.0	SW	84.8	79.8	79.8	29.906	0.00	0.00	0.000	0.206
10/03/24	10:15a	86.4	86.4	84.8	0	---	2.0	N	0.50	4.0	W	86.4	81.1	81.1	29.905	0.00	0.00	0.000	0.223
10/03/24	10:30a	87.9	87.9	86.4	0	---	2.0	SW	0.50	5.0	SW	87.9	82.3	82.3	29.904	0.00	0.00	0.000	0.239
10/03/24	10:45a	88.9	88.9	87.9	0	---	2.0	SW	0.50	5.0	SW	88.9	83.1	83.1	29.902	0.00	0.00	0.000	0.249
10/03/24	11:00a	89.9	89.9	88.9	0	---	3.0	SSW	0.75	6.0	SSW	89.9	83.9	83.9	29.900	0.00	0.00	0.000	0.259
10/03/24	11:15a	91.2	91.2	89.9	0	---	2.0	SSW	0.50	5.0	S	91.2	84.9	84.9	29.897	0.00	0.00	0.000	0.273
10/03/24	11:30a	92.4	92.4	91.1	0	---	2.0	SSW	0.50	7.0	WSW	92.4	85.8	85.8	29.896	0.00	0.00	0.000	0.285
10/03/24	11:45a	93.8	93.0	92.4	0	---	3.0	SW	0.75	7.0	S	92.8	86.1	86.1	29.891	0.00	0.00	0.000	0.290
10/03/24	12:00p	94.2	94.2	92.9	0	---	3.0	SSW	0.75	7.0	SW	94.2	87.1	87.1	29.886	0.00	0.00	0.000	0.304
10/03/24	12:15p	94.8	94.8	94.1	0	---	4.0	SW	1.00	8.0	W	94.8	87.6	87.6	29.882	0.00	0.00	0.000	0.310
10/03/24	12:30p	96.2	96.2	94.8	0	---	3.0	SSW	0.75	8.0	SSW	96.2	88.6	88.6	39.876	0.00	0.00	0.000	0.325

NKSP 10/03/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/03/24	12:45p	97.4	97.4	96.2	0	---	2.0	SSE	0.50	6.0	SSW	97.4	89.5	89.5	29.873	0.00	0.00	0.000	0.338
10/03/24	1:00p	98.1	98.1	97.5	0	---	4.0	SSW	1.00	8.0	SW	98.1	90.0	90.0	29.867	0.00	0.00	0.000	0.345
10/03/24	1:15p	98.5	98.5	97.8	0	---	3.0	SW	0.75	9.0	SW	98.5	90.3	90.3	29.861	0.00	0.00	0.000	0.349
10/03/24	1:30p	99.4	99.5	98.5	0	---	5.0	SW	1.25	9.0	SW	99.4	90.9	90.9	29.849	0.00	0.00	0.000	0.358
10/03/24	1:45p	98.5	99.4	98.5	0	---	5.0	NW	1.25	9.0	N	98.5	90.3	90.3	29.844	0.00	0.00	0.000	0.349
10/03/24	2:00p	98.8	98.9	98.4	0	---	5.0	WNW	1.25	10.0	W	98.8	90.5	90.5	29.839	0.00	0.00	0.000	0.352
10/03/24	2:15p	99.9	99.9	98.8	0	---	4.0	NW	1.00	9.0	NW	99.9	91.2	91.2	29.834	0.00	0.00	0.000	0.364
10/03/24	2:30p	100.5	100.8	99.9	0	---	5.0	W	1.25	10.0	N	100.5	91.7	91.7	29.830	0.00	0.00	0.000	0.370
10/03/24	2:45p	100.9	101.0	100.5	0	---	6.0	NW	1.50	12.0	WNW	100.9	92.0	92.0	29.825	0.00	0.00	0.000	0.374
10/03/24	3:00p	101.1	101.2	100.9	0	---	6.0	WNW	1.50	11.0	WSW	101.1	92.2	92.2	29.823	0.00	0.00	0.000	0.376
10/03/24	3:15p	101.3	101.4	101.1	0	---	4.0	NW	1.00	11.0	WNW	101.3	92.3	92.3	29.820	0.00	0.00	0.000	0.378
10/03/24	3:30p	101.4	101.6	101.3	0	---	5.0	WNW	1.25	9.0	WNW	101.4	92.4	92.4	29.818	0.00	0.00	0.000	0.379
10/03/24	3:45p	102.1	102.2	101.4	0	---	3.0	WNW	0.75	9.0	NW	102.1	92.9	92.9	29.814	0.00	0.00	0.000	0.386
10/03/24	4:00p	102.3	102.3	102.1	0	---	5.0	W	1.25	9.0	WNW	102.3	93.0	93.0	29.815	0.00	0.00	0.000	0.389
10/03/24	4:15p	102.3	102.3	102.1	0	---	5.0	WNW	1.25	9.0	WNW	102.3	93.0	93.0	29.816	0.00	0.00	0.000	0.389
10/03/24	4:30p	102.0	102.3	102.0	0	---	6.0	W	1.50	10.0	W	102.0	92.8	92.8	29.813	0.00	0.00	0.000	0.385
10/03/24	4:45p	102.2	102.2	102.0	0	---	5.0	WNW	1.25	9.0	W	102.2	92.9	92.9	29.812	0.00	0.00	0.000	0.387
10/03/24	5:00p	101.8	102.3	101.8	0	---	5.0	NW	1.25	9.0	NNW	101.8	92.7	92.7	29.812	0.00	0.00	0.000	0.383
10/03/24	5:15p	101.8	101.9	101.7	0	---	4.0	NW	1.00	8.0	NNW	101.8	92.7	92.7	29.809	0.00	0.00	0.000	0.383
10/03/24	5:30p	101.2	101.9	101.2	0	---	4.0	NNW	1.00	8.0	NW	101.2	92.2	92.2	29.805	0.00	0.00	0.000	0.377
10/03/24	5:45p	100.7	101.2	100.7	0	---	4.0	NNW	1.00	6.0	NNW	100.7	91.9	91.9	29.807	0.00	0.00	0.000	0.372
10/03/24	6:00p	100.0	100.7	100.0	0	---	3.0	N	0.75	5.0	NNW	100.0	91.3	91.3	29.806	0.00	0.00	0.000	0.365
10/03/24	6:15p	98.8	100.0	98.8	0	---	2.0	N	0.50	4.0	N	98.8	90.5	90.5	29.804	0.00	0.00	0.000	0.352
10/03/24	6:30p	98.2	98.7	98.2	0	---	2.0	NNW	0.50	3.0	NNW	98.2	90.0	90.0	29.808	0.00	0.00	0.000	0.346
10/03/24	6:45p	96.7	98.2	96.7	0	---	1.0	NNW	0.25	3.0	NNW	96.7	89.0	89.0	29.809	0.00	0.00	0.000	0.330
10/03/24	7:00p	96.0	96.7	96.0	0	---	1.0	NNW	0.25	2.0	NNW	96.0	88.4	88.4	29.807	0.00	0.00	0.000	0.323
10/03/24	7:15p	95.2	96.0	95.1	0	---	2.0	N	0.50	3.0	N	95.2	87.8	87.8	29.810	0.00	0.00	0.000	0.315
10/03/24	7:30p	93.7	95.2	93.7	0	---	1.0	ENE	0.25	2.0	N	93.7	86.8	86.8	29.815	0.00	0.00	0.000	0.299
10/03/24	7:45p	92.1	93.7	92.1	0	---	1.0	ENE	0.25	3.0	ENE	92.1	85.6	85.6	29.813	0.00	0.00	0.000	0.282
10/03/24	8:00p	90.6	92.1	90.6	0	---	2.0	ENE	0.50	3.0	ENE	90.6	84.4	84.4	29.817	0.00	0.00	0.000	0.267
10/03/24	8:15p	88.7	90.5	88.7	0	---	1.0	ENE	0.25	3.0	N	88.7	83.0	83.0	29.821	0.00	0.00	0.000	0.247
10/03/24	8:30p	87.2	88.6	87.1	0	---	2.0	E	0.50	3.0	E	87.2	81.8	81.8	29.827	0.00	0.00	0.000	0.231
10/03/24	8:45p	85.5	87.2	85.5	0	---	2.0	ESE	0.50	3.0	E	85.5	80.4	80.4	29.832	0.00	0.00	0.000	0.214
10/03/24	9:00p	84.1	85.5	84.1	0	---	3.0	ESE	0.75	4.0	ESE	84.1	79.2	79.2	29.842	0.00	0.00	0.000	0.199
10/03/24	9:15p	82.7	84.1	82.7	0	---	3.0	SE	0.75	6.0	ESE	82.7	78.0	78.0	29.844	0.00	0.00	0.000	0.184
10/03/24	9:30p	81.4	82.6	81.4	3	-6.9	3.0	SE	0.75	6.0	ESE	81.4	77.0	77.0	29.852	0.00	0.00	0.000	0.171
10/03/24	9:45p	80.0	81.4	80.0	5	2.9	3.0	SE	0.75	7.0	SE	80.0	75.9	75.9	29.854	0.00	0.00	0.000	0.156
10/03/24	10:00p	78.7	80.0	78.5	7	9.4	4.0	SE	1.00	5.0	SE	78.7	75.0	75.0	29.858	0.00	0.00	0.000	0.143
10/03/24	10:15p	78.3	78.7	78.0	6	5.7	2.0	SE	0.50	4.0	SE	78.3	74.6	74.6	29.861	0.00	0.00	0.000	0.139
10/03/24	10:30p	77.0	78.4	77.0	9	13.8	3.0	SSE	0.75	6.0	S	77.0	73.4	73.4	29.666	0.00	0.00	0.000	0.125
10/03/24	10:45p	76.7	77.3	76.7	9	13.6	2.0	SSE	0.50	4.0	SSE	76.7	73.0	73.0	29.872	0.00	0.00	0.000	0.122
10/03/24	11:00p	76.0	76.7	76.0	12	19.7	3.0	SE	0.75	4.0	SE	76.0	72.7	72.7	29.875	0.00	0.00	0.000	0.115
10/03/24	11:15p	75.6	76.0	75.5	13	21.2	3.0	SE	0.75	4.0	SE	75.6	72.4	72.4	29.877	0.00	0.00	0.000	0.110
10/03/24	11:30p	76.1	76.1	75.5	12	19.8	2.0	SE	0.50	4.0	SE	76.1	72.8	72.8	29.878	0.00	0.00	0.000	0.116
10/03/24	11:45p	75.7	76.1	75.6	10	15.2	2.0	SE	0.50	5.0	SE	75.7	72.1	72.1	29.882	0.00	0.00	0.000	0.111
10/04/24	12:00a	74.7	75.6	74.6	10	14.5	2.0	SE	0.50	4.0	SE	74.7	70.9	70.9	29.885	0.00	0.00	0.000	0.101

NKSP 10/02/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/02/24	12:15a	77.9	52	58.9	78.0	9.49	.0728	351	1	100.0	15
10/02/24	12:30a	77.8	50	57.7	77.8	9.19	.0729	351	1	100.0	15
10/02/24	12:45a	77.8	49	57.1	77.6	8.99	.0729	351	1	100.0	15
10/02/24	1:00a	77.4	53	58.9	77.5	9.65	.0729	351	1	100.0	15
10/02/24	1:15a	77.3	49	56.6	77.1	9.00	.0730	351	1	100.0	15
10/02/24	1:30a	77.5	54	59.5	77.7	9.80	.0728	352	1	100.0	15
10/02/24	1:45a	77.2	51	57.7	77.2	9.35	.0729	351	1	100.0	15
10/02/24	2:00a	77.6	51	58.0	77.6	9.35	.0729	351	1	100.0	15
10/02/24	2:15a	77.3	52	58.3	77.3	9.50	.0729	351	1	100.0	15
10/02/24	2:30a	77.4	49	56.7	77.2	9.00	.0729	352	1	100.0	15
10/02/24	2:45a	77.1	53	58.6	77.2	9.65	.0729	351	1	100.0	15
10/02/24	3:00a	77.2	49	56.6	77.0	9.01	.0729	351	1	100.0	15
10/02/24	3:15a	77.2	54	59.3	77.4	9.81	.0728	351	1	100.0	15
10/02/24	3:30a	77.0	50	56.9	76.9	9.21	.0729	352	1	100.0	15
10/02/24	3:45a	77.3	54	59.4	77.5	9.80	.0728	351	1	100.0	15
10/02/24	4:00a	76.9	51	57.4	76.9	9.35	.0729	351	1	100.0	15
10/02/24	4:15a	77.3	54	59.4	77.5	9.80	.0728	351	1	100.0	15
10/02/24	4:30a	76.9	52	57.9	76.9	9.51	.0729	351	1	100.0	15
10/02/24	4:45a	77.3	52	58.3	77.3	9.50	.0728	352	1	100.0	15
10/02/24	5:00a	76.7	52	57.7	76.7	9.52	.0729	351	1	100.0	15
10/02/24	5:15a	77.1	51	57.6	77.1	9.35	.0729	351	1	100.0	15
10/02/24	5:30a	76.6	53	58.2	76.7	9.65	.0729	351	1	100.0	15
10/02/24	5:45a	77.1	49	56.5	76.9	9.01	.0729	352	1	100.0	15
10/02/24	6:00a	76.5	55	59.1	76.7	9.99	.0729	351	1	100.0	15
10/02/24	6:15a	76.3	51	56.8	76.3	9.35	.0730	351	1	100.0	15
10/02/24	6:30a	76.6	55	59.2	76.8	9.99	.0729	351	1	100.0	15
10/02/24	6:45a	76.7	53	58.3	76.8	9.65	.0729	352	1	100.0	15
10/02/24	7:00a	77.2	52	58.2	77.2	9.51	.0729	351	1	100.0	15
10/02/24	7:15a	76.9	54	59.0	77.0	9.81	.0729	351	1	100.0	15
10/02/24	7:30a	77.0	50	56.9	76.9	9.21	.0730	351	1	100.0	15
10/02/24	7:45a	77.0	55	59.6	77.2	9.97	.0729	351	1	100.0	15
10/02/24	8:00a	76.9	53	58.5	77.0	9.65	.0729	352	1	100.0	15
10/02/24	8:15a	77.2	53	58.7	77.3	9.65	.0729	351	1	100.0	15
10/02/24	8:30a	77.1	55	59.7	77.3	9.97	.0728	351	1	100.0	15
10/02/24	8:45a	77.3	50	57.2	77.2	9.20	.0729	351	1	100.0	15
10/02/24	9:00a	77.4	55	60.0	77.6	9.95	.0728	352	1	100.0	15
10/02/24	9:15a	77.3	53	58.8	77.4	9.65	.0729	351	1	100.0	15
10/02/24	9:30a	77.7	50	57.6	77.7	9.20	.0729	351	1	100.0	15
10/02/24	9:45a	77.6	54	59.6	77.8	9.80	.0728	351	1	100.0	15
10/02/24	10:00a	77.7	50	57.6	77.7	9.20	.0729	351	1	100.0	15
10/02/24	10:15a	78.1	50	57.9	78.1	9.19	.0728	352	1	100.0	15
10/02/24	10:30a	78.1	53	59.6	78.3	9.65	.0727	351	1	100.0	15
10/02/24	10:45a	78.1	49	57.4	78.0	8.99	.0728	351	1	100.0	15
10/02/24	11:00a	78.4	49	57.7	78.3	8.98	.0727	351	1	100.0	15
10/02/24	11:15a	78.6	51	59.0	78.7	9.35	.0726	352	1	100.0	15
10/02/24	11:30a	78.6	49	57.8	78.5	8.98	.0727	351	1	100.0	15
10/02/24	11:45a	78.8	46	56.3	78.3	8.47	.0727	351	1	100.0	15
10/02/24	12:00p	79.1	47	57.1	78.7	8.67	.0726	351	1	100.0	15
10/02/24	12:15p	78.9	48	57.5	78.7	8.87	.0726	352	1	100.0	15
10/02/24	12:30p	79.1	44	55.3	78.4	8.17	.0727	351	1	100.0	15

NKSP 10/02/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/02/24	12:45p	79.2	45	56.0	78.6	8.37	.0726	351	1	100.0	15
10/02/24	1:00p	79.2	43	54.8	78.4	8.05	.0726	351	1	100.0	15
10/02/24	1:15p	79.0	44	55.2	78.3	8.17	.0726	351	1	100.0	15
10/02/24	1:30p	79.4	43	55.0	78.5	8.05	.0726	352	1	100.0	15
10/02/24	1:45p	79.3	41	53.6	78.2	7.75	.0726	351	1	100.0	15
10/02/24	2:00p	79.3	41	53.6	78.2	7.75	.0726	351	1	100.0	15
10/02/24	2:15p	79.5	40	53.1	78.3	7.56	.0726	351	1	100.0	15
10/02/24	2:30p	79.8	40	53.3	78.5	7.55	.0725	352	1	100.0	15
10/02/24	2:45p	79.7	39	52.5	78.3	7.46	.0725	351	1	100.0	15
10/02/24	3:00p	79.8	39	52.6	78.4	7.45	.0725	351	1	100.0	15
10/02/24	3:15p	79.7	38	51.8	78.3	7.26	.0725	351	1	100.0	15
10/02/24	3:30p	79.7	38	51.8	78.3	7.26	.0725	352	1	100.0	15
10/02/24	3:45p	79.7	38	51.8	78.3	7.26	.0725	351	1	100.0	15
10/02/24	4:00p	79.5	38	51.7	78.1	7.26	.0725	351	1	100.0	15
10/02/24	4:15p	79.5	38	51.7	78.1	7.26	.0725	351	1	100.0	15
10/02/24	4:30p	79.5	38	51.7	78.1	7.26	.0725	351	1	100.0	15
10/02/24	4:45p	79.6	38	51.8	78.2	7.26	.0725	352	1	100.0	15
10/02/24	5:00p	79.7	38	51.8	78.3	7.26	.0724	351	1	100.0	15
10/02/24	5:15p	79.6	37	51.0	78.1	7.16	.0725	351	1	100.0	15
10/02/24	5:30p	79.7	37	51.1	78.2	7.16	.0725	351	1	100.0	15
10/02/24	5:45p	79.3	37	50.8	77.8	7.16	.0725	352	1	100.0	15
10/02/24	6:00p	79.5	41	53.7	78.4	7.75	.0724	351	1	100.0	15
10/02/24	6:15p	79.8	38	51.9	78.4	7.25	.0724	351	1	100.0	15
10/02/24	6:30p	79.4	37	50.9	77.9	7.16	.0725	351	1	100.0	15
10/02/24	6:45p	79.4	41	53.6	78.3	7.75	.0724	351	1	100.0	15
10/02/24	7:00p	79.6	39	52.5	78.3	7.46	.0724	352	1	100.0	15
10/02/24	7:15p	79.3	41	53.6	78.2	7.75	.0725	351	1	100.0	15
10/02/24	7:30p	79.4	39	52.3	78.1	7.46	.0725	351	1	100.0	15
10/02/24	7:45p	79.6	42	54.4	78.5	7.86	.0724	351	1	100.0	15
10/02/24	8:00p	79.0	42	53.9	78.0	7.87	.0725	352	1	100.0	15
10/02/24	8:15p	79.1	40	52.7	77.9	7.57	.0725	351	1	100.0	15
10/02/24	8:30p	79.1	43	54.7	78.3	8.05	.0725	351	1	100.0	15
10/02/24	8:45p	78.5	41	52.8	77.4	7.75	.0726	351	1	100.0	15
10/02/24	9:00p	78.3	40	52.0	77.1	7.58	.0727	352	1	100.0	15
10/02/24	9:15p	78.0	45	54.9	77.3	8.39	.0726	351	1	100.0	15
10/02/24	9:30p	77.6	41	52.0	76.5	7.75	.0728	351	1	100.0	15
10/02/24	9:45p	78.1	43	53.8	77.2	8.05	.0727	351	1	100.0	15
10/02/24	10:00p	78.2	44	54.5	77.4	8.19	.0726	352	1	100.0	15
10/02/24	10:15p	77.9	49	57.2	77.8	8.99	.0726	351	1	100.0	15
10/02/24	10:30p	77.8	48	56.5	77.5	8.89	.0726	351	1	100.0	15
10/02/24	10:45p	77.6	46	55.2	77.1	8.50	.0727	351	1	100.0	15
10/02/24	11:00p	77.7	46	55.3	77.3	8.50	.0727	351	1	100.0	15
10/02/24	11:15p	77.9	50	57.8	77.9	9.19	.0726	352	1	100.0	15
10/02/24	11:30p	77.3	51	57.8	77.3	9.35	.0727	351	1	100.0	15
10/02/24	11:45p	77.2	50	57.1	77.1	9.21	.0727	351	1	100.0	15
10/03/24	12:00a	77.1	48	55.9	76.8	8.91	.0728	351	1	100.0	15

NKSP 10/03/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/03/24	12:15a	77.3	54	59.4	77.5	9.80	.0726	350	1	100.0	15
10/03/24	12:30a	76.8	54	58.9	76.9	9.81	.0727	351	1	100.0	15
10/03/24	12:45a	76.7	51	57.2	76.7	9.35	.0727	351	1	100.0	15
10/03/24	1:00a	77.0	55	59.6	77.2	9.97	.0726	352	1	100.0	15
10/03/24	1:15a	76.7	55	59.3	76.9	9.98	.0726	351	1	100.0	15
10/03/24	1:30a	76.6	51	57.1	76.6	9.35	.0728	351	1	100.0	15
10/03/24	1:45a	76.9	56	60.0	77.2	10.17	.0726	351	1	100.0	15
10/03/24	2:00a	76.6	54	58.7	76.7	9.82	.0727	351	1	100.0	15
10/03/24	2:15a	76.8	51	57.3	76.8	9.35	.0727	352	1	100.0	15
10/03/24	2:30a	76.7	55	59.3	76.9	9.98	.0726	351	1	100.0	15
10/03/24	2:45a	76.4	53	58.0	76.5	9.65	.0727	351	1	100.0	15
10/03/24	3:00a	76.8	54	58.9	76.9	9.81	.0726	351	1	100.0	15
10/03/24	3:15a	76.3	55	58.9	76.5	10.00	.0727	352	1	100.0	15
10/03/24	3:30a	76.4	50	56.4	76.3	9.22	.0728	351	1	100.0	15
10/03/24	3:45a	76.4	55	59.0	76.6	9.99	.0727	351	1	100.0	15
10/03/24	4:00a	76.0	52	57.1	76.0	9.53	.0728	351	1	100.0	15
10/03/24	4:15a	76.3	55	58.9	76.5	10.00	.0727	352	1	100.0	15
10/03/24	4:30a	75.9	55	58.6	76.1	10.01	.0727	351	1	100.0	15
10/03/24	4:45a	76.2	51	56.7	76.2	9.35	.0728	351	1	100.0	15
10/03/24	5:00a	75.9	56	59.1	76.2	10.21	.0727	351	1	100.0	15
10/03/24	5:15a	75.8	52	56.9	75.8	9.53	.0728	351	1	100.0	15
10/03/24	5:30a	76.3	56	59.4	76.6	10.20	.0727	352	1	100.0	15
10/03/24	5:45a	76.0	54	58.2	76.1	9.83	.0728	351	1	100.0	15
10/03/24	6:00a	76.4	52	57.5	76.4	9.52	.0727	351	1	100.0	15
10/03/24	6:15a	76.2	55	58.9	76.4	10.00	.0727	351	1	100.0	15
10/03/24	6:30a	76.7	51	57.2	76.7	9.35	.0727	352	1	100.0	15
10/03/24	6:45a	76.6	55	59.2	76.8	9.99	.0726	351	1	100.0	15
10/03/24	7:00a	76.8	51	57.3	76.8	9.35	.0727	351	1	100.0	15
10/03/24	7:15a	76.9	55	59.5	77.1	9.97	.0726	351	1	100.0	15
10/03/24	7:30a	76.8	53	58.4	76.9	9.65	.0727	351	1	100.0	15
10/03/24	7:45a	77.1	52	58.1	77.1	9.51	.0727	352	1	100.0	15
10/03/24	8:00a	76.8	55	59.4	77.0	9.98	.0727	351	1	100.0	15
10/03/24	8:15a	76.9	50	56.8	76.8	9.21	.0728	351	1	100.0	15
10/03/24	8:30a	77.0	55	59.6	77.2	9.97	.0726	351	1	100.0	15
10/03/24	8:45a	77.1	52	58.1	77.1	9.51	.0727	352	1	100.0	15
10/03/24	9:00a	77.4	50	57.3	77.3	9.20	.0727	351	1	100.0	15
10/03/24	9:15a	77.5	54	59.5	77.7	9.80	.0726	351	1	100.0	15
10/03/24	9:30a	77.5	52	58.5	77.6	9.50	.0726	351	1	100.0	15
10/03/24	9:45a	77.7	49	57.0	77.5	9.00	.0727	352	1	100.0	15
10/03/24	10:00a	77.9	52	58.9	78.0	9.49	.0726	351	1	100.0	15
10/03/24	10:15a	77.9	52	58.9	78.0	9.49	.0725	351	1	100.0	15
10/03/24	10:30a	78.0	49	57.3	77.9	8.99	.0726	351	1	100.0	15
10/03/24	10:45a	78.3	47	56.4	77.9	8.68	.0726	351	1	100.0	15
10/03/24	11:00a	78.7	48	57.4	78.4	8.88	.0725	352	1	100.0	15
10/03/24	11:15a	78.9	49	58.1	78.8	8.97	.0724	351	1	100.0	15
10/03/24	11:30a	79.0	50	58.8	79.0	9.17	.0724	351	1	100.0	15
10/03/24	11:45a	79.0	47	57.0	78.6	8.67	.0724	351	1	100.0	15
10/03/24	12:00p	79.2	45	56.0	78.6	8.37	.0724	352	1	100.0	15
10/03/24	12:15p	79.4	46	56.8	78.9	8.46	.0724	351	1	100.0	15
10/03/24	12:30p	79.4	42	54.3	78.4	7.86	.0725	351	1	100.0	15

NKSP 10/03/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/03/24	12:45p	79.8	43	55.3	78.9	8.05	.0724	351	1	100.0	15
10/03/24	1:00p	79.7	41	53.9	78.6	7.75	.0724	352	1	100.0	15
10/03/24	1:15p	79.5	40	53.1	78.3	7.56	.0725	351	1	100.0	15
10/03/24	1:30p	79.6	39	52.5	78.3	7.46	.0724	351	1	100.0	15
10/03/24	1:45p	79.6	39	52.5	78.3	7.46	.0724	351	1	100.0	15
10/03/24	2:00p	79.9	39	52.7	78.5	7.45	.0724	351	1	100.0	15
10/03/24	2:15p	80.0	38	52.1	78.5	7.25	.0724	352	1	100.0	15
10/03/24	2:30p	80.3	38	52.4	78.9	7.25	.0723	351	1	100.0	15
10/03/24	2:45p	80.1	38	52.2	78.6	7.25	.0723	351	1	100.0	15
10/03/24	3:00p	80.1	37	51.5	78.6	7.15	.0723	351	1	100.0	15
10/03/24	3:15p	80.0	37	51.4	78.5	7.15	.0724	352	1	100.0	15
10/03/24	3:30p	80.0	37	51.4	78.5	7.15	.0723	351	1	100.0	15
10/03/24	3:45p	79.9	37	51.3	78.4	7.15	.0724	351	1	100.0	15
10/03/24	4:00p	80.0	37	51.4	78.5	7.15	.0723	351	1	100.0	15
10/03/24	4:15p	80.2	36	50.8	78.6	6.94	.0723	351	1	100.0	15
10/03/24	4:30p	80.3	36	50.9	78.7	6.94	.0723	352	1	100.0	15
10/03/24	4:45p	80.3	36	50.9	78.7	6.94	.0723	351	1	100.0	15
10/03/24	5:00p	80.1	36	50.7	78.5	6.95	.0723	351	1	100.0	15
10/03/24	5:15p	80.0	36	50.6	78.4	6.95	.0723	351	1	100.0	15
10/03/24	5:30p	79.7	37	51.1	78.2	7.16	.0724	352	1	100.0	15
10/03/24	5:45p	80.0	38	52.1	78.5	7.25	.0723	351	1	100.0	15
10/03/24	6:00p	79.8	39	52.6	78.4	7.45	.0723	351	1	100.0	15
10/03/24	6:15p	79.9	38	52.0	78.5	7.25	.0723	351	1	100.0	15
10/03/24	6:30p	80.0	39	52.8	78.6	7.45	.0723	352	1	100.0	15
10/03/24	6:45p	79.9	41	54.1	78.7	7.75	.0722	351	1	100.0	15
10/03/24	7:00p	79.9	38	52.0	78.5	7.25	.0723	351	1	100.0	15
10/03/24	7:15p	80.0	40	53.5	78.7	7.55	.0723	351	1	100.0	15
10/03/24	7:30p	79.9	41	54.1	78.7	7.75	.0723	351	1	100.0	15
10/03/24	7:45p	79.6	42	54.5	78.6	7.86	.0723	352	1	100.0	15
10/03/24	8:00p	79.5	40	53.1	78.3	7.56	.0724	351	1	100.0	15
10/03/24	8:15p	79.5	40	53.1	78.3	7.56	.0724	351	1	100.0	15
10/03/24	8:30p	79.5	42	54.4	78.5	7.86	.0723	351	1	100.0	15
10/03/24	8:45p	79.3	44	55.5	78.6	8.16	.0723	352	1	100.0	15
10/03/24	9:00p	79.2	45	56.0	78.6	8.37	.0723	351	1	100.0	15
10/03/24	9:15p	79.1	45	55.9	78.5	8.37	.0724	351	1	100.0	15
10/03/24	9:30p	79.0	44	55.2	78.3	8.17	.0724	351	1	100.0	15
10/03/24	9:45p	78.9	43	54.5	78.1	8.05	.0725	352	1	100.0	15
10/03/24	10:00p	78.9	43	54.5	78.1	8.05	.0725	351	1	100.0	15
10/03/24	10:15p	78.9	45	55.8	78.3	8.37	.0724	351	1	100.0	15
10/03/24	10:30p	78.7	47	56.8	78.3	8.68	.0724	351	1	100.0	15
10/03/24	10:45p	78.5	48	57.2	78.2	8.88	.0725	352	1	100.0	15
10/03/24	11:00p	78.4	48	57.1	78.1	8.88	.0725	351	1	100.0	15
10/03/24	11:15p	78.2	47	56.3	77.8	8.69	.0725	351	1	100.0	15
10/03/24	11:30p	78.2	46	55.7	77.7	8.49	.0726	351	1	100.0	15
10/03/24	11:45p	78.2	46	55.7	77.7	8.49	.0726	351	1	100.0	15
10/04/24	12:00a	78.2	49	57.5	78.1	8.99	.0725	352	1	100.0	15

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

OUTSIDE TEMPERATURE RECORD

CDCR 2030 (04/18)

INSTITUTION: NKSP

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the OUTSIDE ambient air temperature.

Using an accurate thermometer located in a central, heat neutral location, the outside air temperature is to be taken every hour, seven (7) days a week.

Thermometer Location: Control

Immediately notify the Watch Commander at extension 3141 when the air temperature reaches 90 degrees.

Date	Time	Temp.	Printed Name
10-24-24	0100	72	PANELLA
	0200	72	PANELLA
	0300	70	PANELLA
	0400	70	PANELLA
	0500	68	PANELLA
	0600	68	VALENCIA
	0700	71	VALENCIA
	0800	73	VALENCIA
	0900	79	VALENCIA
	1000	82	VALENCIA
	1100	89	VALENCIA
	1200	93	VALENCIA
	1300	95	VALENCIA
	1400	98	Gonzalez
	1500	99	MONCIBAIZ
	1600	100	MONCIBAIZ
	1700	100	MONCIBAIZ
	1800	99	MONCIBAIZ
	1900	92	MONCIBAIZ
	2000	88	MONCIBAIZ
	2100	84	MONCIBAIZ
	2200	80	J. FIERRO
	2300	77	J. FIERRO
	2400	73	J. FIERRO

UHT: 1101

Date	Time	Temp.	Printed Name
10-5-24	0100	71	J. FIERRO
	0200	71	J. FIERRO
	0300	69	J. FIERRO
	0400	68	J. FIERRO
	0500	67	J. FIERRO
	0600	66	Gonzalez
	0700	65	Gonzalez
	0800	66	Gonzalez
	0900	75	Gonzalez
	1000	84	Gonzalez
	1100	87	Gonzalez
	1200	90	Gonzalez
	1300	94	Gonzalez
	1400	96	Gonzalez
	1500	97	Gonzalez
	1600	99	Gonzalez
	1700	99	Gonzalez
	1800	98	Gonzalez
	1900	92	Gonzalez
	2000	~~88~~ 87	Gonzalez
	2100	82	Gonzalez
	2200	79.2	Romero
	2300	76.5	Romero
	2400	72.7	Romero

UHT 1149

DISTRIBUTION: Original: Institution Heat Plan Coordinator

NKSP 10/05/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/05/24	12:15a	74.7	74.7	73.9	12	18.7	3.0	SE	0.75	5.0	SE	74.7	71.2	71.2	30.004	0.00	0.00	0.000	0.101
10/05/24	12:30a	72.9	74.7	72.9	15	22.5	2.0	SE	0.50	5.0	SE	72.9	69.2	69.2	30.007	0.00	0.00	0.000	0.082
10/05/24	12:45a	71.8	72.8	71.8	18	26.0	3.0	SE	0.75	7.0	SE	71.8	67.9	67.9	30.007	0.00	0.00	0.000	0.071
10/05/24	1:00a	71.5	71.9	71.4	20	28.3	3.0	SE	0.75	5.0	SE	71.5	67.7	67.7	30.009	0.00	0.00	0.000	0.068
10/05/24	1:15a	70.7	71.4	70.5	22	30.0	3.0	SE	0.75	4.0	SSE	70.7	66.7	66.7	30.012	0.00	0.00	0.000	0.059
10/05/24	1:30a	70.9	70.9	70.7	20	27.8	3.0	SE	0.75	4.0	SE	70.9	66.9	66.9	30.016	0.00	0.00	0.000	0.061
10/05/24	1:45a	71.2	71.2	70.8	20	28.0	4.0	SE	1.00	7.0	ESE	71.2	67.3	67.3	30.019	0.00	0.00	0.000	0.065
10/05/24	2:00a	71.2	71.4	71.1	16	22.7	4.0	ESE	1.00	7.0	ESE	71.2	66.9	66.9	30.020	0.00	0.00	0.000	0.065
10/05/24	2:15a	71.3	71.5	71.2	11	14.0	5.0	ESE	1.25	7.0	ESE	71.3	66.5	66.5	30.021	0.00	0.00	0.000	0.066
10/05/24	2:30a	70.6	71.3	70.6	11	13.5	4.0	SE	1.00	6.0	SE	70.6	65.5	65.5	30.023	0.00	0.00	0.000	0.058
10/05/24	2:45a	70.4	71.0	70.4	12	15.3	5.0	SE	1.25	9.0	SE	70.4	65.3	65.3	30.020	0.00	0.00	0.000	0.056
10/05/24	3:00a	69.6	70.4	69.5	13	16.5	5.0	SE	1.25	8.0	SE	69.6	64.4	64.4	30.021	0.00	0.00	0.000	0.048
10/05/24	3:15a	69.6	69.6	69.5	12	14.7	4.0	SE	1.00	7.0	SE	69.6	64.3	64.3	30.019	0.00	0.00	0.000	0.048
10/05/24	3:30a	68.8	69.6	68.7	13	15.9	3.0	SE	0.75	5.0	SE	68.8	63.5	63.5	30.020	0.00	0.00	0.000	0.040
10/05/24	3:45a	69.1	69.3	68.7	11	12.3	3.0	SE	0.75	5.0	SE	69.1	63.6	63.6	30.021	0.00	0.00	0.000	0.043
10/05/24	4:00a	68.9	69.2	68.9	12	14.1	3.0	SE	0.75	7.0	SE	68.9	63.5	63.5	30.021	0.00	0.00	0.000	0.041
10/05/24	4:15a	68.6	68.9	68.6	13	15.7	1.0	SE	0.25	3.0	SE	68.6	63.2	63.2	30.018	0.00	0.00	0.000	0.037
10/05/24	4:30a	68.3	69.0	68.3	13	15.5	3.0	SE	0.75	9.0	ESE	68.3	62.9	62.9	30.026	0.00	0.00	0.000	0.034
10/05/24	4:45a	67.8	68.3	67.6	13	15.1	4.0	SE	1.00	8.0	SE	67.8	62.4	62.4	30.021	0.00	0.00	0.000	0.029
10/05/24	5:00a	67.3	67.8	67.3	14	16.4	4.0	SE	1.00	9.0	SE	67.3	62.0	62.0	30.024	0.00	0.00	0.000	0.024
10/05/24	5:15a	66.3	67.3	66.2	16	18.7	3.0	SSE	0.75	7.0	SE	66.3	61.1	61.1	30.027	0.00	0.00	0.000	0.014
10/05/24	5:30a	65.8	66.3	65.6	19	22.3	2.0	SSE	0.50	5.0	SSE	65.8	60.8	60.8	30.033	0.00	0.00	0.000	0.008
10/05/24	5:45a	66.0	66.2	65.8	18	21.2	3.0	S	0.75	5.0	SSE	66.0	60.9	60.9	30.032	0.00	0.00	0.000	0.010
10/05/24	6:00a	66.0	66.0	65.8	19	22.5	4.0	SE	1.00	7.0	SE	66.0	61.0	61.0	30.041	0.00	0.00	0.000	0.010
10/05/24	6:15a	65.7	66.3	65.6	18	21.0	2.0	SE	0.50	4.0	SE	65.7	60.7	60.7	30.043	0.00	0.00	0.000	0.007
10/05/24	6:30a	65.7	65.7	65.2	18	21.0	3.0	SE	0.75	5.0	SE	65.7	60.7	60.7	30.043	0.00	0.00	0.000	0.007
10/05/24	6:45a	65.3	65.8	65.3	18	20.7	3.0	SE	0.75	5.0	SE	65.3	60.3	60.3	30.049	0.00	0.00	0.000	0.003
10/05/24	7:00a	65.2	65.3	65.1	18	20.6	4.0	SE	1.00	7.0	SE	65.2	60.2	60.2	30.051	0.00	0.00	0.000	0.002
10/05/24	7:15a	65.2	65.3	65.1	18	20.6	5.0	SE	1.25	9.0	SE	65.2	60.2	60.2	30.058	0.00	0.00	0.000	0.002
10/05/24	7:30a	65.2	65.4	65.1	17	19.2	5.0	SE	1.25	8.0	SE	65.2	60.1	60.1	30.059	0.00	0.00	0.000	0.002
10/05/24	7:45a	65.5	65.5	65.1	17	19.5	5.0	SE	1.25	8.0	SE	65.5	60.4	60.4	30.066	0.00	0.00	0.000	0.005
10/05/24	8:00a	66.6	66.6	65.5	17	20.4	3.0	SSE	0.75	7.0	SE	66.6	61.5	61.5	30.074	0.00	0.00	0.000	0.017
10/05/24	8:15a	69.2	69.2	66.6	14	17.9	3.0	SE	0.75	7.0	SE	69.2	64.0	64.0	30.084	0.00	0.00	0.000	0.044
10/05/24	8:30a	70.7	70.7	69.1	12	15.5	4.0	SSE	1.00	7.0	SE	70.7	65.7	65.7	30.083	0.00	0.00	0.000	0.059
10/05/24	8:45a	73.0	73.0	70.7	9	10.8	3.0	SE	0.75	6.0	ESE	73.0	68.6	68.6	30.089	0.00	0.00	0.000	0.083
10/05/24	9:00a	75.6	75.6	73.0	5	-0.2	3.0	SE	0.75	5.0	SE	75.6	71.1	71.1	30.093	0.00	0.00	0.000	0.110
10/05/24	9:15a	77.7	77.7	75.7	1	-30.6	3.0	SE	0.75	5.0	SE	77.7	73.4	73.4	30.098	0.00	0.00	0.000	0.132
10/05/24	9:30a	80.4	80.4	77.7	0	---	3.0	SE	0.75	5.0	SE	80.4	75.9	75.9	30.093	0.00	0.00	0.000	0.160
10/05/24	9:45a	83.5	83.5	80.4	0	---	1.0	SE	0.25	3.0	SE	83.5	78.7	78.7	30.101	0.00	0.00	0.000	0.193
10/05/24	10:00a	84.5	84.5	83.4	0	---	1.0	SSW	0.25	3.0	SSW	84.5	79.6	79.6	30.105	0.00	0.00	0.000	0.203
10/05/24	10:15a	85.9	85.9	84.5	0	---	1.0	NNW	0.25	4.0	NNW	85.9	80.7	80.7	30.104	0.00	0.00	0.000	0.218
10/05/24	10:30a	86.1	86.1	85.8	0	---	3.0	NNW	0.75	7.0	NW	86.1	80.9	80.9	30.104	0.00	0.00	0.000	0.220
10/05/24	10:45a	86.4	86.4	86.0	0	---	4.0	NW	1.00	9.0	NW	86.4	81.1	81.1	30.102	0.00	0.00	0.000	0.223
10/05/24	11:00a	87.0	87.0	86.4	0	---	3.0	NW	0.75	9.0	WNW	87.0	81.6	81.6	30.098	0.00	0.00	0.000	0.229
10/05/24	11:15a	88.3	88.3	87.0	0	---	2.0	NW	0.50	7.0	WNW	88.3	82.6	82.6	30.089	0.00	0.00	0.000	0.243
10/05/24	11:30a	89.3	89.3	88.3	0	---	3.0	NW	0.75	9.0	NW	89.3	83.4	83.4	30.086	0.00	0.00	0.000	0.253
10/05/24	11:45a	89.7	89.7	89.3	0	---	4.0	NW	1.00	10.0	WNW	89.7	83.8	83.8	30.082	0.00	0.00	0.000	0.257
10/05/24	12:00p	90.7	90.7	89.7	0	---	5.0	W	1.25	11.0	WNW	90.7	84.5	84.5	30.074	0.00	0.00	0.000	0.268
10/05/24	12:15p	91.2	91.2	90.6	0	---	4.0	NW	1.00	9.0	WNW	91.2	84.9	84.9	30.072	0.00	0.00	0.000	0.273
10/05/24	12:30p	93.6	93.6	91.2	0	---	5.0	WSW	1.25	11.0	WSW	93.6	86.7	86.7	30.064	0.00	0.00	0.000	0.298

NKSP 10/05/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/05/24	12:45p	93.6	93.7	93.2	0	---	6.0	W	1.50	10.0	WSW	93.6	86.7	86.7	30.053	0.00	0.00	0.000	0.298
10/05/24	1:00p	94.1	94.2	93.5	0	---	4.0	W	1.00	9.0	W	94.1	87.1	87.1	30.046	0.00	0.00	0.000	0.303
10/05/24	1:15p	94.6	94.6	94.1	0	---	4.0	W	1.00	10.0	W	94.6	87.4	87.4	30.040	0.00	0.00	0.000	0.308
10/05/24	1:30p	94.8	94.9	94.6	0	---	4.0	NW	1.00	10.0	W	94.8	87.6	87.6	30.032	0.00	0.00	0.000	0.310
10/05/24	1:45p	95.4	95.6	94.8	0	---	5.0	NW	1.25	11.0	NW	95.4	88.0	88.0	30.028	0.00	0.00	0.000	0.317
10/05/24	2:00p	96.2	96.2	95.3	0	---	5.0	NW	1.25	10.0	NNW	96.2	88.6	88.6	30.016	0.00	0.00	0.000	0.325
10/05/24	2:15p	97.0	97.0	96.2	0	---	4.0	NW	1.00	12.0	WNW	97.0	89.2	89.2	30.012	0.00	0.00	0.000	0.333
10/05/24	2:30p	97.7	97.7	96.9	0	---	4.0	W	1.00	10.0	NW	97.7	89.7	89.7	30.005	0.00	0.00	0.000	0.341
10/05/24	2:45p	97.5	98.0	97.5	0	---	5.0	WNW	1.25	9.0	NW	97.5	89.6	89.6	30.005	0.00	0.00	0.000	0.339
10/05/24	3:00p	97.8	98.1	97.5	0	---	5.0	NW	1.25	11.0	NW	97.8	89.8	89.8	30.000	0.00	0.00	0.000	0.342
10/05/24	3:15p	98.1	98.1	97.7	0	---	5.0	NW	1.25	10.0	WNW	98.1	90.0	90.0	29.994	0.00	0.00	0.000	0.345
10/05/24	3:30p	98.4	98.4	98.1	0	---	4.0	WNW	1.00	9.0	WNW	98.4	90.2	90.2	29.994	0.00	0.00	0.000	0.348
10/05/24	3:45p	99.3	99.3	98.3	0	---	3.0	NNW	0.75	10.0	WNW	99.3	90.8	90.8	29.990	0.00	0.00	0.000	0.357
10/05/24	4:00p	99.3	99.5	99.3	0	---	4.0	WNW	1.00	8.0	WNW	99.3	90.8	90.8	29.992	0.00	0.00	0.000	0.357
10/05/24	4:15p	99.4	99.5	99.2	0	---	3.0	W	0.75	6.0	WNW	99.4	90.9	90.9	29.983	0.00	0.00	0.000	0.358
10/05/24	4:30p	99.6	99.7	99.3	0	---	3.0	N	0.75	7.0	WNW	99.6	91.0	91.0	29.983	0.00	0.00	0.000	0.360
10/05/24	4:45p	99.3	99.7	99.2	0	---	3.0	NW	0.75	7.0	W	99.3	90.8	90.8	29.981	0.00	0.00	0.000	0.357
10/05/24	5:00p	99.5	99.6	99.3	0	---	3.0	NW	0.75	7.0	WSW	99.5	90.9	90.9	29.977	0.00	0.00	0.000	0.359
10/05/24	5:15p	99.2	99.5	99.2	0	---	3.0	W	0.75	7.0	W	99.2	90.7	90.7	29.977	0.00	0.00	0.000	0.356
10/05/24	5:30p	99.1	99.2	99.0	0	---	2.0	NW	0.50	4.0	W	99.1	90.7	90.7	29.977	0.00	0.00	0.000	0.355
10/05/24	5:45p	98.8	99.1	98.8	0	---	2.0	NW	0.50	4.0	WSW	98.8	90.5	90.5	29.978	0.00	0.00	0.000	0.352
10/05/24	6:00p	98.3	98.8	98.3	0	---	0.0	NW	0.00	3.0	N	98.3	90.1	90.1	29.977	0.00	0.00	0.000	0.347
10/05/24	6:15p	97.3	98.3	97.3	0	---	0.0	---	0.00	0.0	---	97.3	89.4	89.4	29.981	0.00	0.00	0.000	0.336
10/05/24	6:30p	96.2	97.3	96.2	0	---	0.0	---	0.00	0.0	---	96.2	88.6	88.6	29.983	0.00	0.00	0.000	0.325
10/05/24	6:45p	94.2	96.2	94.2	0	---	1.0	WSW	0.25	4.0	WSW	94.2	87.1	87.1	29.989	0.00	0.00	0.000	0.304
10/05/24	7:00p	92.5	94.2	92.5	0	---	3.0	WSW	0.75	4.0	WSW	92.5	85.8	85.8	29.989	0.00	0.00	0.000	0.286
10/05/24	7:15p	91.0	92.5	91.0	0	---	3.0	N	0.75	5.0	N	91.0	84.7	84.7	29.991	0.00	0.00	0.000	0.271
10/05/24	7:30p	88.8	91.0	88.8	0	---	3.0	SW	0.75	5.0	N	88.8	83.0	83.0	29.999	0.00	0.00	0.000	0.248
10/05/24	7:45p	87.8	88.8	87.8	0	---	3.0	SW	0.75	5.0	SW	87.8	82.2	82.2	30.002	0.00	0.00	0.000	0.238
10/05/24	8:00p	87.1	87.8	87.1	0	---	2.0	SW	0.50	4.0	SW	87.1	81.7	81.7	30.007	0.00	0.00	0.000	0.230
10/05/24	8:15p	87.2	87.2	86.9	0	---	2.0	SW	0.50	3.0	SSW	87.2	81.8	81.8	30.010	0.00	0.00	0.000	0.231
10/05/24	8:30p	86.7	87.2	86.7	0	---	1.0	SW	0.25	2.0	SW	86.7	81.4	81.4	30.012	0.00	0.00	0.000	0.226
10/05/24	8:45p	86.1	86.7	86.0	0	---	0.0	W	0.00	3.0	W	86.1	80.9	80.9	30.019	0.00	0.00	0.000	0.220
10/05/24	9:00p	82.1	86.0	82.1	0	---	3.0	SSE	0.75	5.0	S	82.1	77.5	77.5	30.027	0.00	0.00	0.000	0.178
10/05/24	9:15p	80.5	82.1	80.5	0	---	2.0	SE	0.50	4.0	SE	80.5	75.9	75.9	30.031	0.00	0.00	0.000	0.161
10/05/24	9:30p	80.9	81.2	80.5	0	---	2.0	SE	0.50	3.0	SE	80.9	76.3	76.3	30.032	0.00	0.00	0.000	0.166
10/05/24	9:45p	80.6	80.9	80.5	2	-15.6	2.0	SE	0.50	4.0	SE	80.6	76.2	76.2	30.035	0.00	0.00	0.000	0.162
10/05/24	10:00p	79.2	80.6	79.2	5	2.4	3.0	SE	0.75	4.0	SE	79.2	75.3	75.3	30.035	0.00	0.00	0.000	0.148
10/05/24	10:15p	78.4	79.3	78.4	5	1.8	2.0	SE	0.50	4.0	SE	78.4	74.7	74.7	30.038	0.00	0.00	0.000	0.140
10/05/24	10:30p	78.7	78.9	78.4	4	-2.8	1.0	SE	0.25	3.0	SE	78.7	74.8	74.8	30.043	0.00	0.00	0.000	0.143
10/05/24	10:45p	77.8	78.7	77.8	5	1.4	2.0	SE	0.50	4.0	SE	77.8	74.0	74.0	30.041	0.00	0.00	0.000	0.133
10/05/24	11:00p	76.5	77.8	76.5	6	4.4	2.0	SE	0.50	3.0	SE	76.5	72.2	72.2	30.040	0.00	0.00	0.000	0.120
10/05/24	11:15p	75.6	76.5	75.6	7	7.1	2.0	SE	0.50	4.0	SE	75.6	71.5	71.5	30.041	0.00	0.00	0.000	0.110
10/05/24	11:30p	74.9	75.9	74.9	6	3.2	3.0	SE	0.75	7.0	SE	74.9	70.8	70.8	30.040	0.00	0.00	0.000	0.103
10/05/24	11:45p	74.1	74.9	74.1	6	2.6	4.0	SE	1.00	7.0	SE	74.1	69.6	69.6	30.040	0.00	0.00	0.000	0.095
10/06/24	12:00a	72.7	74.1	72.7	9	10.5	3.0	SSE	0.75	5.0	S	72.7	68.2	68.2	30.041	0.00	0.00	0.000	0.080

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/05/24	12:15a	77.5	48	56.3	77.2	8.90	.0730	350	1	100.0	15
10/05/24	12:30a	77.2	52	58.2	77.2	9.51	.0729	352	1	100.0	15
10/05/24	12:45a	76.9	49	56.3	76.7	9.01	.0730	351	1	100.0	15
10/05/24	1:00a	76.9	46	54.5	76.4	8.51	.0731	351	1	100.0	15
10/05/24	1:15a	77.0	49	56.4	76.8	9.01	.0730	351	1	100.0	15
10/05/24	1:30a	76.7	51	57.2	76.7	9.35	.0731	351	1	100.0	15
10/05/24	1:45a	77.1	51	57.6	77.1	9.35	.0730	352	1	100.0	15
10/05/24	2:00a	76.9	54	59.0	77.0	9.81	.0730	351	1	100.0	15
10/05/24	2:15a	76.5	51	57.0	76.5	9.35	.0731	351	1	100.0	15
10/05/24	2:30a	76.5	48	55.3	76.2	8.92	.0732	351	1	100.0	15
10/05/24	2:45a	76.7	50	56.7	76.6	9.22	.0731	352	1	100.0	15
10/05/24	3:00a	76.5	52	57.6	76.5	9.52	.0731	351	1	100.0	15
10/05/24	3:15a	76.9	51	57.4	76.9	9.35	.0730	351	1	100.0	15
10/05/24	3:30a	76.7	54	58.8	76.8	9.82	.0730	351	1	100.0	15
10/05/24	3:45a	76.3	51	56.8	76.3	9.35	.0731	352	1	100.0	15
10/05/24	4:00a	76.5	48	55.3	76.2	8.92	.0732	351	1	100.0	15
10/05/24	4:15a	76.5	54	58.6	76.6	9.82	.0730	351	1	100.0	15
10/05/24	4:30a	76.3	52	57.4	76.3	9.52	.0731	351	1	100.0	15
10/05/24	4:45a	76.5	49	55.9	76.3	9.02	.0732	351	1	100.0	15
10/05/24	5:00a	76.4	53	58.0	76.5	9.65	.0731	352	1	100.0	15
10/05/24	5:15a	76.2	51	56.7	76.2	9.35	.0732	351	1	100.0	15
10/05/24	5:30a	76.6	53	58.2	76.7	9.65	.0731	351	1	100.0	15
10/05/24	5:45a	76.3	52	57.4	76.3	9.52	.0731	351	1	100.0	15
10/05/24	6:00a	76.6	51	57.1	76.6	9.35	.0731	352	1	100.0	15
10/05/24	6:15a	76.2	53	57.8	76.3	9.65	.0732	351	1	100.0	15
10/05/24	6:30a	76.6	49	56.0	76.4	9.02	.0732	351	1	100.0	15
10/05/24	6:45a	76.5	53	58.1	76.6	9.65	.0731	351	1	100.0	15
10/05/24	7:00a	76.5	50	56.5	76.4	9.22	.0732	352	1	100.0	15
10/05/24	7:15a	76.7	53	58.3	76.8	9.65	.0731	351	1	100.0	15
10/05/24	7:30a	76.7	51	57.2	76.7	9.35	.0732	351	1	100.0	15
10/05/24	7:45a	77.0	50	56.9	76.9	9.21	.0732	351	1	100.0	15
10/05/24	8:00a	76.7	52	57.7	76.7	9.52	.0732	351	1	100.0	15
10/05/24	8:15a	76.8	49	56.2	76.6	9.01	.0733	352	1	100.0	15
10/05/24	8:30a	77.1	52	58.1	77.1	9.51	.0731	351	1	100.0	15
10/05/24	8:45a	76.9	52	57.9	76.9	9.51	.0732	351	1	100.0	15
10/05/24	9:00a	77.2	48	56.0	76.9	8.91	.0732	351	1	100.0	15
10/05/24	9:15a	77.3	53	58.8	77.4	9.65	.0731	352	1	100.0	15
10/05/24	9:30a	77.3	51	57.8	77.3	9.35	.0731	351	1	100.0	15
10/05/24	9:45a	77.6	47	55.8	77.2	8.70	.0732	351	1	100.0	15
10/05/24	10:00a	77.7	51	58.1	77.7	9.35	.0731	351	1	100.0	15
10/05/24	10:15a	77.8	48	56.5	77.5	8.89	.0732	352	1	100.0	15
10/05/24	10:30a	78.1	45	55.0	77.4	8.39	.0732	351	1	100.0	15
10/05/24	10:45a	78.4	48	57.1	78.1	8.88	.0730	351	1	100.0	15
10/05/24	11:00a	78.4	47	56.5	78.0	8.68	.0731	351	1	100.0	15
10/05/24	11:15a	78.7	43	54.3	77.8	8.05	.0731	351	1	100.0	15
10/05/24	11:30a	79.0	45	55.8	78.4	8.37	.0730	352	1	100.0	15
10/05/24	11:45a	79.0	47	57.0	78.6	8.67	.0729	351	1	100.0	15
10/05/24	12:00p	79.4	42	54.3	78.4	7.86	.0730	351	1	100.0	15
10/05/24	12:15p	79.7	45	56.5	79.1	8.36	.0728	351	1	100.0	15
10/05/24	12:30p	79.7	43	55.2	78.8	8.05	.0728	352	1	100.0	15

NKSP 10/05/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/05/24	12:45p	80.1	40	53.6	78.8	7.55	.0728	351	1	100.0	15
10/05/24	1:00p	80.3	42	55.1	79.3	7.85	.0727	351	1	100.0	15
10/05/24	1:15p	80.4	39	53.2	79.1	7.44	.0728	351	1	100.0	15
10/05/24	1:30p	80.1	37	51.5	78.6	7.15	.0729	351	1	100.0	15
10/05/24	1:45p	80.4	39	53.2	79.1	7.44	.0727	352	1	100.0	15
10/05/24	2:00p	80.6	38	52.6	79.2	7.25	.0727	351	1	100.0	15
10/05/24	2:15p	80.5	37	51.8	79.0	7.14	.0727	351	1	100.0	15
10/05/24	2:30p	80.5	37	51.8	79.0	7.14	.0727	351	1	100.0	15
10/05/24	2:45p	80.5	36	51.1	78.9	6.93	.0727	352	1	100.0	15
10/05/24	3:00p	80.5	36	51.1	78.9	6.93	.0727	351	1	100.0	15
10/05/24	3:15p	80.7	35	50.5	79.0	6.82	.0727	351	1	100.0	15
10/05/24	3:30p	80.9	35	50.7	79.2	6.81	.0727	351	1	100.0	15
10/05/24	3:45p	80.9	35	50.7	79.2	6.81	.0727	352	1	100.0	15
10/05/24	4:00p	80.9	35	50.7	79.2	6.81	.0727	351	1	100.0	15
10/05/24	4:15p	80.7	35	50.5	79.0	6.82	.0727	351	1	100.0	15
10/05/24	4:30p	81.0	37	52.3	79.5	7.13	.0726	351	1	100.0	15
10/05/24	4:45p	80.9	36	51.4	79.3	6.91	.0726	351	1	100.0	15
10/05/24	5:00p	80.7	35	50.5	79.0	6.82	.0727	352	1	100.0	15
10/05/24	5:15p	80.7	35	50.5	79.0	6.82	.0727	351	1	100.0	15
10/05/24	5:30p	81.2	38	53.2	79.8	7.25	.0725	351	1	100.0	15
10/05/24	5:45p	81.3	37	52.5	79.8	7.12	.0725	351	1	100.0	15
10/05/24	6:00p	81.3	37	52.5	79.8	7.12	.0725	352	1	100.0	15
10/05/24	6:15p	80.8	38	52.8	79.4	7.25	.0726	351	1	100.0	15
10/05/24	6:30p	80.7	37	52.0	79.2	7.14	.0726	351	1	100.0	15
10/05/24	6:45p	80.4	40	53.9	79.1	7.55	.0726	351	1	100.0	15
10/05/24	7:00p	80.1	37	51.5	78.6	7.15	.0727	352	1	100.0	15
10/05/24	7:15p	80.1	39	52.9	78.7	7.45	.0727	351	1	100.0	15
10/05/24	7:30p	79.8	41	54.0	78.7	7.75	.0727	351	1	100.0	15
10/05/24	7:45p	79.6	40	53.1	78.3	7.56	.0728	351	1	100.0	15
10/05/24	8:00p	79.7	40	53.2	78.4	7.56	.0728	352	1	100.0	15
10/05/24	8:15p	79.6	42	54.5	78.6	7.86	.0728	351	1	100.0	15
10/05/24	8:30p	79.4	44	55.6	78.7	8.16	.0727	351	1	100.0	15
10/05/24	8:45p	79.1	41	53.4	78.0	7.75	.0729	351	1	100.0	15
10/05/24	9:00p	79.2	41	53.5	78.1	7.75	.0729	351	1	100.0	15
10/05/24	9:15p	79.0	46	56.5	78.5	8.47	.0728	352	1	100.0	15
10/05/24	9:30p	78.6	44	54.9	77.8	8.16	.0729	351	1	100.0	15
10/05/24	9:45p	78.6	42	53.6	77.6	7.88	.0730	351	1	100.0	15
10/05/24	10:00p	78.6	45	55.5	78.0	8.38	.0729	351	1	100.0	15
10/05/24	10:15p	78.5	48	57.2	78.2	8.88	.0729	352	1	100.0	15
10/05/24	10:30p	78.4	47	56.5	78.0	8.68	.0729	351	1	100.0	15
10/05/24	10:45p	78.0	44	54.3	77.2	8.19	.0731	351	1	100.0	15
10/05/24	11:00p	78.1	45	55.0	77.4	8.39	.0730	351	1	100.0	15
10/05/24	11:15p	78.1	49	57.4	78.0	8.99	.0729	351	1	100.0	15
10/05/24	11:30p	77.9	47	56.0	77.5	8.69	.0730	352	1	100.0	15
10/05/24	11:45p	77.7	44	54.0	76.9	8.20	.0731	351	1	100.0	15
10/06/24	12:00a	77.8	51	58.2	77.8	9.35	.0729	351	1	100.0	15

NKSP 10/04/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/04/24	12:15a	74.3	74.9	74.3	9	11.8	2.0	SE	0.50	4.0	SE	74.3	70.3	70.3	29.888	0.00	0.00	0.000	0.097
10/04/24	12:30a	73.8	74.3	73.8	9	11.4	1.0	SE	0.25	3.0	SE	73.8	69.6	69.6	29.887	0.00	0.00	0.000	0.092
10/04/24	12:45a	73.1	73.8	73.1	11	15.4	2.0	SE	0.50	3.0	SE	73.1	69.0	69.0	29.889	0.00	0.00	0.000	0.084
10/04/24	1:00a	72.9	73.1	72.8	11	15.3	1.0	ESE	0.25	4.0	SE	72.9	68.7	68.7	29.892	0.00	0.00	0.000	0.082
10/04/24	1:15a	72.7	73.3	72.7	10	12.9	3.0	SE	0.75	6.0	ESE	72.7	68.3	68.3	29.895	0.00	0.00	0.000	0.080
10/04/24	1:30a	71.9	72.8	71.9	13	18.3	4.0	ESE	1.00	6.0	ESE	71.9	67.5	67.5	29.892	0.00	0.00	0.000	0.072
10/04/24	1:45a	72.2	72.2	71.8	12	16.7	4.0	ESE	1.00	7.0	ESE	72.2	67.8	67.8	29.895	0.00	0.00	0.000	0.075
10/04/24	2:00a	72.3	72.5	72.2	10	12.6	4.0	ESE	1.00	7.0	ESE	72.3	67.7	67.7	29.895	0.00	0.00	0.000	0.076
10/04/24	2:15a	72.0	72.4	72.0	10	12.4	2.0	SE	0.50	5.0	SE	72.0	67.3	67.3	29.895	0.00	0.00	0.000	0.073
10/04/24	2:30a	71.2	71.9	71.1	13	17.8	3.0	S	0.75	6.0	S	71.2	66.6	66.6	29.899	0.00	0.00	0.000	0.065
10/04/24	2:45a	70.3	71.2	70.2	15	20.4	3.0	SSE	0.75	6.0	SSW	70.3	65.5	65.5	29.899	0.00	0.00	0.000	0.055
10/04/24	3:00a	70.9	70.9	70.3	14	19.3	3.0	SSE	0.75	5.0	SSE	70.9	66.3	66.3	29.897	0.00	0.00	0.000	0.061
10/04/24	3:15a	71.0	71.3	70.9	14	19.4	2.0	SE	0.50	4.0	SE	71.0	66.4	66.4	29.897	0.00	0.00	0.000	0.063
10/04/24	3:30a	71.2	71.3	70.9	12	15.9	1.0	SSE	0.25	4.0	S	71.2	66.5	66.5	29.895	0.00	0.00	0.000	0.065
10/04/24	3:45a	71.0	71.3	71.0	12	15.8	3.0	SSE	0.75	5.0	SSE	71.0	66.2	66.2	29.890	0.00	0.00	0.000	0.063
10/04/24	4:00a	70.1	71.0	70.1	14	18.6	2.0	SE	0.50	5.0	SE	70.1	65.1	65.1	29.897	0.00	0.00	0.000	0.053
10/04/24	4:15a	69.7	70.1	69.7	14	18.3	2.0	SE	0.50	4.0	SE	69.7	64.6	64.6	29.898	0.00	0.00	0.000	0.049
10/04/24	4:30a	69.1	69.7	69.0	16	21.0	3.0	SSE	0.75	8.0	SE	69.1	64.1	64.1	29.900	0.00	0.00	0.000	0.043
10/04/24	4:45a	68.9	69.4	68.9	15	19.3	4.0	SE	1.00	7.0	SE	68.9	63.8	63.8	29.900	0.00	0.00	0.000	0.041
10/04/24	5:00a	68.2	68.9	68.1	16	20.2	3.0	SSE	0.75	7.0	SE	68.2	63.1	63.1	29.904	0.00	0.00	0.000	0.033
10/04/24	5:15a	68.5	68.7	68.1	16	20.5	3.0	SSE	0.75	8.0	SE	68.5	63.5	63.5	29.912	0.00	0.00	0.000	0.036
10/04/24	5:30a	68.4	68.5	68.1	16	20.4	3.0	SE	0.75	6.0	SSE	68.4	63.4	63.4	29.915	0.00	0.00	0.000	0.035
10/04/24	5:45a	68.3	68.5	68.2	16	20.3	3.0	SSE	0.75	7.0	SE	68.3	63.2	63.2	29.919	0.00	0.00	0.000	0.034
10/04/24	6:00a	68.9	69.0	68.3	15	19.3	2.0	SE	0.50	5.0	S	68.9	63.8	63.8	29.930	0.00	0.00	0.000	0.041
10/04/24	6:15a	68.7	68.8	68.5	14	17.5	3.0	E	0.75	6.0	ESE	68.7	63.5	63.5	29.921	0.00	0.00	0.000	0.039
10/04/24	6:30a	69.6	69.6	68.7	11	12.7	5.0	ESE	1.25	12.0	E	69.6	64.2	64.2	29.921	0.00	0.00	0.000	0.048
10/04/24	6:45a	70.3	70.4	69.6	9	8.7	3.0	SSE	0.75	8.0	ESE	70.3	64.9	64.9	29.932	0.00	0.00	0.000	0.055
10/04/24	7:00a	71.2	71.2	70.1	4	-8.0	7.0	ENE	1.75	11.0	ENE	71.2	65.8	65.8	29.914	0.00	0.00	0.000	0.065
10/04/24	7:15a	71.4	71.8	71.2	6	0.7	6.0	NE	1.50	20.0	S	71.4	66.2	66.2	29.949	0.00	0.00	0.000	0.067
10/04/24	7:30a	71.8	71.8	71.4	5	-2.9	1.0	ESE	0.25	6.0	ESE	71.8	66.4	66.4	29.948	0.00	0.00	0.000	0.071
10/04/24	7:45a	72.1	72.1	71.8	6	1.2	1.0	SE	0.25	4.0	SE	72.1	66.9	66.9	29.956	0.00	0.00	0.000	0.074
10/04/24	8:00a	73.0	73.0	72.1	5	-2.0	2.0	SE	0.50	10.0	SE	73.0	68.1	68.1	29.972	0.00	0.00	0.000	0.083
10/04/24	8:15a	73.4	73.4	73.0	5	-1.8	3.0	SSE	0.75	7.0	SSE	73.4	68.6	68.6	29.982	0.00	0.00	0.000	0.088
10/04/24	8:30a	74.9	74.9	73.3	1	-32.2	6.0	WSW	1.50	10.0	WSW	74.9	70.3	70.3	29.994	0.00	0.00	0.000	0.103
10/04/24	8:45a	78.0	78.0	74.9	0	---	6.0	SW	1.50	13.0	SW	78.0	73.5	73.5	29.981	0.00	0.00	0.000	0.135
10/04/24	9:00a	79.8	79.8	78.0	0	---	4.0	S	1.00	13.0	E	79.8	75.3	75.3	29.988	0.00	0.00	0.000	0.154
10/04/24	9:15a	80.9	80.9	79.8	0	---	2.0	SW	0.50	6.0	W	80.9	76.3	76.3	29.979	0.00	0.00	0.000	0.166
10/04/24	9:30a	82.1	82.1	80.9	0	---	3.0	SW	0.75	11.0	S	82.1	77.5	77.5	30.002	0.00	0.00	0.000	0.178
10/04/24	9:45a	81.5	82.2	81.4	0	---	5.0	SSW	1.25	10.0	SSW	81.5	76.9	76.9	30.006	0.00	0.00	0.000	0.172
10/04/24	10:00a	82.1	82.1	81.5	0	---	6.0	SSW	1.50	10.0	S	82.1	77.5	77.5	30.010	0.00	0.00	0.000	0.178
10/04/24	10:15a	83.0	83.0	82.1	0	---	3.0	SSW	0.75	8.0	WSW	83.0	78.3	78.3	30.010	0.00	0.00	0.000	0.188
10/04/24	10:30a	84.5	84.5	83.0	0	---	2.0	SSW	0.50	5.0	SW	84.5	79.6	79.6	30.007	0.00	0.00	0.000	0.203
10/04/24	10:45a	87.7	87.7	84.6	0	---	2.0	SE	0.50	4.0	W	87.7	82.2	82.2	30.004	0.00	0.00	0.000	0.236
10/04/24	11:00a	89.9	89.9	87.8	0	---	2.0	SE	0.50	7.0	S	89.9	83.9	83.9	29.997	0.00	0.00	0.000	0.259
10/04/24	11:15a	91.1	91.2	90.0	0	---	4.0	NNE	1.00	13.0	WSW	91.1	84.8	84.8	30.005	0.00	0.00	0.000	0.272
10/04/24	11:30a	90.7	91.1	90.1	0	---	4.0	WSW	1.00	12.0	WSW	90.7	84.5	84.5	30.003	0.00	0.00	0.000	0.268
10/04/24	11:45a	92.5	92.5	90.7	0	---	4.0	S	1.00	10.0	S	92.5	85.8	85.8	29.999	0.00	0.00	0.000	0.286
10/04/24	12:00p	93.5	93.5	92.5	0	---	4.0	SW	1.00	8.0	WSW	93.5	86.6	86.6	29.994	0.00	0.00	0.000	0.297
10/04/24	12:15p	93.9	94.0	93.5	0	---	3.0	SW	0.75	8.0	W	93.9	86.9	86.9	29.985	0.00	0.00	0.000	0.301
10/04/24	12:30p	94.4	94.4	93.9	0	---	5.0	SW	1.25	9.0	WSW	94.4	87.3	87.3	29.978	0.00	0.00	0.000	0.306

NKSP 10/04/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/04/24	12:45p	94.9	94.9	94.3	0	---	4.0	SW	1.00	9.0	SW	94.9	87.6	87.6	29.975	0.00	0.00	0.000	0.311
10/04/24	1:00p	95.6	95.6	94.9	0	---	4.0	SSW	1.00	9.0	W	95.6	88.1	88.1	29.968	0.00	0.00	0.000	0.319
10/04/24	1:15p	96.7	96.7	95.6	0	---	6.0	W	1.50	11.0	SW	96.7	89.0	89.0	29.963	0.00	0.00	0.000	0.330
10/04/24	1:30p	96.8	97.2	96.7	0	---	6.0	W	1.50	12.0	W	96.8	89.0	89.0	29.959	0.00	0.00	0.000	0.331
10/04/24	1:45p	97.7	97.8	96.7	0	---	6.0	WSW	1.50	10.0	W	97.7	89.7	89.7	29.951	0.00	0.00	0.000	0.341
10/04/24	2:00p	98.0	98.1	97.7	0	---	6.0	W	1.50	10.0	W	98.0	89.9	89.9	29.943	0.00	0.00	0.000	0.344
10/04/24	2:15p	98.8	99.0	98.0	0	---	4.0	W	1.00	11.0	WNW	98.8	90.5	90.5	29.940	0.00	0.00	0.000	0.352
10/04/24	2:30p	99.9	99.9	98.8	0	---	4.0	WSW	1.00	11.0	WSW	99.9	91.2	91.2	29.936	0.00	0.00	0.000	0.364
10/04/24	2:45p	99.7	99.9	99.6	0	---	6.0	NW	1.50	11.0	WNW	99.7	91.1	91.1	29.931	0.00	0.00	0.000	0.361
10/04/24	3:00p	99.8	99.8	99.6	0	---	6.0	NW	1.50	10.0	NW	99.8	91.2	91.2	29.933	0.00	0.00	0.000	0.363
10/04/24	3:15p	99.3	99.9	99.2	0	---	5.0	WNW	1.25	11.0	NW	99.3	90.8	90.8	29.933	0.00	0.00	0.000	0.357
10/04/24	3:30p	99.1	99.3	99.1	0	---	6.0	WNW	1.50	11.0	NW	99.1	90.7	90.7	29.929	0.00	0.00	0.000	0.355
10/04/24	3:45p	99.3	99.3	99.1	0	---	6.0	WNW	1.50	9.0	WNW	99.3	90.8	90.8	29.928	0.00	0.00	0.000	0.357
10/04/24	4:00p	100.0	100.0	99.3	0	---	5.0	WNW	1.25	9.0	W	100.0	91.3	91.3	29.926	0.00	0.00	0.000	0.365
10/04/24	4:15p	100.2	100.2	100.0	0	---	4.0	WNW	1.00	9.0	W	100.2	91.5	91.5	29.924	0.00	0.00	0.000	0.367
10/04/24	4:30p	100.2	100.4	100.2	0	---	4.0	N	1.00	7.0	NNE	100.2	91.5	91.5	29.924	0.00	0.00	0.000	0.367
10/04/24	4:45p	99.9	100.2	99.9	0	---	4.0	N	1.00	8.0	NNW	99.9	91.2	91.2	29.925	0.00	0.00	0.000	0.364
10/04/24	5:00p	100.1	100.2	99.9	0	---	3.0	N	0.75	6.0	N	100.1	91.4	91.4	29.922	0.00	0.00	0.000	0.366
10/04/24	5:15p	100.6	100.6	100.1	0	---	3.0	NNW	0.75	6.0	NNW	100.6	91.8	91.8	29.920	0.00	0.00	0.000	0.371
10/04/24	5:30p	100.0	100.7	100.0	0	---	4.0	N	1.00	8.0	NNW	100.0	91.3	91.3	29.922	0.00	0.00	0.000	0.365
10/04/24	5:45p	99.6	99.9	99.6	0	---	4.0	NE	1.00	7.0	NNE	99.6	91.0	91.0	29.922	0.00	0.00	0.000	0.360
10/04/24	6:00p	99.1	99.6	99.0	0	---	4.0	NE	1.00	6.0	NE	99.1	90.7	90.7	29.928	0.00	0.00	0.000	0.355
10/04/24	6:15p	98.0	99.1	98.0	0	---	3.0	ENE	0.75	4.0	NE	98.0	89.9	89.9	29.925	0.00	0.00	0.000	0.344
10/04/24	6:30p	96.7	98.0	96.7	0	---	2.0	ENE	0.50	4.0	N	96.7	89.0	89.0	29.929	0.00	0.00	0.000	0.330
10/04/24	6:45p	94.5	96.7	94.5	0	---	3.0	ENE	0.75	5.0	NE	94.5	87.3	87.3	29.932	0.00	0.00	0.000	0.307
10/04/24	7:00p	92.1	94.4	92.1	0	---	3.0	NE	0.75	6.0	N	92.1	85.6	85.6	29.930	0.00	0.00	0.000	0.282
10/04/24	7:15p	90.9	92.1	90.9	0	---	3.0	NNE	0.75	5.0	NNE	90.9	84.6	84.6	29.932	0.00	0.00	0.000	0.270
10/04/24	7:30p	90.6	90.9	90.6	0	---	2.0	NE	0.50	3.0	NE	90.6	84.4	84.4	29.940	0.00	0.00	0.000	0.267
10/04/24	7:45p	89.8	90.6	89.8	0	---	1.0	NNE	0.25	3.0	NNE	89.8	83.8	83.8	29.948	0.00	0.00	0.000	0.258
10/04/24	8:00p	88.8	89.8	88.8	0	---	1.0	NNE	0.25	4.0	WSW	88.8	83.0	83.0	29.956	0.00	0.00	0.000	0.248
10/04/24	8:15p	87.0	88.7	87.0	0	---	1.0	SSW	0.25	2.0	SW	87.0	81.6	81.6	29.957	0.00	0.00	0.000	0.229
10/04/24	8:30p	86.6	87.0	86.6	0	---	1.0	SSW	0.25	2.0	SSW	86.6	81.3	81.3	29.963	0.00	0.00	0.000	0.225
10/04/24	8:45p	85.7	86.7	85.7	0	---	0.0	SSW	0.00	2.0	SSW	85.7	80.6	80.6	29.964	0.00	0.00	0.000	0.216
10/04/24	9:00p	84.4	85.6	84.3	0	---	0.0	---	0.00	0.0	---	84.4	79.5	79.5	29.964	0.00	0.00	0.000	0.202
10/04/24	9:15p	82.9	84.3	82.8	1	-27.4	2.0	SSE	0.50	4.0	S	82.9	78.3	78.3	29.969	0.00	0.00	0.000	0.186
10/04/24	9:30p	83.4	83.4	82.8	0	---	1.0	SSE	0.25	2.0	SSE	83.4	78.6	78.6	29.975	0.00	0.00	0.000	0.192
10/04/24	9:45p	82.8	83.7	82.8	2	-14.2	2.0	SE	0.50	3.0	SSE	82.8	78.3	78.3	29.981	0.00	0.00	0.000	0.185
10/04/24	10:00p	80.5	82.8	80.5	5	3.3	4.0	SE	1.00	7.0	SE	80.5	76.4	76.4	29.985	0.00	0.00	0.000	0.161
10/04/24	10:15p	78.2	80.4	78.2	8	12.0	4.0	SE	1.00	7.0	SE	78.2	74.6	74.6	29.990	0.00	0.00	0.000	0.137
10/04/24	10:30p	77.7	78.2	77.5	9	14.3	3.0	SE	0.75	5.0	SE	77.7	74.1	74.1	29.991	0.00	0.00	0.000	0.132
10/04/24	10:45p	76.8	77.7	76.6	9	13.6	3.0	SE	0.75	6.0	SSE	76.8	73.1	73.1	29.996	0.00	0.00	0.000	0.123
10/04/24	11:00p	77.3	77.6	76.9	8	11.3	2.0	SE	0.50	3.0	SE	77.3	73.6	73.6	29.993	0.00	0.00	0.000	0.128
10/04/24	11:15p	77.0	77.5	77.0	9	13.8	2.0	SE	0.50	4.0	SE	77.0	73.4	73.4	30.001	0.00	0.00	0.000	0.125
10/04/24	11:30p	74.8	77.0	74.8	14	22.4	3.0	SSW	0.75	6.0	SW	74.8	71.6	71.6	30.004	0.00	0.00	0.000	0.102
10/04/24	11:45p	74.6	74.9	74.6	15	23.9	1.0	SSW	0.25	4.0	SSW	74.6	71.5	71.5	29.999	0.00	0.00	0.000	0.100
10/05/24	12:00a	73.9	74.6	73.9	15	23.3	2.0	S	0.50	6.0	SSE	73.9	70.6	70.6	30.004	0.00	0.00	0.000	0.093

NKSP 10/04/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/04/24	12:15a	77.9	51	58.3	77.9	9.35	.0725	350	1	100.0	15
10/04/24	12:30a	77.9	49	57.2	77.8	8.99	.0726	351	1	100.0	15
10/04/24	12:45a	77.9	47	56.0	77.5	8.69	.0726	352	1	100.0	15
10/04/24	1:00a	77.9	52	58.9	78.0	9.49	.0725	351	1	100.0	15
10/04/24	1:15a	77.7	51	58.1	77.7	9.35	.0726	351	1	100.0	15
10/04/24	1:30a	77.7	48	56.4	77.4	8.90	.0726	351	1	100.0	15
10/04/24	1:45a	77.8	52	58.8	77.9	9.49	.0725	351	1	100.0	15
10/04/24	2:00a	77.6	52	58.6	77.7	9.50	.0726	352	1	100.0	15
10/04/24	2:15a	77.5	49	56.8	77.3	9.00	.0727	351	1	100.0	15
10/04/24	2:30a	77.4	47	55.6	77.0	8.70	.0727	351	1	100.0	15
10/04/24	2:45a	77.1	48	55.9	76.8	8.91	.0728	351	1	100.0	15
10/04/24	3:00a	77.1	51	57.6	77.1	9.35	.0727	352	1	100.0	15
10/04/24	3:15a	76.9	51	57.4	76.9	9.35	.0727	351	1	100.0	15
10/04/24	3:30a	76.8	50	56.8	76.7	9.21	.0728	351	1	100.0	15
10/04/24	3:45a	76.8	48	55.6	76.5	8.91	.0728	351	1	100.0	15
10/04/24	4:00a	76.8	48	55.6	76.5	8.91	.0728	352	1	100.0	15
10/04/24	4:15a	76.8	50	56.8	76.7	9.21	.0728	351	1	100.0	15
10/04/24	4:30a	76.7	52	57.7	76.7	9.52	.0727	351	1	100.0	15
10/04/24	4:45a	76.5	51	57.0	76.5	9.35	.0728	351	1	100.0	15
10/04/24	5:00a	77.0	54	59.1	77.1	9.81	.0727	351	1	100.0	15
10/04/24	5:15a	76.9	53	58.5	77.0	9.65	.0727	352	1	100.0	15
10/04/24	5:30a	77.1	49	56.5	76.9	9.01	.0728	351	1	100.0	15
10/04/24	5:45a	77.1	53	58.6	77.2	9.65	.0727	351	1	100.0	15
10/04/24	6:00a	77.1	50	57.0	77.0	9.21	.0728	351	1	100.0	15
10/04/24	6:15a	77.3	52	58.3	77.3	9.50	.0727	352	1	100.0	15
10/04/24	6:30a	77.1	53	58.6	77.2	9.65	.0727	351	1	100.0	15
10/04/24	6:45a	77.2	48	56.0	76.9	8.91	.0728	351	1	100.0	15
10/04/24	7:00a	77.2	52	58.2	77.2	9.51	.0727	352	1	100.0	15
10/04/24	7:15a	77.0	50	56.9	76.9	9.21	.0729	350	1	100.0	15
10/04/24	7:30a	77.4	49	56.7	77.2	9.00	.0728	352	1	100.0	15
10/04/24	7:45a	77.1	51	57.6	77.1	9.35	.0728	351	1	100.0	15
10/04/24	8:00a	77.2	49	56.6	77.0	9.01	.0729	351	1	100.0	15
10/04/24	8:15a	77.6	49	56.9	77.4	9.00	.0729	351	1	100.0	15
10/04/24	8:30a	77.4	51	57.9	77.4	9.35	.0729	352	1	100.0	15
10/04/24	8:45a	77.6	47	55.8	77.2	8.70	.0729	351	1	100.0	15
10/04/24	9:00a	78.0	49	57.3	77.9	8.99	.0728	351	1	100.0	15
10/04/24	9:15a	77.8	50	57.7	77.8	9.19	.0728	351	1	100.0	15
10/04/24	9:30a	77.9	45	54.8	77.2	8.39	.0730	352	1	100.0	15
10/04/24	9:45a	78.3	48	57.0	78.0	8.88	.0728	351	1	100.0	15
10/04/24	10:00a	78.1	49	57.4	78.0	8.99	.0728	351	1	100.0	15
10/04/24	10:15a	78.2	45	55.1	77.5	8.39	.0729	351	1	100.0	15
10/04/24	10:30a	78.6	48	57.3	78.3	8.88	.0728	352	1	100.0	15
10/04/24	10:45a	78.7	48	57.4	78.4	8.88	.0728	351	1	100.0	15
10/04/24	11:00a	79.0	43	54.6	78.2	8.05	.0728	351	1	100.0	15
10/04/24	11:15a	79.5	44	55.7	78.8	8.16	.0727	351	1	100.0	15
10/04/24	11:30a	79.6	46	57.0	79.1	8.46	.0726	351	1	100.0	15
10/04/24	11:45a	79.5	41	53.7	78.4	7.75	.0728	352	1	100.0	15
10/04/24	12:00p	79.5	41	53.7	78.4	7.75	.0728	351	1	100.0	15
10/04/24	12:15p	79.4	43	55.0	78.5	8.05	.0727	351	1	100.0	15
10/04/24	12:30p	79.6	39	52.5	78.3	7.46	.0728	351	1	100.0	15

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/04/24	12:45p	79.5	42	54.4	78.5	7.86	.0727	352	1	100.0	15
10/04/24	1:00p	79.7	39	52.5	78.3	7.46	.0727	351	1	100.0	15
10/04/24	1:15p	79.6	37	51.0	78.1	7.16	.0728	351	1	100.0	15
10/04/24	1:30p	79.5	37	50.9	78.0	7.16	.0728	351	1	100.0	15
10/04/24	1:45p	79.5	37	50.9	78.0	7.16	.0728	351	1	100.0	15
10/04/24	2:00p	79.6	37	51.0	78.1	7.16	.0727	352	1	100.0	15
10/04/24	2:15p	79.9	37	51.3	78.4	7.15	.0727	351	1	100.0	15
10/04/24	2:30p	80.3	36	50.9	78.7	6.94	.0726	351	1	100.0	15
10/04/24	2:45p	80.6	36	51.2	79.0	6.93	.0726	351	1	100.0	15
10/04/24	3:00p	80.6	36	51.2	79.0	6.93	.0726	352	1	100.0	15
10/04/24	3:15p	80.3	36	50.9	78.7	6.94	.0726	351	1	100.0	15
10/04/24	3:30p	80.0	36	50.6	78.4	6.95	.0726	351	1	100.0	15
10/04/24	3:45p	80.1	36	50.7	78.5	6.95	.0726	351	1	100.0	15
10/04/24	4:00p	80.5	35	50.3	78.8	6.83	.0726	352	1	100.0	15
10/04/24	4:15p	80.7	36	51.3	79.1	6.92	.0725	351	1	100.0	15
10/04/24	4:30p	80.5	35	50.3	78.8	6.83	.0726	351	1	100.0	15
10/04/24	4:45p	80.4	35	50.2	78.7	6.83	.0726	351	1	100.0	15
10/04/24	5:00p	80.2	35	50.1	78.5	6.84	.0726	351	1	100.0	15
10/04/24	5:15p	80.3	35	50.1	78.6	6.84	.0726	352	1	100.0	15
10/04/24	5:30p	80.0	35	49.9	78.3	6.85	.0727	351	1	100.0	15
10/04/24	5:45p	79.9	35	49.8	78.2	6.85	.0727	351	1	100.0	15
10/04/24	6:00p	80.6	37	51.9	79.1	7.14	.0725	351	1	100.0	15
10/04/24	6:15p	80.3	36	50.9	78.7	6.94	.0726	352	1	100.0	15
10/04/24	6:30p	79.9	36	50.6	78.3	6.95	.0727	351	1	100.0	15
10/04/24	6:45p	79.6	36	50.3	78.0	6.96	.0727	351	1	100.0	15
10/04/24	7:00p	79.9	38	52.0	78.5	7.23	.0726	351	1	100.0	15
10/04/24	7:15p	79.0	37	50.5	77.6	7.17	.0728	351	1	100.0	15
10/04/24	7:30p	79.2	39	52.1	77.9	7.47	.0727	352	1	100.0	15
10/04/24	7:45p	78.4	37	50.0	77.0	7.18	.0729	351	1	100.0	15
10/04/24	8:00p	78.6	42	53.6	77.6	7.88	.0728	351	1	100.0	15
10/04/24	8:15p	78.4	38	50.7	77.0	7.28	.0729	351	1	100.0	15
10/04/24	8:30p	78.6	41	52.9	77.5	7.75	.0728	352	1	100.0	15
10/04/24	8:45p	78.2	43	53.9	77.3	8.05	.0729	351	1	100.0	15
10/04/24	9:00p	78.3	40	52.0	77.1	7.58	.0729	351	1	100.0	15
10/04/24	9:15p	78.3	44	54.6	77.5	8.18	.0728	351	1	100.0	15
10/04/24	9:30p	77.9	44	54.2	77.1	8.19	.0729	352	1	100.0	15
10/04/24	9:45p	78.0	41	52.4	76.9	7.75	.0730	351	1	100.0	15
10/04/24	10:00p	78.2	45	55.1	77.5	8.39	.0729	351	1	100.0	15
10/04/24	10:15p	77.8	46	55.4	77.3	8.49	.0729	351	1	100.0	15
10/04/24	10:30p	77.8	43	53.5	76.9	8.05	.0730	352	1	100.0	15
10/04/24	10:45p	78.1	47	56.2	77.7	8.69	.0729	351	1	100.0	15
10/04/24	11:00p	77.9	48	56.6	77.6	8.89	.0729	351	1	100.0	15
10/04/24	11:15p	77.8	45	54.8	77.1	8.39	.0730	351	1	100.0	15
10/04/24	11:30p	78.0	48	56.7	77.7	8.89	.0729	351	1	100.0	15
10/04/24	11:45p	77.5	51	57.9	77.5	9.35	.0729	352	1	100.0	15
10/05/24	12:00a	77.4	48	56.2	77.1	8.90	.0730	351	1	100.0	15

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/19)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: A-1 Temp. Reading Location: A - Side (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-7-24	0300	72	G RAMIREZ
	0600	70°	E. Andrade
	0900	73	E. Andrade
	1200	74	E. Andrade
	1500	73	R. Knight
	1800	72	R. Knight
	2100	72	R. Knight
	2400	72	D Hue

Tuesday

Date	Time	Temp.	Name (Print)
10-8-24	0300	71	D Hue
	0600	70°	E. Andrade
	0900	71°	E. Andrade
	1200	73	E. Andrade
	1500	75°	E. Jones
	1800	75°	E. Jones
	2100	73°	E. Jones
	2400	71	D Hue

Wednesday

Date	Time	Temp.	Name (Print)
10/09/24	0300	70	D Hue
	0600	70	E. Andrade
	0900	74	E. Andrade
	1200	76	E. Andrade
	1500	76	D. Castejon
	1800	76	D. Castejon
	2100	76	D. Castejon
	2400	74	D Hue

Thursday

Date	Time	Temp.	Name (Print)
10/10/24	0300	72	D Hue
	0600	70°	E. Andrade
	0900	74	E Andrade
	1200	75	E. Andrade
	1500	76	Riley
	1800	75.1	Riley
	2100	73	Riley
	2400	72	D Hue

Friday

Date	Time	Temp.	Name (Print)
10/11/24	0300	70	D Hue
	0600	70	R. Rivera
	0900	70	R. Rivera
	1200	72	R. Rivera
	1500	72	E MENDEZ
	1800	72	E MENDEZ
	2100	72	E MENDEZ
	2400	71	G Rios

Saturday

Date	Time	Temp.	Name (Print)
10/12/24	0300	70	G Rios
	0600	70	M. Pompa
	0900	70	M. Pompa
	1200	70	M. Pompa
	1500	70	E MENDEZ
	1800	70	E MENDEZ
	2100	70	E MENDEZ
	2400	70	G Rios

Sunday

Date	Time	Temp.	Name (Print)
10/13/24	0300	70	G Rios
	0600	70	M. Pompa
	0900	70	M. Pompa
	1200	70	M. Pompa
	1500	72	R. Knight
	1800	72	R. Knight
	2100	72	R. Knight
	2400	70	G Rios

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

Attachment 11

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: A-1 Temp. Reading Location: B-side
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/07/24	0300	72°	GRAMIREZ
	0600	72	E. Andrade
	0900	73	E. Andrade
	1200	74	E. Andrad
	1500	73	R. Knight
	1800	72	R. Knight
	2100	72	R. Knight
	2400	72	D Hu

Tuesday

Date	Time	Temp.	Name (Print)
10/08/24	0300	71	D Hu
	0600	71°	E. Andrad
	0900	71°	E. Andrade
	1200	73°	E. Andrade
	1500	72	Z. Jones
	1800	75	Z Jones
	2100	79	Z. Jones
	2400	71	D. Hu

Wednesday

Date	Time	Temp.	Name (Print)
10/09/24	0300	70	D Hu
	0600	70	E. Andrade
	0900	74	E. Andrad
	1200	75	E. Andrade
	1500	76	D. Castrejon
	1800	76	D. Castrejon
	2100	76	D. Castrejon
	2400	74	D. Hu

Thursday

Date	Time	Temp.	Name (Print)
10/10/24	0300	72	D. Hu
	0600	73°	E. Andrade
	0900	74	E. Andrade
	1200	75	E. Andrade
	1500	76	Riley
	1800	75	Riley
	2100	73	Riley
	2400	73	D Hu

Friday

Date	Time	Temp.	Name (Print)
10/11/24	0300	70	D Hu
	0600	70	R. Rivera
	0900	70	R. Rivera
	1200	72	R. Rivera
	1500	72	E MENDEZ
	1800	72	E MENDEZ
	2100	72	E MENDEZ
	2400	71	G Rios

Saturday

Date	Time	Temp.	Name (Print)
10/12/24	0300	70	G Rios
	0600	70	M. Ramos
	0900	70	M. Ramos
	1200	70	M. Ramos
	1500	70	E MENDEZ
	1800	70	E MENDEZ
	2100	70	E MENDEZ
	2400	70	G Rios

Sunday

Date	Time	Temp.	Name (Print)
10/13/24	0300	68	G. Rios
	0600	70	M. Ramos
	0900	70	M. Ramos
	1200	70	M. Ramos
	1500	72	R. Knight
	1800	72	R. Knight
	2100	72	R. Knight
	2400	70	G. Rios

Notes

DISTRIBUTION: Original; Institution Heat Plan Coordinator

Attachment 11

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB -2 Temp. Reading Location: 2nd Tier - A Section
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/07/24	0300	77°	J Bunn
	0600	75	R. Lira
	0900	76	R. Lira
	1200	77	R. Lira
	1500	79	O Rio
	1800	81	O Rio
	2100	79	O Rio
	2400	79	J Bunn

Tuesday

Date	Time	Temp.	Name (Print)
10/08/24	0300	77	J Bunn
	0600	75	R. Lira
	0900	76	R. Lira
	1200	77	R. Lira
	1500	79	O Rio
	1800	80	O Rio
	2100	79	O Rio
	2400	77	CHAPI

Wednesday

Date	Time	Temp.	Name (Print)
10/09/24	0300	76	CHAPI
	0600	75	CHAPI
	0900	76	R. Lira
	1200	77	R. Lira
	1500	79	O Rio
	1800	80	O Rio
	2100	77	O Rio
	2400	74	Gill

Thursday

Date	Time	Temp.	Name (Print)
10/10/24	0300	74	Gill
	0600	74	R. Lira
	0900	75	R. Lira
	1200	76	R. Lira
	1500	78	Fosan
	1800	78	Fosan
	2100	78	Fosan
	2400	75	Gill

Friday

Date	Time	Temp.	Name (Print)
10/11/24	0300	73	Gill
	0600	72	CHAN
	0900	72	CHAN
	1200	72	CHAN
	1500	72	R. Knight
	1800	74	R. Knight
	2100	74	R. Knight
	2400	74	J Bunn

Saturday

Date	Time	Temp.	Name (Print)
10/12/24	0300	72	J Bunn
	0600	70	CHAN
	0900	70	CHAN
	1200	72	CHAN
	1500	72	R. Knight
	1800	72	R. Knight
	2100	72	R. Knight
	2400	72	J Bunn

Sunday

Date	Time	Temp.	Name (Print)
10/13/24	0300	71	J Bunn
	0600	71	R. Lira
	0900	72	R. Lira
	1200	73	R. Lira
	1500	75	O Rio
	1800	76	O Rio
	2100	75	O Rio
	2400	74	J Bunn

Notes

DISTRIBUTION: Original; Institution Heat Plan Coordinator

Attachment 11

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB-2 Temp. Reading Location: 2nd Tier - B section
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/7/24	0300	77	J Blanco
	0600	75	R. Lira
	0900	76	R. Lira
	1200	77	R. Lira
	1500	79	O Rubio
	1800	82	O Rubio
	2100	79	O Rubio
	2400	79	J Blanco

Tuesday

Date	Time	Temp.	Name (Print)
10/08/24	0300	77	J Blanco
	0600	75	R. Lira
	0900	76	R. Lira
	1200	77	R. Lira
	1500	79	O Rubio
	1800	80	O Rubio
	2100	77	O Rubio
	2400	77	CHAPM

Wednesday

Date	Time	Temp.	Name (Print)
10/09/24	0300	76	CHAPM
	0600	75	CHAPM
	0900	76	R. Lira
	1200	77	R. Lira
	1500	79	O Rubio
	1800	81	O Rubio
	2100	77	O Rubio
	2400	74	Gill

Thursday

Date	Time	Temp.	Name (Print)
10/10/24	0300	74	Gill
	0600	74	R. Lira
	0900	75	R. Lira
	1200	76	R. Lira
	1500	78	LOSAN
	1800	78	LOSAN
	2100	78	LOSAN
	2400	75	Gill

Friday

Date	Time	Temp.	Name (Print)
10/11/24	0300	75	Gill
	0600	72	CHAN
	0900	72	CHAN
	1200	72	CHAN
	1500	72	R. Knight
	1800	74	R. Knight
	2100	74	R. Knight
	2400	74	J Blanco

Saturday

Date	Time	Temp.	Name (Print)
10/12/24	0300	72	J Blanco
	0600	70	CHAN
	0900	70	CHAN
	1200	72	CHAN
	1500	72	R. Knight
	1800	72	R. Knight
	2100	72	R. Knight
	2400	72	J Blanco

Sunday

Date	Time	Temp.	Name (Print)
10/13/24	0300	71	J Blanco
	0600	71	R. Lira
	0900	72	R. Lira
	1200	73	R. Lira
	1500	75	O Rubio
	1800	76	O Rubio
	2100	75	O Rubio
	2400	74	J Blanco

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

Attachment 11

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB-A3 Temp. Reading Location: 2nd tier A-sec
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-7-24	0300	70	Gonzalez
	0600	70	Saldana
	0900	70	Saldana
	1200	71	Saldana
	1500	72	Lule
	1800	72	Lule
	2100	72	Lule
	2400	70	Gonzalez

Tuesday

Date	Time	Temp.	Name (Print)
10-8-24	0300	75	A. Macedo
	0600	70	CHAN
	0900	70	CHAN
	1200	72	CHAN
	1500	73	R. Borquez
	1800	73	R. Borquez
	2100	73	R. Borquez
	2400	70	LANE

Wednesday

Date	Time	Temp.	Name (Print)
10-09-24	0300	70°	LANE
	0600	70	Pompa
	0900	70	Pompa
	1200	70	Pompa
	1500	70	GRAYSON
	1800	70	GRAYSON
	2100	70	GRAYSON
	2400	72°	LANE

Thursday

Date	Time	Temp.	Name (Print)
10-10-24	0300	70°	LANE
	0600	69	Saldana
	0900	69	Saldana
	1200	70	Saldana
	1500	70	R. Knight
	1800	70	R. Knight
	2100	70	R. Knight
	2400	70°	LANE

Friday

Date	Time	Temp.	Name (Print)
10-11-24	0300	70°	LANE
	0600	68	Saldana
	0900	69	Saldana
	1200	70	Saldana
	1500	73	HINOJOSA
	1800	73	HINOJOSA
	2100	71	HINOJOSA
	2400	70°	LANE

Saturday

Date	Time	Temp.	Name (Print)
10-12-24	0300	70°	LANE
	0600	65	Saldana
	0900	68	Saldana
	1200	68	Saldana
	1500	74	GAGE
	1800	75	GAGE
	2100	74	GAGE
	2400	70°	LANE

Sunday

Date	Time	Temp.	Name (Print)
10-13-24	0300	70°	LANE
	0600	64	Saldana
	0900	65	Saldana
	1200	68	Saldana
	1500	72	ETHINOJOSA
	1800	72	ETHINOJOSA
	2100	71	ETHINOJOSA
	2400	70°	LANE

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB3 Temp. Reading Location: 2nd Tier B sec
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10.2.24	0300	70	Gonzalez
	0600	70	Saldana
	0900	70	Saldana
	1200	71	Saldana
	1500	72	Lule
	1800	72	Lule
	2100	72	Lule
	2400	70	Gonzalez

Tuesday

Date	Time	Temp.	Name (Print)
10.8.24	0300	75	A. Macedo
	0600	70	CHAN
	0900	70	CHAN
	1200	72	CHAN
	1500	73	R. Borquez
	1800	73	R. Borquez
	2100	73	R. Borquez
	2400	70°	LANE

Wednesday

Date	Time	Temp.	Name (Print)
10.09.24	0300	70°	LANE
	0600	70	Pompa
	0900	70	Pompa
	1200	70	Pompa
	1500	70	GRAYSON
	1800	70	GRAYSON
	2100	70	GRAYSON
	2400	72°	LANE

Thursday

Date	Time	Temp.	Name (Print)
10.10.24	0300	70°	LANE
	0600	69	Saldana
	0900	69	Saldana
	1200	70	Saldana
	1500	70	R. Knight
	1800	70	R. Knight
	2100	70	R. Knight
	2400	70°	LANE

Friday

Date	Time	Temp.	Name (Print)
10.11.24	0300	70°	LANE
	0600	68	Saldana
	0900	69	Saldana
	1200	70	Saldana
	1500	72	HAMUTSA
	1800	72	HAMUTSA
	2100	71	HAMUTSA
	2400	70°	LANE

Saturday

Date	Time	Temp.	Name (Print)
10.12.24	0300	70°	LANE
	0600	65	Saldana
	0900	68	Saldana
	1200	68	Saldana
	1500	74	GAGE
	1800	75	GAGE
	2100	74	GAGE
	2400	70°	LANE

Sunday

Date	Time	Temp.	Name (Print)
10.13.24	0300	70°	LANE
	0600	64	Saldana
	0900	65	Saldana
	1200	68	Saldana
	1500	70	HAMUTSA
	1800	70	HAMUTSA
	2100	69	HAMUTSA
	2400	72°	LANE

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

Attachment 11

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: A4-A Temp. Reading Location: DAY ROOM (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/7/24	0300	73	C. Ramsey
	0600	74	CHAN
	0900	74	CHAN
	1200	74	CHAN
	1500	77	Barza
	1800	76	Barza
	2100	75	Barza
	2400	76	PRICE

Tuesday

Date	Time	Temp.	Name (Print)
10/8/24	0300	76	PRICE
	0600	76	O.Montoya
	0900	76	O.Montoya
	1200	78	O.Montoya
	1500	79	D.Barza
	1800	77	D.Barza
	2100	76	D.Barza
	2400	76	PRICE

Wednesday

Date	Time	Temp.	Name (Print)
10/9/24	0300	76	PRICE
	0600	76	O.Montoya
	0900	76	O.Montoya
	1200	76	O.Montoya
	1500	79	D.Barza
	1800	76	D.Barza
	2100	75	D.Barza
	2400	76	PRICE

Thursday

Date	Time	Temp.	Name (Print)
10/10/24	0300	76	PRICE
	0600	76	O.Montoya
	0900	76	O.Montoya
	1200	76	O.Montoya
	1500	75	D.Barza
	1800	74	D.Barza
	2100	73	D.Barza
	2400	74	PRICE

Friday

Date	Time	Temp.	Name (Print)
10/11/24	0300	74	PRICE
	0600	74	O.Montoya
	0900	74	O.Montoya
	1200	74	O.Montoya
	1500	76	Barza
	1800	75	Barza
	2100	75	Barza
	2400	72	PRICE

Saturday

Date	Time	Temp.	Name (Print)
10/12/24	0300	72	PRICE
	0600	72	O.Montoya
	0900	74	O.Montoya
	1200	76	O.Montoya
	1500	75	Murga
	1800	75	Murga
	2100	75	Murga
	2400	76	C.Ramsey

Sunday

Date	Time	Temp.	Name (Print)
10/13/24	0300	74	C.Ramsey
	0600	70	CHAN
	0900	70	CHAN
	1200	72	CHAN
	1500	75	Murga
	1800	75	Murga
	2100	75	Murga
	2400	75	Reyes

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NICSP Housing Unit: A4-B Temp. Reading Location: DAYROOM (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3041 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/7/24	0300	73	C. Ramirez
	0600	74	CHAN
	0900	74	CHAN
	1200	74	CHAN
	1500	77	Barza
	1800	76	Barza
	2100	74	Barza
	2400	76	PRICE

Tuesday

Date	Time	Temp.	Name (Print)
10/8/24	0300	76	PRICE
	0600	76	O.Montoya
	0900	76	O.Montoya
	1200	78	O.Montoya
	1500	79	D. Barza
	1800	77	D. Barza
	2100	76	D. Barza
	2400	76	PRICE

Wednesday

Date	Time	Temp.	Name (Print)
10/9/24	0300	76	PRICE
	0600	76	O.Montoya
	0900	76	O.Montoya
	1200	76	O.Montoya
	1500	75	D. Barza
	1800	75	D. Barza
	2100	75	D. Barza
	2400	76	PRICE

Thursday

Date	Time	Temp.	Name (Print)
10/10/24	0300	76	PRICE
	0600	76	O.Montoya
	0900	76	O.Montoya
	1200	76	O.Montoya
	1500	74	D.Barza
	1800	73	D.Barza
	2100	73	D.Barza
	2400	74	PRICE

Friday

Date	Time	Temp.	Name (Print)
10/11/24	0300	74	PRICE
	0600	74	O.Montoya
	0900	76	O.Montoya
	1200	77	O.Montoya
	1500	75	Barza
	1800	75	Barza
	2100	75	Barza
	2400	72	PRICE

Saturday

Date	Time	Temp.	Name (Print)
10/12/24	0300	72	PRICE
	0600	72	O.Montoya
	0900	74	O.Montoya
	1200	76	O.Montoya
	1500	74	Morgan
	1800	74	Morgan
	2100	74	Morgan
	2400	74	C. Ramirez

Sunday

Date	Time	Temp.	Name (Print)
10/13/24	0300	72	C. Ramirez
	0600	70	CHAN
	0900	70	CHAN
	1200	72	CHAN
	1500	75	Morgan
	1800	75	Morgan
	2100	75	Morgan
	2400	75	Reveles

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB-5A Temp. Reading Location: 2ND TIER A-SECTION
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/7/24	0300	70	[illegible]
	0600	75	Pompa
	0900	75	Pompa
	1200	75	Pompa
	1500	75	GRAYSON
	1800	75	GRAYSON
	2100	75	GRAYSON
	2400	74	D. [illegible]

Tuesday

Date	Time	Temp.	Name (Print)
10-8-24	0300	72	D. [illegible]
	0600	75	Pompa
	0900	75	Pompa
	1200	75	Pompa
	1500	75	GRAYSON
	1800	75	GRAYSON
	2100	75	GRAYSON
	2400	75	D. [illegible]

Wednesday

Date	Time	Temp.	Name (Print)
10-9-24	0300	74	D. [illegible]
	0600	72	G. ESPINOZA
	0900	75	G. ESPINOZA
	1200	75	G. ESPINOZA
	1500	75	Gill
	1800	75	Gill
	2100	75	Gill
	2400	75	D. [illegible]

Thursday

Date	Time	Temp.	Name (Print)
10-10-24	0300	74	D. [illegible]
	0600	72	G. ESPINOZA
	0900	74	G. ESPINOZA
	1200	75	G. ESPINOZA
	1500	75	Gill
	1800	75	Gill
	2100	75	Gill
	2400	74	Romero

Friday

Date	Time	Temp.	Name (Print)
10/11/24	0300	73	Romero
	0600	71	G. ESPINOZA
	0900	74	G. ESPINOZA
	1200	74	G. ESPINOZA
	1500	76	C. Rios
	1800	76	C. Rios
	2100	72	C. Rios
	2400	74	C. Ramirez

Saturday

Date	Time	Temp.	Name (Print)
10/12/24	0300	72	C. Ramirez
	0600	70	G. ESPINOZA
	0900	70	G. ESPINOZA
	1200	72	G. ESPINOZA
	1500	72	C. Rios
	1800	72	C. Rios
	2100	70	C. Rios
	2400	70	C. Rios

Sunday

Date	Time	Temp.	Name (Print)
10/13/24	0300	70	C. Rios
	0600	70	G. ESPINOZA
	0900	70	G. ESPINOZA
	1200	72	G. ESPINOZA
	1500	72	C. Rios
	1800	72	C. Rios
	2100	70	C. Rios
	2400	70	Ramirez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: FAB-5B Temp. Reading Location: 2ND TIER B-SECTION
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10.7.24	0300	78	Price
	0600	75	Pompa
	0900	75	Pompa
	1200	75	Pompa
	1500	75	Grayson
	1800	75	Grayson
	2100	75	Grayson
	2400	74	D. Tovar

Tuesday

Date	Time	Temp.	Name (Print)
10-8-24	0300	72	D. Tovar
	0600	75	Pompa
	0900	75	Pompa
	1200	75	Pompa
	1500	75	Grayson
	1800	75	Grayson
	2100	75	Grayson
	2400	75	D. Tovar

Wednesday

Date	Time	Temp.	Name (Print)
10-9-24	0300	74	D. Tovar
	0600	72	G. ESPINOZA
	0900	75	G. ESPINOZA
	1200	75	G. ESPINOZA
	1500	75	Gill
	1800	75	Gill
	2100	75	Gill
	2400	75	D. Tovar

Thursday

Date	Time	Temp.	Name (Print)
10/10/24	0300	74	D. Tovar
	0600	72	G. ESPINOZA
	0900	74	G. ESPINOZA
	1200	75	G. ESPINOZA
	1500	75	Gill
	1800	75	Gill
	2100	75	Gill
	2400	74	Reeves

Friday

Date	Time	Temp.	Name (Print)
10/11/24	0300	73°	Reeves
	0600	71	G. ESPINOZA
	0900	74	G. ESPINOZA
	1200	74	G. ESPINOZA
	1500	76	C. Rios
	1800	76	C. Rios
	2100	72	C. Rios
	2400	74	C. Ramirez

Saturday

Date	Time	Temp.	Name (Print)
10/12/24	0300	72	Ramirez
	0600	70	G. ESPINOZA
	0900	70	G. ESPINOZA
	1200	72	G. ESPINOZA
	1500	72	C. Rios
	1800	72	C. Rios
	2100	70	C. Rios
	2400	70	C. Rios

Sunday

Date	Time	Temp.	Name (Print)
10/13/24	0300	70	C. Rios
	0600	70	G. ESPINOZA
	0900	70	G. ESPINOZA
	1200	72	G. ESPINOZA
	1500	72	C. Rios
	1800	72	C. Rios
	2100	70	C. Rios
	2400	70	Ramirez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITA

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 1 (A or B) Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10.07.24	0300	77°	Fagundo
	0600	79	Ehrtower, J.
	0900	80	Ehrtower, J.
	1200	80	Ehrtower, J.
	1500	80	J Soto
	1800	79	J Soto
	2100	78	J Soto
	2400	77	Ortega

Tuesday

Date	Time	Temp.	Name (Print)
10.08.24	0300	77	Ortega
	0600	76	R Ramirez
	0900	77	R Ramirez
	1200	80	R Ramirez
	1500	80	J Soto
	1800	79	J Soto
	2100	78	J Soto
	2400	78	Dunn

Wednesday

Date	Time	Temp.	Name (Print)
10.09.24	0300	78	Dunn
	0600	78	R Ramirez
	0900	78	R Ramirez
	1200	80	R Ramirez
	1500	80	J Soto
	1800	79	J Soto
	2100	78	J Soto
	2400	78	Fagundo

Thursday

Date	Time	Temp.	Name (Print)
10.10.24	0300	78	Fagundo
	0600	78	R Ramirez
	0900	78	R Ramirez
	1200	80	R Ramirez
	1500	79	J Soto
	1800	79	J Soto
	2100	75	J Soto
	2400	77	A Ramos

Friday

Date	Time	Temp.	Name (Print)
10.11.24	0300	77	A Ramos
	0600	77	[illegible]
	0900	77	[illegible]
	1200	78	[illegible]
	1500	78	Tamayo
	1800	78	Tamayo
	2100	77	Tamayo
	2400	77	A Ramos

Saturday

Date	Time	Temp.	Name (Print)
10.12.24	0300	77	A Ramos
	0600	77	[illegible]
	0900	77	Tamayo
	1200	77	Tamayo
	1500	77	Mugnos
	1800	77	Mugnos
	2100	77	[illegible]
	2400	77	G Linares

Sunday

Date	Time	Temp.	Name (Print)
10.13.24	0300	77	G Linares
	0600	76	Barrones
	0900	78	Barrones
	1200	80	Barrones
	1500	79	Castellanes
	1800	79	Castellanes
	2100	77	Castellanes
	2400	75	J MAYORGA

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITA

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # A or B Temp. Reading Location: T I E R 2
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10.07.24	0300	77	M. Ramirez
	0600	79	J. ENRIQUEZ
	0900	80	J. ENRIQUEZ
	1200	80	J. ENRIQUEZ
	1500	80	J Soto
	1800	78	J Soto
	2100	78	J Soto
	2400	78	Ortega

Tuesday

Date	Time	Temp.	Name (Print)
10.08.24	0300	78	Ortega
	0600	77	R Ramirez
	0900	78	R Ramirez
	1200	80	R Ramirez
	1500	80	J Soto
	1800	78	J Soto
	2100	79	J Soto
	2400	78	Dun

Wednesday

Date	Time	Temp.	Name (Print)
10.09.24	0300	78	Dun
	0600	78	R Ramirez
	0900	78	R Ramirez
	1200	80	R Ramirez
	1500	80	J Soto
	1800	79	J Soto
	2100	79	J Soto
	2400	78	Ramos

Thursday

Date	Time	Temp.	Name (Print)
10.10.24	0300	78	Ramos
	0600	78	R Ramirez
	0900	78	R Ramirez
	1200	80	R Ramirez
	1500	80	J Soto
	1800	79	J Soto
	2100	78	J Soto
	2400	77	A. Torres

Friday

Date	Time	Temp.	Name (Print)
10.11.24	0300	77	A. Torres
	0600	78	Jones
	0900	78	Jones
	1200	80	Jones
	1500	80	J Soto
	1800	79	J Soto
	2100	79	J Soto
	2400	77	A. Torres

Saturday

Date	Time	Temp.	Name (Print)
10.12.24	0300	77	A. Ramos
	0600	78	Jones
	0900	78	Jones
	1200	80	Jones
	1500	77	Mirza
	1800	77	Mirza
	2100	77	Mirza
	2400	77	G Linares

Sunday

Date	Time	Temp.	Name (Print)
10.13.24	0300	77	G. Linares
	0600	77	Jones
	0900	78	Jones
	1200	78	Jones
	1500	79	D. Sis
	1800	79	D. Sis
	2100	79	D. Sis
	2400	75	J. MAYORGA

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STAT
INSI
CDCR

ATURE RECORD

DEPARTMENT OF CORRECTIONS AND REHAB

From May through October 31st, the warden shall designate staff to be responsible to monitor and log the INSII ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be house (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the he risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 2 (A) or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reach 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-7-24	0300	74°	E. Gamboa
	0600	75	A. Ortiz
	0900	75	A. Ortiz
	1200	76	A. Ortiz
	1500	78	R. SALAZAR
	1800	79	R. SALAZAR
	2100	78	R. SALAZAR
	2400	78	E. Gamboa

Tuesday

Date	Time	Temp.	Name (Print)
10-08-24	0300	75°	E. Gamboa
	0600	75	A. Ortiz
	0900	75	A. Ortiz
	1200	75	A. Ortiz
	1500	78	R. SALAZAR
	1800	79	R. SALAZAR
	2100	78	R. SALAZAR
	2400	77	Earnest

Wednesday

Date	Time	Temp.	Name (Print)
10-09-24	0300	76	Earnest
	0600	75	A. Ortiz
	0900	75	A. Ortiz
	1200	76	A. Ortiz
	1500	78	R. SALAZAR
	1800	79	R. SALAZAR
	2100	78	R. SALAZAR
	2400	77	Earnest

Thursday

Date	Time	Temp.	Name (Print)
10-10-24	0300	75	Earnest
	0600	75	King
	0900	75	King
	1200	75	King
	1500	78	R. SALAZAR
	1800	79	R. SALAZAR
	2100	78	R. SALAZAR
	2400	77	Earnest

Friday

Date	Time	Temp.	Name (Print)
10-11-24	0300	76	Earnest
	0600	75	A. Ortiz
	0900	75	A. Ortiz
	1200	75	Ortiz
	1500	75	PASUMBAL
	1800	75	PASUMBAL
	2100	74	PASUMBAL
	2400	74	Earnest

Saturday

Date	Time	Temp.	Name (Print)
10-12-24	0300	74	Earnest
	0600	75	Ortiz
	0900	75	Ortiz
	1200	75	Ortiz
	1500	76	Ortiz
	1800	76	Ortiz
	2100	76	Ortiz
	2400	77	Earnest

Sunday

Date	Time	Temp.	Name (Print)
10-13-24	0300	76	Earnest
	0600	75	Ortiz
	0900	76	Ortiz
	1200	76	Ortiz
	1500	77	R. SALAZAR
	1800	78	R. SALAZAR
	2100	77	R. SALAZAR
	2400	76	Ortiz

Notes

10-07-24	DEACT 2045
10-08-24	1935
10-09-24	1945

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF C[illegible]
INSIDE T[illegible]ERATURE RECORD
CDCR 2031 ([illegible] 18)

DEPARTMENT OF CORRECTIONS AND REHABILITA

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 2 A or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-7-24	0300	74°	E. Gamboa
	0600	75	Ortiz
	0900	75	Ortiz
	1200	75	Ortiz
	1500	78	R. SALAZAR
	1800	79	R. SALAZAR
	2100	78	R. SALAZAR
	2400	78	R SALAZAR

Tuesday

Date	Time	Temp.	Name (Print)
10-08-24	0300	75	Ortiz
	0600	75	Ortiz
	0900	75	Ortiz
	1200	75	Ortiz
	1500	78	R. SALAZAR
	1800	79	R. SALAZAR
	2100	78	R. SALAZAR
	2400	76	Earnest

Wednesday

Date	Time	Temp.	Name (Print)
10-09-24	0300	75	Earnest
	0600	75	Ortiz
	0900	75	Ortiz
	1200	75	Ortiz
	1500	78	R. SALAZAR
	1800	78	R. SALAZAR
	2100	78	R. SALAZAR
	2400	76	Earnest

Thursday

Date	Time	Temp.	Name (Print)
10-10-24	0300	75	Earnest
	0600	75	King
	0900	75	King
	1200	75	King
	1500	78	R. SALAZAR
	1800	79	R. SALAZAR
	2100	78	R. SALAZAR
	2400	76	Earnest

Friday

Date	Time	Temp.	Name (Print)
10-11-24	0300	75	Earnest
	0600	75	Ortiz
	0900	75	Ortiz
	1200	75	Ortiz
	1500	75	PASUMBAL
	1800	75	PASUMBAL
	2100	74	PASUMBAL
	2400	74	Earnest

Saturday

Date	Time	Temp.	Name (Print)
10-12-24	0300	74	Earnest
	0600	75	Ortiz
	0900	75	Ortiz
	1200	75	Ortiz
	1500	75	Ortiz
	1800	75	Ortiz
	2100	75	Ortiz
	2400	76	Earnest

Sunday

Date	Time	Temp.	Name (Print)
10-13-24	0300	75	Earnest
	0600	75	Ortiz
	0900	75	Ortiz
	1200	75	Ortiz
	1500	77	R. SALAZAR
	1800	78	R. SALAZAR
	2100	77	R. SALAZAR
	2400	76	Ortiz

Notes

	ACT	DEACT
10-07-24		2045
10-08-24		1930
10-09-24		1945

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITA

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 3 (A or B) Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-7-24	0300	72	P. Cerda
	0600	72	P. Cerda
	0900	74	J. Carson
	1200	74	J. Carson
	1500	75	PASUMBAL
	1800	75	PASUMBAL
	2100	73	PASUMBAL
	2400	73	LUCE

Tuesday

Date	Time	Temp.	Name (Print)
10-8-24	0300	73	LUCE
	0600	76	PRICE
	0900	76	PRICE
	1200	76	PRICE
	1500	76	SOLORIO
	1800	76	SOLORIO
	2100	76	SOLORIO
	2400	74	E Gamboa

Wednesday

Date	Time	Temp.	Name (Print)
10-9-24	0300	74°	E. Gamboa
	0600	73	J. Hernandez
	0900	73	J. Hernandez
	1200	73	J. Hernandez
	1500	75	SOLORIO
	1800	75	SOLORIO
	2100	75	SOLORIO
	2400	72	Jackson

Thursday

Date	Time	Temp.	Name (Print)
10-10-24	0300	72	Jackson
	0600	71	Jackson
	0900	71	J. Hernandez
	1200	71	J. Hernandez
	1500	72	SOLORIO
	1800	74	SOLORIO
	2100	74	SOLORIO
	2400	72	P. Cerda

Friday

Date	Time	Temp.	Name (Print)
10-11-24	0300	72	P. Cerda
	0600	72	King
	0900	72	King
	1200	72	King
	1500	72	SOLORIO
	1800	72	SOLORIO
	2100	72	SOLORIO
	2400	72	P. Cerda

Saturday

Date	Time	Temp.	Name (Print)
10-12-24	0300	72	P. Cerda
	0600	72	King
	0900	72	King
	1200	72	King
	1500	72	SOLORIO
	1800	72	SOLORIO
	2100	72	SOLORIO
	2400	72	P. Cerda

Sunday

Date	Time	Temp.	Name (Print)
10-13-24	0300	72	P. Cerda
	0600	72	J. Hernandez
	0900	72	J. Hernandez
	1200	72	J. Hernandez
	1500	73	PASUMBAL
	1800	73	PASUMBAL
	2100	72	PASUMBAL
	2400	72	P. Cerda

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITA

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: N K S P Housing Unit: FAC "B"- BLD # 3 A or B Temp. Reading Location: T I E R 2 (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3 1 4 1 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-7-24	0300	72	P. Cerda
	0600	72	J. Cantu
	0900	74	J. Cantu
	1200	74	J. Cantu
	1500	75	PASUMBAL
	1800	75	PASUMBAL
	2100	73	PASUMBAL
	2400	73	Lopez

Tuesday

Date	Time	Temp.	Name (Print)
10-8-24	0300	73	Lopez
	0600	76	PRICE
	0900	76	PRICE
	1200	76	PRICE
	1500	78	SOLORIO
	1800	78	SOLORIO
	2100	78	SOLORIO
	2400	74	E Gamboa

Wednesday

Date	Time	Temp.	Name (Print)
10-9-24	0300	74°	E. Gamboa
	0600	73	J. Hernandez
	0900	73	J. Hernandez
	1200	73	J. Hernandez
	1500	76	Solorio
	1800	78	Solorio
	2100	76	Solorio
	2400	72	JACKSON

Thursday

Date	Time	Temp.	Name (Print)
10-10-24	0300	72	JACKSON
	0600	71	JACKSON
	0900	71	J. Hernandez
	1200	71	J. Hernandez
	1500	72	Solorio
	1800	74	Solorio
	2100	76	Solorio
	2400	74	P. Cerda

Friday

Date	Time	Temp.	Name (Print)
10-11-24	0300	72	P. Cerda
	0600	72	King
	0900	72	King
	1200	72	King
	1500	75	Solorio
	1800	75	Solorio
	2100	75	Solorio
	2400	74	P. Cerda

Saturday

Date	Time	Temp.	Name (Print)
10-12-24	0300	72	P. Cerda
	0600	72	King
	0900	72	King
	1200	72	King
	1500	75	Solorio
	1800	75	Solorio
	2100	75	Solorio
	2400	74	P. Cerda

Sunday

Date	Time	Temp.	Name (Print)
10-13-24	0300	72	P. Cerda
	0600	72	J. Hernandez
	0900	72	J. Hernandez
	1200	72	J. Hernandez
	1500	73	PASUMBAL
	1800	73	PASUMBAL
	2100	72	PASUMBAL
	2400	72	P. Cerda

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B4A Temp. Reading Location: TOP TIER BY TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/7	0300	74	M. LOPEZ
	0600	74	King
	0900	74	King
	1200	74	King
	1500	77	H. Mirandas
	1800	76	H. Miranda
	2100	75	H. Miranda
	2400	74	R. Cisneros

Tuesday

Date	Time	Temp.	Name (Print)
10/8	0300	74	R. Cisneros
	0600	74	A. Perez
	0900	74	A. Perez
	1200	74	A. Perez
	1500	75	PASUMBAL
	1800	75	PASUMBAL
	2100	74	PASUMBAL
	2400	74	R. Cisneros

Wednesday

Date	Time	Temp.	Name (Print)
10/9	0300	73	R. Cisneros
	0600	71	A. Perez
	0900	71	A. Perez
	1200	71	A. Perez
	1500	72	Campos
	1800	72	Campos
	2100	72	Campos
	2400	72	R. Cisneros

Thursday

Date	Time	Temp.	Name (Print)
10-10-24	0300	72	R. Cisneros
	0600	72	A. Perez
	0900	72	A. Perez
	1200	72	A. Perez
	1500	73	H. Miranda
	1800	73	H. Miranda
	2100	73	H. Miranda
	2400	72	Z. Green

Friday

Date	Time	Temp.	Name (Print)
10/11	0300	72	Z. Green
	0600	72	A. Perez
	0900	72	A. Perez
	1200	72	A. Perez
	1500	73	H. Miranda
	1800	72	H. Miranda
	2100	72	H. Miranda
	2400	72	Z. Green

Saturday

Date	Time	Temp.	Name (Print)
10/12/24	0300	70	Z. Green
	0600	71	Galvez
	0900	71	Galvez
	1200	72	Galvez
	1500	73	H. Miranda
	1800	73	H. Miranda
	2100	72	H. Miranda
	2400	72	D. Drake

Sunday

Date	Time	Temp.	Name (Print)
10/13/24	0300	72	D. Drake
	0600	72	King
	0900	72	King
	1200	72	King
	1500	73	H. Miranda
	1800	72	H. Miranda
	2100	72	H. Miranda
	2400	72°	Pacheco

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B4B Temp. Reading Location: TOP TIER BY TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-7-24	0300	74	[illegible]
	0600	74	King
	0900	74	King
	1200	74	King
	1500	76	H. Marroquin
	1800	75	H. Marroquin
	2100	74	H. Marroquin
	2400	74	R. Cisneros

Tuesday

Date	Time	Temp.	Name (Print)
10-8-24	0300	73	R. Cisneros
	0600	72	APerez
	0900	72	APerez
	1200	72	APerez
	1500	75	PASUMBAL
	1800	75	PASUMBAL
	2100	74	PASUMBAL
	2400	74	R. Cisneros

Wednesday

Date	Time	Temp.	Name (Print)
10-9-24	0300	73	R. Cisneros
	0600	71	APerez
	0900	71	APerez
	1200	71	APerez
	1500	72	Campos
	1800	72	Campos
	2100	72	Campos
	2400	72	R. Cisneros

Thursday

Date	Time	Temp.	Name (Print)
10-10-24	0300	72	R. Cisneros
	0600	72	APerez
	0900	72	APerez
	1200	72	APerez
	1500	73	H. Marroquin
	1800	73	H. Marroquin
	2100	72	H. Marroquin
	2400	72	Z. Green

Friday

Date	Time	Temp.	Name (Print)
10/11	0300	72	Z. Green
	0600	72	APerez
	0900	72	APerez
	1200	72	APerez
	1500	73	H. Marroquin
	1800	73	H. Marroquin
	2100	72	H. Marroquin
	2400	72	Z. Green

Saturday

Date	Time	Temp.	Name (Print)
10-12-24	0300	70	Z. Green
	0600	71	Galloos
	0900	71	Galloos
	1200	72	Galloos
	1500	73	H. Marroquin
	1800	73	H. Marroquin
	2100	73	H. Marroquin
	2400	73	D Drake

Sunday

Date	Time	Temp.	Name (Print)
10/13/24	0300	73	D Drake
	0600	73	King
	0900	73	King
	1200	73	King
	1500	73	H. Marroquin
	1800	72	H. Marroquin
	2100	72	H. Marroquin
	2400	72	M. Fachman

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B-5-B Temp. Reading Location: _____ (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/07/24	0300	74	[illegible]
	0600	78	T. Smal
	0900	78	T. Smal
	1200	78	T. Smal
	1500	79	J. ortega
	1800	78	J. ortega
	2100	77	J. ortega
	2400	76	[illegible]

Tuesday

Date	Time	Temp.	Name (Print)
10/08/24	0300	76	[illegible]
	0600	76	[illegible]
	0900	77	[illegible]
	1200	77	[illegible]
	1500	77	O. Vejar
	1800	77	O. Vejar
	2100	77	O. Vejar
	2400	75	[illegible]

Wednesday

Date	Time	Temp.	Name (Print)
10/09/24	0300	74	[illegible]
	0600	74	[illegible]
	0900	76	E. Cruz
	1200	74	E. Cruz
	1500	77	O. Vejar
	1800	77	O. Vejar
	2100	77	O. Vejar
	2400	75	[illegible]

Thursday

Date	Time	Temp.	Name (Print)
10/10/24	0300	75	[illegible]
	0600	75	E. Cruz
	0900	77	E. Cruz
	1200	77	E. Cruz
	1500	76	Campos
	1800	76	Campos
	2100	76	Campos
	2400	76	Mlopez

Friday

Date	Time	Temp.	Name (Print)
10/11/24	0300	75	Mlopez
	0600	75	E. Cruz
	0900	75	E. Cruz
	1200	75	[illegible]
	1500	75	Campos
	1800	75	Campos
	2100	75	Campos
	2400	75	Mlopez

Saturday

Date	Time	Temp.	Name (Print)
10/12/24	0300	74	Mlopez
	0600	75	E. Cruz
	0900	77	E. Cruz
	1200	77	E. Cruz
	1500	77	G. Chavez
	1800	77	G. Chavez
	2100	77	G. Chavez
	2400	75	[illegible]

Sunday

Date	Time	Temp.	Name (Print)
10/13	0300	75	[illegible]
	0600	75	Mejia
	0900	76	Mejia
	1200	76	Mejia
	1500	76	Belscones
	1800	76	Gibbs
	2100	75	[illegible]
	2400	77	[illegible]

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: B-5-A Temp. Reading Location: _____ (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/7/24	0300	74	[illegible]
	0600	79	T. Sanchez
	0900	79	T. Sanchez
	1200	79	T. Sanchez
	1500	79	J. Ortesa
	1800	78	J. Ortesa
	2100	77	J. Ortesa
	2400	76	[illegible]

Tuesday

Date	Time	Temp.	Name (Print)
10/08/24	0300	76	[illegible]
	0600	76	L. Hill
	0900	77	Hill
	1200	77	Hill
	1500	77	C. Vejar
	1800	77	C. Vejar
	2100	77	C. Vejar
	2400	75	[illegible]

Wednesday

Date	Time	Temp.	Name (Print)
10/09/24	0300	74	[illegible]
	0600	74	[illegible]
	0900	75	[illegible]
	1200	75	E. Cruz
	1500	77	C. Vejar
	1800	77	C. Vejar
	2100	77	C. Vejar
	2400	75	[illegible]

Thursday

Date	Time	Temp.	Name (Print)
10/10	0300	75	[illegible]
	0600	75	E. Cruz
	0900	79	E. Cruz
	1200	77	E. Cruz
	1500	76	Campos
	1800	76	Campos
	2100	76	Campos
	2400	76	[illegible]

Friday

Date	Time	Temp.	Name (Print)
10/11	0300	75	[illegible]
	0600	75	E. Cruz
	0900	75	E. Cruz
	1200	75	E. Cruz
	1500	75	Campos
	1800	75	Campos
	2100	75	Campos
	2400	75	[illegible]

Saturday

Date	Time	Temp.	Name (Print)
10/12	0300	74	[illegible]
	0600	75	E. Cruz
	0900	77	E. Cruz
	1200	77	E. Cruz
	1500	77	G. Chavez
	1800	77	G. Chavez
	2100	77	G. Chavez
	2400	75	[illegible]

Sunday

Date	Time	Temp.	Name (Print)
10/13	0300	75	[illegible]
	0600	74	[illegible]
	0900	74	[illegible]
	1200	76	[illegible]
	1500	75	Berrones
	1800	76	Gibbs
	2100	75	[illegible]
	2400	77	[illegible]

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Blue Aside Temp. Reading Location: DAYROOM (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10.7.24	0300	74	B. ROSS
	0600	74	B. ROSS
	0900	77	G. Mugs
	1200	77	G. Mugs
	1500	78	J. Navarro
	1800	78	J. Navarro
	2100	77	J. Navarro
	2400	77	D SLS

Tuesday

Date	Time	Temp.	Name (Print)
10.8.24	0300	77	D SLS
	0600	77°	Guerrero
	0900	77°	Guerrero
	1200	77°	Guerrero
	1500	72	Cervantes
	1800	78	Cervantes
	2100	78	Cervantes
	2400	77	D SLS

Wednesday

Date	Time	Temp.	Name (Print)
10.9.24	0300	77	D SLS
	0600	77	J. MAYORGA
	0900	77	J. MAYORGA
	1200	78	J. MAYORGA
	1500	78	Y. Carrasco
	1800	78	Y. Carrasco
	2100	77	Y. Carrasco
	2400	77	M. Romero

Thursday

Date	Time	Temp.	Name (Print)
10.10.24	0300	76	M. Romero
	0600	76	M. Ayala
	0900	75	M. Ayala
	1200	75	M. Ayala
	1500	76	Cervantes
	1800	78	Cervantes
	2100	78	Vasquez
	2400	78	M. Romero

Friday

Date	Time	Temp.	Name (Print)
10/11/24	0300	77	M. Romero
	0600	77	S. BURTON
	0900	75	S. BURTON
	1200	75	S. BURTON
	1500	75	Mugs
	1800	75	Mugs
	2100	75	Mugs
	2400	76	M. Romero

Saturday

Date	Time	Temp.	Name (Print)
10/12/24	0300	75	M. Romero
	0600	75°	Guerrero
	0900	75°	Guerrero
	1200	77°	Guerrero
	1500	78	Y. Carrasco
	1800	78	Y. Carrasco
	2100	77	Y. Carrasco
	2400	76	M. Romero

Sunday

Date	Time	Temp.	Name (Print)
10/13/24	0300	75	G. MARISCAL
	0600	74	Greenfield
	0900	76	Lawrence
	1200	77	Lawrence
	1500	77	J. Navarro
	1800	75	J. Navarro
	2100	74	J. Navarro
	2400	73	B. ROSS

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Blue B Side Temp. Reading Location: Dayroom
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the Inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10.7.24	0300	74	B. ROSS
	0600	74	B. ROSS
	0900	74	[illegible]
	1200	75	[illegible]
	1500	78	J. Navarro
	1800	78	J. Navarro
	2100	77	J. Navarro
	2400	77	D. S. S

Tuesday

Date	Time	Temp.	Name (Print)
10.8.24	0300	77	D. S. S
	0600	77	~~D. S. S~~
	0900	77	[illegible]
	1200	77	[illegible]
	1500	78	[illegible]
	1800	78	[illegible]
	2100	76	[illegible]
	2400	77	D. S. S

Wednesday

Date	Time	Temp.	Name (Print)
10.9.24	0300	77	D. S. S
	0600	77	J. MAYORGA
	0900	77	J. MAYORGA
	1200	78	J. MAYORGA
	1500	78	Y. Carrasco
	1800	78	Y. Carrasco
	2100	78	Y. Carrasco
	2400	78	M. Romero

Thursday

Date	Time	Temp.	Name (Print)
10.10.24	0300	76	M. Romero
	0600	77	[illegible]
	0900	77	[illegible]
	1200	77	[illegible]
	1500	78	[illegible]
	1800	78	[illegible]
	2100	78	[illegible]
	2400	77	M. Romero

Friday

Date	Time	Temp.	Name (Print)
10/11/24	0300	76	M. Romero
	0600	75	S. BURTON
	0900	75	S. BURTON
	1200	75	S. BURTON
	1500	75	[illegible]
	1800	75	[illegible]
	2100	75	[illegible]
	2400	74	M. Romero

Saturday

Date	Time	Temp.	Name (Print)
10/12/24	0300	74	M. Romero
	0600	75	[illegible]
	0900	75	[illegible]
	1200	75	[illegible]
	1500	78	Y. Carrasco
	1800	77	Y. Carrasco
	2100	77	Y. Carrasco
	2400	74	M. Romero

Sunday

Date	Time	Temp.	Name (Print)
10/13/24	0300	74	M. Romero
	0600	74	[illegible]
	0900	74	[illegible]
	1200	77	[illegible]
	1500	77	J. Navarro
	1800	75	J. Navarro
	2100	74	J. Navarro
	2400	73	B. ROSS

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

Attachment 11

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: WKSP Housing Unit: C-2 A Temp. Reading Location: Tier 2
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/7/24	0300	76	M. Ayala
	0600	77	McIntosh
	0900	78	McIntosh
	1200	80	McIntosh
	1500	80	M-Serrato
	1800	80	M-Serrato
	2100	79	M-Serrato
	2400	79	L. Mares

Tuesday

Date	Time	Temp.	Name (Print)
10/8/24	0300	78	L. Mares
	0600	78	McIntosh
	0900	79	McIntosh
	1200	80	McIntosh
	1500	80	M-Serrato
	1800	80°	M-Serrato
	2100	79	M-Serrato
	2400	78	M-Serrato

Wednesday

Date	Time	Temp.	Name (Print)
10/9/24	0300	77	M-Serrato
	0600	77	McIntosh
	0900	79	McIntosh
	1200	80	McIntosh
	1500	80	Ellison
	1800	80	Ellison
	2100	78	Ellison
	2400	78	Ellison

Thursday

Date	Time	Temp.	Name (Print)
10/10/24	0300	76	Ellison
	0600	78	McIntosh
	0900	79	McIntosh
	1200	80	McIntosh
	1500	78	Ellison
	1800	78	Ellison
	2100	78	Ellison
	2400	77	Ellison

Friday

Date	Time	Temp.	Name (Print)
10/11/24	0300	76	Ellison
	0600	77	McIntosh
	0900	78	McIntosh
	1200	80	McIntosh
	1500	80	Riley
	1800	80	Riley
	2100	79	Riley
	2400	77	Ramirez

Saturday

Date	Time	Temp.	Name (Print)
10/12/24	0300	77	Ramirez
	0600	77	T. Delos Santos
	0900	77	T. Delos Santos
	1200	78	T. Delos Santos
	1500	78	G. Contreras
	1800	78	G. Contreras
	2100	78	G. Contreras
	2400	78	D. Alvarado

Sunday

Date	Time	Temp.	Name (Print)
10/13/24	0300	77	D. Alvarado
	0600	77	T. Delos Santos
	0900	77	T. Delos Santos
	1200	78	T. Delos Santos
	1500	78	Cruz
	1800	79	Cruz
	2100	79	Cruz
	2400	78	Pennell

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

Attachment 11

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C2 - B Temp. Reading Location: Tier 2
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-07-24	0300	79	D. Alvarado
	0600	79°	A. CASILLAS
	0900	79°	A. CASILLAS
	1200	79°	A. CASILLAS
	1500	79	D. Alvarado
	1800	79	D. Alvarado
	2100	79	D. Alvarado
	2400	78	A. Walter

Tuesday

Date	Time	Temp.	Name (Print)
10/8/24	0300	78	A. Walter
	0600	78°	A. CASILLAS
	0900	78°	A. CASILLAS
	1200	79°	A. CASILLAS
	1500	79	A. Walter
	1800	79	A. Walter
	2100	78	A. Walter
	2400	78	A. Walter

Wednesday

Date	Time	Temp.	Name (Print)
10/9/24	0300	78	A. Walter
	0600	78	A. WALTERS
	0900	78	A. WALTERS
	1200	79	Riley
	1500	79	Riley
	1800	79	Riley
	2100	78	Riley
	2400	78	A. Walter

Thursday

Date	Time	Temp.	Name (Print)
10/10/24	0300	78	A. Walter
	0600	78	S. Randolph
	0900	78	S. Randolph
	1200	78	S. Randolph
	1500	80	COTTON
	1800	80	COTTON
	2100	78	COTTON
	2400	78	COTTON

Friday

Date	Time	Temp.	Name (Print)
10/11/24	0300	78	COTTON
	0600	78	A. CASILLAS
	0900	78	A. CASILLAS
	1200	78	A. CASILLAS
	1500	78	COTTON
	1800	78	COTTON
	2100	77	COTTON
	2400	76	S. Lull

Saturday

Date	Time	Temp.	Name (Print)
10-12-24	0300	79	S. Lull
	0600	78	A. CASILLAS
	0900	78	A. CASILLAS
	1200	78	A. CASILLAS
	1500	78	COTTON
	1800	78	COTTON
	2100	78	COTTON
	2400	78	C. Montes

Sunday

Date	Time	Temp.	Name (Print)
10-13-24	0300	77	L. Montes
	0600	77	L. Montes
	0900	78	L. Montes
	1200	79	D. ALVARADO
	1500	78	D. Alvarado
	1800	78	D. Alvarado
	2100	78	D. Alvarado
	2400	78	L. Montes

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C3-A Temp. Reading Location: 2nd Tier (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-07-24	0300	80	CANACHO
	0600	79	Zamudio
	0900	80	Zamudio
	1200	80	Zamudio
	1500	79	Suarez
	1800	80	Suarez
	2100	81	Suarez
	2400	80	CANACHO

Tuesday

Date	Time	Temp.	Name (Print)
10-8-24	0300	79	CANACHO
	0600	80	M. Ruiz
	0900	80	M. Ruiz
	1200	79	Suarez
	1500	80	Suarez
	1800	81	Suarez
	2100	82	Suarez
	2400	81	CANACHO

Wednesday

Date	Time	Temp.	Name (Print)
10-9-24	0300	80	CANACHO
	0600	80	M. Ruiz
	0900	80	M. Ruiz
	1200	80	M. Ruiz
	1500	81	Suarez
	1800	81	Suarez
	2100	82	Suarez
	2400	80	CANACHO

Thursday

Date	Time	Temp.	Name (Print)
10-10-24	0300	80	CANACHO
	0600	80	A Araya
	0900	77	A Araya
	1200	76	A Araya
	1500	77	A. Romo
	1800	77	A. Romo
	2100	77	A. Romo
	2400	77	L. Nasco

Friday

Date	Time	Temp.	Name (Print)
10-11-24	0300	77	L. Nasco
	0600	77	T. Williams
	0900	78	T. Williams
	1200	78	T. Williams
	1500	78	M. Rains
	1800	78	M. Rains
	2100	78	M. Rains
	2400	78	L. Nasco

Saturday

Date	Time	Temp.	Name (Print)
10-12-24	0300	78	L. Nasco
	0600	78	J. Padilla
	0900	78	J. Padilla
	1200	78	J. Padilla
	1500	79	J. Padilla
	1800	79	J. Padilla
	2100	79	Camacho
	2400	78	CANACHO

Sunday

Date	Time	Temp.	Name (Print)
10-13-24	0300	77	CANACHO
	0600	77	Y. Sanchez
	0900	77	Y. Sanchez
	1200	77	Y. Sanchez
	1500	77	H. Franklin
	1800	76	H. Franklin
	2100	76	H. Franklin
	2400	76	B. ZAMORA

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C3B Temp. Reading Location: Tier 2
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/7/24	0300	78	E TORRES
	0600	78	SUAREZ
	0900	79	SUAREZ
	1200	80	SUAREZ
	1500	79	J ACOSTA
	1800	79	J ACOSTA
	2100	79	J ACOSTA
	2400	78	E TORRES

Tuesday

Date	Time	Temp.	Name (Print)
10-8-24	0300	78	E. TORRES
	0600	78	J. ENRIQUEZ
	0900	79	J. ENRIQUEZ
	1200	80	J. ENRIQUEZ
	1500	80	J ACOSTA
	1800	79	J ACOSTA
	2100	79	J ACOSTA
	2400	78	E TORRES

Wednesday

Date	Time	Temp.	Name (Print)
10-09-24	0300	78	E TORRES
	0600	78	E. TORRES
	0900	78	E. TORRES
	1200	79	E. TORRES
	1500	79	J ACOSTA
	1800	79	J ACOSTA
	2100	79	J ACOSTA
	2400	78	E TORRES

Thursday

Date	Time	Temp.	Name (Print)
10-10-24	0300	78	E TORRES
	0600	79	J. JONES
	0900	79	J. JONES
	1200	79	J. JONES
	1500	79	R. Aguilar
	1800	78	R. Aguilar
	2100	78	R. Aguilar
	2400	78	E. TORRES

Friday

Date	Time	Temp.	Name (Print)
10-11-24	0300	76	E TORRES
	0600	76	D. ESTRADA
	0900	76	D. ESTRADA
	1200	78	D. ESTRADA
	1500	79	R. Aguilar
	1800	79	R. Aguilar
	2100	79	R. Aguilar
	2400	78	C. WITTHER

Saturday

Date	Time	Temp.	Name (Print)
10-12-24	0300	78	C. WITTHER
	0600	78	[illegible]
	0900	78	[illegible]
	1200	79	[illegible]
	1500	78	M. Ayala
	1800	78	M. Ayala
	2100	77	M. Ayala
	2400	76	C. WITTHER

Sunday

Date	Time	Temp.	Name (Print)
10-13-24	0300	76	C. WITTHER
	0600	76	D. Valencia
	0900	78	D. Valencia
	1200	79	D. Valencia
	1500	79	D. Valencia
	1800	79	D. Valencia
	2100	78	[illegible]
	2400	78	[illegible]

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

Attachment 11

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

DEPARTMENT OF CORRECTIONS AND REHABILITATION

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: C4 A Temp. Reading Location: Right Side of T.V.
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/7/24	0300	77°	S.Rau
	0600	79	Torres
	0900	79	Torres
	1200	80	Torres
	1500	83	Vielmas
	1800	82	Vielmas
	2100	81	Vielmas
	2400	77°	S.Rau

Tuesday

Date	Time	Temp.	Name (Print)
10/8/24	0300	76	Rall
	0600	77	J.Padilla
	0900	78	J.Padilla
	1200	78	J.Padilla
	1500	82	Vielmas
	1800	81	Vielmas
	2100	80	Vielmas
	2400	77°	S.Rau

Wednesday

Date	Time	Temp.	Name (Print)
10/9/24	0300	76°	S.Rau
	0600	76°	E. Jones
	0900	76°	E. Jones
	1200	78°	E. Jones
	1500	81	Vielmas
	1800	80	Vielmas
	2100	79	Vielmas
	2400	76	C.WITCHER

Thursday

Date	Time	Temp.	Name (Print)
10/10/24	0300	76	C.WITCHER
	0600	77	E.Torres
	0900	78	Torres
	1200	78	Torres
	1500	81	Vielmas
	1800	80	Vielmas
	2100	79	Vielmas
	2400	78	C.WITCHER

Friday

Date	Time	Temp.	Name (Print)
10/11/24	0300	78	C.WITCHER
	0600	78	J.MARTINEZ
	0900	77	J.MARTINEZ
	1200	78	J.MARTINEZ
	1500	80	Vielmas
	1800	80	Vielmas
	2100	78	Vielmas
	2400	77°	S.Rau

Saturday

Date	Time	Temp.	Name (Print)
10/12/24	0300	77°	S.Rau
	0600	76	L.Torres
	0900	78	L.Torres
	1200	78	L.Torres
	1500	78	R.Aguilar
	1800	78	R.Aguilar
	2100	77	R.Aguilar
	2400	76°	S.Rau

Sunday

Date	Time	Temp.	Name (Print)
10/13/24	0300	74°	S.Rau
	0600	76	R.Aguilar
	0900	77	R.Aguilar
	1200	77	R.Aguilar
	1500	78	R.Aguilar
	1800	77	R.Aguilar
	2100	77	R.Aguilar
	2400	76°	S.Rau

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: WKSP Housing Unit: C4B Temp. Reading Location: above T.V (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/7/24	0300	78	A. Martinez
	0600	78	J. Padilla
	0900	79	J. Padilla
	1200	79	J. Padilla
	1500	79	Tovar
	1800	78	Tovar
	2100	78	Tovar
	2400	78	A. Martinez

Tuesday

Date	Time	Temp.	Name (Print)
10/8/24	0300	78	H. Gill
	0600	78	A. Herrera
	0900	79	A. Herrera
	1200	80	A. Herrera
	1500	81	P. Hyer
	1800	82	P. Hyer
	2100	79	P. Hyer
	2400	79	H. Gill

Wednesday

Date	Time	Temp.	Name (Print)
10/9/24	0300	79	P. Rencero
	0600	78	A. Herrera
	0900	78	A. Herrera
	1200	79	A. Herrera
	1500	79	R. Aguilar
	1800	79	R. Aguilar
	2100	78	R. Aguilar
	2400	78	P. Rencero

Thursday

Date	Time	Temp.	Name (Print)
10/10/24	0300	77	P. Rencero
	0600	77	T. Delos Santos
	0900	78	T. Delos Santos
	1200	78	T. Delos Santos
	1500	78	K. Madrigal
	1800	78	K. Madrigal
	2100	78	K. Madrigal
	2400	78	P. Rencero

Friday

Date	Time	Temp.	Name (Print)
10/11/24	0300	77	P. Rencero
	0600	77	T. Delos Santos
	0900	78	T. Delos Santos
	1200	78	T. Delos Santos
	1500	78	H. Franklin
	1800	78	H. Franklin
	2100	78	H. Franklin
	2400	77	Jacques

Saturday

Date	Time	Temp.	Name (Print)
10/12/24	0300	77	Jacques
	0600	77	A. Herrera
	0900	78	A. Herrera
	1200	75	Herrera
	1500	76	Tovar
	1800	75	Tovar
	2100	75	Tovar
	2400	75	Jacques

Sunday

Date	Time	Temp.	Name (Print)
10/13/24	0300	75	Jacques
	0600	74	J. Padilla
	0900	75	J. Padilla
	1200	76	J. Padilla
	1500	77	Tovar
	1800	77	Tovar
	2100	76	Tovar
	2400	75	Witcher

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D1 (A-SIDE) Temp. Reading Location: 2ND TIER ABOVE DAYROOM TV (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
Tue 10/7/24	0300	74	W. Colbert
	0600	74	V. Rodriguez
	0900	74	V. Rodriguez
	1200	74	V. Rodriguez
	1500	75	S. Moreno
	1800	75	S. Moreno
	2100	72	S. Moreno
	2400	74	W. Colbert

Tuesday

Date	Time	Temp.	Name (Print)
Tue 10/8/24	0300	75	W. Colbert
	0600	75	J. Ramirez
	0900	76	J. Ramirez
	1200	78	J. Ramirez
	1500	78	NIETO
	1800	77	NIETO
	2100	77	NIETO
	2400	76	W. COLBERT

Wednesday

Date	Time	Temp.	Name (Print)
Tue 10/9/24	0300	76	W. COLBERT
	0600	75	B. COVERT
	0900	75	B. COVERT
	1200	76	B. COVERT
	1500	76	NIETO
	1800	77	NIETO
	2100	77	NIETO
	2400	77	R. MORALES

Thursday

Date	Time	Temp.	Name (Print)
Tue 10/10	0300	76	R. MORALES
	0600	75	B. COVERT
	0900	75	B. COVERT
	1200	76	B. COVERT
	1500	76	M. Lyle
	1800	77	M. Lyle
	2100	77	M. Lyle
	2400	78	RAMIREZ

Friday

Date	Time	Temp.	Name (Print)
Tue 10/11/24	0300	78	RAMIREZ
	0600	77	B. COVERT
	0900	77	B. COVERT
	1200	77	B. COVERT
	1500	77	Ramirez
	1800	76	Ramirez
	2100	76	Ramirez
	2400	75	W. Colbert

Saturday

Date	Time	Temp.	Name (Print)
Tue 10/12	0300	75	W. Colbert
	0600	74	E. MENDOZA
	0900	76	E. MENDOZA
	1200	76	E. MENDOZA
	1500	77	H. Coll
	1800	77	H. Coll
	2100	76	H. Coll
	2400	74	W. COLBERT

Sunday

Date	Time	Temp.	Name (Print)
Tue 10/13/24	0300	74	W. Colbert
	0600	72	E. MENDOZA
	0900	72	E. MENDOZA
	1200	72	E. MENDOZA
	1500	72	S. Moreno
	1800	72	S. Moreno
	2100	70	S. Moreno
	2400	74	W. COLBERT

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D1 (B-SIDE) Temp. Reading Location: 2ND TIER ABOVE DAYROOM TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/7/24	0300	74	W. Colbert
	0600	74	V. Rodriguez
	0900	74	V. Rodriguez
	1200	74	V. Rodriguez
	1500	78	S. Moreno
	1800	78	S. Moreno
	2100	78	S. Moreno
	2400	74	W. Colbert

Tuesday

Date	Time	Temp.	Name (Print)
10/8/24	0300	75	W. Colbert
	0600	75	S. Ramirez
	0900	78	S. Ramirez
	1200	78	S. Ramirez
	1500	77	NIETO
	1800	77	NIETO
	2100	77	NIETO
	2400	76	W. Colbert

Wednesday

Date	Time	Temp.	Name (Print)
10/9/24	0300	76	W. Colbert
	0600	75	B. Covert
	0900	75	B. Covert
	1200	76	B. Covert
	1500	76	NIETO
	1800	77	NIETO
	2100	77	NIETO
	2400	77	P. Gonzales

Thursday

Date	Time	Temp.	Name (Print)
10/10/24	0300	76	P. Gonzales
	0600	75	B. Covert
	0900	76	B. Covert
	1200	76	B. Covert
	1500	76	M. Aron
	1800	76	M. Aron
	2100	77	M. Aron
	2400	77	Ramirez

Friday

Date	Time	Temp.	Name (Print)
10/11/24	0300	77	Ramirez
	0600	76	B. Covert
	0900	76	B. Covert
	1200	77	B. Covert
	1500	77	Ramirez
	1800	76	Ramirez
	2100	76	Ramirez
	2400	75	W. Colbert

Saturday

Date	Time	Temp.	Name (Print)
10/12/24	0300	75	W. Colbert
	0600	74	E. Munoz
	0900	76	E. Munoz
	1200	76	E. Munoz
	1500	77	H. Gall
	1800	77	H. Gall
	2100	76	H. Gall
	2400	74	W. Colbert

Sunday

Date	Time	Temp.	Name (Print)
10/13/24	0300	74	W. Colbert
	0600	72	E. Munoz
	0900	72	E. Munoz
	1200	72	E. Munoz
	1500	72	S. Moreno
	1800	72	S. Moreno
	2100	72	S. Moreno
	2400	72	W. Colbert

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D2 (A) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
Tues 10/7/24	0300	70	A-[illegible]
	0600	77	[illegible]
	0900	77	[illegible]
	1200	78	[illegible]
	1500	78	J. Valencia
	1800	79	J. Valencia
	2100	79	J. Valencia
	2400	79	Torres

Tuesday

Date	Time	Temp.	Name (Print)
Tues 10/8/24	0300	78	Torres
	0600	76	[illegible]
	0900	76	[illegible]
	1200	77	[illegible]
	1500	77	J. ESQUIVEL
	1800	78	J. ESQUIVEL
	2100	76	J. ESQUIVEL
	2400	79	R Roberts

Wednesday

Date	Time	Temp.	Name (Print)
Tues 10/9/24	0300	79	R Roberts
	0600	77	[illegible]
	0900	77	[illegible]
	1200	78	[illegible]
	1500	78	[illegible]
	1800	78	[illegible]
	2100	78	[illegible]
	2400	78	R Roberts

Thursday

Date	Time	Temp.	Name (Print)
Tues 10/10/24	0300	78	R Roberts
	0600	76	[illegible]
	0900	76	[illegible]
	1200	77	[illegible]
	1500	78	C. Solano
	1800	78	C. Solano
	2100	77	C. Solano
	2400	76	R Roberts

Friday

Date	Time	Temp.	Name (Print)
Tues 10/11/24	0300	76	R Roberts
	0600	76	G. Contreras
	0900	76	G. Contreras
	1200	77	G. Contreras
	1500	77	C. Solano
	1800	77	C. Solano
	2100	77	C. Solano
	2400	78	R Roberts

Saturday

Date	Time	Temp.	Name (Print)
Tues 10/12/24	0300	78	R Roberts
	0600	76	G. Contreras
	0900	76	G. Contreras
	1200	77	G. Contreras
	1500	78	J. VALENCIA
	1800	77	J. Valencia
	2100	77	J. Valencia
	2400	76	R Roberts

Sunday

Date	Time	Temp.	Name (Print)
Tues 10/13/24	0300	76	R Roberts
	0600	76	[illegible]
	0900	76	[illegible]
	1200	76	[illegible]
	1500	77	J. VALENCIA
	1800	77	LUQUIN
	2100	77	LUQUIN
	2400	75	D. Mardarian

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D2 (B) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
Tue 10/7/24	0300	75	A. MALDONADO
	0600	77	[illegible]
	0900	77	[illegible]
	1200	78	[illegible]
	1500	78	J. Valencia
	1800	79	J. VALENCIA
	2100	79	J. VALENCIA
	2400	78	TORRES

Tuesday

Date	Time	Temp.	Name (Print)
Tue 10/8/24	0300	78	TORRES
	0600	76	[illegible]
	0900	76	[illegible]
	1200	77	[illegible]
	1500	77	J. ESQUNEL
	1800	78	J. ESQUNEL
	2100	77	J. ESQUNEL
	2400	80	R Roberts

Wednesday

Date	Time	Temp.	Name (Print)
Tue 10/9/24	0300	80	R. Roberts
	0600	77	[illegible]
	0900	77	[illegible]
	1200	78	[illegible]
	1500	78	Gonzalez
	1800	78	Gonzalez
	2100	78	Gonzalez
	2400	79	R. Roberts

Thursday

Date	Time	Temp.	Name (Print)
Tue 10/10/24	0300	79	R Roberts
	0600	76	[illegible]
	0900	76	[illegible]
	1200	77	[illegible]
	1500	78	C. Solem
	1800	78	C. Solem
	2100	77	C. Solem
	2400	79	R Roberts

Friday

Date	Time	Temp.	Name (Print)
Tue 10/11/24	0300	79	R. Roberts
	0600	78	G. Contreras
	0900	78	G. Contreras
	1200	78	G. Contreras
	1500	78	C. Solem
	1800	77	C. Solem
	2100	77	C. Solem
	2400	79	R Roberts

Saturday

Date	Time	Temp.	Name (Print)
Tue 10/12/24	0300	79	R Roberts
	0600	78	G. Contreras
	0900	78	G. Contreras
	1200	77	G. Contreras
	1500	77	J. Valencia
	1800	77	J. Valencia
	2100	77	J. VALENCIA
	2400	79	R Roberts

Sunday

Date	Time	Temp.	Name (Print)
Tue 10/13/24	0300	79	R Roberts
	0600	76	[illegible]
	0900	76	[illegible]
	1200	76	[illegible]
	1500	77	J. VALENCIA
	1800	77	[illegible]
	2100	77	[illegible]
	2400	75	A. MALDONADO

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D3 (A) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
Tue 10	0300	76	G. LINARES
	0600	76	J. ESQUIVEL
	0900	77	J. ESQUIVEL
07	1200	78	J. ESQUIVEL
	1500	77	A. MARTIN
24	1800	77	A. MARTIN
	2100	76	A. MARTIN
	2400	76	M. GARTE

Tuesday

Date	Time	Temp.	Name (Print)
Tue 10	0300	76	M. GARTE
	0600	76	J. ESQUIVEL
	0900	77	J. ESQUIVEL
08	1200	78	J. ESQUIVEL
	1500	77	A. MARTIN
24	1800	76	A. MARTIN
	2100	76	A. MARTIN
	2400	76	M. GARTE

Wednesday

Date	Time	Temp.	Name (Print)
Tue 10	0300	76	M. GARTE
	0600	76	D. Castrejon
	0900	76	D. Castrejon
09	1200	76	D. Castrejon
	1500	77	A. MARTIN
24	1800	76	A. MARTIN
	2100	76	A. MARTIN
	2400	75	M. GARTE

Thursday

Date	Time	Temp.	Name (Print)
Tue 10	0300	75	M. GARTE
	0600	69	N. TOVAR
	0900	70	N. TOVAR
10	1200	70	N. TOVAR
	1500	76	A. MARTIN
24	1800	76	A. MARTIN
	2100	76	A. MARTIN
	2400	75	J. Ferrer

Friday

Date	Time	Temp.	Name (Print)
Tue 10	0300	75	J. Ferrer
	0600	75	J. ESQUIVEL
	0900	76	J. ESQUIVEL
	1200	77	J. ESQUIVEL
11	1500	77	S. MORENO
	1800	77	S. MORENO
24	2100	75	S. MORENO
	2400	76	A. Martinez

Saturday

Date	Time	Temp.	Name (Print)
Tue 10	0300	75	A. Martinez
	0600	75	J. ESQUIVEL
	0900	76	J. ESQUIVEL
	1200	77	J. ESQUIVEL
12	1500	77	S. MORENO
	1800	77	S. MORENO
24	2100	72	S. MORENO
	2400	72	PRICE

Sunday

Date	Time	Temp.	Name (Print)
Tue 10	0300	72	PRICE
	0600	72	S. MORENO
	0900	72	S. MORENO
	1200	72	S. MORENO
13	1500	75	A. MARTINEZ
24	1800	76	A. MARTINEZ
	2100	76	A. MARTINEZ
	2400	76	D. Mandillon

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D3 (B) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
Tue 10	0300	74	G. Linares
	0600	74	J. Esquivel
	0900	76	J. Esquivel
09	1200	77	J. Esquivel
	1500	77	A. Martinez
	1800	76	A. Martinez
24	2100	76	A. Martinez
	2400	78	M. Gaste

Tuesday

Date	Time	Temp.	Name (Print)
Tue 10	0300	78	M. Gaste
	0600	77	J. Esquivel
	0900	77	J. Esquivel
09	1200	77	J. Esquivel
	1500	76	A. Martinez
	1800	76	A. Martinez
24	2100	75	A. Martinez
	2400	78	M. Gaste

Wednesday

Date	Time	Temp.	Name (Print)
Tue 10	0300	78	M. Gaste
	0600	78	D. Castrejon
	0900	78	D. Castrejon
09	1200	79	D. Castrejon
	1500	77	A. Martinez
	1800	77	A. Martinez
24	2100	77	A. Martinez
	2400	75	M. Gaste

Thursday

Date	Time	Temp.	Name (Print)
Tue 10	0300	77	M. Gaste
	0600	69	W. Tovar
	0900	70	W. Tovar
	1200	70	W. Tovar
10	1500	77	A. Martinez
	1800	76	A. Martinez
24	2100	76	A. Martinez
	2400	75	J. Ferrer

Friday

Date	Time	Temp.	Name (Print)
Tue 10	0300	75	J. Ferrer
	0600	75	J. Esquivel
	0900	76	J. Esquivel
	1200	77	J. Esquivel
11	1500	77	S. Moreno
	1800	77	S. Moreno
24	2100	75	S. Moreno
	2400	75	A. Martinez

Saturday

Date	Time	Temp.	Name (Print)
Tue 10	0300	75	A. Martinez
	0600	75	J. Esquivel
	0900	76	J. Esquivel
	1200	77	J. Esquivel
12	1500	77	S. Moreno
	1800	77	S. Moreno
24	2100	72	S. Moreno
	2400	72	Price

Sunday

Date	Time	Temp.	Name (Print)
Tue 10	0300	72	Price
	0600	72	S. Moreno
	0900	72	S. Moreno
	1200	72	S. Moreno
13	1500	75	A. Martinez
	1800	75	A. Martinez
24	2100	75	A. Martinez
	2400	70	D. Marcelo

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. D - 4 (A) Side Temp. Reading Location: Tier 2 - Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
Tu 10-7-24	0300	77	S. Baez
	0600	77	M. CERDA
	0900	78	M. CERDA
	1200	78	M. CERDA
	1500	79	Arreola
	1800	79	Arreola
	2100	79	Arreola
	2400	79	S. Baez

Tuesday

Date	Time	Temp.	Name (Print)
Tu 10-8-24	0300	79	S. Baez
	0600	79	A Lopez
	0900	79	A Lopez
	1200	79	A Lopez
	1500	79	Arreola
	1800	79	Arreola
	2100	78	Arreola
	2400	78	S. Baez

Wednesday

Date	Time	Temp.	Name (Print)
Th 10-9-24	0300	78	S. Baez
	0600	78	A Lopez
	0900	78	A Lopez
	1200	80	A Lopez
	1500	79	R. PASCUA
	1800	79	R. PASCUA
	2100	79	R. PASCUA
	2400	78	S. Baez

Thursday

Date	Time	Temp.	Name (Print)
Fri 10-10-24	0300	78	S. Baez
	0600	78	D. Castejon
	0900	78	D. Castejon
	1200	78	D. Castejon
	1500	79	R. PASCUA
	1800	79	R. PASCUA
	2100	79	R. PASCUA
	2400	76	DUNN

Friday

Date	Time	Temp.	Name (Print)
Sa 10-11-24	0300	75	DUNN
	0600	74	E MENDOZA
	0900	74	E MENDOZA
	1200	74	E MENDOZA
	1500	75	M. [illegible]
	1800	77	M. [illegible]
	2100	76	M. HALL
	2400	76	M. ESCAMILLA

Saturday

Date	Time	Temp.	Name (Print)
Su 10-12-24	0300	76	M. ESCAMILLA
	0600	76	A Lopez
	0900	77	A Lopez
	1200	77	A Lopez
	1500	75	GIBBS
	1800	75	GIBBS
	2100	74	GIBBS
	2400	74	S. Baez

Sunday

Date	Time	Temp.	Name (Print)
Mo 10-13-24	0300	74	S. Baez
	0600	74	A Lopez
	0900	75	A Lopez
	1200	76	A Lopez
	1500	76	C. McGregor
	1800	76	C. McGregor
	2100	76	C. McGregor
	2400	76	S. Baez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. D - 4 (B) Side Temp. Reading Location: Tier 2 - Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-7-24	0300	78	S. Baez
	0600	78	M. CERDA
	0900	79	M. CERDA
	1200	80	M. CERDA
	1500	79	Arnold
	1800	79	Arnold
	2100	79	Arnold
	2400	79	S. Baez

Tuesday

Date	Time	Temp.	Name (Print)
10-8-24	0300	79	S. Baez
	0600	79	A Lopez
	0900	79	A Lopez
	1200	79	A Lopez
	1500	79	Arnold
	1800	79	Arnold
	2100	78	Arnold
	2400	78	S. Baez

Wednesday

Date	Time	Temp.	Name (Print)
10-9-24	0300	78	S. Baez
	0600	78	A Lopez
	0900	78	A Lopez
	1200	80	A Lopez
	1500	79	R. PASCUA
	1800	79	R. PASCUA
	2100	79	R. PASCUA
	2400	78	S. Baez

Thursday

Date	Time	Temp.	Name (Print)
10-10-24	0300	78	S. Baez
	0600	78	J. Castrejon
	0900	78	J. Castrejon
	1200	78	J. Castrejon
	1500	79	R. PASCUA
	1800	79	R. PASCUA
	2100	79	R. PASCUA
	2400	76	DUNN

Friday

Date	Time	Temp.	Name (Print)
10-11-24	0300	75	DUNN
	0600	74	E MENDOZA
	0900	74	E MENDOZA
	1200	74	E MENDOZA
	1500	75	M. Ayala
	1800	77	M. Ayala
	2100	76	M. Ayala
	2400	76	[illegible]

Saturday

Date	Time	Temp.	Name (Print)
10-12-24	0300	75	[illegible]
	0600	75	A Lopez
	0900	77	A Lopez
	1200	77	A Lopez
	1500	75	GIBBS
	1800	75	GIBBS
	2100	74	GIBBS
	2400	74	S. Baez

Sunday

Date	Time	Temp.	Name (Print)
10-13-24	0300	74	S. Baez
	0600	74	A Lopez
	0900	75	A Lopez
	1200	76	A Lopez
	1500	76	C. McGregor
	1800	76	C. McGregor
	2100	76	C. McGregor
	2400	76	S. Baez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. D - 5 (A) Side Temp. Reading Location: Tier 2 - Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/7/24 Tue	0300	74	J. Navarro
	0600	74	M. Serrato
	0900	74	M. Serrato
	1200	75	M. Serrato
	1500	74	Goodell
	1800	74	Goodell
	2100	73	Goodell
	2400	73	Sanchez

Tuesday

Date	Time	Temp.	Name (Print)
10/8/24 Tue	0300	73	J. Sanchez
	0600	73	A. Cisneros
	0900	73	A. Cisneros
	1200	73	A. Cisneros
	1500	72	N. Torres
	1800	71	N. Torres
	2100	70	N. Torres
	2400	70	Sanchez

Wednesday

Date	Time	Temp.	Name (Print)
10/9/24 Tue	0300	70	J. Sanchez
	0600	74	Price
	0900	74	Price
	1200	74	Price
	1500	74	N. Torres
	1800	75	N. Torres
	2100	74	N. Torres
	2400	73	Sanchez

Thursday

Date	Time	Temp.	Name (Print)
10/10/24 Tue	0300	72	J. Sanchez
	0600	73	N. Cruz
	0900	74	N. Cruz
	1200	75	N. Cruz
	1500	74	N. Tom
	1800	73	N. Tom
	2100	72	N. Tom
	2400	72	J. Sanchez

Friday

Date	Time	Temp.	Name (Print)
10/11/24 Tue	0300	70	J. Sanchez
	0600	73	M. Cerda
	0900	73	M. Cerda
	1200	73	M. Cerda
	1500	73	G. Contreras
	1800	74	G. Contreras
	2100	73	G. Contreras
	2400	75	Amaro

Saturday

Date	Time	Temp.	Name (Print)
10/12/24 Tue	0300	74	Amaro
	0600	74	Price
	0900	74	Price
	1200	74	Price
	1500	74	Sordahn
	1800	74	Sordahn
	2100	73	Sordahn
	2400	73	Amaro

Sunday

Date	Time	Temp.	Name (Print)
10/13/24 Tue	0300	72	Amaro
	0600	73	G. Contreras
	0900	73	G. Contreras
	1200	73	G. Contreras
	1500	73	Amaro
	1800	73	Amaro
	2100	73	Amaro
	2400	73	Sanchez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D5 (B) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
Tu 10/7/24	0300	74	J. Navarro
	0600	74	M. Serrato
	0900	74	M. Serrato
	1200	75	M. Serrato
	1500	74	Goodell
	1800	74	Goodell
	2100	73	Goodell
	2400	73	J. Sanchez

Tuesday

Date	Time	Temp.	Name (Print)
Tu 10/8/24	0300	73	J. Sanchez
	0600	72	A. Cisneros
	0900	73	A. Cisneros
	1200	73	A. Cisneros
	1500	72	N. Tovar
	1800	71	N. Tovar
	2100	70	N. Tovar
	2400	70	J. Sanchez

Wednesday

Date	Time	Temp.	Name (Print)
Tu 10/9/24	0300	70	J. Sanchez
	0600	74	Price
	0900	74	Price
	1200	74	Price
	1500	74	N. Tovar
	1800	75	N. Tovar
	2100	74	N. Tovar
	2400	73	J. Sanchez

Thursday

Date	Time	Temp.	Name (Print)
Tu 10/10/24	0300	72	J. Sanchez
	0600	73	N. Cruz
	0900	74	N. Cruz
	1200	75	N. Cruz
	1500	74	N. Tovar
	1800	73	N. Tovar
	2100	72	N. Tovar
	2400	72	J. Sanchez

Friday

Date	Time	Temp.	Name (Print)
Tu 10/11/24	0300	70	J. Sanchez
	0600	72	M. Cerda
	0900	72	M. Cerda
	1200	74	M. Cerda
	1500	73	G. Contreras
	1800	73	G. Contreras
	2100	73	G. Contreras
	2400	73	Anaghlan

Saturday

Date	Time	Temp.	Name (Print)
Tu 10/12/24	0300	72	Anaghlan
	0600	74	Price
	0900	74	Price
	1200	74	Price
	1500	74	Sardinha
	1800	74	Sardinha
	2100	73	Sardinha
	2400	73	Anaghlan

Sunday

Date	Time	Temp.	Name (Print)
Tu 10/13/24	0300	73	Anaghlan
	0600	73	G. Contreras
	0900	73	G. Contreras
	1200	73	G. Contreras
	1500	73	Arnold
	1800	73	Arnold
	2100	73	Arnold
	2400	73	Sanchez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D-6 (A) Side Temp. Reading Location: Tier 2 - Above Dayroom TV
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/7/24	0300	79	G. ZAMORA
	0600	78	STANTON
	0900	78	STANTON
	1200	78	STANTON
	1500	78	R. Aguilar
	1800	78	R. Aguilar
	2100	78	R. Aguilar
	2400	78	A. Martinez

Tuesday

Date	Time	Temp.	Name (Print)
10/8/24	0300	78	A. Martinez
	0600	78	Medina
	0900	79	Medina
	1200	79	Medina
	1500	79	R. Aguilar
	1800	79	R. Aguilar
	2100	79	R. Aguilar
	2400	78	A. [illegible]

Wednesday

Date	Time	Temp.	Name (Print)
10/9/24	0300	78	A. [illegible]
	0600	78	Medina
	0900	78	Medina
	1200	79	Medina
	1500	75	M. VASQUEZ
	1800	75	M. VASQUEZ
	2100	73	M. VASQUEZ
	2400	72	M. VASQUEZ

Thursday

Date	Time	Temp.	Name (Print)
10/10/24	0300	71	M. VASQUEZ
	0600	74	Medina
	0900	74	Medina
	1200	76	Medina
	1500	76	M. Vasquez
	1800	76	M. Vasquez
	2100	75	M. Vasquez
	2400	74	K. Gibson

Friday

Date	Time	Temp.	Name (Print)
10-11-24	0300	73	K. Gibson
	0600	73	Medina
	0900	74	Medina
	1200	75	Medina
	1500	75	M. VASQUEZ
	1800	74	M. VASQUEZ
	2100	73	M. VASQUEZ
	2400	73	M. VASQUEZ

Saturday

Date	Time	Temp.	Name (Print)
10-12-24	0300	72	M. VASQUEZ
	0600	72	M. VASQUEZ
	0900	73	Medina
	1200	74	Medina
	1500	74	A. Arreola
	1800	74	A. Arreola
	2100	72	A. Arreola
	2400	72	D. Santoyo

Sunday

Date	Time	Temp.	Name (Print)
10-13-24	0300	70	D. Santoyo
	0600	70	Stanton
	0900	71	STANTON
	1200	72	STANTON
	1500	72	D. SANTOYO
	1800	71	D. SANTOYO
	2100	71	D. SANTOYO
	2400	70	D. SANTOYO

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: D6 (B) SIDE Temp. Reading Location: 2nd Tier Above Dayroom TV (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/7/24	0300	79°	G. ZAMORA
	0600	79	STANTON
	0900	79	STANTON
	1200	79	STANTON
	1500	79	R. Aguilar
	1800	79	R. Aguilar
	2100	79	R. Aguilar
	2400	78	A. Martin

Tuesday

Date	Time	Temp.	Name (Print)
10/8/24	0300	78	A. Martin
	0600	78	Mdn
	0900	79	Medina
	1200	78	Medina
	1500	78	R. Aguilar
	1800	78	R. Aguilar
	2100	78	R. Aguilar
	2400	78	A. Martin

Wednesday

Date	Time	Temp.	Name (Print)
10/9/24	0300	78	A. Martin
	0600	78	Medina
	0900	78	Medina
	1200	79	Medina
	1500	75	M. VASQUEZ
	1800	75	M. VASQUEZ
	2100	73	M. VASQUEZ
	2400	72	M. VASQUEZ

Thursday

Date	Time	Temp.	Name (Print)
10/10/24	0300	74	M. VASQUEZ
	0600	74	Medina
	0900	74	Mridaina
	1200	76	Medina
	1500	76	M. Vasquez
	1800	76	M. Vasquez
	2100	75	M. Vasquez
	2400	74	K. Gibson

Friday

Date	Time	Temp.	Name (Print)
10-11-24	0300	73	K. Gibson
	0600	73	Medina
	0900	74	Medina
	1200	75	Medina
	1500	74	M. VASQUEZ
	1800	73	M. VASQUEZ
	2100	72	M. VASQUEZ
	2400	71	M. VASQUEZ

Saturday

Date	Time	Temp.	Name (Print)
10-12-24	0300	71	M. VASQUEZ
	0600	71	M. VASQUEZ
	0900	73	Mdn
	1200	74	Mdn
	1500	74	A. Arreola
	1800	74	A. Arreola
	2100	72	A. Arreola
	2400	72	D. SANTOYO

Sunday

Date	Time	Temp.	Name (Print)
10-13-24	0300	71	D. SANTOYO
	0600	71	STANTON
	0900	72	STANTON
	1200	73	STANTON
	1500	73	D. SANTOYO
	1800	73	D. SANTOYO
	2100	73	D. SANTOYO
	2400	72	D. SANTOYO

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

Attachment 11

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: WKSP Housing Unit: M1 A Temp. Reading Location: Behind Pedestal (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3144 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/7/24	0300	79	J. MONTOYA
	0600	77	J. Lawlerros
	0900	78	J. Lawlerros
	1200	79	J. Lawlerros
	1500	80	R. DURAN
	1800	80	R. DURAN
	2100	80	R. DURAN
	2400	80	J. LOPEZ

Tuesday

Date	Time	Temp.	Name (Print)
10/8/24	0300	79	J LOPEZ
	0600	79	J. Lawlerros
	0900	79	J. Lawlerros
	1200	79	J. Lawlerros
	1500	80	M Rains
	1800	80	M Rains
	2100	80	M Rains
	2400	79	J. LOPEZ

Wednesday

Date	Time	Temp.	Name (Print)
10/9/24	0300	77	J LOPEZ
	0600	77°	M. VEGA
	0900	77°	M. VEGA
	1200	75°	M. VEGA
	1500	77	Duran
	1800	77	Duran
	2100	77	Duran
	2400	77	L LOPEZ

Thursday

Date	Time	Temp.	Name (Print)
10/10/24	0300	76	LOPEZ
	0600	76°	M. VEGA
	0900	76°	M. VEGA
	1200	77°	M. VEGA
	1500	77°	R. LOR
	1800	78°	R. LOR
	2100	78°	R. LOR
	2400	76	LOPEZ

Friday

Date	Time	Temp.	Name (Print)
10/11/24	0300	76	LOPEZ
	0600	76°	M. VEGA
	0900	76°	M. VEGA
	1200	76°	M. VEGA
	1500	77	R. DURAN
	1800	76	R. DURAN
	2100	78	R. DURAN
	2400	76	LOPEZ

Saturday

Date	Time	Temp.	Name (Print)
10/12/24	0300	75	J. LOPEZ
	0600	75°	M. VEGA
	0900	75°	M. VEGA
	1200	75°	M. VEGA
	1500	75	J. MONTOYA
	1800	75	J. MONTOYA
	2100	76	J. MONTOYA
	2400	75	J. MONTOYA

Sunday

Date	Time	Temp.	Name (Print)
10/13/24	0300	72	J. MONTOYA
	0600	73°	M. VEGA
	0900	73°	M. VEGA
	1200	74°	M. VEGA
	1500	75	J. MONTOYA
	1800	75	J. MONTOYA
	2100	75	J. MONTOYA
	2400	75	L. TORRES

Notes

HT Activated		HT Deactivated	
10-7-24	1129	2045	
10-8-24	1127	1930	
10-9-24		1945	

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: Fac. M Dorm 1 B Temp. Reading Location: 1st Tier - Behind C/O Podium
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/7/24	0300	79	J. MONTOYA
	0600	77	J. Landeros
	0900	78	J. Landeros
	1200	79°	J. Landeros
	1500	80	R. DURAN
	1800	80	R. DURAN
	2100	80	R. DURAN
	2400	80°	J. Lopez

Tuesday

Date	Time	Temp.	Name (Print)
10/8/24	0300	79°	J. Lopez
	0600	79	J. Landeros
	0900	79	J. Landeros
	1200	79	J. Landeros
	1500	80	M. Rains
	1800	80	M. Rains
	2100	80	M. Rains
	2400	79°	J. Lopez

Wednesday

Date	Time	Temp.	Name (Print)
10/9/24	0300	78°	J. Lopez
	0600	77°	M. VEGA
	0900	77°	M. VEGA
	1200	78°	M. VEGA
	1500	80	M. Rains
	1800	80	M. Rains
	2100	80°	M. RAINS
	2400	79°	J. Lopez

Thursday

Date	Time	Temp.	Name (Print)
10/10/24	0300	76°	J. Lopez
	0600	76°	M. VEGA
	0900	76°	M. VEGA
	1200	77°	M. VEGA
	1500	77°	R. LOR
	1800	78°	R. LOR
	2100	78°	R. LOR
	2400	77°	J. Lopez

Friday

Date	Time	Temp.	Name (Print)
10/11/24	0300	76	J. Lopez
	0600	76°	M. VEGA
	0900	76°	M. VEGA
	1200	76°	M. VEGA
	1500	77	R. DURAN
	1800	78	R. DURAN
	2100	79	R. DURAN
	2400	78°	J. Lopez

Saturday

Date	Time	Temp.	Name (Print)
10/12/24	0300	75°	J. Lopez
	0600	75°	M. VEGA
	0900	75°	M. VEGA
	1200	75°	M. VEGA
	1500	75	J. MONTOYA
	1800	75	J. MONTOYA
	2100	76	J. MONTOYA
	2400	75	J. MONTOYA

Sunday

Date	Time	Temp.	Name (Print)
10/13/24	0300	72	J. MONTOYA
	0600	73°	M. VEGA
	0900	73°	M. VEGA
	1200	74°	M. VEGA
	1500	75	J. MONTOYA
	1800	75	J. MONTOYA
	2100	75	J. MONTOYA
	2400	78	L. Torres

Notes

UHT Activated		UHT Deactivated
10-7-24	1129	2045
10-8-24	1127	1930
10-9-24	1335	1945

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: M-DORM-2 A-SIDE Temp. Reading Location: BEHIND PODIUM (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10/7/24	0300	75	HOUSE
	0600	75	VARGAS
	0900	70	VARGAS
	1200	75	VARGAS
	1500	78	Fritz
	1800	78	Fritz
	2100	78	Fritz
	2400	77	R. DURAN

Tuesday

Date	Time	Temp.	Name (Print)
10/8/24	0300	77	R. DURAN
	0600	76	Gonzalez
	0900	76	Gonzalez
	1200	78	Gonzalez
	1500	78	Fritz
	1800	78	Fritz
	2100	78	Fritz
	2400	79	R. DURAN

Wednesday

Date	Time	Temp.	Name (Print)
10/9/24	0300	77	R. DURAN
	0600	76	S. CROWELL
	0900	78	S. CROWELL
	1200	79	S. CROWELL
	1500	79	J. Medina
	1800	79	J Medina
	2100	79	J Medina
	2400	77°	K. MADRIGAL

Thursday

Date	Time	Temp.	Name (Print)
10/10/24	0300	77°	K. MADRIGAL
	0600	75	VARGAS
	0900	75	VARGAS
	1200	75	VARGAS
	1500	76	J Medina
	1800	78	J. Medina
	2100	78	J. Medina
	2400	78°	K. MADRIGAL

Friday

Date	Time	Temp.	Name (Print)
10/11/24	0300	75°	K. MADRIGAL
	0600	73	VARGAS
	0900	73	VARGAS
	1200	73	VARGAS
	1500	74	J. Medina
	1800	75	J Medina
	2100	75	J. Medina
	2400	75°	K. MADRIGAL

Saturday

Date	Time	Temp.	Name (Print)
10/12/13	0300	73°	K. MADRIGAL
	0600	73	VARGAS
	0900	73	VARGAS
	1200	75	VARGAS
	1500	75	J Medina
	1800	75	J Medina
	2100	75	J Medina
	2400	75°	H. [illegible]

Sunday

Date	Time	Temp.	Name (Print)
10/13/24	0300	73°	H. [illegible]
	0600	71	VARGAS
	0900	71	VARGAS
	1200	73	VARGAS
	1500	73	J. Medina
	1800	74	Medina
	2100	74	Medina
	2400	74	C. HOUSE

Notes

UHT	ACTIVATED	DEACTIVATED
10-7		2045
10-8	1133	1930
10-9	1335	1945
10-10		
10-11		
10-12		
10-13		

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

INSIDE TEMPERATURE RECORD

CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: MaDORM-2 (B-side) Temp. Reading Location: BEHIND PODIUM (e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10	0300	75	HOUSE
	0600	75	VARGAS
	0900	75	VARGAS
7	1200	75	VARGAS
	1500	78	Fritz
	1800	78	Fritz
24	2100	78	Fritz
	2400	77	R. DURAN

Tuesday

Date	Time	Temp.	Name (Print)
10	0300	77	R. DURAN
	0600	76	L. Gonzalez
	0900	76	Gonzalez
8	1200	78	Gonzalez
	1500	78	Fritz
	1800	78	Fritz
24	2100	78	Fritz
	2400	78	R. DURAN

Wednesday

Date	Time	Temp.	Name (Print)
10	0300	77	R. DURAN
	0600	76	S. Crowell
	0900	78	S. Crowell
9	1200	79	S. Crowell
	1500	79	J Medina
	1800	79	J Medina
24	2100	79	J Medina
	2400	77	K. MADRIGAL

Thursday

Date	Time	Temp.	Name (Print)
10	0300	77	K. MADRIGAL
	0600	75	VARGAS
	0900	75	VARGAS
10	1200	75	VARGAS
	1500	76	J. Medina
	1800	78	J Medina
24	2100	78	J Medina
	2400	78	K. MADRIGAL

Friday

Date	Time	Temp.	Name (Print)
10	0300	75°	K. MADRIGAL
	0600	73	VARGAS
	0900	73	VARGAS
11	1200	73	VARGAS
	1500	74	J Medina
	1800	75	J Medina
24	2100	75	J Medina
	2400	75°	K. MADRIGAL

Saturday

Date	Time	Temp.	Name (Print)
10	0300	73°	K. MADRIGAL
	0600	73	VARGAS
	0900	73	VARGAS
12	1200	75	VARGAS
	1500	75	J. Medina
	1800	75	J Medina
24	2100	75	J Medina
	2400	75°	K. [illegible]

Sunday

Date	Time	Temp.	Name (Print)
10	0300	75°	K. [illegible]
	0600	71	VARGAS
	0900	71	VARGAS
13	1200	73	VARGAS
	1500	73	J. Medina
	1800	74	J Medina
24	2100	74	J Medina
	2400	74	C. HOUSE

Notes

UHT	ACTIVATED	DEACTIVATED
10-7		2045
10-8	1133	1930
10-9	1335	1945
10-10		
10-11		
10-12		
10-13		

DISTRIBUTION: Original: Institution Heat Plan Coordinator

DEPARTMENT OF CORRECTIONS AND REHABILITATION

STATE OF CALIFORNIA
INSIDE TEMPERATURE RECORD
CDCR 2031 (04/18)

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the INSIDE ambient air temperature in all non-air-conditioned housing units where an inmate on the heat risk list may be housed. (Note: Air-conditioned housing units will also be monitored when the air conditioner is malfunctioning).

Using an accurate thermometer on the highest location in the housing unit (e.g., top tier) where an inmate on the heat risk list is housed. The inside air temperature is to be taken every three (3) hours, seven (7) days a week.

Institution: NKSP Housing Unit: CTC/INF Temp. Reading Location: Above Isolation Log
(e.g., 1st tier, 2nd tier, 3rd tier, etc.)

Immediately notify the Watch Commander at extension 3141 when the inside air temperature reaches 90 degrees and again at 95 degrees.

Monday

Date	Time	Temp.	Name (Print)
10-7-24	0300	71.1	Y. Fernandez
	0600	71.2	Brown
	0900	71.2	Brown
	1200	71.2	Brown
	1500	71.8	Penetta
	1800	71.8	Penetta
	2100	71.8	Penetta
	2400	71.9	Y. Fernandez

Tuesday

Date	Time	Temp.	Name (Print)
10-8-24	0300	71.8	Y. Fernandez
	0600	71.8	Brown
	0900	71.8	Brown
	1200	71.8	Brown
	1500	71.4	I. ALVAREZ
	1800	71.4	I. ALVAREZ
	2100	71.2	I. ALVAREZ
	2400	71.0	Y. Fernandez

Wednesday

Date	Time	Temp.	Name (Print)
10-9-24	0300	71.2	Y. Fernandez
	0600	71.2	Brown
	0900	71.2	Brown
	1200	71.2	H. Brown
	1500	71.2	I. ALVAREZ
	1800	71.2	I. ALVAREZ
	2100	71.2	I. ALVAREZ
	2400	71.1	Y. Fernandez

Thursday

Date	Time	Temp.	Name (Print)
10-10-24	0300	70.3	Y. Fernandez
	0600	70.4	H. Brown
	0900	72.3	H. Brown
	1200	72.2	H. Brown
	1500	71.4	I. ALVAREZ
	1800	71.4	I. ALVAREZ
	2100	71.4	I. ALVAREZ
	2400	71.8	J. Rodriguez

Friday

Date	Time	Temp.	Name (Print)
10/11/24	0300	72.1	J. Rodriguez
	0600	70.1	[illegible]
	0900	70.2	[illegible]
	1200	71.3	[illegible]
	1500	71.8	I. ALVAREZ
	1800	71.8	I. ALVAREZ
	2100	71.8	I. ALVAREZ
	2400	72.3	J. Rodriguez

Saturday

Date	Time	Temp.	Name (Print)
10/12/24	0300	72.5	J. Rodriguez
	0600	73.7	I. ALVAREZ
	0900	71.8	I. ALVAREZ
	1200	71.8	I. ALVAREZ
	1500	71.8	I. ALVAREZ
	1800	71.8	I. ALVAREZ
	2100	71.8	I. ALVAREZ
	2400	71.7	Y. Fernandez

Sunday

Date	Time	Temp.	Name (Print)
10/13/24	0300	71.8	Y. Fernandez
	0600	72.7	Y. Fernandez
	0900	72.7	Penetta
	1200	72.7	Penetta
	1500	71.4	Penetta
	1800	71.4	Penetta
	2100	72.1	Penetta
	2400	72.1	Y. Fernandez

Notes

DISTRIBUTION: Original: Institution Heat Plan Coordinator

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

OUTSIDE TEMPERATURE RECORD

CDCR 2030 (04/18)

INSTITUTION: NKSP

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the OUTSIDE ambient air temperature.

Using an accurate thermometer located in a central, heat neutral location, the outside air temperature is to be taken every hour, seven (7) days a week.

Thermometer Location: CONTROL, CENTRAL

Immediately notify the Watch Commander at extension 3141 when the air temperature reaches 90 degrees.

Date	Time	Temp.	Printed Name
10/6/24	0100	73.0	Ruano
	0200	71.1	Ruano
	0300	69.5	Ruano
	0400	68.8	Ruano
	0500	67.4	Ruano
	0600	66	Gonzalez
	0700	66	Gonzalez
	0800	69	Gonzalez
	0900	76	Gonzalez
	1000	81	Gonzalez
	1100	86	Gonzalez
	1200	90	Gonzalez
	1300	94	Gonzalez
	1400	96	Gonzalez
	1500	98	Gonzalez
	1600	99	Gonzalez
	1700	99	Gonzalez
	1800	97	Gonzalez
	1900	92	Gonzalez
	2000	88	Gonzalez
	2100	81	Gonzalez
	2200	78	ARIAS
	2300	75	ARIAS
	2400	74	ARIAS

WHT ACTIVATED 11:55

Date	Time	Temp.	Printed Name
10/7/24	0100	70	ARIAS
	0200	70	ARIAS
	0300	69	ARIAS
	0400	67	ARIAS
	0500	67	ARIAS
	0600	67	Gonzalez
	0700	66	Gonzalez
	0800	67	Gonzalez
	0900	74	Gonzalez
	1000	80	Gonzalez
	1100	86	Gonzalez
	1200	90	Gonzalez
	1300	93	Gonzalez
	1400	95	MONCIBAIZ
	1500	98	MONCIBAIZ
	1600	98	MONCIBAIZ
	1700	98	MONCIBAIZ
	1800	97	MONCIBAIZ
	1900	93	MONCIBAIZ
	2000	88	MONCIBAIZ
	2100	84	MONCIBAIZ
	2200	78	AGUILERA
	2300	74	AGUILERA
	2400	74	AGUILERA

WHT ACTIVATED 1129

DISTRIBUTION: Original: Institution Heat Plan Coordinator

NKSP 10/06/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/06/24	12:15a	72.9	73.0	72.7	12	17.3	2.0	SSE	0.50	5.0	SSE	72.9	68.8	68.8	30.043	0.00	0.00	0.000	0.082
10/06/24	12:30a	72.9	73.0	72.8	14	20.9	3.0	SSE	0.75	5.0	SSE	72.9	69.0	69.0	30.041	0.00	0.00	0.000	0.082
10/06/24	12:45a	72.6	73.0	72.6	14	20.6	2.0	SSE	0.50	5.0	S	72.6	68.6	68.6	30.038	0.00	0.00	0.000	0.079
10/06/24	1:00a	73.0	73.1	72.6	14	20.9	2.0	SSE	0.50	5.0	SSE	73.0	69.2	69.2	30.040	0.00	0.00	0.000	0.083
10/06/24	1:15a	72.6	73.0	72.4	15	22.3	1.0	SSE	0.25	3.0	SSE	72.6	68.7	68.7	30.037	0.00	0.00	0.000	0.079
10/06/24	1:30a	72.0	72.9	72.0	14	20.1	2.0	SSE	0.50	4.0	SE	72.0	67.8	67.8	30.037	0.00	0.00	0.000	0.073
10/06/24	1:45a	72.0	72.0	71.6	14	20.1	2.0	SE	0.50	4.0	SE	72.0	67.8	67.8	30.040	0.00	0.00	0.000	0.073
10/06/24	2:00a	71.1	72.0	71.0	13	17.7	3.0	SE	0.75	5.0	SE	71.1	66.4	66.4	30.039	0.00	0.00	0.000	0.064
10/06/24	2:15a	70.4	71.0	70.4	13	17.2	3.0	SE	0.75	7.0	ESE	70.4	65.4	65.4	30.044	0.00	0.00	0.000	0.056
10/06/24	2:30a	69.7	70.4	69.6	14	18.3	3.0	SE	0.75	7.0	SE	69.7	64.6	64.6	30.043	0.00	0.00	0.000	0.049
10/06/24	2:45a	69.9	70.1	69.7	13	16.8	3.0	SE	0.75	5.0	SE	69.9	64.7	64.7	30.043	0.00	0.00	0.000	0.051
10/06/24	3:00a	69.5	69.9	69.5	12	14.6	3.0	SE	0.75	4.0	SE	69.5	64.2	64.2	30.042	0.00	0.00	0.000	0.047
10/06/24	3:15a	69.5	69.6	69.4	13	16.4	3.0	ESE	0.75	6.0	ESE	69.5	64.3	64.3	30.045	0.00	0.00	0.000	0.047
10/06/24	3:30a	69.4	69.7	69.3	11	12.5	3.0	SE	0.75	7.0	SE	69.4	63.9	63.9	30.040	0.00	0.00	0.000	0.046
10/06/24	3:45a	68.9	69.4	68.9	12	14.1	3.0	ESE	0.75	6.0	ESE	68.9	63.5	63.5	30.038	0.00	0.00	0.000	0.041
10/06/24	4:00a	68.8	69.0	68.8	11	12.1	3.0	ESE	0.75	6.0	ESE	68.8	63.2	63.2	30.040	0.00	0.00	0.000	0.040
10/06/24	4:15a	69.1	69.1	68.8	13	16.1	3.0	ESE	0.75	6.0	ESE	69.1	63.8	63.8	30.040	0.00	0.00	0.000	0.043
10/06/24	4:30a	68.1	69.1	68.1	11	11.5	3.0	SE	0.75	7.0	ESE	68.1	62.4	62.4	30.046	0.00	0.00	0.000	0.032
10/06/24	4:45a	67.9	68.1	67.6	12	13.3	3.0	SE	0.75	6.0	SSE	67.9	62.3	62.3	30.046	0.00	0.00	0.000	0.030
10/06/24	5:00a	67.4	68.0	67.3	12	13.0	3.0	SE	0.75	6.0	ESE	67.4	62.0	62.0	30.048	0.00	0.00	0.000	0.025
10/06/24	5:15a	67.0	67.4	67.0	12	12.6	3.0	SE	0.75	7.0	SE	67.0	61.7	61.7	30.050	0.00	0.00	0.000	0.021
10/06/24	5:30a	66.9	67.0	66.8	12	12.6	3.0	SE	0.75	5.0	SE	66.9	61.6	61.6	30.054	0.00	0.00	0.000	0.020
10/06/24	5:45a	66.4	67.0	66.4	14	15.7	3.0	SE	0.75	7.0	SE	66.4	61.1	61.1	30.056	0.00	0.00	0.000	0.015
10/06/24	6:00a	66.5	66.5	66.0	15	17.4	3.0	SE	0.75	5.0	SE	66.5	61.2	61.2	30.063	0.00	0.00	0.000	0.016
10/06/24	6:15a	66.2	66.7	66.2	15	17.1	3.0	SE	0.75	5.0	SE	66.2	60.9	60.9	30.062	0.00	0.00	0.000	0.012
10/06/24	6:30a	66.3	66.4	66.0	15	17.2	3.0	SE	0.75	4.0	SE	66.3	61.0	61.0	30.065	0.00	0.00	0.000	0.014
10/06/24	6:45a	65.7	66.3	65.7	16	18.2	3.0	SE	0.75	5.0	SE	65.7	60.5	60.5	30.066	0.00	0.00	0.000	0.007
10/06/24	7:00a	66.4	66.4	65.7	14	15.7	3.0	SE	0.75	4.0	SE	66.4	61.1	61.1	30.065	0.00	0.00	0.000	0.015
10/06/24	7:15a	67.2	67.2	66.4	12	12.8	3.0	SE	0.75	4.0	SE	67.2	61.8	61.8	30.071	0.00	0.00	0.000	0.023
10/06/24	7:30a	67.4	67.5	67.2	12	13.0	3.0	SE	0.75	5.0	SE	67.4	62.0	62.0	30.070	0.00	0.00	0.000	0.025
10/06/24	7:45a	67.5	67.6	67.4	12	13.0	4.0	ESE	1.00	6.0	ESE	67.5	62.0	62.0	30.070	0.00	0.00	0.000	0.026
10/06/24	8:00a	69.1	69.1	67.5	7	2.3	4.0	ESE	1.00	6.0	ESE	69.1	63.2	63.2	30.072	0.00	0.00	0.000	0.043
10/06/24	8:15a	70.6	70.6	69.1	5	-3.8	4.0	ESE	1.00	7.0	ESE	70.6	65.0	65.0	30.075	0.00	0.00	0.000	0.058
10/06/24	8:30a	71.7	71.7	70.7	2	-21.4	4.0	ESE	1.00	7.0	ESE	71.7	66.2	66.2	30.079	0.00	0.00	0.000	0.070
10/06/24	8:45a	73.9	73.9	71.7	0	---	3.0	SE	0.75	6.0	ESE	73.9	69.0	69.0	30.081	0.00	0.00	0.000	0.093
10/06/24	9:00a	76.1	76.1	73.9	0	---	4.0	SSE	1.00	7.0	SE	76.1	71.5	71.5	30.087	0.00	0.00	0.000	0.116
10/06/24	9:15a	76.9	76.9	76.0	0	---	5.0	SSE	1.25	8.0	SE	76.9	72.5	72.5	30.086	0.00	0.00	0.000	0.124
10/06/24	9:30a	78.1	78.1	76.8	0	---	4.0	SSE	1.00	9.0	SSE	78.1	73.6	73.6	30.087	0.00	0.00	0.000	0.136
10/06/24	9:45a	79.9	79.9	78.0	0	---	3.0	S	0.75	7.0	S	79.9	75.4	75.4	30.090	0.00	0.00	0.000	0.155
10/06/24	10:00a	81.2	81.2	79.8	0	---	3.0	SW	0.75	7.0	S	81.2	76.6	76.6	30.089	0.00	0.00	0.000	0.169
10/06/24	10:15a	83.1	83.1	81.2	0	---	2.0	SSW	0.50	5.0	SSW	83.1	78.4	78.4	30.090	0.00	0.00	0.000	0.189
10/06/24	10:30a	84.1	84.2	83.1	0	---	3.0	SSE	0.75	7.0	S	84.1	79.2	79.2	30.090	0.00	0.00	0.000	0.199
10/06/24	10:45a	85.3	85.3	84.1	0	---	3.0	SW	0.75	9.0	SE	85.3	80.2	80.2	30.083	0.00	0.00	0.000	0.211
10/06/24	11:00a	86.5	86.5	85.2	0	---	3.0	SSW	0.75	6.0	SSW	86.5	81.2	81.2	30.078	0.00	0.00	0.000	0.224
10/06/24	11:15a	87.6	87.6	86.4	0	---	3.0	SSW	0.75	6.0	SSW	87.6	82.1	82.1	30.072	0.00	0.00	0.000	0.235
10/06/24	11:30a	88.5	88.5	87.6	0	---	3.0	SW	0.75	7.0	SSW	88.5	82.8	82.8	30.068	0.00	0.00	0.000	0.245
10/06/24	11:45a	89.7	89.8	88.5	0	---	2.0	S	0.50	6.0	S	89.7	83.8	83.8	30.063	0.00	0.00	0.000	0.257
10/06/24	12:00p	90.5	90.5	89.6	0	---	2.0	W	0.50	7.0	SSW	90.5	84.3	84.3	30.061	0.00	0.00	0.000	0.266
10/06/24	12:15p	92.1	92.2	90.5	0	---	2.0	SSW	0.50	6.0	WSW	92.1	85.6	85.6	30.056	0.00	0.00	0.000	0.282
10/06/24	12:30p	93.0	93.0	92.2	0	---	2.0	SW	0.50	6.0	SW	93.0	85.2	86.2	30.046	0.00	0.00	0.000	0.292

NKSP 10/06/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/06/24	12:45p	94.1	94.1	93.1	0	---	3.0	SW	0.75	8.0	W	94.1	87.1	87.1	30.041	0.00	0.00	0.000	0.303
10/06/24	1:00p	94.0	94.1	93.8	0	---	2.0	WSW	0.50	9.0	WSW	94.0	87.0	87.0	30.030	0.00	0.00	0.000	0.302
10/06/24	1:15p	95.3	95.4	94.1	0	---	2.0	WSW	0.50	8.0	WNW	95.3	87.9	87.9	30.024	0.00	0.00	0.000	0.316
10/06/24	1:30p	94.9	95.3	94.9	0	---	3.0	NW	0.75	8.0	NNW	94.9	87.6	87.6	30.016	0.00	0.00	0.000	0.311
10/06/24	1:45p	95.7	95.7	94.9	0	---	4.0	N	1.00	9.0	N	95.7	88.2	88.2	30.009	0.00	0.00	0.000	0.320
10/06/24	2:00p	96.1	96.2	95.7	0	---	3.0	N	0.75	9.0	NW	96.1	88.5	88.5	29.999	0.00	0.00	0.000	0.324
10/06/24	2:15p	96.9	96.9	96.1	0	---	4.0	NW	1.00	9.0	NNW	96.9	89.1	89.1	29.989	0.00	0.00	0.000	0.332
10/06/24	2:30p	97.6	97.7	96.8	0	---	4.0	NW	1.00	10.0	NW	97.6	89.6	89.6	29.986	0.00	0.00	0.000	0.340
10/06/24	2:45p	98.1	98.1	97.5	0	---	4.0	W	1.00	9.0	W	98.1	90.0	90.0	29.981	0.00	0.00	0.000	0.345
10/06/24	3:00p	98.3	98.4	98.0	0	---	3.0	NNW	0.75	9.0	WNW	98.3	90.1	90.1	29.976	0.00	0.00	0.000	0.347
10/06/24	3:15p	98.3	98.5	98.2	0	---	4.0	NW	1.00	9.0	NNW	98.3	90.1	90.1	29.972	0.00	0.00	0.000	0.347
10/06/24	3:30p	98.5	98.6	98.2	0	---	6.0	NNE	1.50	10.0	NNE	98.5	90.3	90.3	29.965	0.00	0.00	0.000	0.349
10/06/24	3:45p	98.9	99.0	98.5	0	---	7.0	NW	1.75	12.0	NNW	98.9	90.5	90.5	29.958	0.00	0.00	0.000	0.353
10/06/24	4:00p	99.0	99.1	98.8	0	---	6.0	NNW	1.50	12.0	NNW	99.0	90.6	90.6	29.954	0.00	0.00	0.000	0.354
10/06/24	4:15p	99.1	99.2	99.0	0	---	5.0	NNW	1.25	9.0	N	99.1	90.7	90.7	29.953	0.00	0.00	0.000	0.355
10/06/24	4:30p	99.3	99.4	99.0	0	---	5.0	NW	1.25	10.0	NW	99.3	90.8	90.8	29.954	0.00	0.00	0.000	0.357
10/06/24	4:45p	99.0	99.3	98.9	0	---	5.0	NW	1.25	9.0	NW	99.0	90.6	90.6	29.952	0.00	0.00	0.000	0.354
10/06/24	5:00p	99.0	99.2	99.0	0	---	5.0	NNW	1.25	9.0	NNW	99.0	90.6	90.6	29.951	0.00	0.00	0.000	0.354
10/06/24	5:15p	98.7	99.1	98.7	0	---	4.0	NNE	1.00	8.0	N	98.7	90.4	90.4	29.950	0.00	0.00	0.000	0.351
10/06/24	5:30p	98.2	98.8	98.2	0	---	5.0	N	1.25	9.0	NNE	98.2	90.0	90.0	29.949	0.00	0.00	0.000	0.346
10/06/24	5:45p	97.6	98.3	97.5	0	---	5.0	NNE	1.25	9.0	NNE	97.6	89.6	89.6	29.951	0.00	0.00	0.000	0.340
10/06/24	6:00p	97.0	97.5	96.9	0	---	3.0	NNE	0.75	7.0	NNE	97.0	89.2	89.2	29.948	0.00	0.00	0.000	0.333
10/06/24	6:15p	95.8	96.9	95.8	0	---	2.0	N	0.50	4.0	N	95.8	88.3	88.3	29.952	0.00	0.00	0.000	0.321
10/06/24	6:30p	94.2	95.9	94.2	0	---	3.0	N	0.75	4.0	N	94.2	87.1	87.1	29.952	0.00	0.00	0.000	0.304
10/06/24	6:45p	92.8	94.2	92.7	0	---	2.0	N	0.50	3.0	N	92.8	86.1	86.1	29.956	0.00	0.00	0.000	0.290
10/06/24	7:00p	92.4	92.8	92.4	0	---	0.0	N	0.00	2.0	N	92.4	85.8	85.8	29.958	0.00	0.00	0.000	0.285
10/06/24	7:15p	91.3	92.4	91.3	0	---	0.0	---	0.00	0.0	---	91.3	84.9	84.9	29.959	0.00	0.00	0.000	0.274
10/06/24	7:30p	89.3	91.3	89.3	0	---	0.0	W	0.00	5.0	WSW	89.3	83.4	83.4	29.962	0.00	0.00	0.000	0.253
10/06/24	7:45p	88.6	89.3	88.6	0	---	0.0	W	0.00	2.0	W	88.6	82.9	82.9	29.968	0.00	0.00	0.000	0.246
10/06/24	8:00p	88.4	88.6	88.4	0	---	0.0	---	0.00	0.0	---	88.4	82.7	82.7	29.971	0.00	0.00	0.000	0.244
10/06/24	8:15p	88.6	88.6	88.3	0	---	1.0	W	0.25	2.0	W	88.6	82.9	82.9	29.976	0.00	0.00	0.000	0.246
10/06/24	8:30p	84.8	88.6	84.8	0	---	2.0	SSE	0.50	5.0	S	84.8	79.8	79.8	29.981	0.00	0.00	0.000	0.206
10/06/24	8:45p	82.2	84.7	82.2	0	---	2.0	SE	0.50	4.0	SE	82.2	77.6	77.6	29.986	0.00	0.00	0.000	0.179
10/06/24	9:00p	81.2	82.2	81.2	0	---	3.0	SE	0.75	5.0	SE	81.2	76.6	76.6	29.990	0.00	0.00	0.000	0.169
10/06/24	9:15p	80.4	81.3	80.4	1	-28.9	3.0	SE	0.75	5.0	SE	80.4	75.9	75.9	29.988	0.00	0.00	0.000	0.160
10/06/24	9:30p	79.9	80.4	79.9	5	2.9	3.0	SE	0.75	5.0	SE	79.9	75.8	75.8	29.990	0.00	0.00	0.000	0.155
10/06/24	9:45p	79.1	79.9	78.9	7	9.7	4.0	SE	1.00	6.0	ESE	79.1	75.4	75.4	29.995	0.00	0.00	0.000	0.147
10/06/24	10:00p	78.4	79.1	78.3	10	17.3	3.0	ESE	0.75	5.0	SE	78.4	74.8	74.8	29.995	0.00	0.00	0.000	0.140
10/06/24	10:15p	77.8	78.4	77.7	9	14.4	3.0	ESE	0.75	6.0	ESE	77.8	74.2	74.2	29.995	0.00	0.00	0.000	0.133
10/06/24	10:30p	77.1	77.8	77.1	11	18.5	3.0	SE	0.75	4.0	SE	77.1	73.7	73.7	29.997	0.00	0.00	0.000	0.126
10/06/24	10:45p	76.5	77.1	76.4	11	18.0	2.0	SE	0.50	4.0	ESE	76.5	73.1	73.1	30.001	0.00	0.00	0.000	0.120
10/06/24	11:00p	75.2	76.5	75.2	11	17.0	1.0	SW	0.25	4.0	S	75.2	71.7	71.7	30.005	0.00	0.00	0.000	0.106
10/06/24	11:15p	73.9	75.1	73.9	15	23.3	1.0	SW	0.25	4.0	SW	73.9	70.6	70.6	30.002	0.00	0.00	0.000	0.093
10/06/24	11:30p	74.0	74.1	73.7	16	24.9	2.0	S	0.50	4.0	S	74.0	70.8	70.8	30.002	0.00	0.00	0.000	0.094
10/06/24	11:45p	74.8	74.8	73.8	12	18.7	3.0	SSE	0.75	5.0	S	74.8	71.3	71.3	30.002	0.00	0.00	0.000	0.102
10/07/24	12:00a	74.2	74.9	74.2	11	16.3	2.0	SE	0.50	5.0	SE	74.2	70.4	70.4	30.001	0.00	0.00	0.000	0.096

NKSP 10/06/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/06/24	12:15a	77.5	49	56.8	77.3	9.00	.0730	351	1	100.0	15
10/06/24	12:30a	77.7	48	56.4	77.4	8.90	.0730	351	1	100.0	15
10/06/24	12:45a	77.5	51	57.9	77.5	9.35	.0730	351	1	100.0	15
10/06/24	1:00a	77.3	48	56.1	77.0	8.90	.0731	351	1	100.0	15
10/06/24	1:15a	77.6	52	58.6	77.7	9.50	.0729	352	1	100.0	15
10/06/24	1:30a	77.3	51	57.8	77.3	9.35	.0730	351	1	100.0	15
10/06/24	1:45a	77.4	47	55.6	77.0	8.70	.0731	351	1	100.0	15
10/06/24	2:00a	77.3	52	58.3	77.3	9.50	.0730	351	1	100.0	15
10/06/24	2:15a	77.2	50	57.1	77.1	9.21	.0731	351	1	100.0	15
10/06/24	2:30a	77.5	52	58.5	77.6	9.50	.0730	352	1	100.0	15
10/06/24	2:45a	77.2	51	57.7	77.2	9.35	.0730	351	1	100.0	15
10/06/24	3:00a	77.3	48	56.1	77.0	8.90	.0731	351	1	100.0	15
10/06/24	3:15a	77.1	52	58.1	77.1	9.51	.0730	351	1	100.0	15
10/06/24	3:30a	77.0	49	56.4	76.8	9.01	.0731	352	1	100.0	15
10/06/24	3:45a	77.1	52	58.1	77.1	9.51	.0730	351	1	100.0	15
10/06/24	4:00a	76.9	50	56.8	76.8	9.21	.0731	351	1	100.0	15
10/06/24	4:15a	77.2	49	56.6	77.0	9.01	.0731	351	1	100.0	15
10/06/24	4:30a	76.9	51	57.4	76.9	9.35	.0731	352	1	100.0	15
10/06/24	4:45a	77.0	47	55.2	76.6	8.71	.0732	351	1	100.0	15
10/06/24	5:00a	76.9	51	57.4	76.9	9.35	.0731	351	1	100.0	15
10/06/24	5:15a	76.7	48	55.5	76.4	8.92	.0732	351	1	100.0	15
10/06/24	5:30a	76.9	51	57.4	76.9	9.35	.0731	351	1	100.0	15
10/06/24	5:45a	76.6	50	56.6	76.5	9.22	.0732	352	1	100.0	15
10/06/24	6:00a	76.9	48	55.7	76.6	8.91	.0732	351	1	100.0	15
10/06/24	6:15a	76.8	51	57.3	76.8	9.35	.0732	351	1	100.0	15
10/06/24	6:30a	76.6	47	54.9	76.2	8.72	.0733	351	1	100.0	15
10/06/24	6:45a	76.9	51	57.4	76.9	9.35	.0731	352	1	100.0	15
10/06/24	7:00a	76.7	50	56.7	76.6	9.22	.0732	351	1	100.0	15
10/06/24	7:15a	76.9	47	55.1	76.5	8.71	.0733	351	1	100.0	15
10/06/24	7:30a	76.6	51	57.1	76.6	9.35	.0732	351	1	100.0	15
10/06/24	7:45a	76.5	48	55.3	76.2	8.92	.0733	351	1	100.0	15
10/06/24	8:00a	76.7	51	57.2	76.7	9.35	.0732	352	1	100.0	15
10/06/24	8:15a	76.6	50	56.6	76.5	9.22	.0732	351	1	100.0	15
10/06/24	8:30a	77.0	48	55.8	76.7	8.91	.0732	351	1	100.0	15
10/06/24	8:45a	76.7	50	56.7	76.6	9.22	.0732	351	1	100.0	15
10/06/24	9:00a	76.8	47	55.0	76.4	8.71	.0733	352	1	100.0	15
10/06/24	9:15a	77.2	48	56.0	76.9	8.91	.0732	351	1	100.0	15
10/06/24	9:30a	77.0	49	56.4	76.8	9.01	.0732	351	1	100.0	15
10/06/24	9:45a	77.3	45	54.3	76.7	8.40	.0733	351	1	100.0	15
10/06/24	10:00a	77.6	48	56.4	77.3	8.90	.0732	352	1	100.0	15
10/06/24	10:15a	77.6	49	56.9	77.4	9.00	.0731	351	1	100.0	15
10/06/24	10:30a	77.9	45	54.8	77.2	8.39	.0732	351	1	100.0	15
10/06/24	10:45a	78.3	47	56.4	77.9	8.68	.0730	351	1	100.0	15
10/06/24	11:00a	78.4	48	57.1	78.1	8.88	.0730	351	1	100.0	15
10/06/24	11:15a	78.6	46	56.1	78.1	8.48	.0730	352	1	100.0	15
10/06/24	11:30a	79.0	44	55.2	78.3	8.17	.0730	351	1	100.0	15
10/06/24	11:45a	79.2	48	57.8	79.0	8.87	.0728	351	1	100.0	15
10/06/24	12:00p	79.2	45	56.0	78.6	8.37	.0729	351	1	100.0	15
10/06/24	12:15p	79.5	43	55.0	78.6	8.05	.0729	352	1	100.0	15
10/06/24	12:30p	79.7	45	56.5	79.1	8.36	.0728	351	1	100.0	15

NKSP 10/06/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/06/24	12:45p	79.7	46	57.1	79.2	8.46	.0727	351	1	100.0	15
10/06/24	1:00p	79.9	41	54.1	78.7	7.75	.0728	351	1	100.0	15
10/06/24	1:15p	80.0	44	56.1	79.3	8.15	.0727	352	1	100.0	15
10/06/24	1:30p	80.1	41	54.3	78.9	7.75	.0727	351	1	100.0	15
10/06/24	1:45p	80.1	43	55.6	79.2	8.05	.0726	351	1	100.0	15
10/06/24	2:00p	80.4	40	53.9	79.1	7.55	.0726	351	1	100.0	15
10/06/24	2:15p	80.4	39	53.2	79.1	7.44	.0726	351	1	100.0	15
10/06/24	2:30p	80.3	38	52.4	78.9	7.25	.0727	352	1	100.0	15
10/06/24	2:45p	80.3	38	52.4	78.9	7.25	.0727	351	1	100.0	15
10/06/24	3:00p	80.4	37	51.7	78.9	7.14	.0727	351	1	100.0	15
10/06/24	3:15p	80.5	37	51.8	79.0	7.14	.0726	351	1	100.0	15
10/06/24	3:30p	80.5	37	51.8	79.0	7.14	.0726	352	1	100.0	15
10/06/24	3:45p	80.6	36	51.2	79.0	6.93	.0726	351	1	100.0	15
10/06/24	4:00p	80.6	36	51.2	79.0	6.93	.0726	351	1	100.0	15
10/06/24	4:15p	80.7	36	51.3	79.1	6.92	.0726	351	1	100.0	15
10/06/24	4:30p	80.6	36	51.2	79.0	6.93	.0726	352	1	100.0	15
10/06/24	4:45p	80.9	39	53.6	79.6	7.43	.0725	351	1	100.0	15
10/06/24	5:00p	81.0	37	52.3	79.5	7.13	.0725	351	1	100.0	15
10/06/24	5:15p	81.1	39	53.8	79.8	7.43	.0724	351	1	100.0	15
10/06/24	5:30p	81.0	37	52.3	79.5	7.13	.0725	351	1	100.0	15
10/06/24	5:45p	81.1	39	53.8	79.8	7.43	.0724	352	1	100.0	15
10/06/24	6:00p	80.9	40	54.3	79.7	7.55	.0724	351	1	100.0	15
10/06/24	6:15p	80.8	38	52.8	79.4	7.25	.0725	351	1	100.0	15
10/06/24	6:30p	80.9	40	54.3	79.7	7.55	.0724	351	1	100.0	15
10/06/24	6:45p	80.5	39	53.3	79.2	7.44	.0726	352	1	100.0	15
10/06/24	7:00p	80.5	39	53.3	79.2	7.44	.0726	351	1	100.0	15
10/06/24	7:15p	80.3	42	55.1	79.3	7.85	.0725	351	1	100.0	15
10/06/24	7:30p	79.9	39	52.7	78.5	7.45	.0727	351	1	100.0	15
10/06/24	7:45p	80.0	40	53.5	78.7	7.55	.0726	352	1	100.0	15
10/06/24	8:00p	79.8	43	55.3	78.9	8.05	.0726	351	1	100.0	15
10/06/24	8:15p	79.5	43	55.0	78.6	8.05	.0727	351	1	100.0	15
10/06/24	8:30p	79.3	40	52.9	78.1	7.56	.0728	351	1	100.0	15
10/06/24	8:45p	79.4	42	54.3	78.4	7.86	.0727	351	1	100.0	15
10/06/24	9:00p	79.3	45	56.1	78.7	8.36	.0727	352	1	100.0	15
10/06/24	9:15p	78.9	44	55.1	78.2	8.17	.0728	351	1	100.0	15
10/06/24	9:30p	78.8	43	54.4	77.9	8.05	.0728	351	1	100.0	15
10/06/24	9:45p	78.3	44	54.6	77.5	8.18	.0729	351	1	100.0	15
10/06/24	10:00p	78.0	46	55.5	77.4	8.49	.0729	352	1	100.0	15
10/06/24	10:15p	77.8	49	57.1	77.6	8.99	.0729	351	1	100.0	15
10/06/24	10:30p	77.8	46	55.4	77.3	8.49	.0729	351	1	100.0	15
10/06/24	10:45p	78.0	44	54.3	77.2	8.19	.0730	351	1	100.0	15
10/06/24	11:00p	78.1	48	56.8	77.8	8.89	.0729	352	1	100.0	15
10/06/24	11:15p	77.9	49	57.2	77.8	8.99	.0729	351	1	100.0	15
10/06/24	11:30p	77.8	47	56.0	77.4	8.69	.0729	351	1	100.0	15
10/06/24	11:45p	78.0	47	56.1	77.6	8.69	.0729	351	1	100.0	15
10/07/24	12:00a	77.7	51	58.1	77.7	9.35	.0728	351	1	100.0	15

NKSP 10/07/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/07/24	12:15a	73.5	74.3	73.5	12	17.7	2.0	SE	0.50	5.0	SSE	73.5	69.6	69.6	30.002	0.00	0.00	0.000	0.089
10/07/24	12:30a	72.0	73.5	71.9	15	21.8	2.0	SE	0.50	4.0	SSE	72.0	67.9	67.9	29.998	0.00	0.00	0.000	0.073
10/07/24	12:45a	71.3	72.1	71.3	15	21.2	4.0	SE	1.00	7.0	SE	71.3	66.9	66.9	29.997	0.00	0.00	0.000	0.066
10/07/24	1:00a	70.6	71.3	70.5	18	25.0	4.0	SE	1.00	7.0	SE	70.6	66.2	66.2	29.996	0.00	0.00	0.000	0.058
10/07/24	1:15a	70.0	70.6	69.9	18	24.5	3.0	SE	0.75	5.0	SE	70.0	65.3	65.3	29.994	0.00	0.00	0.000	0.052
10/07/24	1:30a	70.4	70.7	70.0	17	23.5	3.0	SE	0.75	5.0	SE	70.4	65.8	65.8	29.995	0.00	0.00	0.000	0.056
10/07/24	1:45a	70.5	70.5	70.2	17	23.5	3.0	SE	0.75	4.0	SE	70.5	65.9	65.9	29.992	0.00	0.00	0.000	0.057
10/07/24	2:00a	70.9	71.1	70.5	15	20.9	2.0	SE	0.50	4.0	SE	70.9	66.4	66.4	29.989	0.00	0.00	0.000	0.061
10/07/24	2:15a	70.4	70.9	70.3	17	23.5	2.0	SE	0.50	4.0	SE	70.4	65.8	65.8	29.988	0.00	0.00	0.000	0.056
10/07/24	2:30a	69.9	70.4	69.9	17	23.1	2.0	SE	0.50	4.0	SE	69.9	65.1	65.1	29.979	0.00	0.00	0.000	0.051
10/07/24	2:45a	70.2	70.2	69.6	17	23.3	3.0	SE	0.75	4.0	SE	70.2	65.5	65.5	29.981	0.00	0.00	0.000	0.054
10/07/24	3:00a	69.6	70.3	69.6	18	24.2	3.0	SE	0.75	4.0	SE	69.6	64.9	64.9	29.975	0.00	0.00	0.000	0.048
10/07/24	3:15a	69.3	69.6	69.3	17	22.6	3.0	SE	0.50	4.0	SE	69.3	64.4	64.4	29.974	0.00	0.00	0.000	0.045
10/07/24	3:30a	68.7	69.3	68.7	18	23.4	3.0	SE	0.75	4.0	SE	68.7	63.9	63.9	29.975	0.00	0.00	0.000	0.039
10/07/24	3:45a	67.8	68.8	67.8	20	25.2	4.0	SE	1.00	7.0	SE	67.8	63.1	63.1	29.976	0.00	0.00	0.000	0.029
10/07/24	4:00a	67.1	67.8	67.1	21	25.8	4.0	SE	1.00	7.0	SE	67.1	62.3	62.3	29.977	0.00	0.00	0.000	0.022
10/07/24	4:15a	67.3	67.4	67.1	21	26.0	3.0	SE	0.75	4.0	SE	67.3	62.6	62.6	29.973	0.00	0.00	0.000	0.024
10/07/24	4:30a	67.4	67.4	67.1	21	26.1	3.0	SE	0.75	5.0	SE	67.4	62.7	62.7	29.975	0.00	0.00	0.000	0.025
10/07/24	4:45a	67.5	67.7	67.4	19	23.7	3.0	SE	0.75	5.0	SE	67.5	62.7	62.7	29.969	0.00	0.00	0.000	0.026
10/07/24	5:00a	67.2	67.5	67.2	20	24.7	3.0	SE	0.75	5.0	SE	67.2	62.4	62.4	29.971	0.00	0.00	0.000	0.023
10/07/24	5:15a	67.0	67.2	66.8	21	25.7	2.0	ESE	0.50	4.0	ESE	67.0	62.2	62.2	29.970	0.00	0.00	0.000	0.021
10/07/24	5:30a	67.4	67.4	67.0	20	24.9	1.0	ESE	0.25	3.0	ESE	67.4	62.6	62.6	29.973	0.00	0.00	0.000	0.025
10/07/24	5:45a	67.1	67.4	67.1	18	22.1	0.0	---	0.00	0.0	---	67.1	62.1	62.1	29.976	0.00	0.00	0.000	0.022
10/07/24	6:00a	67.2	67.3	67.0	17	20.9	1.0	SE	0.25	4.0	ESE	67.2	62.1	62.1	29.976	0.00	0.00	0.000	0.023
10/07/24	6:15a	66.6	67.3	66.6	18	21.7	3.0	SE	0.75	4.0	SE	66.6	61.5	61.5	29.977	0.00	0.00	0.000	0.017
10/07/24	6:30a	66.5	66.8	66.5	18	21.6	3.0	SE	0.75	4.0	SE	66.5	61.4	61.4	29.978	0.00	0.00	0.000	0.016
10/07/24	6:45a	66.6	66.6	66.2	18	21.7	3.0	SE	0.75	4.0	SE	66.6	61.5	61.5	29.978	0.00	0.00	0.000	0.017
10/07/24	7:00a	66.9	66.9	66.6	19	23.3	3.0	SE	0.75	4.0	SE	66.9	61.9	61.9	29.981	0.00	0.00	0.000	0.020
10/07/24	7:15a	67.3	67.3	66.8	17	20.9	2.0	SE	0.50	3.0	SE	67.3	62.2	62.2	29.984	0.00	0.00	0.000	0.024
10/07/24	7:30a	66.9	67.3	66.9	16	19.2	1.0	SE	0.25	3.0	SE	66.9	61.7	61.7	29.987	0.00	0.00	0.000	0.020
10/07/24	7:45a	67.7	67.7	66.8	15	18.3	2.0	SE	0.50	3.0	SE	67.7	62.5	62.5	29.990	0.00	0.00	0.000	0.028
10/07/24	8:00a	67.6	67.7	67.4	16	19.8	3.0	SE	0.75	6.0	ESE	67.6	62.5	62.5	29.994	0.00	0.00	0.000	0.027
10/07/24	8:15a	69.1	69.1	67.6	14	17.8	2.0	SE	0.50	4.0	ESE	69.1	63.9	63.9	29.996	0.00	0.00	0.000	0.043
10/07/24	8:30a	70.8	70.8	69.1	12	15.6	2.0	SE	0.50	4.0	SE	70.8	65.9	65.9	29.999	0.00	0.00	0.000	0.060
10/07/24	8:45a	72.4	72.4	70.9	8	7.7	2.0	SE	0.50	4.0	SE	72.4	67.6	67.6	29.999	0.00	0.00	0.000	0.077
10/07/24	9:00a	74.4	74.4	72.4	4	-5.7	3.0	N	0.75	5.0	SSE	74.4	69.9	69.9	29.999	0.00	0.00	0.000	0.098
10/07/24	9:15a	76.3	76.3	74.4	0	---	4.0	SE	1.00	7.0	SE	76.3	71.8	71.8	30.004	0.00	0.00	0.000	0.118
10/07/24	9:30a	77.2	77.2	76.3	---	---	3.0	SSE	0.75	7.0	SE	77.2	---	---	30.002	0.00	0.00	0.000	0.127
10/07/24	9:45a	79.1	79.1	77.2	0	---	2.0	S	0.50	5.0	S	79.1	74.6	74.6	30.002	0.00	0.00	0.000	0.147
10/07/24	10:00a	80.4	80.4	79.1	0	---	2.0	SW	0.50	5.0	SW	80.4	75.9	75.9	30.003	0.00	0.00	0.000	0.160
10/07/24	10:15a	82.9	82.9	80.5	0	---	1.0	S	0.25	5.0	S	82.9	78.2	78.2	30.001	0.00	0.00	0.000	0.186
10/07/24	10:30a	83.4	83.4	82.8	0	---	2.0	WSW	0.50	5.0	SW	83.4	78.6	78.6	29.998	0.00	0.00	0.000	0.192
10/07/24	10:45a	84.7	84.7	83.4	0	---	2.0	SW	0.50	4.0	WSW	84.7	79.7	79.7	29.997	0.00	0.00	0.000	0.205
10/07/24	11:00a	86.4	86.4	84.7	0	---	2.0	SW	0.50	4.0	SW	86.4	81.1	81.1	29.988	0.00	0.00	0.000	0.223
10/07/24	11:15a	88.5	88.5	86.4	0	---	2.0	SSW	0.50	5.0	SW	88.5	82.8	82.8	29.981	0.00	0.00	0.000	0.245
10/07/24	11:30a	90.1	90.1	88.5	0	---	2.0	N	0.50	5.0	SSW	90.1	84.1	84.1	29.981	0.00	0.00	0.000	0.261
10/07/24	11:45a	90.2	90.8	90.2	0	---	2.0	WSW	0.50	6.0	W	90.2	84.1	84.1	29.975	0.00	0.00	0.000	0.262
10/07/24	12:00p	90.8	90.8	90.1	0	---	2.0	W	0.50	8.0	W	90.8	84.6	84.6	29.964	0.00	0.00	0.000	0.269
10/07/24	12:15p	91.4	91.5	90.8	0	---	4.0	W	1.00	9.0	W	91.4	85.0	85.0	29.958	0.00	0.00	0.000	0.275
10/07/24	12:30p	92.3	92.4	91.5	0	---	4.0	NW	1.00	9.0	NW	92.3	85.7	85.7	29.950	0.00	0.00	0.000	0.284

NKSP 10/07/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/07/24	12:45p	92.7	92.8	92.2	0	---	4.0	NW	1.00	9.0	W	92.7	86.0	86.0	29.943	0.00	0.00	0.000	0.289
10/07/24	1:00p	93.5	93.5	92.7	0	---	4.0	NW	1.00	9.0	NW	93.5	86.6	86.6	29.933	0.00	0.00	0.000	0.297
10/07/24	1:15p	93.5	93.6	93.5	0	---	4.0	NW	1.00	9.0	NW	93.5	86.6	86.6	29.927	0.00	0.00	0.000	0.297
10/07/24	1:30p	94.6	94.6	93.5	0	---	4.0	W	1.00	10.0	W	94.6	87.4	87.4	29.916	0.00	0.00	0.000	0.308
10/07/24	1:45p	95.4	95.4	94.6	0	---	5.0	W	1.25	11.0	W	95.4	88.0	88.0	29.909	0.00	0.00	0.000	0.317
10/07/24	2:00p	95.6	95.7	95.4	0	---	5.0	WNW	1.25	12.0	WNW	95.6	88.1	88.1	29.903	0.00	0.00	0.000	0.319
10/07/24	2:15p	96.2	96.3	95.7	0	---	6.0	N	1.50	11.0	N	96.2	88.6	88.6	29.896	0.00	0.00	0.000	0.325
10/07/24	2:30p	97.1	97.1	96.2	0	---	5.0	W	1.25	10.0	WNW	97.1	89.3	89.3	29.886	0.00	0.00	0.000	0.334
10/07/24	2:45p	97.3	97.4	97.0	0	---	5.0	WNW	1.25	9.0	NW	97.3	89.4	89.4	29.879	0.00	0.00	0.000	0.336
10/07/24	3:00p	98.2	98.2	97.3	0	---	4.0	WNW	1.00	9.0	W	98.2	90.0	90.0	29.874	0.00	0.00	0.000	0.346
10/07/24	3:15p	98.4	98.4	98.1	0	---	4.0	WNW	1.00	9.0	WNW	98.4	90.2	90.2	29.869	0.00	0.00	0.000	0.348
10/07/24	3:30p	98.5	98.7	98.3	0	---	5.0	NNW	1.25	11.0	WNW	98.5	90.3	90.3	29.864	0.00	0.00	0.000	0.349
10/07/24	3:45p	98.8	98.9	98.5	0	---	4.0	NW	1.00	8.0	WNW	98.8	90.5	90.5	29.861	0.00	0.00	0.000	0.352
10/07/24	4:00p	98.5	98.8	98.4	0	---	4.0	NW	1.00	9.0	NW	98.5	90.3	90.3	29.855	0.00	0.00	0.000	0.349
10/07/24	4:15p	98.5	98.9	98.5	0	---	5.0	NNW	1.25	11.0	N	98.5	90.3	90.3	29.854	0.00	0.00	0.000	0.349
10/07/24	4:30p	98.5	98.7	98.4	0	---	4.0	NNW	1.00	8.0	NNW	98.5	90.3	90.3	29.851	0.00	0.00	0.000	0.349
10/07/24	4:45p	98.4	98.5	98.3	0	---	4.0	NNW	1.00	9.0	NNW	98.4	90.2	90.2	29.848	0.00	0.00	0.000	0.348
10/07/24	5:00p	98.2	98.4	98.1	0	---	5.0	NW	1.25	9.0	NW	98.2	90.0	90.0	29.848	0.00	0.00	0.000	0.346
10/07/24	5:15p	98.2	98.3	98.2	0	---	4.0	N	1.00	6.0	NNW	98.2	90.0	90.0	29.847	0.00	0.00	0.000	0.346
10/07/24	5:30p	98.0	98.2	98.0	0	---	2.0	NE	0.50	5.0	NE	98.0	89.9	89.9	29.846	0.00	0.00	0.000	0.344
10/07/24	5:45p	97.6	98.1	97.6	0	---	2.0	NNE	0.50	4.0	NE	97.6	89.6	89.6	29.847	0.00	0.00	0.000	0.340
10/07/24	6:00p	97.1	97.6	97.1	0	---	2.0	NNE	0.50	3.0	NNE	97.1	89.3	89.3	29.848	0.00	0.00	0.000	0.334
10/07/24	6:15p	96.6	97.1	96.6	0	---	1.0	NNE	0.25	3.0	NNE	96.6	88.9	88.9	29.846	0.00	0.00	0.000	0.329
10/07/24	6:30p	95.8	96.7	95.8	0	---	0.0	NNE	0.00	2.0	NNE	95.8	88.3	88.3	29.848	0.00	0.00	0.000	0.321
10/07/24	6:45p	95.0	95.8	95.0	0	---	0.0	NE	0.00	1.0	NE	95.0	87.7	87.7	29.846	0.00	0.00	0.000	0.313
10/07/24	7:00p	93.1	95.1	93.1	0	---	1.0	NE	0.25	2.0	NE	93.1	86.3	86.3	29.846	0.00	0.00	0.000	0.293
10/07/24	7:15p	91.3	93.0	91.3	0	---	1.0	ENE	0.25	3.0	ENE	91.3	84.9	84.9	29.847	0.00	0.00	0.000	0.274
10/07/24	7:30p	90.3	91.3	90.2	0	---	2.0	ENE	0.50	3.0	ENE	90.3	84.2	84.2	29.848	0.00	0.00	0.000	0.264
10/07/24	7:45p	89.5	90.3	89.5	0	---	2.0	WNW	0.50	3.0	ENE	89.5	83.6	83.6	29.850	0.00	0.00	0.000	0.255
10/07/24	8:00p	88.5	89.5	88.5	0	---	1.0	WNW	0.25	2.0	WNW	88.5	82.8	82.8	29.854	0.00	0.00	0.000	0.245
10/07/24	8:15p	87.4	88.6	87.4	0	---	1.0	WNW	0.25	4.0	WNW	87.4	81.9	81.9	29.859	0.00	0.00	0.000	0.233
10/07/24	8:30p	85.6	87.4	85.6	0	---	0.0	WNW	0.00	2.0	WNW	85.6	80.5	80.5	29.866	0.00	0.00	0.000	0.215
10/07/24	8:45p	85.0	85.6	84.9	0	---	0.0	W	0.00	2.0	W	85.0	80.0	80.0	29.865	0.00	0.00	0.000	0.208
10/07/24	9:00p	84.9	85.0	84.7	0	---	0.0	W	0.00	2.0	W	84.9	79.9	79.9	29.868	0.00	0.00	0.000	0.207
10/07/24	9:15p	82.3	85.0	82.3	---	---	3.0	ESE	0.75	5.0	SSE	82.3	---	---	29.872	0.00	0.00	0.000	0.180
10/07/24	9:30p	79.6	82.2	79.6	5	2.6	4.0	ESE	1.00	6.0	ESE	79.6	75.6	75.6	29.872	0.00	0.00	0.000	0.152
10/07/24	9:45p	78.9	79.6	78.8	6	6.1	4.0	SE	1.00	7.0	ESE	78.9	75.1	75.1	29.877	0.00	0.00	0.000	0.145
10/07/24	10:00p	78.2	79.0	78.1	9	14.7	4.0	ESE	1.00	7.0	ESE	78.2	74.6	74.6	29.880	0.00	0.00	0.000	0.137
10/07/24	10:15p	77.8	79.0	77.8	6	5.3	3.0	ESE	0.75	9.0	SE	77.8	74.0	74.0	29.882	0.00	0.00	0.000	0.133
10/07/24	10:30p	77.1	78.1	77.1	6	4.8	4.0	ESE	1.00	10.0	ESE	77.1	73.1	73.1	29.883	0.00	0.00	0.000	0.126
10/07/24	10:45p	76.5	77.1	76.2	8	10.7	2.0	ESE	0.50	6.0	ESE	76.5	72.6	72.6	29.888	0.00	0.00	0.000	0.120
10/07/24	11:00p	74.8	76.5	74.8	8	9.5	2.0	SSW	0.50	8.0	SSW	74.8	70.9	70.9	29.886	0.00	0.00	0.000	0.102
10/07/24	11:15p	73.9	74.8	73.9	12	18.0	2.0	SSW	0.50	5.0	SSW	73.9	70.1	70.1	29.884	0.00	0.00	0.000	0.093
10/07/24	11:30p	75.0	75.0	73.9	10	14.7	1.0	SSE	0.25	3.0	SSE	75.0	71.3	71.3	29.885	0.00	0.00	0.000	0.104
10/07/24	11:45p	75.4	75.4	75.0	8	9.9	1.0	SSE	0.25	5.0	SE	75.4	71.5	71.5	29.888	0.00	0.00	0.000	0.108
10/08/24	12:00a	74.1	75.4	74.1	10	14.0	2.0	SE	0.50	6.0	ESE	74.1	70.1	70.1	29.886	0.00	0.00	0.000	0.095

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/07/24	12:15a	77.3	49	56.6	77.1	9.00	.0730	350	1	100.0	15
10/07/24	12:30a	77.6	51	58.0	77.6	9.35	.0729	351	1	100.0	15
10/07/24	12:45a	77.3	52	58.3	77.3	9.50	.0729	351	1	100.0	15
10/07/24	1:00a	77.3	48	56.1	77.0	8.90	.0730	352	1	100.0	15
10/07/24	1:15a	77.2	54	59.3	77.4	9.81	.0728	351	1	100.0	15
10/07/24	1:30a	77.0	51	57.5	77.0	9.35	.0730	351	1	100.0	15
10/07/24	1:45a	77.3	55	59.9	77.5	9.96	.0728	351	1	100.0	15
10/07/24	2:00a	77.0	53	58.6	77.1	9.65	.0729	351	1	100.0	15
10/07/24	2:15a	77.3	52	58.3	77.3	9.50	.0729	352	1	100.0	15
10/07/24	2:30a	76.9	54	59.0	77.0	9.81	.0729	351	1	100.0	15
10/07/24	2:45a	77.2	50	57.1	77.1	9.21	.0729	351	1	100.0	15
10/07/24	3:00a	76.9	54	59.0	77.0	9.81	.0729	351	1	100.0	15
10/07/24	3:15a	76.9	50	56.8	76.8	9.21	.0729	352	1	100.0	15
10/07/24	3:30a	76.9	55	59.5	77.1	9.97	.0728	351	1	100.0	15
10/07/24	3:45a	76.7	51	57.2	76.7	9.35	.0730	351	1	100.0	15
10/07/24	4:00a	77.0	54	59.1	77.1	9.81	.0728	351	1	100.0	15
10/07/24	4:15a	76.6	53	58.2	76.7	9.65	.0729	352	1	100.0	15
10/07/24	4:30a	77.0	52	58.0	77.0	9.51	.0729	351	1	100.0	15
10/07/24	4:45a	76.5	54	58.6	76.6	9.82	.0729	351	1	100.0	15
10/07/24	5:00a	76.8	50	56.8	76.7	9.21	.0730	351	1	100.0	15
10/07/24	5:15a	76.6	54	58.7	76.7	9.82	.0729	352	1	100.0	15
10/07/24	5:30a	76.7	49	56.1	76.5	9.02	.0730	351	1	100.0	15
10/07/24	5:45a	76.7	54	58.8	76.8	9.82	.0729	351	1	100.0	15
10/07/24	6:00a	76.5	51	57.0	76.5	9.35	.0730	351	1	100.0	15
10/07/24	6:15a	76.8	54	58.9	76.9	9.81	.0729	351	1	100.0	15
10/07/24	6:30a	76.4	53	58.0	76.5	9.65	.0730	352	1	100.0	15
10/07/24	6:45a	76.7	51	57.2	76.7	9.35	.0730	351	1	100.0	15
10/07/24	7:00a	76.3	54	58.4	76.4	9.82	.0730	351	1	100.0	15
10/07/24	7:15a	76.4	50	56.4	76.3	9.22	.0731	351	1	100.0	15
10/07/24	7:30a	76.4	54	58.5	76.5	9.82	.0730	352	1	100.0	15
10/07/24	7:45a	76.4	51	56.9	76.4	9.35	.0730	351	1	100.0	15
10/07/24	8:00a	76.7	54	58.8	76.8	9.82	.0729	351	1	100.0	15
10/07/24	8:15a	76.6	53	58.2	76.7	9.65	.0730	351	1	100.0	15
10/07/24	8:30a	77.0	50	56.9	76.9	9.21	.0730	351	1	100.0	15
10/07/24	8:45a	76.9	53	58.5	77.0	9.65	.0729	352	1	100.0	15
10/07/24	9:00a	76.9	50	56.8	76.8	9.21	.0730	351	1	100.0	15
10/07/24	9:15a	77.3	52	58.3	77.3	9.50	.0729	351	1	100.0	15
10/07/24	9:30a	77.4	52	58.4	77.5	9.50	.0729	351	1	100.0	15
10/07/24	9:45a	77.6	48	56.4	77.3	8.90	.0729	352	1	100.0	15
10/07/24	10:00a	77.9	51	58.3	77.9	9.35	.0728	351	1	100.0	15
10/07/24	10:15a	77.9	51	58.3	77.9	9.35	.0728	351	1	100.0	15
10/07/24	10:30a	78.2	47	56.3	77.8	8.69	.0728	351	1	100.0	15
10/07/24	10:45a	78.5	51	58.9	78.6	9.35	.0727	352	1	100.0	15
10/07/24	11:00a	78.5	49	57.7	78.4	8.98	.0727	351	1	100.0	15
10/07/24	11:15a	78.8	46	56.3	78.3	8.47	.0727	351	1	100.0	15
10/07/24	11:30a	79.1	47	57.1	78.7	8.67	.0726	351	1	100.0	15
10/07/24	11:45a	79.2	49	58.4	79.1	8.97	.0726	351	1	100.0	15
10/07/24	12:00p	79.2	44	55.4	78.5	8.17	.0727	352	1	100.0	15
10/07/24	12:15p	79.5	45	56.3	78.9	8.36	.0726	351	1	100.0	15
10/07/24	12:30p	79.3	45	56.1	78.7	8.36	.0726	351	1	100.0	15

NKSP 10/07/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/07/24	12:45p	79.5	43	55.0	78.6	8.05	.0726	351	1	100.0	15
10/07/24	1:00p	79.5	44	55.7	78.8	8.16	.0725	352	1	100.0	15
10/07/24	1:15p	79.7	41	53.9	78.6	7.75	.0726	351	1	100.0	15
10/07/24	1:30p	79.6	40	53.1	78.3	7.56	.0726	351	1	100.0	15
10/07/24	1:45p	79.7	39	52.5	78.3	7.46	.0726	351	1	100.0	15
10/07/24	2:00p	80.0	39	52.8	78.6	7.45	.0725	351	1	100.0	15
10/07/24	2:15p	80.3	38	52.4	78.9	7.25	.0725	352	1	100.0	15
10/07/24	2:30p	80.5	38	52.6	79.1	7.25	.0724	351	1	100.0	15
10/07/24	2:45p	80.8	37	52.1	79.3	7.13	.0724	351	1	100.0	15
10/07/24	3:00p	81.0	37	52.3	79.5	7.13	.0723	351	1	100.0	15
10/07/24	3:15p	81.1	37	52.4	79.6	7.13	.0723	352	1	100.0	15
10/07/24	3:30p	81.1	36	51.6	79.5	6.91	.0723	351	1	100.0	15
10/07/24	3:45p	81.1	36	51.6	79.5	6.91	.0723	351	1	100.0	15
10/07/24	4:00p	80.9	36	51.4	79.3	6.91	.0723	351	1	100.0	15
10/07/24	4:15p	80.7	36	51.3	79.1	6.92	.0723	352	1	100.0	15
10/07/24	4:30p	80.7	36	51.3	79.1	6.92	.0723	351	1	100.0	15
10/07/24	4:45p	80.5	36	51.1	78.9	6.93	.0724	351	1	100.0	15
10/07/24	5:00p	81.0	38	53.0	79.6	7.25	.0722	351	1	100.0	15
10/07/24	5:15p	80.8	36	51.4	79.2	6.92	.0723	351	1	100.0	15
10/07/24	5:30p	80.6	36	51.2	79.0	6.93	.0723	352	1	100.0	15
10/07/24	5:45p	80.4	37	51.7	78.9	7.14	.0724	351	1	100.0	15
10/07/24	6:00p	80.8	37	52.1	79.3	7.13	.0723	351	1	100.0	15
10/07/24	6:15p	80.3	36	50.9	78.7	6.94	.0724	351	1	100.0	15
10/07/24	6:30p	80.5	39	53.3	79.2	7.44	.0723	352	1	100.0	15
10/07/24	6:45p	80.3	37	51.7	78.8	7.14	.0724	351	1	100.0	15
10/07/24	7:00p	80.1	40	53.6	78.8	7.55	.0723	351	1	100.0	15
10/07/24	7:15p	80.0	37	51.4	78.5	7.15	.0724	351	1	100.0	15
10/07/24	7:30p	80.1	40	53.6	78.8	7.55	.0723	352	1	100.0	15
10/07/24	7:45p	79.7	40	53.2	78.4	7.56	.0724	351	1	100.0	15
10/07/24	8:00p	79.7	39	52.5	78.3	7.46	.0724	351	1	100.0	15
10/07/24	8:15p	79.7	41	53.9	78.6	7.75	.0724	351	1	100.0	15
10/07/24	8:30p	79.3	42	54.2	78.3	7.86	.0725	351	1	100.0	15
10/07/24	8:45p	79.2	40	52.8	78.0	7.57	.0725	352	1	100.0	15
10/07/24	9:00p	79.2	42	54.1	78.2	7.87	.0725	351	1	100.0	15
10/07/24	9:15p	79.0	45	55.8	78.4	8.37	.0724	351	1	100.0	15
10/07/24	9:30p	78.7	43	54.3	77.8	8.05	.0725	351	1	100.0	15
10/07/24	9:45p	78.7	42	53.7	77.7	7.88	.0726	352	1	100.0	15
10/07/24	10:00p	78.8	46	56.3	78.3	8.47	.0725	351	1	100.0	15
10/07/24	10:15p	78.6	46	56.1	78.1	8.48	.0725	351	1	100.0	15
10/07/24	10:30p	78.5	44	54.8	77.7	8.18	.0726	351	1	100.0	15
10/07/24	10:45p	78.6	44	54.9	77.8	8.18	.0726	352	1	100.0	15
10/07/24	11:00p	78.5	49	57.7	78.4	8.98	.0725	351	1	100.0	15
10/07/24	11:15p	78.3	47	56.4	77.9	8.68	.0725	351	1	100.0	15
10/07/24	11:30p	78.3	45	55.2	77.6	8.38	.0726	351	1	100.0	15
10/07/24	11:45p	78.4	49	57.7	78.3	8.98	.0725	351	1	100.0	15
10/08/24	12:00a	78.1	49	57.4	78.0	8.99	.0725	352	1	100.0	15

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

OUTSIDE TEMPERATURE RECORD
CDCR 2030 (04/18)

INSTITUTION: NKSP

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the OUTSIDE ambient air temperature.

Using an accurate thermometer located in a central, heat neutral location, the outside air temperature is to be taken every hour, seven (7) days a week.

Thermometer Location: CONTROL, CENTRAL

Immediately notify the Watch Commander at extension 3141 when the air temperature reaches 90 degrees.

Date	Time	Temp.	Printed Name
10/8/24	0100	71	AGUILERA
	0200	71	AGUILERA
	0300	69	AGUILERA
	0400	67	AGUILERA
	0500	67	ACIAS
	0600	66	LMartinez
	0700	67	LMartinez
	0800	69	LMartinez
	0900	78	LMartinez
	1000	83	LMartinez
	1100	88	LMartinez
	1200	90	LMartinez
	1300	92	LMartinez
	1400	94	O. Moncibaiz
	1500	95	O. Moncibaiz
	1600	95	O. Moncibaiz
	1700	94	O. Moncibaiz
	1800	92	O. Moncibaiz
	1900	88	O. Moncibaiz
	2000	84	O. Moncibaiz
	2100	81	B. AGUILERA
	2200	75	B. AGUILERA
	2300	72	PARRA
	2400	70	PARRA

UHT Activated 1133 hrs

Date	Time	Temp.	Printed Name
10/9/24	0100	68	Parra
	0200	67	Parra
	0300	65	Parra
	0400	65	Parra
	0500	64	Parra
	0600	65	LMartinez
	0700	64	LMartinez
	0800	66	LMartinez
	0900	73	LMartinez
	1000	78	LMartinez
	1100	84	LMartinez
	1200	86	LMartinez
	1300	88	LMartinez
	1400	90.3	Renkert
	1500	92.6	Renkert
	1600	93.7	Renkert
	1700	94.2	Renkert
	1800	92.3	Renkert
	1900	87.4	Renkert
	2000	82.7	Renkert
	2100	79.1	Renkert
	2200	75	Portillo
	2300	72	Portillo
	2400	68	Portillo

90

UHT Activated 1335 hrs

DISTRIBUTION: Original: Institution Heat Plan Coordinator

NKSP 10/08/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/08/24	12:15a	73.4	74.0	73.3	13	19.5	3.0	ESE	0.75	6.0	ESE	73.4	69.6	69.6	29.885	0.00	0.00	0.000	0.088
10/08/24	12:30a	72.9	73.4	72.8	14	20.9	3.0	ESE	0.75	4.0	ESE	72.9	69.0	69.0	29.886	0.00	0.00	0.000	0.082
10/08/24	12:45a	72.2	73.0	72.2	14	20.3	2.0	SE	0.50	4.0	SE	72.2	68.1	68.1	29.884	0.00	0.00	0.000	0.075
10/08/24	1:00a	71.2	72.2	71.2	17	24.1	2.0	SSE	0.50	7.0	SE	71.2	67.0	67.0	29.884	0.00	0.00	0.000	0.065
10/08/24	1:15a	70.8	71.3	70.8	17	23.8	2.0	SSE	0.50	4.0	SSE	70.8	66.4	66.4	29.884	0.00	0.00	0.000	0.060
10/08/24	1:30a	71.0	71.1	70.6	16	22.5	2.0	SSE	0.50	7.0	ESE	71.0	66.6	66.6	29.886	0.00	0.00	0.000	0.063
10/08/24	1:45a	70.2	70.9	70.2	18	24.7	2.0	ESE	0.50	7.0	ESE	70.2	65.6	65.6	29.890	0.00	0.00	0.000	0.054
10/08/24	2:00a	71.0	71.0	70.2	16	22.5	3.0	SE	0.75	4.0	ESE	71.0	66.6	66.6	29.889	0.00	0.00	0.000	0.063
10/08/24	2:15a	71.1	71.1	70.9	14	19.4	3.0	SE	0.75	7.0	SE	71.1	66.5	66.5	29.885	0.00	0.00	0.000	0.064
10/08/24	2:30a	70.1	71.2	70.1	14	18.6	4.0	SE	1.00	8.0	SE	70.1	65.1	65.1	29.882	0.00	0.00	0.000	0.053
10/08/24	2:45a	69.5	70.1	69.5	15	19.8	6.0	SE	1.50	9.0	ESE	69.5	64.4	64.4	29.877	0.00	0.00	0.000	0.047
10/08/24	3:00a	69.7	69.8	69.4	14	18.3	4.0	SE	1.00	8.0	SE	69.7	64.6	64.6	29.871	0.00	0.00	0.000	0.049
10/08/24	3:15a	69.7	69.7	69.4	14	18.3	3.0	SE	0.75	5.0	SE	69.7	64.6	64.6	29.872	0.00	0.00	0.000	0.049
10/08/24	3:30a	68.8	69.6	68.8	16	20.7	4.0	SE	1.00	8.0	SE	68.8	63.8	63.8	29.879	0.00	0.00	0.000	0.040
10/08/24	3:45a	67.6	68.8	67.6	18	22.5	3.0	SSW	0.75	6.0	SSW	67.6	62.7	62.7	29.878	0.00	0.00	0.000	0.027
10/08/24	4:00a	67.6	67.8	67.5	19	23.8	3.0	SSW	0.75	5.0	SSW	67.6	62.8	62.8	29.879	0.00	0.00	0.000	0.027
10/08/24	4:15a	68.3	68.3	67.6	20	25.6	2.0	SSW	0.50	5.0	SSE	68.3	63.7	63.7	29.879	0.00	0.00	0.000	0.034
10/08/24	4:30a	68.3	68.4	68.0	19	24.4	3.0	S	0.75	6.0	S	68.3	63.6	63.6	29.877	0.00	0.00	0.000	0.034
10/08/24	4:45a	68.6	68.9	68.4	18	23.4	3.0	SE	0.75	8.0	ESE	68.6	63.8	63.8	29.880	0.00	0.00	0.000	0.037
10/08/24	5:00a	67.7	68.6	67.7	20	25.1	4.0	SSE	1.00	7.0	SE	67.7	63.0	63.0	29.876	0.00	0.00	0.000	0.028
10/08/24	5:15a	67.3	67.8	67.3	20	24.8	3.0	SE	0.75	7.0	SE	67.3	62.5	62.5	29.880	0.00	0.00	0.000	0.024
10/08/24	5:30a	66.8	67.3	66.8	21	25.6	5.0	SE	1.25	8.0	SE	66.8	62.0	62.0	29.876	0.00	0.00	0.000	0.019
10/08/24	5:45a	66.2	66.7	66.2	21	25.1	4.0	SE	1.00	8.0	ESE	66.2	61.4	61.4	29.881	0.00	0.00	0.000	0.012
10/08/24	6:00a	66.3	66.5	66.2	18	21.5	5.0	SE	1.25	8.0	SE	66.3	61.2	61.2	29.884	0.00	0.00	0.000	0.014
10/08/24	6:15a	66.6	66.7	66.2	17	20.4	5.0	SE	1.25	8.0	SE	66.6	61.5	61.5	29.881	0.00	0.00	0.000	0.017
10/08/24	6:30a	67.0	67.1	66.7	15	17.8	5.0	SE	1.25	8.0	SE	67.0	61.7	61.7	29.884	0.00	0.00	0.000	0.021
10/08/24	6:45a	67.3	67.3	66.9	13	14.7	5.0	SE	1.25	8.0	SE	67.3	61.9	61.9	29.886	0.00	0.00	0.000	0.024
10/08/24	7:00a	67.5	67.6	67.3	12	13.0	4.0	SE	1.00	7.0	SE	67.5	62.0	62.0	29.893	0.00	0.00	0.000	0.026
10/08/24	7:15a	67.6	67.7	67.3	11	11.1	3.0	SE	0.75	7.0	SE	67.6	62.0	62.0	29.895	0.00	0.00	0.000	0.027
10/08/24	7:30a	67.7	67.8	67.6	10	9.1	3.0	SE	0.75	7.0	ESE	67.7	62.0	62.0	29.892	0.00	0.00	0.000	0.028
10/08/24	7:45a	68.6	68.6	67.7	9	7.4	4.0	SE	1.00	8.0	SE	68.6	62.8	62.8	29.894	0.00	0.00	0.000	0.037
10/08/24	8:00a	69.7	69.7	68.6	8	5.7	4.0	SE	1.00	8.0	ESE	69.7	64.0	64.0	29.898	0.00	0.00	0.000	0.049
10/08/24	8:15a	70.8	70.9	69.8	8	6.5	3.0	SE	0.75	5.0	N	70.8	65.6	65.6	29.901	0.00	0.00	0.000	0.060
10/08/24	8:30a	73.1	73.1	70.6	5	-2.0	3.0	SE	0.75	6.0	SSE	73.1	68.2	68.2	29.907	0.00	0.00	0.000	0.084
10/08/24	8:45a	75.7	75.7	73.2	2	-18.8	4.0	SE	1.00	8.0	SE	75.7	71.1	71.1	29.912	0.00	0.00	0.000	0.111
10/08/24	9:00a	78.8	78.8	75.8	0	---	4.0	SSE	1.00	7.0	SE	78.8	74.3	74.3	29.919	0.00	0.00	0.000	0.144
10/08/24	9:15a	80.7	80.7	78.8	0	---	4.0	S	1.00	8.0	S	80.7	76.1	76.1	29.926	0.00	0.00	0.000	0.164
10/08/24	9:30a	82.3	82.3	80.7	0	---	3.0	SSW	0.75	6.0	SSW	82.3	77.7	77.7	29.931	0.00	0.00	0.000	0.180
10/08/24	9:45a	82.7	82.7	82.3	0	---	3.0	SW	0.75	6.0	SW	82.7	78.0	78.0	29.933	0.00	0.00	0.000	0.184
10/08/24	10:00a	83.5	83.6	82.6	0	---	4.0	SW	1.00	7.0	SSW	83.5	78.7	78.7	29.935	0.00	0.00	0.000	0.193
10/08/24	10:15a	84.2	84.2	83.5	0	---	4.0	SW	1.00	8.0	W	84.2	79.3	79.3	29.937	0.00	0.00	0.000	0.200
10/08/24	10:30a	85.5	85.6	84.2	0	---	4.0	SW	1.00	7.0	W	85.5	80.4	80.4	29.933	0.00	0.00	0.000	0.214
10/08/24	10:45a	86.8	86.8	85.5	0	---	4.0	SW	1.00	7.0	WSW	86.8	81.4	81.4	29.932	0.00	0.00	0.000	0.227
10/08/24	11:00a	88.1	88.1	86.8	0	---	3.0	SW	0.75	10.0	SW	88.1	82.5	82.5	29.926	0.00	0.00	0.000	0.241
10/08/24	11:15a	89.0	89.0	88.1	0	---	3.0	SSW	0.75	9.0	W	89.0	83.2	83.2	29.928	0.00	0.00	0.000	0.250
10/08/24	11:30a	89.8	89.8	89.0	0	---	4.0	SW	1.00	8.0	WSW	89.8	83.8	83.8	29.923	0.00	0.00	0.000	0.258
10/08/24	11:45a	90.1	90.1	89.8	0	---	5.0	SW	1.25	11.0	WSW	90.1	84.1	84.1	29.920	0.00	0.00	0.000	0.261
10/08/24	12:00p	90.7	90.7	90.0	0	---	6.0	WSW	1.50	12.0	SSW	90.7	84.5	84.5	29.918	0.00	0.00	0.000	0.268
10/08/24	12:15p	91.7	91.7	90.7	0	---	6.0	W	1.50	14.0	WSW	91.7	85.3	85.3	29.911	0.00	0.00	0.000	0.278
10/08/24	12:30p	91.4	91.7	91.4	0	---	8.0	W	2.00	17.0	W	91.4	85.0	85.0	29.908	0.00	0.00	0.000	0.275

NKSP 10/08/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/08/24	12:45p	91.7	92.2	91.4	0	---	9.0	W	2.25	17.0	W	91.7	85.3	85.3	29.901	0.00	0.00	0.000	0.278
10/08/24	1:00p	92.7	92.7	91.7	0	---	8.0	W	2.00	15.0	W	92.7	86.0	86.0	29.899	0.00	0.00	0.000	0.289
10/08/24	1:15p	93.3	93.6	92.7	0	---	8.0	W	2.00	17.0	WSW	93.3	86.4	86.4	29.888	0.00	0.00	0.000	0.295
10/08/24	1:30p	93.5	93.5	93.1	0	---	8.0	W	2.00	15.0	W	93.5	86.6	86.6	29.883	0.00	0.00	0.000	0.297
10/08/24	1:45p	94.5	94.5	93.5	0	---	8.0	WSW	2.00	17.0	WNW	94.5	87.3	87.3	29.878	0.00	0.00	0.000	0.307
10/08/24	2:00p	94.5	95.1	94.3	0	---	9.0	W	2.25	15.0	WNW	94.5	87.3	87.3	29.866	0.00	0.00	0.000	0.307
10/08/24	2:15p	95.0	95.0	94.5	0	---	7.0	W	1.75	14.0	W	95.0	87.7	87.7	29.859	0.00	0.00	0.000	0.313
10/08/24	2:30p	95.5	95.7	95.1	0	---	7.0	W	1.75	14.0	SW	95.5	88.1	88.1	29.855	0.00	0.00	0.000	0.318
10/08/24	2:45p	96.2	96.4	95.4	0	---	7.0	W	1.75	12.0	N	96.2	88.6	88.6	29.848	0.00	0.00	0.000	0.325
10/08/24	3:00p	95.9	96.7	95.9	0	---	9.0	W	2.25	15.0	WSW	95.9	88.3	88.3	29.844	0.00	0.00	0.000	0.322
10/08/24	3:15p	96.9	97.0	96.0	0	---	9.0	WSW	2.25	17.0	WSW	96.9	89.1	89.1	29.844	0.00	0.00	0.000	0.332
10/08/24	3:30p	96.7	97.0	96.6	0	---	9.0	WSW	2.25	14.0	WSW	96.7	89.0	89.0	29.841	0.00	0.00	0.000	0.330
10/08/24	3:45p	97.1	97.3	96.7	0	---	7.0	W	1.75	14.0	W	97.1	89.3	89.3	29.840	0.00	0.00	0.000	0.334
10/08/24	4:00p	95.9	97.1	95.8	0	---	6.0	WNW	1.50	12.0	WNW	95.9	88.3	88.3	29.836	0.00	0.00	0.000	0.322
10/08/24	4:15p	95.5	95.9	95.4	0	---	6.0	WNW	1.50	11.0	W	95.5	88.1	88.1	29.836	0.00	0.00	0.000	0.318
10/08/24	4:30p	95.3	95.7	95.3	0	---	5.0	WNW	1.25	10.0	NNW	95.3	87.9	87.9	29.834	0.00	0.00	0.000	0.316
10/08/24	4:45p	94.9	95.4	94.9	0	---	6.0	NW	1.50	11.0	WNW	94.9	87.6	87.6	29.834	0.00	0.00	0.000	0.311
10/08/24	5:00p	94.1	94.9	94.1	0	---	6.0	NW	1.50	11.0	WNW	94.1	87.1	87.1	29.832	0.00	0.00	0.000	0.303
10/08/24	5:15p	94.0	94.2	93.9	0	---	4.0	NW	1.00	9.0	NW	94.0	87.0	87.0	29.838	0.00	0.00	0.000	0.302
10/08/24	5:30p	93.3	93.9	93.3	0	---	5.0	NW	1.25	8.0	WNW	93.3	86.4	86.4	29.838	0.00	0.00	0.000	0.295
10/08/24	5:45p	93.0	93.3	93.0	0	---	4.0	WNW	1.00	8.0	NW	93.0	86.2	86.2	29.841	0.00	0.00	0.000	0.292
10/08/24	6:00p	92.5	93.0	92.5	0	---	2.0	W	0.50	7.0	WNW	92.5	85.8	85.8	29.837	0.00	0.00	0.000	0.286
10/08/24	6:15p	91.2	92.5	91.2	0	---	3.0	WNW	0.75	6.0	WNW	91.2	84.9	84.9	29.836	0.00	0.00	0.000	0.273
10/08/24	6:30p	89.6	91.2	89.6	0	---	3.0	WNW	0.75	5.0	WNW	89.6	83.7	83.7	29.842	0.00	0.00	0.000	0.256
10/08/24	6:45p	88.8	89.6	88.8	0	---	2.0	WNW	0.50	4.0	WNW	88.8	83.0	83.0	29.842	0.00	0.00	0.000	0.248
10/08/24	7:00p	88.0	88.8	88.0	0	---	1.0	WNW	0.25	3.0	WNW	88.0	82.4	82.4	29.844	0.00	0.00	0.000	0.240
10/08/24	7:15p	86.9	88.0	86.8	0	---	1.0	WNW	0.25	3.0	WNW	86.9	81.5	81.5	29.847	0.00	0.00	0.000	0.228
10/08/24	7:30p	85.7	86.8	85.7	0	---	1.0	WNW	0.25	3.0	WNW	85.7	80.6	80.6	29.855	0.00	0.00	0.000	0.216
10/08/24	7:45p	85.7	85.9	85.7	0	---	1.0	WNW	0.25	2.0	WNW	85.7	80.6	80.6	29.856	0.00	0.00	0.000	0.216
10/08/24	8:00p	84.5	85.7	84.5	0	---	1.0	WNW	0.25	6.0	W	84.5	79.6	79.6	29.864	0.00	0.00	0.000	0.203
10/08/24	8:15p	83.3	84.5	83.3	0	---	4.0	N	1.00	6.0	W	83.3	78.5	78.5	29.869	0.00	0.00	0.000	0.191
10/08/24	8:30p	83.0	83.3	82.9	0	---	4.0	N	1.00	6.0	N	83.0	78.3	78.3	29.873	0.00	0.00	0.000	0.188
10/08/24	8:45p	82.6	83.1	82.5	0	---	4.0	W	1.00	7.0	W	82.6	77.9	77.9	29.878	0.00	0.00	0.000	0.183
10/08/24	9:00p	81.7	82.5	81.7	0	---	1.0	W	0.25	4.0	W	81.7	77.1	77.1	29.882	0.00	0.00	0.000	0.174
10/08/24	9:15p	79.9	81.7	79.9	0	---	1.0	W	0.25	3.0	W	79.9	75.4	75.4	29.890	0.00	0.00	0.000	0.155
10/08/24	9:30p	76.6	79.8	76.6	3	-10.1	1.0	E	0.25	5.0	E	76.6	72.2	72.2	29.898	0.00	0.00	0.000	0.121
10/08/24	9:45p	76.0	76.5	76.0	4	-4.6	1.0	ENE	0.25	3.0	ENE	76.0	71.3	71.3	29.902	0.00	0.00	0.000	0.115
10/08/24	10:00p	75.9	76.1	75.9	3	-10.6	1.0	ENE	0.25	2.0	ENE	75.9	71.3	71.3	29.910	0.00	0.00	0.000	0.114
10/08/24	10:15p	75.1	76.0	75.1	5	-0.6	1.0	E	0.25	3.0	E	75.1	70.9	70.9	29.912	0.00	0.00	0.000	0.105
10/08/24	10:30p	74.7	75.1	74.7	7	6.4	1.0	E	0.25	3.0	E	74.7	70.6	70.6	29.914	0.00	0.00	0.000	0.101
10/08/24	10:45p	74.0	74.7	74.0	7	5.9	1.0	E	0.25	3.0	E	74.0	69.6	69.6	29.915	0.00	0.00	0.000	0.094
10/08/24	11:00p	72.1	74.1	72.1	11	14.6	2.0	E	0.50	4.0	E	72.1	67.6	67.6	29.919	0.00	0.00	0.000	0.074
10/08/24	11:15p	72.0	72.0	71.6	12	16.6	1.0	ESE	0.25	3.0	ESE	72.0	67.5	67.5	29.922	0.00	0.00	0.000	0.073
10/08/24	11:30p	71.0	71.9	71.0	13	17.6	2.0	ESE	0.50	4.0	ESE	71.0	66.3	66.3	29.927	0.00	0.00	0.000	0.063
10/08/24	11:45p	70.8	71.0	70.6	16	22.3	2.0	ESE	0.50	6.0	ESE	70.8	66.3	66.3	29.929	0.00	0.00	0.000	0.060
10/09/24	12:00a	70.5	71.2	70.5	15	20.6	1.0	ESE	0.25	4.0	ESE	70.5	65.8	65.8	29.934	0.00	0.00	0.000	0.057

NKSP 10/09/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/09/24	12:15a	70.5	70.6	70.3	15	20.6	1.0	ESE	0.25	2.0	ESE	70.5	65.8	65.8	29.934	0.00	0.00	0.000	0.057
10/09/24	12:30a	70.2	70.6	70.1	15	20.3	1.0	ESE	0.25	3.0	ESE	70.2	65.3	65.3	29.935	0.00	0.00	0.000	0.054
10/09/24	12:45a	69.0	70.2	69.0	17	22.3	2.0	ESE	0.50	4.0	ESE	69.0	64.1	64.1	29.937	0.00	0.00	0.000	0.042
10/09/24	1:00a	68.3	69.0	68.3	19	24.4	3.0	ESE	0.75	6.0	ESE	68.3	63.6	63.6	29.936	0.00	0.00	0.000	0.034
10/09/24	1:15a	68.2	68.4	68.1	19	24.3	2.0	ESE	0.50	4.0	ESE	68.2	63.5	63.5	29.935	0.00	0.00	0.000	0.033
10/09/24	1:30a	68.1	68.3	68.1	18	23.0	3.0	ESE	0.75	6.0	ESE	68.1	63.3	63.3	29.945	0.00	0.00	0.000	0.032
10/09/24	1:45a	67.9	68.1	67.9	17	21.4	3.0	SE	0.75	5.0	SE	67.9	62.9	62.9	29.947	0.00	0.00	0.000	0.030
10/09/24	2:00a	67.4	67.9	67.4	17	21.0	3.0	SE	0.75	5.0	SE	67.4	62.3	62.3	29.950	0.00	0.00	0.000	0.025
10/09/24	2:15a	67.2	67.4	67.1	18	22.2	4.0	SE	1.00	7.0	SE	67.2	62.2	62.2	29.951	0.00	0.00	0.000	0.023
10/09/24	2:30a	66.5	67.2	66.4	18	21.6	3.0	ESE	0.75	8.0	SE	66.5	61.4	61.4	29.951	0.00	0.00	0.000	0.016
10/09/24	2:45a	66.3	66.9	66.3	18	21.5	4.0	SE	1.00	8.0	E	66.3	61.2	61.2	29.951	0.00	0.00	0.000	0.014
10/09/24	3:00a	65.2	66.3	65.2	22	25.4	4.0	SSE	1.00	7.0	SE	65.2	60.5	60.5	29.951	0.00	0.00	0.000	0.002
10/09/24	3:15a	65.2	65.5	65.2	22	25.4	3.0	SSE	0.75	5.0	SSE	65.2	60.5	60.5	29.949	0.00	0.00	0.000	0.002
10/09/24	3:30a	65.3	65.3	65.0	23	26.5	3.0	SSE	0.75	5.0	SSE	65.3	60.7	60.7	29.951	0.00	0.00	0.000	0.003
10/09/24	3:45a	65.1	65.5	65.1	22	25.3	2.0	SSE	0.50	4.0	SSE	65.1	60.5	60.5	29.951	0.00	0.00	0.000	0.001
10/09/24	4:00a	65.0	65.1	64.6	22	25.2	3.0	SSE	0.75	5.0	SE	65.0	60.4	60.4	29.955	0.00	0.00	0.000	0.000
10/09/24	4:15a	64.6	65.0	64.6	21	23.7	3.0	SE	0.75	5.0	SE	64.6	59.9	59.9	29.956	0.00	0.00	0.004	0.000
10/09/24	4:30a	64.6	64.8	64.5	20	22.6	4.0	SE	1.00	6.0	ESE	64.6	59.8	59.8	29.958	0.00	0.00	0.004	0.000
10/09/24	4:45a	64.6	64.6	64.4	20	22.6	4.0	ESE	1.00	6.0	ESE	64.6	59.8	59.8	29.965	0.00	0.00	0.004	0.000
10/09/24	5:00a	64.7	64.7	64.5	18	20.2	3.0	ESE	0.75	5.0	ESE	64.7	59.7	59.7	29.966	0.00	0.00	0.003	0.000
10/09/24	5:15a	65.0	65.1	64.6	18	20.4	3.0	SE	0.75	5.0	SE	65.0	60.0	60.0	29.967	0.00	0.00	0.000	0.000
10/09/24	5:30a	65.3	65.4	65.1	17	19.3	1.0	SE	0.25	3.0	SE	65.3	60.2	60.2	29.972	0.00	0.00	0.000	0.003
10/09/24	5:45a	65.6	65.6	65.3	17	19.6	2.0	SSE	0.50	4.0	SSE	65.6	60.5	60.5	29.976	0.00	0.00	0.000	0.006
10/09/24	6:00a	65.0	65.6	64.9	18	20.4	2.0	SSE	0.50	5.0	SSE	65.0	60.0	60.0	29.982	0.00	0.00	0.000	0.000
10/09/24	6:15a	65.1	65.4	64.9	17	19.2	2.0	SSE	0.50	4.0	SSE	65.1	60.0	60.0	29.987	0.00	0.00	0.000	0.001
10/09/24	6:30a	64.9	65.1	64.7	16	17.6	2.0	SSE	0.50	5.0	SSE	64.9	59.8	59.8	29.991	0.00	0.00	0.001	0.000
10/09/24	6:45a	64.3	65.0	64.3	16	17.1	3.0	SSE	0.75	5.0	SSE	64.3	59.2	59.2	29.996	0.00	0.00	0.007	0.000
10/09/24	7:00a	64.5	64.6	64.2	14	14.2	3.0	SE	0.75	4.0	SE	64.5	59.3	59.3	30.007	0.00	0.00	0.005	0.000
10/09/24	7:15a	64.0	64.6	64.0	15	15.4	4.0	SE	1.00	5.0	SE	64.0	58.8	58.8	30.005	0.00	0.00	0.010	0.000
10/09/24	7:30a	65.0	65.0	63.9	14	14.6	3.0	SSE	0.75	5.0	SE	65.0	59.8	59.8	30.013	0.00	0.00	0.000	0.000
10/09/24	7:45a	65.0	65.2	65.0	14	14.6	2.0	SSE	0.50	4.0	SSE	65.0	59.8	59.8	30.019	0.00	0.00	0.000	0.000
10/09/24	8:00a	66.1	66.1	64.9	13	13.8	2.0	SSE	0.50	3.0	SSE	66.1	60.8	60.8	30.023	0.00	0.00	0.000	0.011
10/09/24	8:15a	66.4	66.4	66.1	14	15.7	3.0	SE	0.75	4.0	SE	66.4	61.1	61.1	30.030	0.00	0.00	0.000	0.015
10/09/24	8:30a	68.3	68.3	66.4	13	15.5	2.0	SE	0.50	4.0	SE	68.3	62.9	62.9	30.031	0.00	0.00	0.000	0.034
10/09/24	8:45a	70.8	70.8	68.3	6	0.2	2.0	SSE	0.50	5.0	SSE	70.8	65.4	65.4	30.037	0.00	0.00	0.000	0.060
10/09/24	9:00a	73.6	73.6	70.8	0	---	2.0	S	0.50	6.0	S	73.6	68.5	68.5	30.037	0.00	0.00	0.000	0.090
10/09/24	9:15a	74.9	74.9	73.6	0	---	3.0	S	0.75	6.0	SSW	74.9	70.2	70.2	30.042	0.00	0.00	0.000	0.103
10/09/24	9:30a	76.0	76.0	74.9	0	---	2.0	SW	0.50	4.0	SSW	76.0	71.4	71.4	30.042	0.00	0.00	0.000	0.115
10/09/24	9:45a	77.3	77.3	76.1	0	---	2.0	SW	0.50	6.0	W	77.3	72.9	72.9	30.046	0.00	0.00	0.000	0.128
10/09/24	10:00a	78.6	78.6	77.3	0	---	2.0	WSW	0.50	5.0	WSW	78.6	74.1	74.1	30.045	0.00	0.00	0.000	0.142
10/09/24	10:15a	80.0	80.0	78.6	0	---	1.0	WSW	0.25	3.0	WSW	80.0	75.5	75.5	30.046	0.00	0.00	0.000	0.156
10/09/24	10:30a	82.5	82.5	80.1	0	---	2.0	SSW	0.50	7.0	SE	82.5	77.9	77.9	30.043	0.00	0.00	0.000	0.182
10/09/24	10:45a	83.1	83.1	82.4	0	---	2.0	SE	0.50	4.0	S	83.1	78.4	78.4	30.043	0.00	0.00	0.000	0.189
10/09/24	11:00a	84.0	84.1	83.1	0	---	2.0	N	0.50	6.0	W	84.0	79.1	79.1	30.040	0.00	0.00	0.000	0.198
10/09/24	11:15a	84.4	84.4	84.0	0	---	2.0	WNW	0.50	6.0	WNW	84.4	79.5	79.5	30.040	0.00	0.00	0.000	0.202
10/09/24	11:30a	84.7	84.8	84.3	0	---	3.0	NNW	0.75	8.0	NNW	84.7	79.7	79.7	30.037	0.00	0.00	0.000	0.205
10/09/24	11:45a	85.8	85.8	84.8	0	---	3.0	W	0.75	7.0	SW	85.8	80.6	80.6	30.033	0.00	0.00	0.000	0.217
10/09/24	12:00p	86.4	86.4	85.9	0	---	3.0	SW	0.75	7.0	WNW	86.4	81.1	81.1	30.025	0.00	0.00	0.000	0.223
10/09/24	12:15p	86.8	86.8	86.2	0	---	3.0	NNW	0.75	9.0	NNW	86.8	81.4	81.4	30.024	0.00	0.00	0.000	0.227
10/09/24	12:30p	87.1	87.2	86.7	0	---	4.0	NW	1.00	10.0	WNW	87.1	81.7	81.7	30.016	0.00	0.00	0.000	0.230

NKSP 10/09/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/09/24	12:45p	87.9	87.9	87.1	0	---	5.0	NW	1.25	11.0	WNW	87.9	82.3	82.3	30.012	0.00	0.00	0.000	0.239
10/09/24	1:00p	88.4	88.5	87.8	0	---	6.0	NW	1.50	10.0	W	88.4	82.7	82.7	30.008	0.00	0.00	0.000	0.244
10/09/24	1:15p	88.8	88.8	88.3	0	---	6.0	NW	1.50	13.0	NNW	88.8	83.0	83.0	30.003	0.00	0.00	0.000	0.248
10/09/24	1:30p	89.5	89.5	88.8	0	---	4.0	NW	1.00	9.0	NW	89.5	83.6	83.6	29.995	0.00	0.00	0.000	0.255
10/09/24	1:45p	90.3	90.4	89.5	0	---	4.0	NW	1.00	8.0	NW	90.3	84.2	84.2	29.988	0.00	0.00	0.000	0.264
10/09/24	2:00p	90.3	90.4	90.1	0	---	3.0	NW	0.75	10.0	NNW	90.3	84.2	84.2	29.985	0.00	0.00	0.000	0.264
10/09/24	2:15p	90.9	90.9	90.2	0	---	5.0	NW	1.25	10.0	NW	90.9	84.6	84.6	29.981	0.00	0.00	0.000	0.270
10/09/24	2:30p	91.4	91.5	90.8	0	---	4.0	NW	1.00	8.0	NW	91.4	85.0	85.0	29.974	0.00	0.00	0.000	0.275
10/09/24	2:45p	91.8	91.8	91.4	0	---	4.0	NW	1.00	9.0	WNW	91.8	85.3	85.3	29.970	0.00	0.00	0.000	0.279
10/09/24	3:00p	92.6	92.6	91.8	0	---	3.0	WNW	0.75	6.0	WNW	92.6	85.9	85.9	29.966	0.00	0.00	0.000	0.287
10/09/24	3:15p	93.1	93.2	92.6	0	---	5.0	WNW	1.25	10.0	W	93.1	86.3	86.3	29.965	0.00	0.00	0.000	0.293
10/09/24	3:30p	93.7	93.7	93.1	0	---	6.0	NW	1.50	11.0	NW	93.7	86.8	86.8	29.961	0.00	0.00	0.000	0.299
10/09/24	3:45p	93.7	93.8	93.6	0	---	5.0	NW	1.25	10.0	W	93.7	86.8	86.8	29.956	0.00	0.00	0.000	0.299
10/09/24	4:00p	93.7	93.8	93.6	0	---	4.0	NW	1.00	9.0	WNW	93.7	86.8	86.8	29.954	0.00	0.00	0.000	0.299
10/09/24	4:15p	94.0	94.1	93.7	0	---	4.0	NW	1.00	8.0	WNW	94.0	87.0	87.0	29.952	0.00	0.00	0.000	0.302
10/09/24	4:30p	94.6	94.7	94.0	0	---	4.0	W	1.00	9.0	NW	94.6	87.4	87.4	29.948	0.00	0.00	0.000	0.308
10/09/24	4:45p	94.5	94.7	94.4	0	---	4.0	WNW	1.00	8.0	W	94.5	87.3	87.3	29.948	0.00	0.00	0.000	0.307
10/09/24	5:00p	94.2	94.4	94.1	0	---	4.0	NW	1.00	8.0	WNW	94.2	87.1	87.1	29.949	0.00	0.00	0.000	0.304
10/09/24	5:15p	94.0	94.2	94.0	0	---	4.0	NW	1.00	8.0	WNW	94.0	87.0	87.0	29.948	0.00	0.00	0.000	0.302
10/09/24	5:30p	93.7	94.0	93.7	0	---	3.0	N	0.75	5.0	NW	93.7	86.8	86.8	29.947	0.00	0.00	0.000	0.299
10/09/24	5:45p	93.2	93.7	93.2	0	---	3.0	N	0.75	4.0	NNE	93.2	86.4	86.4	29.950	0.00	0.00	0.000	0.294
10/09/24	6:00p	92.3	93.2	92.3	0	---	2.0	N	0.50	4.0	N	92.3	85.7	85.7	29.952	0.00	0.00	0.000	0.284
10/09/24	6:15p	91.3	92.3	91.3	0	---	2.0	NE	0.50	3.0	N	91.3	84.9	84.9	29.952	0.00	0.00	0.000	0.274
10/09/24	6:30p	90.3	91.3	90.3	0	---	1.0	N	0.25	3.0	N	90.3	84.2	84.2	29.953	0.00	0.00	0.000	0.264
10/09/24	6:45p	89.2	90.3	89.2	0	---	1.0	N	0.25	2.0	NNE	89.2	83.4	83.4	29.957	0.00	0.00	0.000	0.252
10/09/24	7:00p	87.4	89.2	87.4	0	---	1.0	N	0.25	3.0	N	87.4	81.9	81.9	29.962	0.00	0.00	0.000	0.233
10/09/24	7:15p	86.7	87.4	86.7	0	---	1.0	NNE	0.25	2.0	NNE	86.7	81.4	81.4	29.966	0.00	0.00	0.000	0.226
10/09/24	7:30p	85.9	86.7	85.9	0	---	0.0	N	0.00	1.0	N	85.9	80.7	80.7	29.971	0.00	0.00	0.000	0.218
10/09/24	7:45p	84.6	85.9	84.6	0	---	1.0	ESE	0.25	4.0	ESE	84.6	79.6	79.6	29.978	0.00	0.00	0.000	0.204
10/09/24	8:00p	82.7	84.6	82.6	0	---	0.0	ESE	0.00	1.0	ESE	82.7	78.0	78.0	29.983	0.00	0.00	0.000	0.184
10/09/24	8:15p	82.7	82.7	82.5	0	---	0.0	ESE	0.00	2.0	ESE	82.7	78.0	78.0	29.989	0.00	0.00	0.000	0.184
10/09/24	8:30p	82.0	82.7	82.0	0	---	1.0	ESE	0.25	3.0	SW	82.0	77.4	77.4	29.992	0.00	0.00	0.000	0.177
10/09/24	8:45p	80.1	82.0	80.0	0	---	1.0	WSW	0.25	4.0	WSW	80.1	75.6	75.6	29.995	0.00	0.00	0.000	0.157
10/09/24	9:00p	79.1	80.1	79.1	0	---	1.0	WSW	0.25	4.0	S	79.1	74.6	74.6	30.001	0.00	0.00	0.000	0.147
10/09/24	9:15p	77.3	79.1	77.3	1	-30.8	2.0	SSE	0.50	4.0	S	77.3	72.9	72.9	30.007	0.00	0.00	0.000	0.128
10/09/24	9:30p	76.7	77.3	76.7	3	-10.1	1.0	SE	0.25	4.0	SE	76.7	72.3	72.3	30.011	0.00	0.00	0.000	0.122
10/09/24	9:45p	76.2	76.7	76.1	3	-10.4	2.0	SE	0.50	4.0	SE	76.2	71.6	71.6	30.014	0.00	0.00	0.000	0.117
10/09/24	10:00p	75.9	76.3	75.6	5	0.0	2.0	SE	0.50	4.0	SE	75.9	71.3	71.3	30.016	0.00	0.00	0.000	0.114
10/09/24	10:15p	75.2	75.9	75.1	6	3.4	1.0	SE	0.25	3.0	SE	75.2	71.1	71.1	30.025	0.00	0.00	0.000	0.106
10/09/24	10:30p	75.0	75.3	75.0	6	3.3	1.0	SE	0.25	3.0	SE	75.0	71.0	71.0	30.027	0.00	0.00	0.000	0.104
10/09/24	10:45p	74.6	75.1	74.6	7	6.4	2.0	SE	0.50	3.0	SE	74.6	70.5	70.5	30.028	0.00	0.00	0.000	0.100
10/09/24	11:00p	72.6	74.6	72.6	11	15.0	2.0	SE	0.50	5.0	SE	72.6	68.3	68.3	30.031	0.00	0.00	0.000	0.079
10/09/24	11:15p	70.9	72.7	70.9	13	17.5	2.0	SE	0.50	3.0	SE	70.9	66.2	66.2	30.032	0.00	0.00	0.000	0.061
10/09/24	11:30p	70.3	70.9	70.3	7	3.2	4.0	WSW	1.00	7.0	W	70.3	64.7	64.7	30.036	0.00	0.00	0.000	0.055
10/09/24	11:45p	68.6	70.3	68.6	7	1.9	5.0	W	1.25	8.0	W	68.6	62.5	62.5	30.042	0.00	0.00	0.000	0.037
10/10/24	12:00a	68.3	68.6	68.2	6	-1.6	5.0	W	1.25	9.0	WNW	68.3	62.0	62.0	30.044	0.00	0.00	0.000	0.034

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/08/24	12:15a	77.9	47	56.0	77.5	8.69	.0726	350	1	100.0	15
10/08/24	12:30a	77.9	52	58.9	78.0	9.49	.0725	351	1	100.0	15
10/08/24	12:45a	77.5	51	57.9	77.5	9.35	.0726	352	1	100.0	15
10/08/24	1:00a	77.7	49	57.0	77.5	9.00	.0726	351	1	100.0	15
10/08/24	1:15a	77.4	53	58.9	77.5	9.65	.0726	351	1	100.0	15
10/08/24	1:30a	77.5	48	56.3	77.2	8.90	.0727	351	1	100.0	15
10/08/24	1:45a	77.4	53	58.9	77.5	9.65	.0726	352	1	100.0	15
10/08/24	2:00a	77.4	50	57.3	77.3	9.20	.0726	351	1	100.0	15
10/08/24	2:15a	77.6	48	56.4	77.3	8.90	.0726	351	1	100.0	15
10/08/24	2:30a	77.7	50	57.6	77.7	9.20	.0726	351	1	100.0	15
10/08/24	2:45a	77.6	51	58.0	77.6	9.35	.0726	351	1	100.0	15
10/08/24	3:00a	77.3	49	56.6	77.1	9.00	.0726	352	1	100.0	15
10/08/24	3:15a	77.4	47	55.6	77.0	8.70	.0727	351	1	100.0	15
10/08/24	3:30a	77.6	50	57.5	77.6	9.20	.0726	351	1	100.0	15
10/08/24	3:45a	77.3	51	57.8	77.3	9.35	.0726	351	1	100.0	15
10/08/24	4:00a	77.2	49	56.6	77.0	9.01	.0727	352	1	100.0	15
10/08/24	4:15a	77.4	49	56.7	77.2	9.00	.0726	351	1	100.0	15
10/08/24	4:30a	77.3	52	58.3	77.3	9.50	.0726	351	1	100.0	15
10/08/24	4:45a	77.0	51	57.5	77.0	9.35	.0727	351	1	100.0	15
10/08/24	5:00a	77.4	51	57.9	77.4	9.35	.0726	352	1	100.0	15
10/08/24	5:15a	77.0	52	58.0	77.0	9.51	.0726	351	1	100.0	15
10/08/24	5:30a	77.0	49	56.4	76.8	9.01	.0727	351	1	100.0	15
10/08/24	5:45a	77.3	53	58.8	77.4	9.65	.0726	351	1	100.0	15
10/08/24	6:00a	77.0	51	57.5	77.0	9.35	.0727	351	1	100.0	15
10/08/24	6:15a	77.4	50	57.3	77.3	9.20	.0726	352	1	100.0	15
10/08/24	6:30a	77.3	53	58.8	77.4	9.65	.0726	351	1	100.0	15
10/08/24	6:45a	77.3	48	56.1	77.0	8.90	.0727	351	1	100.0	15
10/08/24	7:00a	77.2	53	58.7	77.3	9.65	.0726	351	1	100.0	15
10/08/24	7:15a	77.0	50	56.9	76.9	9.21	.0727	352	1	100.0	15
10/08/24	7:30a	77.0	53	58.6	77.1	9.65	.0727	351	1	100.0	15
10/08/24	7:45a	76.8	51	57.3	76.8	9.35	.0727	351	1	100.0	15
10/08/24	8:00a	77.1	52	58.1	77.1	9.51	.0727	351	1	100.0	15
10/08/24	8:15a	76.9	51	57.4	76.9	9.35	.0727	352	1	100.0	15
10/08/24	8:30a	77.4	49	56.7	77.2	9.00	.0727	351	1	100.0	15
10/08/24	8:45a	77.3	52	58.3	77.3	9.50	.0727	351	1	100.0	15
10/08/24	9:00a	77.4	49	56.7	77.2	9.00	.0727	351	1	100.0	15
10/08/24	9:15a	77.8	50	57.7	77.8	9.19	.0727	351	1	100.0	15
10/08/24	9:30a	77.7	51	58.1	77.7	9.35	.0727	352	1	100.0	15
10/08/24	9:45a	77.9	47	56.0	77.5	8.69	.0727	351	1	100.0	15
10/08/24	10:00a	78.3	49	57.6	78.2	8.98	.0726	351	1	100.0	15
10/08/24	10:15a	78.2	50	58.0	78.2	9.19	.0726	351	1	100.0	15
10/08/24	10:30a	78.4	46	55.9	77.9	8.48	.0727	352	1	100.0	15
10/08/24	10:45a	78.9	47	57.0	78.5	8.67	.0726	351	1	100.0	15
10/08/24	11:00a	78.9	49	58.1	78.8	8.97	.0725	351	1	100.0	15
10/08/24	11:15a	79.0	44	55.2	78.3	8.17	.0726	351	1	100.0	15
10/08/24	11:30a	79.3	45	56.1	78.7	8.36	.0725	351	1	100.0	15
10/08/24	11:45a	79.2	46	56.6	78.7	8.47	.0725	352	1	100.0	15
10/08/24	12:00p	79.3	41	53.6	78.2	7.75	.0726	351	1	100.0	15
10/08/24	12:15p	79.6	43	55.1	78.7	8.05	.0725	351	1	100.0	15
10/08/24	12:30p	79.5	40	53.1	78.3	7.56	.0726	351	1	100.0	15

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/08/24	12:45p	79.9	40	53.4	78.6	7.55	.0725	352	1	100.0	15
10/08/24	1:00p	79.7	38	51.8	78.3	7.26	.0726	351	1	100.0	15
10/08/24	1:15p	79.7	37	51.1	78.2	7.16	.0726	351	1	100.0	15
10/08/24	1:30p	79.6	36	50.3	78.0	6.96	.0726	351	1	100.0	15
10/08/24	1:45p	79.8	36	50.5	78.2	6.95	.0726	352	1	100.0	15
10/08/24	2:00p	80.1	36	50.7	78.5	6.95	.0725	351	1	100.0	15
10/08/24	2:15p	80.3	36	50.9	78.7	6.94	.0724	351	1	100.0	15
10/08/24	2:30p	80.3	35	50.1	78.6	6.84	.0724	351	1	100.0	15
10/08/24	2:45p	80.2	35	50.1	78.5	6.84	.0724	351	1	100.0	15
10/08/24	3:00p	80.4	35	50.2	78.7	6.83	.0724	352	1	100.0	15
10/08/24	3:15p	80.7	35	50.5	79.0	6.82	.0723	351	1	100.0	15
10/08/24	3:30p	80.7	34	49.7	78.9	6.62	.0724	351	1	100.0	15
10/08/24	3:45p	80.7	35	50.5	79.0	6.82	.0723	351	1	100.0	15
10/08/24	4:00p	80.8	35	50.6	79.1	6.82	.0723	352	1	100.0	15
10/08/24	4:15p	80.8	35	50.6	79.1	6.82	.0723	351	1	100.0	15
10/08/24	4:30p	80.7	35	50.5	79.0	6.82	.0723	351	1	100.0	15
10/08/24	4:45p	80.7	35	50.5	79.0	6.82	.0723	351	1	100.0	15
10/08/24	5:00p	80.6	35	50.4	78.9	6.83	.0723	352	1	100.0	15
10/08/24	5:15p	80.8	38	52.8	79.4	7.25	.0722	351	1	100.0	15
10/08/24	5:30p	80.9	36	51.4	79.3	6.91	.0723	351	1	100.0	15
10/08/24	5:45p	80.6	35	50.4	78.9	6.83	.0724	351	1	100.0	15
10/08/24	6:00p	80.1	35	50.0	78.4	6.85	.0724	351	1	100.0	15
10/08/24	6:15p	79.7	36	50.4	78.1	6.96	.0725	352	1	100.0	15
10/08/24	6:30p	80.0	37	51.4	78.5	7.15	.0724	351	1	100.0	15
10/08/24	6:45p	80.1	41	54.3	78.9	7.75	.0723	351	1	100.0	15
10/08/24	7:00p	80.0	41	54.2	78.8	7.75	.0723	351	1	100.0	15
10/08/24	7:15p	80.0	40	53.5	78.7	7.55	.0723	352	1	100.0	15
10/08/24	7:30p	80.0	40	53.5	78.7	7.55	.0724	351	1	100.0	15
10/08/24	7:45p	80.0	43	55.5	79.1	8.05	.0723	351	1	100.0	15
10/08/24	8:00p	79.7	43	55.2	78.8	8.05	.0724	351	1	100.0	15
10/08/24	8:15p	79.5	41	53.7	78.4	7.75	.0725	352	1	100.0	15
10/08/24	8:30p	79.6	41	53.8	78.5	7.75	.0724	351	1	100.0	15
10/08/24	8:45p	79.5	44	55.7	78.8	8.16	.0724	351	1	100.0	15
10/08/24	9:00p	79.2	45	56.0	78.6	8.37	.0724	351	1	100.0	15
10/08/24	9:15p	79.0	43	54.6	78.2	8.05	.0725	351	1	100.0	15
10/08/24	9:30p	79.0	42	53.9	78.0	7.87	.0726	352	1	100.0	15
10/08/24	9:45p	79.0	45	55.8	78.4	8.37	.0725	351	1	100.0	15
10/08/24	10:00p	78.9	47	57.0	78.5	8.67	.0725	351	1	100.0	15
10/08/24	10:15p	78.7	46	56.2	78.2	8.49	.0726	351	1	100.0	15
10/08/24	10:30p	78.5	45	55.4	77.9	8.38	.0726	352	1	100.0	15
10/08/24	10:45p	78.5	46	56.0	78.0	8.48	.0726	351	1	100.0	15
10/08/24	11:00p	78.4	49	57.7	78.3	8.98	.0726	351	1	100.0	15
10/08/24	11:15p	78.2	48	56.9	77.9	8.89	.0726	351	1	100.0	15
10/08/24	11:30p	78.2	46	55.7	77.7	8.49	.0727	352	1	100.0	15
10/08/24	11:45p	78.3	49	57.6	78.2	8.98	.0726	351	1	100.0	15
10/09/24	12:00a	78.0	50	57.9	78.0	9.19	.0727	352	1	100.0	15

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/09/24	12:15a	78.0	48	56.7	77.7	8.89	.0727	349	1	100.0	15
10/09/24	12:30a	78.1	48	56.8	77.8	8.89	.0727	352	1	100.0	15
10/09/24	12:45a	77.9	51	58.3	77.9	9.35	.0727	351	1	100.0	15
10/09/24	1:00a	77.6	49	56.9	77.4	9.00	.0727	351	1	100.0	15
10/09/24	1:15a	77.6	53	59.1	77.7	9.65	.0727	351	1	100.0	15
10/09/24	1:30a	77.2	51	57.7	77.2	9.35	.0728	352	1	100.0	15
10/09/24	1:45a	77.4	50	57.3	77.3	9.20	.0728	351	1	100.0	15
10/09/24	2:00a	77.1	52	58.1	77.1	9.51	.0728	351	1	100.0	15
10/09/24	2:15a	77.2	49	56.6	77.0	9.01	.0729	351	1	100.0	15
10/09/24	2:30a	77.1	52	58.1	77.1	9.51	.0728	352	1	100.0	15
10/09/24	2:45a	76.9	50	56.8	76.8	9.21	.0729	351	1	100.0	15
10/09/24	3:00a	77.1	52	58.1	77.1	9.51	.0728	351	1	100.0	15
10/09/24	3:15a	76.7	52	57.7	76.7	9.52	.0729	351	1	100.0	15
10/09/24	3:30a	77.0	50	56.9	76.9	9.21	.0729	351	1	100.0	15
10/09/24	3:45a	76.6	52	57.7	76.6	9.52	.0729	352	1	100.0	15
10/09/24	4:00a	76.8	48	55.6	76.5	8.91	.0730	351	1	100.0	15
10/09/24	4:15a	76.7	52	57.7	76.7	9.52	.0729	351	1	100.0	15
10/09/24	4:30a	76.6	50	56.6	76.5	9.22	.0730	351	1	100.0	15
10/09/24	4:45a	76.6	52	57.7	76.6	9.52	.0729	352	1	100.0	15
10/09/24	5:00a	76.4	51	56.9	76.4	9.35	.0730	351	1	100.0	15
10/09/24	5:15a	76.7	50	56.7	76.6	9.22	.0730	351	1	100.0	15
10/09/24	5:30a	76.4	51	56.9	76.4	9.35	.0730	351	1	100.0	15
10/09/24	5:45a	76.8	48	55.6	76.5	8.91	.0730	351	1	100.0	15
10/09/24	6:00a	76.8	51	57.3	76.8	9.35	.0730	352	1	100.0	15
10/09/24	6:15a	76.7	50	56.7	76.6	9.22	.0730	351	1	100.0	15
10/09/24	6:30a	76.9	49	56.3	76.7	9.01	.0730	351	1	100.0	15
10/09/24	6:45a	76.6	51	57.1	76.6	9.35	.0730	351	1	100.0	15
10/09/24	7:00a	75.9	47	54.2	75.5	8.73	.0733	352	1	100.0	15
10/09/24	7:15a	75.2	53	56.9	75.3	9.65	.0732	351	1	100.0	15
10/09/24	7:30a	75.2	47	53.6	74.8	8.75	.0734	351	1	100.0	15
10/09/24	7:45a	74.8	53	56.5	74.9	9.66	.0734	351	1	100.0	15
10/09/24	8:00a	74.9	49	54.4	74.7	9.05	.0734	352	1	100.0	15
10/09/24	8:15a	75.0	53	56.7	75.1	9.65	.0733	351	1	100.0	15
10/09/24	8:30a	74.8	51	55.5	74.7	9.35	.0734	351	1	100.0	15
10/09/24	8:45a	75.4	52	56.5	75.4	9.54	.0733	351	1	100.0	15
10/09/24	9:00a	74.9	53	56.6	75.0	9.65	.0734	351	1	100.0	15
10/09/24	9:15a	75.5	48	54.4	75.2	8.94	.0734	352	1	100.0	15
10/09/24	9:30a	75.2	52	56.4	75.2	9.55	.0734	351	1	100.0	15
10/09/24	9:45a	75.3	48	54.3	75.0	8.94	.0734	351	1	100.0	15
10/09/24	10:00a	75.7	51	56.3	75.7	9.35	.0733	351	1	100.0	15
10/09/24	10:15a	75.4	50	55.5	75.3	9.24	.0734	352	1	100.0	15
10/09/24	10:30a	76.0	46	53.7	75.5	8.53	.0734	351	1	100.0	15
10/09/24	10:45a	76.0	50	56.0	75.9	9.23	.0733	351	1	100.0	15
10/09/24	11:00a	75.9	47	54.2	75.5	8.73	.0733	352	1	100.0	15
10/09/24	11:15a	76.8	47	55.0	76.4	8.71	.0732	351	1	100.0	15
10/09/24	11:30a	76.6	49	56.0	76.4	9.02	.0732	351	1	100.0	15
10/09/24	11:45a	76.9	43	52.7	76.1	8.05	.0732	351	1	100.0	15
10/09/24	12:00p	77.3	46	54.9	76.8	8.50	.0731	351	1	100.0	15
10/09/24	12:15p	76.7	46	54.4	76.2	8.52	.0732	351	1	100.0	15
10/09/24	12:30p	77.2	43	53.0	76.4	8.05	.0732	352	1	100.0	15

NKSP 10/09/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/09/24	12:45p	77.1	46	54.7	76.6	8.51	.0731	351	1	100.0	15
10/09/24	1:00p	76.8	43	52.6	76.0	8.05	.0732	351	1	100.0	15
10/09/24	1:15p	77.3	41	51.8	76.3	7.75	.0732	351	1	100.0	15
10/09/24	1:30p	77.0	45	54.0	76.4	8.41	.0731	352	1	100.0	15
10/09/24	1:45p	77.1	40	50.9	76.0	7.61	.0732	351	1	100.0	15
10/09/24	2:00p	77.1	44	53.5	76.4	8.21	.0731	351	1	100.0	15
10/09/24	2:15p	77.2	40	51.0	76.1	7.61	.0731	351	1	100.0	15
10/09/24	2:30p	78.2	42	53.2	77.2	7.89	.0729	352	1	100.0	15
10/09/24	2:45p	79.2	42	54.1	78.2	7.87	.0727	351	1	100.0	15
10/09/24	3:00p	79.7	38	51.8	78.3	7.26	.0727	351	1	100.0	15
10/09/24	3:15p	79.7	37	51.1	78.2	7.16	.0728	351	1	100.0	15
10/09/24	3:30p	80.1	38	52.2	78.6	7.25	.0727	351	1	100.0	15
10/09/24	3:45p	80.0	37	51.4	78.5	7.15	.0727	352	1	100.0	15
10/09/24	4:00p	79.9	38	52.0	78.5	7.25	.0727	351	1	100.0	15
10/09/24	4:15p	80.2	37	51.6	78.7	7.15	.0726	351	1	100.0	15
10/09/24	4:30p	80.4	38	52.5	79.0	7.25	.0726	351	1	100.0	15
10/09/24	4:45p	80.3	36	50.9	78.7	6.94	.0726	352	1	100.0	15
10/09/24	5:00p	80.5	38	52.6	79.1	7.25	.0726	351	1	100.0	15
10/09/24	5:15p	80.4	39	53.2	79.1	7.44	.0725	351	1	100.0	15
10/09/24	5:30p	80.3	37	51.7	78.8	7.14	.0726	351	1	100.0	15
10/09/24	5:45p	80.3	38	52.4	78.9	7.25	.0726	351	1	100.0	15
10/09/24	6:00p	80.3	40	53.8	79.0	7.55	.0725	352	1	100.0	15
10/09/24	6:15p	80.2	41	54.4	79.1	7.75	.0725	351	1	100.0	15
10/09/24	6:30p	80.0	38	52.1	78.5	7.25	.0727	351	1	100.0	15
10/09/24	6:45p	80.0	39	52.8	78.6	7.45	.0726	351	1	100.0	15
10/09/24	7:00p	80.0	41	54.2	78.8	7.75	.0726	352	1	100.0	15
10/09/24	7:15p	79.8	43	55.3	78.9	8.05	.0726	351	1	100.0	15
10/09/24	7:30p	79.6	42	54.5	78.6	7.86	.0727	351	1	100.0	15
10/09/24	7:45p	79.5	40	53.1	78.3	7.56	.0727	351	1	100.0	15
10/09/24	8:00p	79.5	42	54.4	78.5	7.86	.0727	352	1	100.0	15
10/09/24	8:15p	79.2	45	56.0	78.6	8.37	.0727	351	1	100.0	15
10/09/24	8:30p	79.0	44	55.2	78.3	8.17	.0728	351	1	100.0	15
10/09/24	8:45p	78.8	41	53.1	77.7	7.75	.0729	351	1	100.0	15
10/09/24	9:00p	78.9	44	55.1	78.2	8.17	.0728	352	1	100.0	15
10/09/24	9:15p	78.7	47	56.8	78.3	8.68	.0728	351	1	100.0	15
10/09/24	9:30p	78.5	46	56.0	78.0	8.48	.0729	351	1	100.0	15
10/09/24	9:45p	78.4	43	54.0	77.5	8.05	.0729	351	1	100.0	15
10/09/24	10:00p	78.4	45	55.3	77.7	8.38	.0729	351	1	100.0	15
10/09/24	10:15p	78.3	48	57.0	78.0	8.88	.0729	352	1	100.0	15
10/09/24	10:30p	78.0	49	57.3	77.9	8.99	.0729	351	1	100.0	15
10/09/24	10:45p	77.7	47	55.9	77.3	8.70	.0730	351	1	100.0	15
10/09/24	11:00p	77.9	46	55.5	77.3	8.49	.0730	351	1	100.0	15
10/09/24	11:15p	77.6	50	57.5	77.6	9.20	.0730	352	1	100.0	15
10/09/24	11:30p	77.5	49	56.8	77.3	9.00	.0730	351	1	100.0	15
10/09/24	11:45p	77.6	46	55.2	77.1	8.50	.0731	351	1	100.0	15
10/10/24	12:00a	77.3	50	57.2	77.2	9.20	.0730	351	1	100.0	15

STATE OF CALIFORNIA
DEPARTMENT OF CORRECTIONS AND REHABILITATION

OUTSIDE TEMPERATURE RECORD

CDCR 2030 (04/18)

INSTITUTION: Kern Valley State Prison

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the OUTSIDE ambient air temperature.

Using an accurate thermometer located in a central, heat neutral location, the outside air temperature is to be taken every hour, seven (7) days a week.

Thermometer Location: Control Center Rear Door

Immediately notify the Watch Commander at extension 3141 when the air temperature reaches 90 degrees.

Date	Time	Temp.	Printed Name
10/10/24	0100	68	Padilla
	0200	66	Padilla
	0300	66	Padilla
	0400	65	Padilla
	0500	63	Padilla
	0600	63	L Martinez
	0700	63	L Martinez
	0800	66	L Martinez
	0900	72	L Martinez
	1000	77	L Martinez
	1100	79	L Martinez
	1200	82	L Martinez
	1300	85	L Martinez
	1400	88	Renkoff
	1500	89.5	Renkoff
	1600	89.2	Renkoff
	1700	88.5	Renkoff
	1800	85.9	Renkoff
	1900	82.3	Renkoff
	2000	80.3	Renkoff
	2100	77.3	Renkoff
	2200	73	Padilla
	2300	73	Padilla
	2400	69	Padilla

Date	Time	Temp.	Printed Name
10/11/24	0100	66	Padilla
	0200	64	Padilla
	0300	64	Padilla
	0400	62	Padilla
	0500	60	Padilla
	0600	59	Gonzalez
	0700	57	Gonzalez
	0800	59	Gonzalez
	0900	67	Gonzalez
	1000	74	Gonzalez
	1100	78	Gonzalez
	1200	82	Gonzalez
	1300	83	Gonzalez
	1400	85	Gonzalez
	1500	85	Gonzalez
	1600	87	Gonzalez
	1700	88	Gonzalez
	1800	86	Gonzalez
	1900	83	Gonzalez
	2000	76	Gonzalez
	2100	74	Gonzalez
	2200	72	J. Fierro
	2300	72	J. Fierro
	2400	69	J. Fierro

DISTRIBUTION: Original: Institution Heat Plan Coordinator

NKSP 10/10/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/10/24	12:15a	67.8	68.3	67.7	7	1.4	5.0	WNW	1.25	8.0	WNW	67.8	61.5	61.5	30.046	0.00	0.00	0.000	0.029
10/10/24	12:30a	67.8	68.1	67.8	7	1.4	4.0	WNW	1.00	7.0	W	67.8	61.5	61.5	30.047	0.00	0.00	0.000	0.029
10/10/24	12:45a	68.6	68.6	67.8	5	-5.2	3.0	WNW	0.75	6.0	WNW	68.6	62.3	62.3	30.050	0.00	0.00	0.000	0.037
10/10/24	1:00a	68.5	69.0	68.5	4	-9.8	2.0	WNW	0.50	4.0	WNW	68.5	62.0	62.0	30.054	0.00	0.00	0.000	0.036
10/10/24	1:15a	68.7	68.7	68.3	4	-9.7	1.0	WNW	0.25	4.0	S	68.7	62.3	62.3	30.051	0.00	0.00	0.000	0.039
10/10/24	1:30a	68.2	68.7	68.2	5	-5.5	1.0	S	0.25	3.0	S	68.2	61.7	61.7	30.054	0.00	0.00	0.000	0.033
10/10/24	1:45a	67.2	68.3	67.2	6	-2.4	2.0	SSE	0.50	5.0	SSE	67.2	60.8	60.8	30.053	0.00	0.00	0.000	0.023
10/10/24	2:00a	66.2	67.2	66.2	10	7.9	2.0	SSE	0.50	4.0	SSE	66.2	60.9	60.9	30.056	0.00	0.00	0.000	0.012
10/10/24	2:15a	65.0	66.3	65.0	12	11.1	3.0	SE	0.75	6.0	S	65.0	59.8	59.8	30.057	0.00	0.00	0.000	0.000
10/10/24	2:30a	64.8	65.0	64.6	13	12.7	3.0	S	0.75	4.0	S	64.8	59.6	59.6	30.052	0.00	0.00	0.002	0.000
10/10/24	2:45a	65.9	65.9	64.8	10	7.7	2.0	SW	0.50	4.0	SSW	65.9	60.6	60.6	30.052	0.00	0.00	0.000	0.009
10/10/24	3:00a	66.0	66.2	65.9	10	7.8	3.0	SW	0.75	4.0	SW	66.0	60.7	60.7	30.050	0.00	0.00	0.000	0.010
10/10/24	3:15a	66.2	66.3	65.8	10	7.9	3.0	SW	0.75	5.0	SW	66.2	60.9	60.9	30.048	0.00	0.00	0.000	0.012
10/10/24	3:30a	67.0	67.1	66.2	9	6.2	3.0	SW	0.75	6.0	SW	67.0	61.4	61.4	30.044	0.00	0.00	0.000	0.021
10/10/24	3:45a	66.5	67.0	66.5	9	5.8	4.0	WSW	1.00	6.0	SW	66.5	61.0	61.0	30.050	0.00	0.00	0.000	0.016
10/10/24	4:00a	65.6	66.5	65.6	11	9.6	2.0	SW	0.50	4.0	SW	65.6	60.3	60.3	30.051	0.00	0.00	0.000	0.006
10/10/24	4:15a	64.8	65.6	64.8	13	12.7	3.0	SE	0.75	7.0	ESE	64.8	59.6	59.6	30.055	0.00	0.00	0.002	0.000
10/10/24	4:30a	63.5	64.7	63.5	17	17.8	3.0	SE	0.75	7.0	SE	63.5	58.5	58.5	30.058	0.00	0.00	0.016	0.000
10/10/24	4:45a	63.6	63.6	63.3	18	19.3	3.0	SE	0.75	5.0	SE	63.6	58.7	58.7	30.056	0.00	0.00	0.015	0.000
10/10/24	5:00a	63.4	63.8	63.4	18	19.1	4.0	SE	1.00	8.0	SE	63.4	58.5	58.5	30.059	0.00	0.00	0.017	0.000
10/10/24	5:15a	63.6	63.6	63.3	19	20.5	4.0	SE	1.00	9.0	SE	63.6	58.8	58.8	30.065	0.00	0.00	0.015	0.000
10/10/24	5:30a	63.3	63.6	63.3	19	20.3	3.0	SE	0.75	7.0	SE	63.3	58.5	58.5	30.062	0.00	0.00	0.018	0.000
10/10/24	5:45a	62.9	63.4	62.9	19	20.0	2.0	SE	0.50	5.0	SE	62.9	58.1	58.1	30.065	0.00	0.00	0.022	0.000
10/10/24	6:00a	63.1	63.1	62.7	20	21.3	3.0	SE	0.75	5.0	SE	63.1	58.4	58.4	30.065	0.00	0.00	0.020	0.000
10/10/24	6:15a	62.9	63.3	62.9	20	21.2	3.0	SE	0.75	5.0	SE	62.9	58.2	58.2	30.066	0.00	0.00	0.022	0.000
10/10/24	6:30a	63.1	63.2	62.8	19	20.1	3.0	SE	0.75	4.0	SE	63.1	58.3	58.3	30.068	0.00	0.00	0.020	0.000
10/10/24	6:45a	63.1	63.3	63.0	18	18.9	3.0	S	0.75	6.0	S	63.1	58.2	58.2	30.077	0.00	0.00	0.020	0.000
10/10/24	7:00a	63.5	63.5	63.0	16	16.4	3.0	S	0.75	5.0	S	63.5	58.4	58.4	30.084	0.00	0.00	0.016	0.000
10/10/24	7:15a	64.0	64.0	63.5	15	15.4	3.0	S	0.75	6.0	S	64.0	58.8	58.8	30.087	0.00	0.00	0.010	0.000
10/10/24	7:30a	64.2	64.3	64.1	14	13.9	1.0	S	0.25	4.0	S	64.2	59.0	59.0	30.089	0.00	0.00	0.008	0.000
10/10/24	7:45a	64.9	64.9	64.2	13	12.8	0.0	S	0.00	2.0	S	64.9	59.7	59.7	30.091	0.00	0.00	0.001	0.000
10/10/24	8:00a	66.3	66.3	64.9	11	10.1	0.0	---	0.00	0.0	---	66.3	61.0	61.0	30.094	0.00	0.00	0.000	0.014
10/10/24	8:15a	68.7	68.7	66.3	7	2.0	0.0	---	0.00	0.0	---	68.7	62.7	62.7	30.098	0.00	0.00	0.000	0.039
10/10/24	8:30a	69.9	69.9	68.7	6	-0.4	1.0	SE	0.25	4.0	SSE	69.9	64.0	64.0	30.101	0.00	0.00	0.000	0.051
10/10/24	8:45a	70.4	70.4	69.8	6	-0.0	3.0	SE	0.75	4.0	SE	70.4	64.8	64.8	30.101	0.00	0.00	0.000	0.056
10/10/24	9:00a	72.0	72.0	70.3	4	-7.4	2.0	SE	0.50	4.0	SE	72.0	66.6	66.6	30.102	0.00	0.00	0.000	0.073
10/10/24	9:15a	73.8	73.8	72.0	1	-32.9	1.0	SE	0.25	3.0	SE	73.8	68.9	68.9	30.099	0.00	0.00	0.000	0.092
10/10/24	9:30a	76.0	76.0	73.7	0	---	0.0	SE	0.00	2.0	SE	76.0	71.4	71.4	30.102	0.00	0.00	0.000	0.115
10/10/24	9:45a	76.9	77.0	76.0	0	---	1.0	SE	0.25	5.0	NW	76.9	72.5	72.5	30.100	0.00	0.00	0.000	0.124
10/10/24	10:00a	77.1	77.1	76.9	0	---	2.0	NW	0.50	5.0	NW	77.1	72.7	72.7	30.100	0.00	0.00	0.000	0.126
10/10/24	10:15a	77.5	77.5	77.1	0	---	3.0	NNE	0.75	7.0	NNE	77.5	73.1	73.1	30.099	0.00	0.00	0.000	0.130
10/10/24	10:30a	78.1	78.1	77.5	0	---	4.0	NNE	1.00	7.0	NNE	78.1	73.6	73.6	30.103	0.00	0.00	0.000	0.136
10/10/24	10:45a	78.8	78.8	78.0	0	---	3.0	NE	0.75	5.0	NE	78.8	74.3	74.3	30.100	0.00	0.00	0.000	0.144
10/10/24	11:00a	79.8	79.8	78.8	0	---	3.0	NNW	0.75	8.0	NNW	79.8	75.3	75.3	30.095	0.00	0.00	0.000	0.154
10/10/24	11:15a	80.7	80.7	79.7	0	---	3.0	NNW	0.75	7.0	NNE	80.7	76.1	76.1	30.091	0.00	0.00	0.000	0.164
10/10/24	11:30a	81.6	81.6	80.7	0	---	3.0	W	0.75	9.0	W	81.6	77.0	77.0	30.081	0.00	0.00	0.000	0.173
10/10/24	11:45a	81.9	81.9	81.5	0	---	5.0	WNW	1.25	9.0	W	81.9	77.3	77.3	30.076	0.00	0.00	0.000	0.176
10/10/24	12:00p	82.9	83.0	81.9	0	---	4.0	WNW	1.00	8.0	W	82.9	78.2	78.2	30.073	0.00	0.00	0.000	0.186
10/10/24	12:15p	83.8	83.8	82.9	0	---	5.0	NW	1.25	10.0	W	83.8	78.9	78.9	30.071	0.00	0.00	0.000	0.196
10/10/24	12:30p	84.3	84.3	83.8	0	---	4.0	NW	1.00	10.0	NW	84.3	79.4	79.4	30.065	0.00	0.00	0.000	0.201

NKSP 10/10/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/10/24	12:45p	84.8	84.8	84.3	0	---	5.0	WNW	1.25	11.0	WNW	84.8	79.8	79.8	30.063	0.00	0.00	0.000	0.206
10/10/24	1:00p	85.9	85.9	84.8	0	---	4.0	NW	1.00	10.0	NW	85.9	80.7	80.7	30.056	0.00	0.00	0.000	0.218
10/10/24	1:15p	86.3	86.3	85.7	0	---	5.0	NW	1.25	10.0	N	86.3	81.0	81.0	30.049	0.00	0.00	0.000	0.222
10/10/24	1:30p	86.8	86.9	86.3	0	---	5.0	NNW	1.25	11.0	N	86.8	81.4	81.4	30.043	0.00	0.00	0.000	0.227
10/10/24	1:45p	87.2	87.4	86.8	0	---	4.0	NNW	1.00	11.0	WNW	87.2	81.8	81.8	30.039	0.00	0.00	0.000	0.231
10/10/24	2:00p	88.0	88.0	87.2	0	---	6.0	NW	1.50	12.0	NNW	88.0	82.4	82.4	30.036	0.00	0.00	0.000	0.240
10/10/24	2:15p	88.3	88.3	88.0	0	---	5.0	NW	1.25	14.0	NW	88.3	82.6	82.6	30.026	0.00	0.00	0.000	0.243
10/10/24	2:30p	88.5	88.9	88.4	0	---	6.0	N	1.50	12.0	NNW	88.5	82.8	82.8	30.022	0.00	0.00	0.000	0.245
10/10/24	2:45p	89.2	89.2	88.4	0	---	6.0	NW	1.50	12.0	NW	89.2	83.4	83.4	30.020	0.00	0.00	0.000	0.252
10/10/24	3:00p	89.5	89.6	89.1	0	---	6.0	NNW	1.50	12.0	NNW	89.5	83.6	83.6	30.017	0.00	0.00	0.000	0.255
10/10/24	3:15p	89.0	89.6	89.0	0	---	7.0	NNW	1.75	12.0	NNW	89.0	83.2	83.2	30.019	0.00	0.00	0.000	0.250
10/10/24	3:30p	89.0	89.1	88.8	0	---	6.0	NW	1.50	10.0	NW	89.0	83.2	83.2	30.018	0.00	0.00	0.000	0.250
10/10/24	3:45p	89.6	89.6	89.0	0	---	6.0	NNW	1.50	12.0	NNW	89.6	83.7	83.7	30.016	0.00	0.00	0.000	0.256
10/10/24	4:00p	89.2	89.6	89.2	0	---	6.0	NW	1.50	11.0	NW	89.2	83.4	83.4	30.016	0.00	0.00	0.000	0.252
10/10/24	4:15p	89.1	89.4	89.0	0	---	6.0	NNW	1.50	11.0	N	89.1	83.3	83.3	30.008	0.00	0.00	0.000	0.251
10/10/24	4:30p	88.6	89.1	88.6	0	---	5.0	NW	1.25	9.0	NW	88.6	82.9	82.9	30.007	0.00	0.00	0.000	0.246
10/10/24	4:45p	88.2	88.6	88.1	0	---	5.0	NNW	1.25	9.0	N	88.2	82.6	82.6	30.008	0.00	0.00	0.000	0.242
10/10/24	5:00p	88.5	88.6	88.2	0	---	5.0	NNW	1.25	8.0	NNW	88.5	82.8	82.8	30.004	0.00	0.00	0.000	0.245
10/10/24	5:15p	87.9	88.6	87.9	0	---	4.0	NNW	1.00	9.0	NNW	87.9	82.3	82.3	30.008	0.00	0.00	0.000	0.239
10/10/24	5:30p	87.2	87.9	87.2	0	---	4.0	NNW	1.00	8.0	NW	87.2	81.8	81.8	30.010	0.00	0.00	0.000	0.231
10/10/24	5:45p	86.4	87.2	86.4	0	---	4.0	NNW	1.00	6.0	NNW	86.4	81.1	81.1	30.009	0.00	0.00	0.000	0.223
10/10/24	6:00p	85.9	86.4	85.9	0	---	3.0	N	0.75	5.0	NNW	85.9	80.7	80.7	30.010	0.00	0.00	0.000	0.218
10/10/24	6:15p	85.0	86.0	85.0	0	---	3.0	N	0.75	5.0	N	85.0	80.0	80.0	30.012	0.00	0.00	0.000	0.208
10/10/24	6:30p	84.1	85.0	84.1	0	---	2.0	N	0.50	4.0	N	84.1	79.2	79.2	30.012	0.00	0.00	0.000	0.199
10/10/24	6:45p	83.2	84.1	83.2	0	---	3.0	N	0.75	5.0	NNW	83.2	78.5	78.5	30.018	0.00	0.00	0.000	0.190
10/10/24	7:00p	82.3	83.2	82.3	0	---	3.0	N	0.75	4.0	N	82.3	77.7	77.7	30.019	0.00	0.00	0.000	0.180
10/10/24	7:15p	81.1	82.4	81.1	0	---	3.0	NNE	0.75	4.0	NNE	81.1	76.5	76.5	30.023	0.00	0.00	0.000	0.168
10/10/24	7:30p	80.7	81.1	80.7	0	---	2.0	NNE	0.50	4.0	NNE	80.7	76.1	76.1	30.030	0.00	0.00	0.000	0.164
10/10/24	7:45p	80.3	80.7	80.3	0	---	1.0	NNE	0.25	2.0	NNE	80.3	75.8	75.8	30.034	0.00	0.00	0.000	0.159
10/10/24	8:00p	80.3	80.3	80.2	0	---	0.0	NNE	0.00	2.0	NNE	80.3	75.8	75.8	30.037	0.00	0.00	0.000	0.159
10/10/24	8:15p	79.3	80.4	79.3	0	---	1.0	NNE	0.25	3.0	NNE	79.3	74.8	74.8	30.041	0.00	0.00	0.000	0.149
10/10/24	8:30p	76.8	79.3	76.8	---	---	2.0	SW	0.50	4.0	WSW	76.8	---	---	30.045	0.00	0.00	0.000	0.123
10/10/24	8:45p	76.8	76.9	76.8	---	---	3.0	WSW	0.75	4.0	WSW	76.8	---	---	30.046	0.00	0.00	0.000	0.123
10/10/24	9:00p	77.3	77.4	76.8	0	---	3.0	WSW	0.75	5.0	WSW	77.3	72.9	72.9	30.047	0.00	0.00	0.000	0.128
10/10/24	9:15p	77.1	77.5	77.1	0	---	1.0	WSW	0.25	4.0	WSW	77.1	72.7	72.7	30.050	0.00	0.00	0.000	0.126
10/10/24	9:30p	76.7	77.1	76.7	0	---	0.0	SSW	0.00	2.0	WSW	76.7	72.2	72.2	30.053	0.00	0.00	0.000	0.122
10/10/24	9:45p	74.6	76.7	74.6	2	-19.5	1.0	SSW	0.25	3.0	SSW	74.6	70.0	70.0	30.047	0.00	0.00	0.000	0.100
10/10/24	10:00p	73.8	74.6	73.7	3	-12.0	0.0	SSW	0.00	2.0	SSW	73.8	69.0	69.0	30.054	0.00	0.00	0.000	0.092
10/10/24	10:15p	74.0	74.2	73.7	3	-11.9	0.0	SSW	0.00	2.0	SSW	74.0	69.2	69.2	30.057	0.00	0.00	0.000	0.094
10/10/24	10:30p	73.4	74.0	73.4	3	-12.3	0.0	---	0.00	0.0	---	73.4	68.5	68.5	30.057	0.00	0.00	0.000	0.088
10/10/24	10:45p	73.1	73.4	73.1	4	-6.6	0.0	---	0.00	0.0	---	73.1	68.1	68.1	30.063	0.00	0.00	0.000	0.084
10/10/24	11:00p	73.3	73.3	73.1	3	-12.3	0.0	---	0.00	0.0	---	73.3	68.3	68.3	30.061	0.00	0.00	0.000	0.086
10/10/24	11:15p	73.0	73.4	73.0	3	-12.6	0.0	---	0.00	0.0	---	73.0	67.9	67.9	30.061	0.00	0.00	0.000	0.083
10/10/24	11:30p	72.0	73.1	72.0	6	1.1	1.0	S	0.25	3.0	S	72.0	66.7	66.7	30.061	0.00	0.00	0.000	0.073
10/10/24	11:45p	70.8	72.0	70.8	9	9.1	2.0	SE	0.50	4.0	S	70.8	65.6	65.6	30.063	0.00	0.00	0.000	0.060
10/11/24	12:00a	69.1	70.8	69.1	12	14.3	2.0	SE	0.50	5.0	SE	69.1	63.7	63.7	30.063	0.00	0.00	0.000	0.043

NKSP 10/11/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/11/24	12:15a	67.9	69.0	67.9	18	22.8	3.0	S	0.75	5.0	S	67.9	63.0	63.0	30.065	0.00	0.00	0.000	0.030
10/11/24	12:30a	67.4	67.9	67.4	18	22.4	3.0	SSW	0.75	4.0	S	67.4	62.4	62.4	30.068	0.00	0.00	0.000	0.025
10/11/24	12:45a	67.0	67.4	66.7	18	22.1	2.0	SSW	0.50	4.0	SSW	67.0	61.9	61.9	30.071	0.00	0.00	0.000	0.021
10/11/24	1:00a	66.5	67.2	66.4	19	22.9	0.0	S	0.00	2.0	S	66.5	61.5	61.5	30.076	0.00	0.00	0.000	0.016
10/11/24	1:15a	66.0	66.5	66.0	20	23.7	0.0	SSE	0.00	4.0	S	66.0	61.1	61.1	30.078	0.00	0.00	0.000	0.010
10/11/24	1:30a	65.5	66.0	65.5	22	25.6	2.0	SSE	0.50	5.0	SSE	65.5	60.8	60.8	30.076	0.00	0.00	0.000	0.005
10/11/24	1:45a	64.9	65.5	64.9	23	26.2	1.0	SSE	0.25	3.0	SSE	64.9	60.3	60.3	30.077	0.00	0.00	0.001	0.000
10/11/24	2:00a	64.3	64.9	64.3	23	25.7	1.0	SSE	0.25	3.0	SSE	64.3	59.7	59.7	30.077	0.00	0.00	0.007	0.000
10/11/24	2:15a	63.9	64.3	63.9	23	25.3	0.0	SSE	0.00	2.0	SSE	63.9	59.3	59.3	30.078	0.00	0.00	0.011	0.000
10/11/24	2:30a	63.5	64.0	63.5	24	26.0	0.0	---	0.00	0.0	---	63.5	59.0	59.0	30.081	0.00	0.00	0.016	0.000
10/11/24	2:45a	63.6	63.6	63.2	19	20.5	0.0	---	0.00	0.0	---	63.6	58.8	58.8	30.077	0.00	0.00	0.015	0.000
10/11/24	3:00a	64.0	64.2	63.6	16	16.8	4.0	WSW	1.00	8.0	WSW	64.0	58.9	58.9	30.079	0.00	0.00	0.010	0.000
10/11/24	3:15a	63.2	64.0	63.2	16	16.2	2.0	WSW	0.50	4.0	WSW	63.2	58.2	58.2	30.080	0.00	0.00	0.019	0.000
10/11/24	3:30a	62.9	63.2	62.9	15	14.5	2.0	WSW	0.50	4.0	WSW	62.9	57.8	57.8	30.079	0.00	0.00	0.022	0.000
10/11/24	3:45a	62.5	62.9	62.5	16	15.6	1.0	WSW	0.25	6.0	W	62.5	57.5	57.5	30.082	0.00	0.00	0.026	0.000
10/11/24	4:00a	62.0	62.5	62.0	16	15.2	2.0	WSW	0.50	3.0	WSW	62.0	57.1	57.1	30.081	0.00	0.00	0.031	0.000
10/11/24	4:15a	61.3	61.9	61.3	18	17.4	2.0	SW	0.50	4.0	SW	61.3	56.6	56.6	30.085	0.00	0.00	0.039	0.000
10/11/24	4:30a	61.1	61.3	61.1	17	15.9	2.0	WSW	0.50	4.0	SW	61.1	56.3	56.3	30.084	0.00	0.00	0.041	0.000
10/11/24	4:45a	60.9	61.1	60.9	17	15.7	0.0	WSW	0.00	3.0	WSW	60.9	56.2	56.2	30.086	0.00	0.00	0.043	0.000
10/11/24	5:00a	60.4	60.9	60.4	19	17.9	1.0	WSW	0.25	3.0	WSW	60.4	55.9	55.9	30.089	0.00	0.00	0.048	0.000
10/11/24	5:15a	59.5	60.4	59.5	21	19.5	2.0	SSW	0.50	4.0	S	59.5	55.2	55.2	30.090	0.00	0.00	0.057	0.000
10/11/24	5:30a	59.3	59.6	59.2	25	23.4	3.0	ESE	0.75	6.0	ESE	59.3	55.3	55.3	30.092	0.00	0.00	0.059	0.000
10/11/24	5:45a	59.0	59.3	58.9	26	24.1	2.0	ESE	0.50	4.0	ESE	59.0	55.1	55.1	30.092	0.00	0.00	0.063	0.000
10/11/24	6:00a	59.2	59.5	59.0	24	22.4	2.0	ESE	0.50	4.0	ESE	59.2	55.1	55.1	30.096	0.00	0.00	0.060	0.000
10/11/24	6:15a	59.0	59.2	58.5	25	23.2	2.0	ESE	0.50	4.0	ESE	59.0	55.0	55.0	30.097	0.00	0.00	0.063	0.000
10/11/24	6:30a	58.6	59.2	58.6	24	21.9	2.0	SE	0.50	3.0	SE	58.6	54.6	54.6	30.099	0.00	0.00	0.067	0.000
10/11/24	6:45a	58.4	58.7	58.4	25	22.7	2.0	SE	0.50	5.0	S	58.4	54.5	54.5	30.104	0.00	0.00	0.069	0.000
10/11/24	7:00a	57.7	58.4	57.7	26	23.0	3.0	S	0.75	6.0	S	57.7	54.0	54.0	30.109	0.00	0.00	0.076	0.000
10/11/24	7:15a	57.6	57.7	57.3	27	23.8	2.0	SSE	0.50	5.0	SSE	57.6	54.1	54.1	30.109	0.00	0.00	0.077	0.000
10/11/24	7:30a	58.0	58.0	57.5	25	22.3	0.0	SSE	0.00	3.0	SSE	58.0	54.2	54.2	30.112	0.00	0.00	0.073	0.000
10/11/24	7:45a	58.6	58.6	58.0	25	22.8	2.0	SSE	0.50	5.0	SSE	58.6	54.7	54.7	30.117	0.00	0.00	0.067	0.000
10/11/24	8:00a	59.0	59.1	58.6	25	23.2	2.0	SE	0.50	4.0	SSE	59.0	55.0	55.0	30.123	0.00	0.00	0.063	0.000
10/11/24	8:15a	59.5	59.5	59.1	26	24.5	2.0	SE	0.50	5.0	SE	59.5	55.6	55.6	30.122	0.00	0.00	0.057	0.000
10/11/24	8:30a	61.5	61.5	59.5	24	24.3	3.0	SE	0.75	5.0	ESE	61.5	57.2	57.2	30.125	0.00	0.00	0.036	0.000
10/11/24	8:45a	64.5	64.5	61.5	21	23.7	3.0	SE	0.75	4.0	SSE	64.5	59.8	59.8	30.131	0.00	0.00	0.005	0.000
10/11/24	9:00a	67.0	67.0	64.5	14	16.2	3.0	SE	0.75	5.0	SE	67.0	61.7	61.7	30.132	0.00	0.00	0.000	0.021
10/11/24	9:15a	69.1	69.1	67.0	10	10.2	4.0	SE	1.00	7.0	ESE	69.1	63.5	63.5	30.135	0.00	0.00	0.000	0.043
10/11/24	9:30a	70.4	70.4	69.1	8	6.2	5.0	SE	1.25	9.0	SSE	70.4	64.9	64.9	30.136	0.00	0.00	0.000	0.056
10/11/24	9:45a	72.4	72.4	70.4	5	-2.5	4.0	SSE	1.00	8.0	SE	72.4	67.2	67.2	30.131	0.00	0.00	0.000	0.077
10/11/24	10:00a	74.4	74.4	72.4	3	-11.6	3.0	SSE	0.75	6.0	N	74.4	69.8	69.8	30.129	0.00	0.00	0.000	0.098
10/11/24	10:15a	75.4	75.4	74.4	2	-19.0	3.0	SE	0.75	7.0	SE	75.4	70.9	70.9	30.133	0.00	0.00	0.000	0.108
10/11/24	10:30a	76.6	76.6	75.3	0	---	3.0	SE	0.75	7.0	ESE	76.6	72.1	72.1	30.134	0.00	0.00	0.000	0.121
10/11/24	10:45a	78.1	78.1	76.6	0	---	2.0	SE	0.50	5.0	SSE	78.1	73.6	73.6	30.132	0.00	0.00	0.000	0.136
10/11/24	11:00a	78.9	78.9	78.1	0	---	2.0	SE	0.50	6.0	ESE	78.9	74.4	74.4	30.130	0.00	0.00	0.000	0.145
10/11/24	11:15a	79.9	79.9	78.9	0	---	2.0	SE	0.50	5.0	SE	79.9	75.4	75.4	30.128	0.00	0.00	0.000	0.155
10/11/24	11:30a	80.4	80.4	79.9	0	---	2.0	ESE	0.50	6.0	ESE	80.4	75.9	75.9	30.126	0.00	0.00	0.000	0.160
10/11/24	11:45a	81.6	81.6	80.4	0	---	1.0	ESE	0.25	3.0	ESE	81.6	77.0	77.0	30.118	0.00	0.00	0.000	0.173
10/11/24	12:00p	82.7	82.8	81.6	0	---	1.0	ESE	0.25	4.0	E	82.7	78.0	78.0	30.117	0.00	0.00	0.000	0.184
10/11/24	12:15p	84.0	84.1	82.8	0	---	2.0	SE	0.50	6.0	N	84.0	79.1	79.1	30.117	0.00	0.00	0.000	0.198
10/11/24	12:30p	83.2	83.9	83.1	0	---	3.0	NW	0.75	10.0	N	83.2	78.5	78.5	30.111	0.00	0.00	0.000	0.190

NKSP 10/11/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/11/24	12:45p	83.2	83.3	83.0	0	---	5.0	NNE	1.25	11.0	NW	83.2	78.5	78.5	30.103	0.00	0.00	0.000	0.190
10/11/24	1:00p	83.8	83.8	83.3	0	---	4.0	NW	1.00	9.0	NNW	83.8	78.9	78.9	30.097	0.00	0.00	0.000	0.196
10/11/24	1:15p	84.1	84.5	83.8	0	---	4.0	NNW	1.00	9.0	NNW	84.1	79.2	79.2	30.097	0.00	0.00	0.000	0.199
10/11/24	1:30p	84.4	84.4	84.1	0	---	3.0	NE	0.75	7.0	NNE	84.4	79.5	79.5	30.090	0.00	0.00	0.000	0.202
10/11/24	1:45p	84.7	84.7	84.4	0	---	4.0	NE	1.00	9.0	NNW	84.7	79.7	79.7	30.085	0.00	0.00	0.000	0.205
10/11/24	2:00p	85.1	85.1	84.7	0	---	4.0	NNE	1.00	9.0	NNE	85.1	80.1	80.1	30.078	0.00	0.00	0.000	0.209
10/11/24	2:15p	85.0	85.3	84.9	0	---	6.0	NNE	1.50	11.0	N	85.0	80.0	80.0	30.078	0.00	0.00	0.000	0.208
10/11/24	2:30p	85.0	85.1	84.9	0	---	5.0	NNW	1.25	10.0	NNE	85.0	80.0	80.0	30.078	0.00	0.00	0.000	0.208
10/11/24	2:45p	85.0	85.2	84.8	0	---	5.0	NNW	1.25	11.0	NW	85.0	80.0	80.0	30.077	0.00	0.00	0.000	0.208
10/11/24	3:00p	85.6	85.6	84.9	0	---	6.0	NW	1.50	10.0	NW	85.6	80.5	80.5	30.079	0.00	0.00	0.000	0.215
10/11/24	3:15p	85.7	85.8	85.5	0	---	6.0	NW	1.50	12.0	NNE	85.7	80.6	80.6	30.078	0.00	0.00	0.000	0.216
10/11/24	3:30p	86.3	86.3	85.6	0	---	5.0	NNW	1.25	10.0	NNW	86.3	81.0	81.0	30.074	0.00	0.00	0.000	0.222
10/11/24	3:45p	87.2	87.2	86.3	0	---	5.0	N	1.25	10.0	NNE	87.2	81.8	81.8	30.067	0.00	0.00	0.000	0.231
10/11/24	4:00p	87.4	87.5	87.2	0	---	5.0	N	1.25	11.0	N	87.4	81.9	81.9	30.060	0.00	0.00	0.000	0.233
10/11/24	4:15p	87.8	87.8	87.5	0	---	4.0	NNE	1.00	9.0	NNE	87.8	82.2	82.2	30.058	0.00	0.00	0.000	0.238
10/11/24	4:30p	87.9	87.9	87.8	0	---	4.0	NNE	1.00	10.0	N	87.9	82.3	82.3	30.057	0.00	0.00	0.000	0.239
10/11/24	4:45p	88.0	88.0	87.8	0	---	4.0	NNE	1.00	9.0	NNE	88.0	82.4	82.4	30.056	0.00	0.00	0.000	0.240
10/11/24	5:00p	88.3	88.3	87.9	0	---	3.0	NNE	0.75	5.0	NW	88.3	82.6	82.6	30.052	0.00	0.00	0.000	0.243
10/11/24	5:15p	88.5	88.5	88.3	0	---	3.0	NNE	0.75	5.0	NNE	88.5	82.8	82.8	30.051	0.00	0.00	0.000	0.245
10/11/24	5:30p	88.1	88.5	88.1	0	---	3.0	NE	0.75	6.0	NE	88.1	82.5	82.5	30.050	0.00	0.00	0.000	0.241
10/11/24	5:45p	87.7	88.1	87.7	0	---	2.0	ENE	0.50	4.0	NE	87.7	82.2	82.2	30.048	0.00	0.00	0.000	0.236
10/11/24	6:00p	86.9	87.7	86.9	0	---	2.0	ENE	0.50	4.0	ENE	86.9	81.5	81.5	30.049	0.00	0.00	0.000	0.228
10/11/24	6:15p	86.2	87.0	86.2	0	---	1.0	NE	0.25	2.0	NE	86.2	81.0	81.0	30.052	0.00	0.00	0.000	0.221
10/11/24	6:30p	85.4	86.2	85.4	0	---	0.0	NE	0.00	2.0	NE	85.4	80.3	80.3	30.058	0.00	0.00	0.000	0.213
10/11/24	6:45p	84.3	85.5	84.3	0	---	1.0	NE	0.25	2.0	NE	84.3	79.4	79.4	30.059	0.00	0.00	0.000	0.201
10/11/24	7:00p	83.0	84.3	83.0	0	---	2.0	NE	0.50	3.0	NE	83.0	78.3	78.3	30.065	0.00	0.00	0.000	0.188
10/11/24	7:15p	82.0	83.0	82.0	0	---	2.0	NE	0.50	3.0	NE	82.0	77.4	77.4	30.069	0.00	0.00	0.000	0.177
10/11/24	7:30p	81.0	82.0	81.0	0	---	1.0	E	0.25	3.0	NE	81.0	76.4	76.4	30.070	0.00	0.00	0.000	0.167
10/11/24	7:45p	78.6	81.0	78.6	0	---	2.0	E	0.50	4.0	E	78.6	74.1	74.1	30.076	0.00	0.00	0.000	0.142
10/11/24	8:00p	76.8	78.6	76.8	0	---	1.0	SE	0.25	3.0	SE	76.8	72.4	72.4	30.079	0.00	0.00	0.000	0.123
10/11/24	8:15p	75.5	76.8	75.5	2	-18.9	1.0	SE	0.25	3.0	SE	75.5	70.9	70.9	30.083	0.00	0.00	0.000	0.109
10/11/24	8:30p	75.2	75.5	75.0	3	-11.1	3.0	SE	0.75	4.0	SE	75.2	70.8	70.8	30.088	0.00	0.00	0.000	0.106
10/11/24	8:45p	74.5	75.4	74.5	5	-1.0	2.0	ESE	0.50	4.0	ESE	74.5	70.1	70.1	30.094	0.00	0.00	0.000	0.099
10/11/24	9:00p	74.2	74.5	74.2	7	6.1	3.0	SE	0.75	4.0	SE	74.2	69.9	69.9	30.096	0.00	0.00	0.000	0.096
10/11/24	9:15p	72.1	74.2	72.0	9	10.1	2.0	S	0.50	11.0	SW	72.1	67.3	67.3	30.105	0.00	0.00	0.000	0.074
10/11/24	9:30p	71.8	72.1	71.8	11	14.4	1.0	SSE	0.25	5.0	SSW	71.8	67.2	67.2	30.106	0.00	0.00	0.000	0.071
10/11/24	9:45p	71.5	71.8	71.5	11	14.2	1.0	SSE	0.25	5.0	SSE	71.5	66.8	66.8	30.107	0.00	0.00	0.000	0.068
10/11/24	10:00p	72.7	72.7	71.5	4	-6.9	0.0	S	0.00	3.0	S	72.7	67.6	67.6	30.110	0.00	0.00	0.000	0.080
10/11/24	10:15p	73.7	73.7	72.7	0	---	1.0	SSW	0.25	3.0	SSW	73.7	68.7	68.7	30.110	0.00	0.00	0.000	0.091
10/11/24	10:30p	73.2	73.9	73.2	1	-33.3	0.0	SSW	0.00	2.0	SSW	73.2	68.1	68.1	30.113	0.00	0.00	0.000	0.085
10/11/24	10:45p	72.4	73.2	72.4	---	---	1.0	SSW	0.25	2.0	SSW	72.4	---	---	30.116	0.00	0.00	0.000	0.077
10/11/24	11:00p	72.0	72.5	72.0	---	---	1.0	SSW	0.25	3.0	SSW	72.0	---	---	30.114	0.00	0.00	0.000	0.073
10/11/24	11:15p	70.8	72.0	70.8	---	---	2.0	SSW	0.50	3.0	SSW	70.8	---	---	30.114	0.00	0.00	0.000	0.060
10/11/24	11:30p	70.2	70.8	70.2	0	---	0.0	SSW	0.00	2.0	SSW	70.2	64.2	64.2	30.114	0.00	0.00	0.000	0.054
10/11/24	11:45p	70.3	70.3	69.9	0	---	1.0	SSW	0.25	4.0	SW	70.3	64.3	64.3	30.119	0.00	0.00	0.000	0.055
10/12/24	12:00a	69.7	70.3	69.7	0	---	1.0	SW	0.25	4.0	SW	69.7	63.4	63.4	30.119	0.00	0.00	0.000	0.049

NKSP 10/10/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/10/24	12:15a	77.2	48	56.0	76.9	8.91	.0731	351	1	100.0	15
10/10/24	12:30a	77.4	46	55.0	76.9	8.50	.0731	351	1	100.0	15
10/10/24	12:45a	77.2	49	56.6	77.0	9.01	.0731	351	1	100.0	15
10/10/24	1:00a	77.0	47	55.2	76.6	8.71	.0732	351	1	100.0	15
10/10/24	1:15a	77.1	46	54.7	76.6	8.51	.0732	352	1	100.0	15
10/10/24	1:30a	76.8	49	56.2	76.6	9.01	.0732	351	1	100.0	15
10/10/24	1:45a	76.5	47	54.8	76.1	8.72	.0733	351	1	100.0	15
10/10/24	2:00a	76.6	48	55.4	76.3	8.92	.0732	351	1	100.0	15
10/10/24	2:15a	76.2	48	55.1	75.9	8.93	.0733	352	1	100.0	15
10/10/24	2:30a	76.3	45	53.4	75.7	8.42	.0734	351	1	100.0	15
10/10/24	2:45a	76.2	48	55.1	75.9	8.93	.0733	351	1	100.0	15
10/10/24	3:00a	76.0	47	54.3	75.6	8.73	.0734	351	1	100.0	15
10/10/24	3:15a	76.3	48	55.2	76.0	8.92	.0733	351	1	100.0	15
10/10/24	3:30a	76.1	48	55.0	75.8	8.93	.0733	352	1	100.0	15
10/10/24	3:45a	76.4	45	53.5	75.8	8.42	.0733	351	1	100.0	15
10/10/24	4:00a	76.1	48	55.0	75.8	8.93	.0733	351	1	100.0	15
10/10/24	4:15a	76.2	46	53.9	75.7	8.53	.0734	351	1	100.0	15
10/10/24	4:30a	76.3	48	55.2	76.0	8.92	.0733	352	1	100.0	15
10/10/24	4:45a	76.2	47	54.5	75.8	8.73	.0733	351	1	100.0	15
10/10/24	5:00a	76.3	48	55.2	76.0	8.92	.0733	351	1	100.0	15
10/10/24	5:15a	76.1	48	55.0	75.8	8.93	.0734	351	1	100.0	15
10/10/24	5:30a	76.5	48	55.3	76.2	8.92	.0733	352	1	100.0	15
10/10/24	5:45a	76.2	48	55.1	75.9	8.93	.0733	351	1	100.0	15
10/10/24	6:00a	76.5	47	54.8	76.1	8.72	.0733	351	1	100.0	15
10/10/24	6:15a	76.4	49	55.8	76.2	9.02	.0733	351	1	100.0	15
10/10/24	6:30a	76.5	47	54.8	76.1	8.72	.0733	351	1	100.0	15
10/10/24	6:45a	76.6	49	56.0	76.4	9.02	.0733	352	1	100.0	15
10/10/24	7:00a	76.3	48	55.2	76.0	8.92	.0734	351	1	100.0	15
10/10/24	7:15a	76.6	49	56.0	76.4	9.02	.0733	351	1	100.0	15
10/10/24	7:30a	76.3	48	55.2	76.0	8.92	.0734	351	1	100.0	15
10/10/24	7:45a	76.6	47	54.9	76.2	8.72	.0734	352	1	100.0	15
10/10/24	8:00a	76.4	49	55.8	76.2	9.02	.0733	351	1	100.0	15
10/10/24	8:15a	76.5	47	54.8	76.1	8.72	.0734	351	1	100.0	15
10/10/24	8:30a	76.7	48	55.5	76.4	8.92	.0733	351	1	100.0	15
10/10/24	8:45a	76.6	48	55.4	76.3	8.92	.0734	352	1	100.0	15
10/10/24	9:00a	76.9	45	53.9	76.3	8.41	.0734	351	1	100.0	15
10/10/24	9:15a	77.0	48	55.8	76.7	8.91	.0733	351	1	100.0	15
10/10/24	9:30a	76.9	47	55.1	76.5	8.71	.0733	351	1	100.0	15
10/10/24	9:45a	77.4	45	54.4	76.8	8.40	.0733	351	1	100.0	15
10/10/24	10:00a	77.5	47	55.7	77.1	8.70	.0732	352	1	100.0	15
10/10/24	10:15a	77.4	46	55.0	76.9	8.50	.0733	351	1	100.0	15
10/10/24	10:30a	77.9	44	54.2	77.1	8.19	.0732	351	1	100.0	15
10/10/24	10:45a	77.9	47	56.0	77.5	8.69	.0731	351	1	100.0	15
10/10/24	11:00a	78.0	45	54.9	77.3	8.39	.0732	352	1	100.0	15
10/10/24	11:15a	78.5	44	54.8	77.7	8.18	.0731	351	1	100.0	15
10/10/24	11:30a	78.6	46	56.1	78.1	8.48	.0730	351	1	100.0	15
10/10/24	11:45a	78.7	45	55.6	78.1	8.38	.0730	351	1	100.0	15
10/10/24	12:00p	78.9	43	54.5	78.1	8.05	.0730	352	1	100.0	15
10/10/24	12:15p	79.2	45	56.0	78.6	8.37	.0729	351	1	100.0	15
10/10/24	12:30p	79.3	46	56.7	78.8	8.46	.0728	351	1	100.0	15

NKSP 10/10/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/10/24	12:45p	79.4	44	55.6	78.7	8.16	.0729	351	1	100.0	15
10/10/24	1:00p	79.6	41	53.8	78.5	7.75	.0729	351	1	100.0	15
10/10/24	1:15p	79.8	42	54.7	78.8	7.85	.0728	352	1	100.0	15
10/10/24	1:30p	80.1	42	54.9	79.1	7.85	.0728	351	1	100.0	15
10/10/24	1:45p	80.1	42	54.9	79.1	7.85	.0727	351	1	100.0	15
10/10/24	2:00p	80.5	40	54.0	79.3	7.55	.0727	351	1	100.0	15
10/10/24	2:15p	80.4	40	53.9	79.1	7.55	.0727	352	1	100.0	15
10/10/24	2:30p	80.7	39	53.4	79.4	7.44	.0727	351	1	100.0	15
10/10/24	2:45p	81.0	39	53.7	79.7	7.43	.0726	351	1	100.0	15
10/10/24	3:00p	80.9	41	55.0	79.8	7.73	.0726	351	1	100.0	15
10/10/24	3:15p	80.7	39	53.4	79.4	7.44	.0727	351	1	100.0	15
10/10/24	3:30p	80.9	39	53.6	79.6	7.43	.0726	352	1	100.0	15
10/10/24	3:45p	81.0	40	54.4	79.8	7.55	.0726	351	1	100.0	15
10/10/24	4:00p	80.8	40	54.2	79.6	7.55	.0726	351	1	100.0	15
10/10/24	4:15p	80.8	38	52.8	79.4	7.25	.0727	351	1	100.0	15
10/10/24	4:30p	80.8	39	53.5	79.5	7.43	.0726	352	1	100.0	15
10/10/24	4:45p	80.8	41	54.9	79.7	7.73	.0726	351	1	100.0	15
10/10/24	5:00p	80.7	41	54.8	79.6	7.74	.0726	351	1	100.0	15
10/10/24	5:15p	80.6	40	54.0	79.4	7.55	.0726	351	1	100.0	15
10/10/24	5:30p	80.7	40	54.1	79.5	7.55	.0726	352	1	100.0	15
10/10/24	5:45p	80.7	41	54.8	79.6	7.74	.0726	351	1	100.0	15
10/10/24	6:00p	80.4	43	55.9	79.6	8.04	.0726	351	1	100.0	15
10/10/24	6:15p	80.2	43	55.7	79.3	8.05	.0726	351	1	100.0	15
10/10/24	6:30p	80.1	42	54.9	79.1	7.85	.0727	352	1	100.0	15
10/10/24	6:45p	80.0	41	54.2	78.8	7.75	.0727	351	1	100.0	15
10/10/24	7:00p	80.0	42	54.8	79.0	7.85	.0727	351	1	100.0	15
10/10/24	7:15p	79.9	45	56.7	79.3	8.35	.0727	351	1	100.0	15
10/10/24	7:30p	79.6	44	55.8	78.9	8.16	.0728	351	1	100.0	15
10/10/24	7:45p	79.4	43	55.0	78.5	8.05	.0728	352	1	100.0	15
10/10/24	8:00p	79.2	43	54.8	78.4	8.05	.0729	351	1	100.0	15
10/10/24	8:15p	79.2	44	55.4	78.5	8.17	.0729	351	1	100.0	15
10/10/24	8:30p	79.1	47	57.1	78.7	8.67	.0728	351	1	100.0	15
10/10/24	8:45p	78.8	46	56.3	78.3	8.47	.0729	352	1	100.0	15
10/10/24	9:00p	78.7	44	55.0	78.0	8.18	.0730	351	1	100.0	15
10/10/24	9:15p	78.8	46	56.3	78.3	8.47	.0729	351	1	100.0	15
10/10/24	9:30p	78.7	48	57.4	78.4	8.88	.0729	351	1	100.0	15
10/10/24	9:45p	78.4	47	56.5	78.0	8.68	.0729	351	1	100.0	15
10/10/24	10:00p	78.3	45	55.2	77.6	8.38	.0730	352	1	100.0	15
10/10/24	10:15p	78.5	46	56.0	78.0	8.48	.0730	351	1	100.0	15
10/10/24	10:30p	78.3	50	58.1	78.3	9.18	.0729	351	1	100.0	15
10/10/24	10:45p	78.1	48	56.8	77.8	8.89	.0730	351	1	100.0	15
10/10/24	11:00p	78.0	46	55.5	77.4	8.49	.0731	352	1	100.0	15
10/10/24	11:15p	78.2	49	57.5	78.1	8.99	.0730	351	1	100.0	15
10/10/24	11:30p	78.0	50	57.9	78.0	9.19	.0730	351	1	100.0	15
10/10/24	11:45p	77.8	47	56.0	77.4	8.69	.0731	351	1	100.0	15
10/11/24	12:00a	78.0	48	56.7	77.7	8.89	.0730	352	1	100.0	15

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/11/24	12:15a	77.8	50	57.7	77.8	9.19	.0730	350	1	100.0	15
10/11/24	12:30a	77.6	48	56.4	77.3	8.90	.0731	351	1	100.0	15
10/11/24	12:45a	77.8	49	57.1	77.6	8.99	.0730	351	1	100.0	15
10/11/24	1:00a	77.4	50	57.3	77.3	9.20	.0731	352	1	100.0	15
10/11/24	1:15a	77.3	47	55.5	76.9	8.70	.0732	351	1	100.0	15
10/11/24	1:30a	77.4	47	55.6	77.0	8.70	.0732	351	1	100.0	15
10/11/24	1:45a	77.1	50	57.0	77.0	9.21	.0732	351	1	100.0	15
10/11/24	2:00a	76.9	49	56.3	76.7	9.01	.0732	352	1	100.0	15
10/11/24	2:15a	77.1	51	57.6	77.1	9.35	.0731	351	1	100.0	15
10/11/24	2:30a	76.9	50	56.8	76.8	9.21	.0732	351	1	100.0	15
10/11/24	2:45a	76.7	49	56.1	76.5	9.02	.0733	351	1	100.0	15
10/11/24	3:00a	76.7	47	55.0	76.3	8.72	.0733	352	1	100.0	15
10/11/24	3:15a	76.3	52	57.4	76.3	9.52	.0733	351	1	100.0	15
10/11/24	3:30a	75.6	50	55.6	75.5	9.24	.0734	351	1	100.0	15
10/11/24	3:45a	75.7	52	56.8	75.7	9.54	.0734	351	1	100.0	15
10/11/24	4:00a	75.2	50	55.3	75.1	9.25	.0735	352	1	100.0	15
10/11/24	4:15a	75.4	51	56.0	75.4	9.35	.0735	351	1	100.0	15
10/11/24	4:30a	75.0	50	55.1	74.9	9.25	.0735	351	1	100.0	15
10/11/24	4:45a	75.3	47	53.7	74.9	8.74	.0736	351	1	100.0	15
10/11/24	5:00a	74.7	50	54.8	74.6	9.25	.0736	351	1	100.0	15
10/11/24	5:15a	75.3	48	54.3	75.0	8.94	.0736	352	1	100.0	15
10/11/24	5:30a	74.6	50	54.7	74.5	9.25	.0736	351	1	100.0	15
10/11/24	5:45a	75.4	49	54.9	75.2	9.04	.0735	351	1	100.0	15
10/11/24	6:00a	75.5	49	55.0	75.3	9.04	.0735	352	1	100.0	15
10/11/24	6:15a	75.6	46	53.4	75.1	8.54	.0736	350	1	100.0	15
10/11/24	6:30a	74.5	50	54.6	74.4	9.25	.0737	352	1	100.0	15
10/11/24	6:45a	74.9	47	53.3	74.5	8.75	.0737	351	1	100.0	15
10/11/24	7:00a	74.2	51	54.9	74.1	9.37	.0737	351	1	100.0	15
10/11/24	7:15a	74.8	48	53.8	74.5	8.95	.0737	351	1	100.0	15
10/11/24	7:30a	74.1	51	54.8	74.0	9.37	.0737	352	1	100.0	15
10/11/24	7:45a	74.8	48	53.8	74.5	8.95	.0737	351	1	100.0	15
10/11/24	8:00a	74.2	51	54.9	74.1	9.37	.0738	351	1	100.0	15
10/11/24	8:15a	74.9	48	53.9	74.6	8.95	.0737	351	1	100.0	15
10/11/24	8:30a	74.3	51	55.0	74.2	9.36	.0737	352	1	100.0	15
10/11/24	8:45a	75.1	47	53.5	74.7	8.75	.0737	351	1	100.0	15
10/11/24	9:00a	74.7	52	55.9	74.7	9.56	.0737	351	1	100.0	15
10/11/24	9:15a	75.1	46	52.9	74.6	8.55	.0737	351	1	100.0	15
10/11/24	9:30a	75.2	51	55.8	75.2	9.35	.0736	351	1	100.0	15
10/11/24	9:45a	75.3	48	54.3	75.0	8.94	.0737	352	1	100.0	15
10/11/24	10:00a	76.4	49	55.8	76.2	9.02	.0734	351	1	100.0	15
10/11/24	10:15a	77.0	49	56.4	76.8	9.01	.0733	351	1	100.0	15
10/11/24	10:30a	77.5	46	55.1	77.0	8.50	.0733	351	1	100.0	15
10/11/24	10:45a	78.1	47	56.2	77.7	8.69	.0732	352	1	100.0	15
10/11/24	11:00a	78.4	48	57.1	78.1	8.88	.0731	351	1	100.0	15
10/11/24	11:15a	78.5	46	56.0	78.0	8.48	.0731	351	1	100.0	15
10/11/24	11:30a	78.4	45	55.3	77.7	8.38	.0732	351	1	100.0	15
10/11/24	11:45a	77.9	49	57.2	77.8	8.99	.0731	352	1	100.0	15
10/11/24	12:00p	77.9	47	56.0	77.5	8.69	.0732	351	1	100.0	15
10/11/24	12:15p	78.2	44	54.5	77.4	8.19	.0732	351	1	100.0	15
10/11/24	12:30p	78.4	47	56.5	78.0	8.68	.0731	351	1	100.0	15

NKSP 10/11/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/11/24	12:45p	78.1	48	56.8	77.8	8.89	.0731	351	1	100.0	15
10/11/24	1:00p	78.2	43	53.9	77.3	8.05	.0732	352	1	100.0	15
10/11/24	1:15p	78.6	45	55.5	78.0	8.38	.0731	351	1	100.0	15
10/11/24	1:30p	78.5	48	57.2	78.2	8.88	.0730	351	1	100.0	15
10/11/24	1:45p	78.4	45	55.3	77.7	8.38	.0731	351	1	100.0	15
10/11/24	2:00p	78.5	43	54.1	77.6	8.05	.0731	352	1	100.0	15
10/11/24	2:15p	78.8	45	55.7	78.2	8.37	.0730	351	1	100.0	15
10/11/24	2:30p	78.7	48	57.4	78.4	8.88	.0729	351	1	100.0	15
10/11/24	2:45p	78.5	46	56.0	78.0	8.48	.0730	351	1	100.0	15
10/11/24	3:00p	78.9	44	55.1	78.2	8.17	.0730	352	1	100.0	15
10/11/24	3:15p	79.4	43	55.0	78.5	8.05	.0729	351	1	100.0	15
10/11/24	3:30p	79.5	45	56.3	78.9	8.36	.0729	351	1	100.0	15
10/11/24	3:45p	79.4	46	56.8	78.9	8.46	.0728	351	1	100.0	15
10/11/24	4:00p	78.9	45	55.8	78.3	8.37	.0729	351	1	100.0	15
10/11/24	4:15p	78.7	43	54.3	77.8	8.05	.0730	352	1	100.0	15
10/11/24	4:30p	79.0	43	54.6	78.2	8.05	.0730	351	1	100.0	15
10/11/24	4:45p	78.8	46	56.3	78.3	8.47	.0729	351	1	100.0	15
10/11/24	5:00p	78.3	46	55.8	77.8	8.48	.0730	351	1	100.0	15
10/11/24	5:15p	78.1	44	54.4	77.3	8.19	.0731	352	1	100.0	15
10/11/24	5:30p	78.1	43	53.8	77.2	8.05	.0731	351	1	100.0	15
10/11/24	5:45p	78.2	45	55.1	77.5	8.39	.0730	351	1	100.0	15
10/11/24	6:00p	77.9	48	56.6	77.6	8.89	.0730	351	1	100.0	15
10/11/24	6:15p	77.6	47	55.8	77.2	8.70	.0731	352	1	100.0	15
10/11/24	6:30p	77.4	45	54.4	76.8	8.40	.0732	351	1	100.0	15
10/11/24	6:45p	77.6	44	54.0	76.8	8.20	.0732	351	1	100.0	15
10/11/24	7:00p	77.4	48	56.2	77.1	8.90	.0731	351	1	100.0	15
10/11/24	7:15p	76.9	47	55.1	76.5	8.71	.0732	351	1	100.0	15
10/11/24	7:30p	76.7	45	53.8	76.1	8.42	.0733	352	1	100.0	15
10/11/24	7:45p	76.9	46	54.5	76.4	8.51	.0733	351	1	100.0	15
10/11/24	8:00p	76.6	50	56.6	76.5	9.22	.0733	351	1	100.0	15
10/11/24	8:15p	76.4	48	55.3	76.1	8.92	.0733	351	1	100.0	15
10/11/24	8:30p	76.7	46	54.4	76.2	8.52	.0733	352	1	100.0	15
10/11/24	8:45p	76.4	52	57.5	76.4	9.52	.0733	351	1	100.0	15
10/11/24	9:00p	76.0	49	55.5	75.8	9.03	.0734	351	1	100.0	15
10/11/24	9:15p	76.2	47	54.5	75.8	8.73	.0735	351	1	100.0	15
10/11/24	9:30p	76.1	53	57.7	76.2	9.65	.0733	352	1	100.0	15
10/11/24	9:45p	75.8	51	56.4	75.8	9.35	.0734	351	1	100.0	15
10/11/24	10:00p	76.0	48	54.9	75.7	8.93	.0735	351	1	100.0	15
10/11/24	10:15p	75.8	54	58.0	75.9	9.83	.0734	351	1	100.0	15
10/11/24	10:30p	75.6	50	55.6	75.5	9.24	.0735	351	1	100.0	15
10/11/24	10:45p	75.9	52	57.0	75.9	9.53	.0734	352	1	100.0	15
10/11/24	11:00p	75.4	52	56.5	75.4	9.54	.0735	351	1	100.0	15
10/11/24	11:15p	75.7	47	54.0	75.3	8.74	.0736	351	1	100.0	15
10/11/24	11:30p	75.3	52	56.5	75.3	9.54	.0735	351	1	100.0	15
10/11/24	11:45p	75.3	48	54.3	75.0	8.94	.0736	352	1	100.0	15
10/12/24	12:00a	75.4	51	56.0	75.4	9.35	.0735	351	1	100.0	15

STATE OF CALIFORNIA

DEPARTMENT OF CORRECTIONS AND REHABILITATION

OUTSIDE TEMPERATURE RECORD

CDCR 2030 (04/18)

INSTITUTION: North Kern State Prison

From May 1st through October 31st, the warden shall designate staff to be responsible to monitor and log the OUTSIDE ambient air temperature.

Using an accurate thermometer located in a central, heat neutral location, the outside air temperature is to be taken every hour, seven (7) days a week.

Thermometer Location: Central control roof top

Immediately notify the Watch Commander at extension 3141 when the air temperature reaches 90 degrees.

Date	Time	Temp.	Printed Name
10/12/24	0100	65	J. FIERRO
	0200	63	J. FIERRO
	0300	58	J. FIERRO
	0400	57	J. FIERRO
	0500	57	J. FIERRO
	0600	55	Gonzalez
	0700	54	Gonzalez
	0800	56	Gonzalez
	0900	62	Gonzalez
	1000	65	Gonzalez
	1100	69	Gonzalez
	1200	74	Gonzalez
	1300	77	Gonzalez
	1400	79	Gonzalez
	1500	82	Gonzalez
	1600	83	Gonzalez
	1700	83	Gonzalez
	1800	82	Gonzalez
	1900	78	Gonzalez
	2000	75	Gonzalez
	2100	71	Gonzalez
	2200	70	C. Reys
	2300	68	CReys
	2400	66	CReys

Date	Time	Temp.	Printed Name
10-13-24	0100	64	CReys
	0200	60	CReys
	0300	58	CReys
	0400	58	CReys
	0500	58	CReys
	0600	56	Gonzalez
	0700	56	Gonzalez
	0800	57	Gonzalez
	0900	64	Gonzalez
	1000	67	Gonzalez
	1100	68	Gonzalez
	1200	70	Gonzalez
	1300	73	Gonzalez
	1400	76	Gonzalez
	1500	78	Gonzalez
	1600	80	Gonzalez
	1700	81	Gonzalez
	1800	80	Gonzalez
	1900	76	Gonzalez
	2000	73	Gonzalez
	2100	70	Gonzalez
	2200	67	ARIAS
	2300	64	ARIAS
	2400	63	ARIAS

DISTRIBUTION: Original: Institution Heat Plan Coordinator

NKSP 10/12/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/12/24	12:15a	68.2	69.6	68.1	0	---	2.0	SW	0.50	5.0	SW	68.2	61.1	61.1	30.116	0.00	0.00	0.000	0.033
10/12/24	12:30a	66.9	68.1	66.8	---	---	0.0	SW	0.00	2.0	SW	66.9	---	---	30.117	0.00	0.00	0.000	0.020
10/12/24	12:45a	66.0	67.0	66.0	---	---	1.0	S	0.25	3.0	S	66.0	---	---	30.116	0.00	0.00	0.000	0.010
10/12/24	1:00a	65.7	66.0	65.7	---	---	0.0	S	0.00	3.0	S	65.7	---	---	30.120	0.00	0.00	0.000	0.007
10/12/24	1:15a	66.1	66.1	65.7	0	---	0.0	S	0.00	2.0	S	66.1	59.1	59.1	30.121	0.00	0.00	0.000	0.011
10/12/24	1:30a	66.1	66.4	66.1	0	---	0.0	S	0.00	2.0	S	66.1	59.1	59.1	30.121	0.00	0.00	0.000	0.011
10/12/24	1:45a	65.0	66.2	65.0	1	-38.3	0.0	S	0.00	4.0	S	65.0	58.2	58.2	30.125	0.00	0.00	0.000	0.000
10/12/24	2:00a	63.7	65.1	63.7	4	-13.2	0.0	S	0.00	3.0	S	63.7	57.4	57.4	30.126	0.00	0.00	0.014	0.000
10/12/24	2:15a	61.0	63.7	61.0	7	-3.7	1.0	S	0.25	4.0	S	61.0	55.6	55.6	30.130	0.00	0.00	0.042	0.000
10/12/24	2:30a	59.7	60.9	59.7	9	0.7	3.0	SSW	0.75	6.0	SW	59.7	54.9	54.9	30.128	0.00	0.00	0.055	0.000
10/12/24	2:45a	58.6	59.7	58.6	12	6.1	3.0	WSW	0.75	7.0	WSW	58.6	54.1	54.1	30.129	0.00	0.00	0.067	0.000
10/12/24	3:00a	58.2	58.6	58.1	14	9.1	4.0	WSW	1.00	7.0	SW	58.2	53.8	53.8	30.127	0.00	0.00	0.071	0.000
10/12/24	3:15a	58.5	58.5	58.2	15	10.9	3.0	WSW	0.75	6.0	W	58.5	54.0	54.0	30.127	0.00	0.00	0.068	0.000
10/12/24	3:30a	58.2	58.6	58.2	15	10.7	3.0	WSW	0.75	5.0	WSW	58.2	53.8	53.8	30.124	0.00	0.00	0.071	0.000
10/12/24	3:45a	57.7	58.2	57.7	16	11.7	3.0	W	0.75	6.0	W	57.7	53.4	53.4	30.125	0.00	0.00	0.076	0.000
10/12/24	4:00a	57.6	57.7	57.5	17	13.0	2.0	W	0.50	6.0	W	57.6	53.4	53.4	30.125	0.00	0.00	0.077	0.000
10/12/24	4:15a	57.6	57.7	57.6	18	14.3	1.0	W	0.25	3.0	W	57.6	53.5	53.5	30.125	0.00	0.00	0.077	0.000
10/12/24	4:30a	57.1	57.6	57.1	18	13.9	0.0	---	0.00	0.0	---	57.1	53.1	53.1	30.129	0.00	0.00	0.082	0.000
10/12/24	4:45a	56.8	57.1	56.8	19	14.9	0.0	W	0.00	1.0	W	56.8	52.9	52.9	30.133	0.00	0.00	0.085	0.000
10/12/24	5:00a	57.0	57.0	56.8	18	13.8	0.0	W	0.00	2.0	W	57.0	53.0	53.0	30.136	0.00	0.00	0.083	0.000
10/12/24	5:15a	56.7	57.0	56.7	18	13.6	0.0	W	0.00	1.0	W	56.7	52.7	52.7	30.139	0.00	0.00	0.086	0.000
10/12/24	5:30a	56.0	56.7	56.0	20	15.4	1.0	SSE	0.25	4.0	S	56.0	52.2	52.2	30.143	0.00	0.00	0.094	0.000
10/12/24	5:45a	55.9	56.0	55.8	21	16.5	0.0	SSE	0.00	2.0	SSE	55.9	52.2	52.2	30.149	0.00	0.00	0.095	0.000
10/12/24	6:00a	55.2	55.9	55.1	22	17.0	0.0	SSE	0.00	3.0	SSE	55.2	51.7	51.7	30.154	0.00	0.00	0.102	0.000
10/12/24	6:15a	54.7	55.2	54.6	24	18.6	2.0	SE	0.50	4.0	SE	54.7	51.4	51.4	30.156	0.00	0.00	0.107	0.000
10/12/24	6:30a	54.0	54.8	53.9	26	19.8	2.0	SSE	0.50	5.0	SE	54.0	51.0	51.0	30.166	0.00	0.00	0.115	0.000
10/12/24	6:45a	54.2	54.2	53.9	25	19.1	2.0	SSE	0.50	4.0	SSE	54.2	51.1	51.1	30.168	0.00	0.00	0.112	0.000
10/12/24	7:00a	54.1	54.2	54.1	25	19.0	1.0	SSE	0.25	4.0	S	54.1	51.0	51.0	30.172	0.00	0.00	0.114	0.000
10/12/24	7:15a	53.8	54.2	53.7	26	19.7	1.0	S	0.25	4.0	S	53.8	50.8	50.8	30.177	0.00	0.00	0.117	0.000
10/12/24	7:30a	54.7	54.7	53.8	25	19.5	0.0	S	0.00	3.0	S	54.7	51.5	51.5	30.183	0.00	0.00	0.107	0.000
10/12/24	7:45a	55.1	55.2	54.7	24	18.9	0.0	S	0.00	1.0	S	55.1	51.7	51.7	30.185	0.00	0.00	0.103	0.000
10/12/24	8:00a	56.3	56.3	55.1	23	18.9	0.0	---	0.00	0.0	---	56.3	52.6	52.6	30.193	0.00	0.00	0.091	0.000
10/12/24	8:15a	58.4	58.4	56.3	17	13.7	2.0	WSW	0.50	5.0	SW	58.4	54.0	54.0	30.199	0.00	0.00	0.069	0.000
10/12/24	8:30a	60.3	60.3	58.4	13	9.2	3.0	WSW	0.75	7.0	WSW	60.3	55.5	55.5	30.204	0.00	0.00	0.049	0.000
10/12/24	8:45a	61.4	61.4	60.4	10	4.2	4.0	WSW	1.00	8.0	WSW	61.4	56.5	56.5	30.212	0.00	0.00	0.037	0.000
10/12/24	9:00a	62.1	62.2	61.4	9	2.5	4.0	WSW	1.00	7.0	WSW	62.1	56.9	56.9	30.211	0.00	0.00	0.030	0.000
10/12/24	9:15a	62.9	62.9	62.1	9	3.1	3.0	WSW	0.75	7.0	WSW	62.9	57.6	57.6	30.214	0.00	0.00	0.022	0.000
10/12/24	9:30a	63.9	63.9	62.9	8	1.3	3.0	WSW	0.75	8.0	WSW	63.9	58.3	58.3	30.217	0.00	0.00	0.011	0.000
10/12/24	9:45a	64.3	64.3	63.8	8	1.6	3.0	W	0.75	8.0	WSW	64.3	58.6	58.6	30.219	0.00	0.00	0.007	0.000
10/12/24	10:00a	65.9	65.9	64.3	6	-3.3	2.0	SW	0.50	7.0	SSW	65.9	59.7	59.7	30.224	0.00	0.00	0.000	0.009
10/12/24	10:15a	66.9	66.9	65.9	5	-6.4	2.0	WSW	0.50	6.0	SSW	66.9	60.3	60.3	30.222	0.00	0.00	0.000	0.020
10/12/24	10:30a	68.1	68.1	66.9	3	-15.9	3.0	SW	0.75	8.0	SSW	68.1	61.3	61.3	30.219	0.00	0.00	0.000	0.032
10/12/24	10:45a	69.0	69.0	68.1	1	-35.8	3.0	SW	0.75	9.0	SW	69.0	62.5	62.5	30.215	0.00	0.00	0.000	0.042
10/12/24	11:00a	69.7	69.7	69.0	0	---	3.0	WSW	0.75	7.0	WSW	69.7	63.4	63.4	30.210	0.00	0.00	0.000	0.049
10/12/24	11:15a	71.0	71.1	69.7	0	---	3.0	SW	0.75	6.0	SSW	71.0	65.2	65.2	30.206	0.00	0.00	0.000	0.063
10/12/24	11:30a	72.2	72.2	71.1	0	---	3.0	W	0.75	9.0	W	72.2	66.7	66.7	30.205	0.00	0.00	0.000	0.075
10/12/24	11:45a	72.8	72.8	72.2	0	---	3.0	W	0.75	8.0	WSW	72.8	67.5	67.5	30.195	0.00	0.00	0.000	0.081
10/12/24	12:00p	74.5	74.5	72.9	0	---	4.0	W	1.00	12.0	WSW	74.5	69.7	69.7	30.192	0.00	0.00	0.000	0.099
10/12/24	12:15p	75.1	75.1	74.4	0	---	3.0	WSW	0.75	11.0	WSW	75.1	70.4	70.4	30.188	0.00	0.00	0.000	0.105
10/12/24	12:30p	76.0	76.2	75.1	0	---	3.0	W	0.75	10.0	WNW	76.0	71.4	71.4	30.185	0.00	0.00	0.000	0.115

NKSP 10/12/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/12/24	12:45p	77.3	77.3	76.1	0	---	3.0	WSW	0.75	9.0	WNW	77.3	72.9	72.9	30.179	0.00	0.00	0.000	0.128
10/12/24	1:00p	77.9	78.1	77.2	0	---	4.0	W	1.00	10.0	NW	77.9	73.4	73.4	30.171	0.00	0.00	0.000	0.134
10/12/24	1:15p	77.8	78.0	77.6	0	---	5.0	NW	1.25	12.0	WNW	77.8	73.3	73.3	30.163	0.00	0.00	0.000	0.133
10/12/24	1:30p	78.7	78.7	77.8	0	---	5.0	NW	1.25	10.0	WNW	78.7	74.2	74.2	30.158	0.00	0.00	0.000	0.143
10/12/24	1:45p	79.4	79.5	78.7	0	---	5.0	WNW	1.25	12.0	W	79.4	74.9	74.9	30.151	0.00	0.00	0.000	0.150
10/12/24	2:00p	79.4	79.4	79.3	0	---	5.0	NW	1.25	10.0	N	79.4	74.9	74.9	30.143	0.00	0.00	0.000	0.150
10/12/24	2:15p	80.6	80.6	79.4	0	---	3.0	N	0.75	10.0	NW	80.6	76.0	76.0	30.141	0.00	0.00	0.000	0.162
10/12/24	2:30p	81.8	81.8	80.7	0	---	3.0	NE	0.75	10.0	WNW	81.8	77.2	77.2	30.137	0.00	0.00	0.000	0.175
10/12/24	2:45p	81.9	82.0	81.7	0	---	5.0	WNW	1.25	12.0	WNW	81.9	77.3	77.3	30.131	0.00	0.00	0.000	0.176
10/12/24	3:00p	82.0	82.0	81.8	0	---	4.0	W	1.00	10.0	WNW	82.0	77.4	77.4	30.130	0.00	0.00	0.000	0.177
10/12/24	3:15p	82.6	82.7	82.0	0	---	4.0	NNE	1.00	9.0	NE	82.6	77.9	77.9	30.125	0.00	0.00	0.000	0.183
10/12/24	3:30p	82.7	82.8	82.5	0	---	4.0	NW	1.00	10.0	NNW	82.7	78.0	78.0	30.121	0.00	0.00	0.000	0.184
10/12/24	3:45p	82.9	83.0	82.7	0	---	5.0	N	1.25	10.0	NNE	82.9	78.2	78.2	30.121	0.00	0.00	0.000	0.186
10/12/24	4:00p	83.4	83.5	82.9	0	---	4.0	NNE	1.00	9.0	NNE	83.4	78.6	78.6	30.124	0.00	0.00	0.000	0.192
10/12/24	4:15p	83.8	83.8	83.3	0	---	3.0	NW	0.75	9.0	NNW	83.8	78.9	78.9	30.122	0.00	0.00	0.000	0.196
10/12/24	4:30p	84.3	84.3	83.8	0	---	4.0	NNW	1.00	9.0	NW	84.3	79.4	79.4	30.115	0.00	0.00	0.000	0.201
10/12/24	4:45p	84.0	84.3	84.0	0	---	5.0	NNW	1.25	10.0	N	84.0	79.1	79.1	30.116	0.00	0.00	0.000	0.198
10/12/24	5:00p	83.8	84.0	83.8	0	---	5.0	NNW	1.25	10.0	NNW	83.8	78.9	78.9	30.109	0.00	0.00	0.000	0.196
10/12/24	5:15p	83.6	83.8	83.5	0	---	5.0	NNW	1.25	9.0	NNW	83.6	78.8	78.8	30.107	0.00	0.00	0.000	0.194
10/12/24	5:30p	83.3	83.6	83.3	0	---	4.0	NNW	1.00	8.0	NNW	83.3	78.5	78.5	30.113	0.00	0.00	0.000	0.191
10/12/24	5:45p	83.1	83.3	83.1	0	---	3.0	NNW	0.75	6.0	NNW	83.1	78.4	78.4	30.112	0.00	0.00	0.000	0.189
10/12/24	6:00p	82.6	83.2	82.6	0	---	2.0	N	0.50	5.0	NNW	82.6	77.9	77.9	30.110	0.00	0.00	0.000	0.183
10/12/24	6:15p	81.3	82.6	81.3	0	---	2.0	N	0.50	4.0	NNW	81.3	76.7	76.7	30.110	0.00	0.00	0.000	0.170
10/12/24	6:30p	80.4	81.3	80.4	0	---	1.0	N	0.25	3.0	N	80.4	75.9	75.9	30.111	0.00	0.00	0.000	0.160
10/12/24	6:45p	79.4	80.5	79.4	0	---	1.0	N	0.25	3.0	N	79.4	74.9	74.9	30.114	0.00	0.00	0.000	0.150
10/12/24	7:00p	78.6	79.4	78.6	0	---	3.0	NNW	0.75	4.0	NNW	78.6	74.1	74.1	30.120	0.00	0.00	0.000	0.142
10/12/24	7:15p	77.8	78.7	77.8	0	---	3.0	NNW	0.75	5.0	NNW	77.8	73.3	73.3	30.122	0.00	0.00	0.000	0.133
10/12/24	7:30p	76.2	77.8	76.1	0	---	3.0	NW	0.75	7.0	W	76.2	71.6	71.6	30.127	0.00	0.00	0.000	0.117
10/12/24	7:45p	75.9	76.1	75.8	0	---	2.0	NW	0.50	4.0	NW	75.9	71.3	71.3	30.125	0.00	0.00	0.000	0.114
10/12/24	8:00p	75.4	75.9	75.4	0	---	2.0	NW	0.50	4.0	NW	75.4	70.7	70.7	30.127	0.00	0.00	0.000	0.108
10/12/24	8:15p	74.5	75.4	74.4	---	---	0.0	NW	0.00	2.0	NW	74.5	---	---	30.130	0.00	0.00	0.000	0.099
10/12/24	8:30p	73.5	74.4	73.5	1	-33.1	0.0	NW	0.00	1.0	NW	73.5	68.5	68.5	30.132	0.00	0.00	0.000	0.089
10/12/24	8:45p	72.6	73.5	72.6	2	-20.8	0.0	NW	0.00	1.0	NW	72.6	67.3	67.3	30.133	0.00	0.00	0.000	0.079
10/12/24	9:00p	71.8	72.6	71.8	1	-34.1	0.0	NW	0.00	1.0	NW	71.8	66.3	66.3	30.135	0.00	0.00	0.000	0.071
10/12/24	9:15p	71.6	71.8	71.6	0	---	1.0	NW	0.25	2.0	NW	71.6	66.0	66.0	30.140	0.00	0.00	0.000	0.069
10/12/24	9:30p	71.4	71.6	71.4	0	---	0.0	NW	0.00	2.0	NW	71.4	65.7	65.7	30.142	0.00	0.00	0.000	0.067
10/12/24	9:45p	70.8	71.4	70.8	1	-34.7	0.0	NW	0.00	2.0	NW	70.8	65.0	65.0	30.144	0.00	0.00	0.000	0.060
10/12/24	10:00p	70.1	70.8	70.1	3	-14.5	0.0	NW	0.00	1.0	NW	70.1	64.1	64.1	30.150	0.00	0.00	0.000	0.053
10/12/24	10:15p	69.7	70.1	69.7	3	-14.8	0.0	---	0.00	0.0	---	69.7	63.6	63.6	30.154	0.00	0.00	0.000	0.049
10/12/24	10:30p	69.5	69.7	69.4	3	-14.9	0.0	---	0.00	0.0	---	69.5	63.3	63.3	30.157	0.00	0.00	0.000	0.047
10/12/24	10:45p	69.5	69.5	69.4	3	-14.9	0.0	---	0.00	0.0	---	69.5	63.3	63.3	30.156	0.00	0.00	0.000	0.047
10/12/24	11:00p	68.7	69.5	68.7	5	-5.1	0.0	---	0.00	0.0	---	68.7	62.4	62.4	30.160	0.00	0.00	0.000	0.039
10/12/24	11:15p	68.6	68.7	68.5	5	-5.2	0.0	---	0.00	0.0	---	68.6	62.3	62.3	30.159	0.00	0.00	0.000	0.037
10/12/24	11:30p	68.4	68.7	68.4	5	-5.3	0.0	---	0.00	0.0	---	68.4	62.0	62.0	30.160	0.00	0.00	0.000	0.035
10/12/24	11:45p	67.4	68.4	67.4	5	-6.0	0.0	---	0.00	0.0	---	67.4	60.8	60.8	30.159	0.00	0.00	0.000	0.025
10/13/24	12:00a	66.2	67.4	66.2	8	3.0	0.0	W	0.00	2.0	NW	66.2	60.4	60.4	30.158	0.00	0.00	0.000	0.012

NKSP 10/13/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/13/24	12:15a	65.5	66.2	65.5	9	5.1	0.0	W	0.00	2.0	W	65.5	60.0	60.0	30.157	0.00	0.00	0.000	0.005
10/13/24	12:30a	65.0	65.5	65.0	10	7.0	0.0	W	0.00	2.0	W	65.0	59.8	59.8	30.155	0.00	0.00	0.000	0.000
10/13/24	12:45a	64.2	65.1	64.2	11	8.5	1.0	W	0.25	2.0	W	64.2	59.0	59.0	30.154	0.00	0.00	0.008	0.000
10/13/24	1:00a	64.2	64.2	64.0	12	10.5	0.0	---	0.00	0.0	---	64.2	59.0	59.0	30.154	0.00	0.00	0.006	0.000
10/13/24	1:15a	63.7	64.2	63.6	14	13.5	0.0	---	0.00	0.0	---	63.7	58.5	58.5	30.153	0.00	0.00	0.014	0.000
10/13/24	1:30a	62.9	63.7	62.9	15	14.5	0.0	---	0.00	0.0	---	62.9	57.8	57.8	30.153	0.00	0.00	0.022	0.000
10/13/24	1:45a	61.3	62.9	61.3	18	17.4	1.0	S	0.25	4.0	SSE	61.3	56.6	56.6	30.153	0.00	0.00	0.039	0.000
10/13/24	2:00a	60.2	61.3	60.2	21	20.1	1.0	SE	0.25	5.0	SE	60.2	55.8	55.8	30.155	0.00	0.00	0.050	0.000
10/13/24	2:15a	59.2	60.3	59.2	22	20.3	1.0	SE	0.25	3.0	SE	59.2	55.0	55.0	30.153	0.00	0.00	0.060	0.000
10/13/24	2:30a	58.8	59.3	58.7	24	22.0	1.0	SSE	0.25	4.0	SSE	58.8	54.8	54.8	30.155	0.00	0.00	0.065	0.000
10/13/24	2:45a	58.6	58.9	58.6	24	21.9	0.0	SSE	0.00	2.0	SSE	58.6	54.6	54.6	30.154	0.00	0.00	0.067	0.000
10/13/24	3:00a	58.6	58.6	58.5	25	22.8	1.0	S	0.25	4.0	SSE	58.6	54.7	54.7	30.150	0.00	0.00	0.067	0.000
10/13/24	3:15a	58.7	58.7	58.5	25	22.9	1.0	S	0.25	4.0	S	58.7	54.8	54.8	30.146	0.00	0.00	0.066	0.000
10/13/24	3:30a	58.6	58.8	58.5	25	22.8	1.0	S	0.25	4.0	S	58.6	54.7	54.7	30.140	0.00	0.00	0.067	0.000
10/13/24	3:45a	58.5	58.6	58.4	26	23.7	0.0	S	0.00	4.0	S	58.5	54.7	54.7	30.141	0.00	0.00	0.068	0.000
10/13/24	4:00a	58.7	58.7	58.4	26	23.9	1.0	S	0.25	4.0	S	58.7	54.9	54.9	30.139	0.00	0.00	0.066	0.000
10/13/24	4:15a	59.2	59.2	58.7	26	24.3	0.0	S	0.00	2.0	S	59.2	55.3	55.3	30.138	0.00	0.00	0.060	0.000
10/13/24	4:30a	59.2	59.4	59.2	26	24.3	0.0	---	0.00	0.0	---	59.2	55.3	55.3	30.143	0.00	0.00	0.060	0.000
10/13/24	4:45a	59.4	59.5	59.2	26	24.5	0.0	---	0.00	0.0	---	59.4	55.5	55.5	30.139	0.00	0.00	0.058	0.000
10/13/24	5:00a	58.9	59.4	58.9	26	24.0	0.0	---	0.00	0.0	---	58.9	55.1	55.1	30.142	0.00	0.00	0.064	0.000
10/13/24	5:15a	57.7	58.9	57.7	27	23.9	0.0	---	0.00	0.0	---	57.7	54.2	54.2	30.145	0.00	0.00	0.076	0.000
10/13/24	5:30a	57.5	57.7	57.5	29	25.5	1.0	SE	0.25	4.0	SE	57.5	54.2	54.2	30.143	0.00	0.00	0.078	0.000
10/13/24	5:45a	57.1	57.6	57.1	30	25.9	3.0	ESE	0.75	6.0	ESE	57.1	54.0	54.0	30.148	0.00	0.00	0.082	0.000
10/13/24	6:00a	56.9	57.1	56.9	31	26.5	3.0	ESE	0.75	7.0	ESE	56.9	53.9	53.9	30.151	0.00	0.00	0.084	0.000
10/13/24	6:15a	56.5	56.9	56.5	30	25.4	2.0	ESE	0.50	7.0	ESE	56.5	53.5	53.5	30.153	0.00	0.00	0.089	0.000
10/13/24	6:30a	56.3	56.5	56.2	31	26.0	1.0	ESE	0.25	3.0	ESE	56.3	53.3	53.3	30.155	0.00	0.00	0.091	0.000
10/13/24	6:45a	56.5	56.5	56.1	32	27.0	2.0	ESE	0.50	4.0	SE	56.5	53.6	53.6	30.155	0.00	0.00	0.089	0.000
10/13/24	7:00a	56.0	56.5	56.0	32	26.5	1.0	SE	0.25	3.0	SE	56.0	53.1	53.1	30.160	0.00	0.00	0.094	0.000
10/13/24	7:15a	55.7	56.0	55.6	33	27.0	1.0	SE	0.25	3.0	SE	55.7	52.9	52.9	30.159	0.00	0.00	0.097	0.000
10/13/24	7:30a	56.3	56.3	55.7	32	26.8	1.0	SE	0.25	3.0	SE	56.3	53.4	53.4	30.164	0.00	0.00	0.091	0.000
10/13/24	7:45a	56.7	56.7	56.2	32	27.1	1.0	SE	0.25	3.0	SE	56.7	53.8	53.8	30.169	0.00	0.00	0.086	0.000
10/13/24	8:00a	57.9	57.9	56.7	32	28.2	0.0	SSE	0.00	2.0	SSE	57.9	54.8	54.8	30.172	0.00	0.00	0.074	0.000
10/13/24	8:15a	59.8	59.8	58.0	32	29.9	1.0	S	0.25	4.0	SSE	59.8	56.6	56.6	30.179	0.00	0.00	0.054	0.000
10/13/24	8:30a	62.4	62.5	59.8	31	31.3	1.0	S	0.25	4.0	S	62.4	59.0	59.0	30.180	0.00	0.00	0.027	0.000
10/13/24	8:45a	63.8	63.9	62.5	29	30.9	3.0	SSW	0.75	6.0	S	63.8	60.1	60.1	30.182	0.00	0.00	0.013	0.000
10/13/24	9:00a	64.6	64.6	63.8	29	31.6	2.0	W	0.50	6.0	SSW	64.6	60.9	60.9	30.183	0.00	0.00	0.004	0.000
10/13/24	9:15a	65.0	65.0	64.6	30	32.8	3.0	W	0.75	6.0	W	65.0	61.5	61.5	30.186	0.00	0.00	0.000	0.000
10/13/24	9:30a	65.9	66.0	65.0	29	32.7	3.0	SW	0.75	6.0	W	65.9	62.3	62.3	30.183	0.00	0.00	0.000	0.009
10/13/24	9:45a	67.1	67.1	65.9	27	32.0	2.0	SW	0.50	7.0	WSW	67.1	63.1	63.1	30.189	0.00	0.00	0.000	0.022
10/13/24	10:00a	67.1	67.2	67.0	27	32.0	3.0	WNW	0.75	9.0	NW	67.1	63.1	63.1	30.188	0.00	0.00	0.000	0.022
10/13/24	10:15a	67.3	67.3	67.0	26	31.2	2.0	W	0.50	9.0	NW	67.3	63.1	63.1	30.186	0.00	0.00	0.000	0.024
10/13/24	10:30a	67.7	67.7	67.3	26	31.6	3.0	WSW	0.75	9.0	W	67.7	63.7	63.7	30.187	0.00	0.00	0.000	0.028
10/13/24	10:45a	67.7	67.8	67.5	27	32.5	7.0	WNW	1.75	12.0	W	67.7	63.8	63.8	30.186	0.00	0.00	0.000	0.028
10/13/24	11:00a	68.2	68.2	67.8	26	32.0	3.0	NW	0.75	8.0	W	68.2	64.3	64.3	30.181	0.00	0.00	0.000	0.033
10/13/24	11:15a	68.1	68.3	68.1	26	31.9	4.0	WNW	1.00	8.0	W	68.1	64.2	64.2	30.178	0.00	0.00	0.000	0.032
10/13/24	11:30a	68.8	68.8	68.1	25	31.5	3.0	NNW	0.75	8.0	W	68.8	64.7	64.7	30.176	0.00	0.00	0.000	0.040
10/13/24	11:45a	70.0	70.0	68.8	23	30.5	5.0	NW	1.25	12.0	NW	70.0	65.7	65.7	30.169	0.00	0.00	0.000	0.052
10/13/24	12:00p	70.6	70.6	70.0	22	29.9	4.0	WNW	1.00	12.0	NW	70.6	66.6	66.6	30.164	0.00	0.00	0.000	0.058
10/13/24	12:15p	71.3	71.3	70.6	19	26.9	4.0	W	1.00	12.0	W	71.3	67.3	67.3	30.158	0.00	0.00	0.000	0.066
10/13/24	12:30p	71.9	72.0	71.2	18	26.1	6.0	WNW	1.50	10.0	WNW	71.9	68.1	68.1	30.153	0.00	0.00	0.000	0.072

NKSP 10/13/24

Date	Time	Temp Out	Hi Temp	Low Temp	Out Hum	Dew Pt.	Wind Speed	Wind Dir	Wind Run	Hi Speed	Hi Dir	Wind Chill	Heat Index	THW Index	Bar	Rain	Rain Rate	Heat D-D	Cool D-D
10/13/24	12:45p	72.5	72.6	71.8	16	23.7	6.0	WNW	1.50	11.0	NW	72.5	68.7	68.7	30.148	0.00	0.00	0.000	0.078
10/13/24	1:00p	73.6	73.6	72.5	14	21.4	4.0	WSW	1.00	11.0	W	73.6	70.0	70.0	30.138	0.00	0.00	0.000	0.090
10/13/24	1:15p	74.3	74.4	73.5	13	20.2	4.0	WSW	1.00	11.0	WSW	74.3	70.8	70.8	30.131	0.00	0.00	0.000	0.097
10/13/24	1:30p	75.1	75.1	74.3	11	17.0	2.0	WNW	0.50	8.0	NW	75.1	71.6	71.6	30.125	0.00	0.00	0.000	0.105
10/13/24	1:45p	75.8	75.9	75.0	10	15.3	3.0	W	0.75	9.0	NW	75.8	72.2	72.2	30.119	0.00	0.00	0.000	0.113
10/13/24	2:00p	76.2	76.3	75.6	8	10.5	2.0	NNW	0.50	9.0	NW	76.2	72.2	72.2	30.112	0.00	0.00	0.000	0.117
10/13/24	2:15p	76.7	76.8	76.2	7	7.9	3.0	NNW	0.75	9.0	WNW	76.7	72.7	72.7	30.108	0.00	0.00	0.000	0.122
10/13/24	2:30p	77.6	77.6	76.7	5	1.2	3.0	WNW	0.75	9.0	WNW	77.6	73.7	73.7	30.096	0.00	0.00	0.000	0.131
10/13/24	2:45p	78.2	78.2	77.5	4	-3.1	2.0	NE	0.50	7.0	NNE	78.2	74.3	74.3	30.095	0.00	0.00	0.000	0.137
10/13/24	3:00p	78.5	78.5	78.2	4	-2.9	3.0	NNW	0.75	10.0	WNW	78.5	74.6	74.6	30.092	0.00	0.00	0.000	0.141
10/13/24	3:15p	79.3	79.4	78.5	2	-16.4	3.0	NW	0.75	8.0	NW	79.3	75.0	75.0	30.089	0.00	0.00	0.000	0.149
10/13/24	3:30p	79.7	79.8	79.2	2	-16.2	2.0	WNW	0.50	8.0	NNE	79.7	75.4	75.4	30.085	0.00	0.00	0.000	0.153
10/13/24	3:45p	80.5	80.6	79.8	0	---	3.0	WNW	0.75	8.0	NNW	80.5	75.9	75.9	30.086	0.00	0.00	0.000	0.161
10/13/24	4:00p	80.6	80.6	80.3	0	---	2.0	WNW	0.50	7.0	NW	80.6	76.0	76.0	30.086	0.00	0.00	0.000	0.162
10/13/24	4:15p	81.3	81.4	80.7	0	---	2.0	NW	0.50	6.0	SW	81.3	76.7	76.7	30.083	0.00	0.00	0.000	0.170
10/13/24	4:30p	81.9	81.9	81.2	---	---	1.0	NNW	0.25	4.0	WSW	81.9	---	---	30.078	0.00	0.00	0.000	0.176
10/13/24	4:45p	81.5	81.9	81.4	---	---	3.0	W	0.75	9.0	W	81.5	---	---	30.081	0.00	0.00	0.000	0.172
10/13/24	5:00p	81.1	81.6	81.1	0	---	2.0	NW	0.50	6.0	NNW	81.1	76.5	76.5	30.078	0.00	0.00	0.000	0.168
10/13/24	5:15p	81.1	81.2	81.0	---	---	2.0	NNE	0.50	7.0	NW	81.1	---	---	30.075	0.00	0.00	0.000	0.168
10/13/24	5:30p	80.9	81.1	80.8	0	---	2.0	NNE	0.50	5.0	NNE	80.9	76.3	76.3	30.070	0.00	0.00	0.000	0.166
10/13/24	5:45p	80.6	80.9	80.6	0	---	3.0	N	0.75	8.0	N	80.6	76.0	76.0	30.070	0.00	0.00	0.000	0.162
10/13/24	6:00p	80.2	80.6	80.2	0	---	3.0	N	0.75	5.0	NW	80.2	75.7	75.7	30.069	0.00	0.00	0.000	0.158
10/13/24	6:15p	79.6	80.3	79.6	---	---	1.0	N	0.25	3.0	N	79.6	---	---	30.071	0.00	0.00	0.000	0.152
10/13/24	6:30p	78.8	79.6	78.8	0	---	1.0	N	0.25	3.0	N	78.8	74.3	74.3	30.073	0.00	0.00	0.000	0.144
10/13/24	6:45p	77.8	78.8	77.8	1	-30.5	0.0	N	0.00	2.0	N	77.8	73.5	73.5	30.077	0.00	0.00	0.000	0.133
10/13/24	7:00p	76.8	77.8	76.8	2	-18.1	1.0	N	0.25	3.0	N	76.8	72.4	72.4	30.078	0.00	0.00	0.000	0.123
10/13/24	7:15p	75.7	76.8	75.7	4	-4.8	1.0	N	0.25	2.0	N	75.7	71.2	71.2	30.084	0.00	0.00	0.000	0.111
10/13/24	7:30p	74.9	75.7	74.9	6	3.2	1.0	NNE	0.25	3.0	NNE	74.9	70.8	70.8	30.094	0.00	0.00	0.000	0.103
10/13/24	7:45p	74.1	74.9	74.0	9	11.6	1.0	NNE	0.25	2.0	NNE	74.1	70.0	70.0	30.097	0.00	0.00	0.000	0.095
10/13/24	8:00p	73.3	74.0	73.3	10	13.4	1.0	NNE	0.25	3.0	NNE	73.3	69.1	69.1	30.099	0.00	0.00	0.000	0.086
10/13/24	8:15p	73.0	73.4	73.0	9	10.8	0.0	NNE	0.00	2.0	NNE	73.0	68.6	68.6	30.100	0.00	0.00	0.000	0.083
10/13/24	8:30p	71.9	73.0	71.9	10	12.3	1.0	E	0.25	3.0	E	71.9	67.2	67.2	30.103	0.00	0.00	0.000	0.072
10/13/24	8:45p	70.7	71.9	70.7	13	17.4	1.0	ESE	0.25	3.0	ESE	70.7	65.8	65.8	30.107	0.00	0.00	0.000	0.059
10/13/24	9:00p	70.7	71.0	70.5	14	19.1	1.0	ESE	0.25	3.0	ESE	70.7	65.9	65.9	30.106	0.00	0.00	0.000	0.059
10/13/24	9:15p	70.4	70.7	70.2	17	23.5	1.0	ESE	0.25	3.0	ESE	70.4	65.8	65.8	30.112	0.00	0.00	0.000	0.056
10/13/24	9:30p	70.1	70.6	70.1	17	23.2	1.0	ESE	0.25	3.0	ESE	70.1	65.3	65.3	30.113	0.00	0.00	0.000	0.055
10/13/24	9:45p	69.1	70.1	69.1	17	22.4	2.0	ESE	0.50	4.0	ESE	69.1	64.2	64.2	30.114	0.00	0.00	0.000	0.043
10/13/24	10:00p	67.4	69.1	67.4	22	27.2	2.0	SE	0.50	3.0	SE	67.4	62.8	62.8	30.118	0.00	0.00	0.000	0.025
10/13/24	10:15p	67.3	67.6	67.3	21	26.0	1.0	ESE	0.25	3.0	ESE	67.3	62.6	62.6	30.121	0.00	0.00	0.000	0.024
10/13/24	10:30p	66.4	67.3	66.4	21	25.2	0.0	ESE	0.00	3.0	ESE	66.4	61.6	61.6	30.128	0.00	0.00	0.000	0.015
10/13/24	10:45p	65.8	66.4	65.8	22	25.9	1.0	SE	0.25	4.0	SE	65.8	61.1	61.1	30.124	0.00	0.00	0.000	0.008
10/13/24	11:00p	64.8	65.9	64.6	24	27.1	2.0	SE	0.50	4.0	SE	64.8	60.3	60.3	30.127	0.00	0.00	0.002	0.000
10/13/24	11:15p	64.5	64.7	64.2	24	26.9	1.0	ESE	0.25	3.0	SE	64.5	60.0	60.0	30.125	0.00	0.00	0.005	0.000
10/13/24	11:30p	63.8	64.4	63.8	26	28.2	2.0	ESE	0.50	4.0	ESE	63.8	59.6	59.6	30.125	0.00	0.00	0.013	0.000
10/13/24	11:45p	63.7	63.8	63.5	25	27.2	2.0	SE	0.50	4.0	ESE	63.7	59.3	59.3	30.129	0.00	0.00	0.014	0.000
10/14/24	12:00a	63.1	63.8	63.1	24	25.7	2.0	SE	0.50	4.0	SE	63.1	58.6	58.6	30.122	0.00	0.00	0.020	0.000

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/12/24	12:15a	75.0	49	54.5	74.8	9.05	.0736	350	1	100.0	15
10/12/24	12:30a	75.4	50	55.5	75.3	9.24	.0736	351	1	100.0	15
10/12/24	12:45a	74.9	49	54.4	74.7	9.05	.0737	352	1	100.0	15
10/12/24	1:00a	75.3	47	53.7	74.9	8.74	.0736	351	1	100.0	15
10/12/24	1:15a	74.7	48	53.7	74.4	8.94	.0737	351	1	100.0	15
10/12/24	1:30a	75.3	45	52.5	74.7	8.44	.0737	351	1	100.0	15
10/12/24	1:45a	74.6	47	53.0	74.2	8.75	.0738	352	1	100.0	15
10/12/24	2:00a	75.2	44	51.8	74.5	8.25	.0737	351	1	100.0	15
10/12/24	2:15a	74.5	47	52.9	74.1	8.75	.0738	351	1	100.0	15
10/12/24	2:30a	75.2	44	51.8	74.5	8.25	.0737	351	1	100.0	15
10/12/24	2:45a	74.3	47	52.8	73.8	8.75	.0738	352	1	100.0	15
10/12/24	3:00a	74.8	46	52.6	74.3	8.55	.0738	351	1	100.0	15
10/12/24	3:15a	74.8	43	50.8	74.0	8.06	.0738	351	1	100.0	15
10/12/24	3:30a	74.2	46	52.1	73.6	8.57	.0739	351	1	100.0	15
10/12/24	3:45a	74.8	45	52.0	74.2	8.45	.0738	351	1	100.0	15
10/12/24	4:00a	74.6	43	50.6	73.8	8.07	.0739	352	1	100.0	15
10/12/24	4:15a	74.2	46	52.1	73.6	8.57	.0739	351	1	100.0	15
10/12/24	4:30a	74.7	45	51.9	74.1	8.45	.0738	351	1	100.0	15
10/12/24	4:45a	74.6	42	50.0	73.7	7.96	.0739	351	1	100.0	15
10/12/24	5:00a	74.0	45	51.3	73.3	8.45	.0740	352	1	100.0	15
10/12/24	5:15a	74.6	45	51.9	74.0	8.45	.0739	351	1	100.0	15
10/12/24	5:30a	75.0	44	51.6	74.3	8.25	.0738	351	1	100.0	15
10/12/24	5:45a	73.9	45	51.2	73.2	8.45	.0740	351	1	100.0	15
10/12/24	6:00a	74.2	46	52.1	73.6	8.57	.0739	352	1	100.0	15
10/12/24	6:15a	74.8	44	51.4	74.1	8.25	.0739	351	1	100.0	15
10/12/24	6:30a	73.8	46	51.7	73.2	8.57	.0740	351	1	100.0	15
10/12/24	6:45a	74.1	46	52.0	73.5	8.57	.0740	351	1	100.0	15
10/12/24	7:00a	74.7	45	51.9	74.1	8.45	.0739	351	1	100.0	15
10/12/24	7:15a	75.3	45	52.5	74.7	8.44	.0738	352	1	100.0	15
10/12/24	7:30a	75.3	43	51.3	74.5	8.05	.0739	351	1	100.0	15
10/12/24	7:45a	75.0	45	52.2	74.4	8.45	.0739	351	1	100.0	15
10/12/24	8:00a	75.3	45	52.5	74.7	8.44	.0739	351	1	100.0	15
10/12/24	8:15a	74.4	46	52.3	73.8	8.56	.0740	352	1	100.0	15
10/12/24	8:30a	74.6	46	52.4	74.1	8.56	.0740	351	1	100.0	15
10/12/24	8:45a	74.3	46	52.2	73.7	8.56	.0741	351	1	100.0	15
10/12/24	9:00a	74.5	46	52.4	73.9	8.56	.0740	351	1	100.0	15
10/12/24	9:15a	74.5	45	51.8	73.9	8.45	.0741	351	1	100.0	15
10/12/24	9:30a	74.7	46	52.5	74.2	8.56	.0740	352	1	100.0	15
10/12/24	9:45a	74.6	45	51.9	74.0	8.45	.0741	351	1	100.0	15
10/12/24	10:00a	74.9	46	52.7	74.4	8.55	.0740	351	1	100.0	15
10/12/24	10:15a	74.8	46	52.6	74.3	8.55	.0740	351	1	100.0	15
10/12/24	10:30a	75.4	46	53.2	74.9	8.54	.0739	352	1	100.0	15
10/12/24	10:45a	74.9	46	52.7	74.4	8.55	.0740	351	1	100.0	15
10/12/24	11:00a	75.4	42	50.7	74.5	7.94	.0740	351	1	100.0	15
10/12/24	11:15a	75.6	46	53.4	75.1	8.54	.0738	351	1	100.0	15
10/12/24	11:30a	75.3	45	52.5	74.7	8.44	.0739	352	1	100.0	15
10/12/24	11:45a	75.9	42	51.2	75.0	7.93	.0738	351	1	100.0	15
10/12/24	12:00p	75.8	45	52.9	75.2	8.43	.0738	351	1	100.0	15
10/12/24	12:15p	75.7	45	52.8	75.1	8.44	.0738	351	1	100.0	15
10/12/24	12:30p	76.3	41	50.9	75.3	7.75	.0738	351	1	100.0	15

NKSP 10/12/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/12/24	12:45p	76.5	45	53.6	75.9	8.42	.0736	352	1	100.0	15
10/12/24	1:00p	76.2	45	53.3	75.6	8.43	.0737	351	1	100.0	15
10/12/24	1:15p	76.3	42	51.5	75.4	7.92	.0737	351	1	100.0	15
10/12/24	1:30p	76.8	42	52.0	75.9	7.91	.0736	351	1	100.0	15
10/12/24	1:45p	76.6	45	53.7	76.0	8.42	.0735	352	1	100.0	15
10/12/24	2:00p	76.4	43	52.2	75.6	8.05	.0736	351	1	100.0	15
10/12/24	2:15p	77.0	42	52.1	76.1	7.91	.0735	351	1	100.0	15
10/12/24	2:30p	76.7	46	54.4	76.2	8.52	.0735	351	1	100.0	15
10/12/24	2:45p	76.7	43	52.5	75.9	8.05	.0735	352	1	100.0	15
10/12/24	3:00p	77.1	41	51.6	76.1	7.75	.0735	351	1	100.0	15
10/12/24	3:15p	77.2	45	54.2	76.6	8.41	.0734	351	1	100.0	15
10/12/24	3:30p	76.8	44	53.2	76.1	8.21	.0735	351	1	100.0	15
10/12/24	3:45p	77.3	41	51.8	76.3	7.75	.0734	351	1	100.0	15
10/12/24	4:00p	77.3	46	54.9	76.8	8.50	.0733	352	1	100.0	15
10/12/24	4:15p	77.1	44	53.5	76.4	8.21	.0734	351	1	100.0	15
10/12/24	4:30p	77.9	42	53.0	76.9	7.89	.0733	351	1	100.0	15
10/12/24	4:45p	78.0	45	54.9	77.3	8.39	.0732	351	1	100.0	15
10/12/24	5:00p	77.3	45	54.3	76.7	8.40	.0733	352	1	100.0	15
10/12/24	5:15p	77.5	41	51.9	76.4	7.75	.0734	351	1	100.0	15
10/12/24	5:30p	78.0	45	54.9	77.3	8.39	.0732	351	1	100.0	15
10/12/24	5:45p	77.8	46	55.4	77.3	8.49	.0732	351	1	100.0	15
10/12/24	6:00p	77.6	42	52.7	76.6	7.90	.0733	352	1	100.0	15
10/12/24	6:15p	77.6	47	55.8	77.2	8.70	.0732	351	1	100.0	15
10/12/24	6:30p	77.0	47	55.2	76.6	8.71	.0733	351	1	100.0	15
10/12/24	6:45p	77.1	43	52.9	76.3	8.05	.0734	351	1	100.0	15
10/12/24	7:00p	76.9	49	56.3	76.7	9.01	.0733	352	1	100.0	15
10/12/24	7:15p	76.4	47	54.7	76.0	8.72	.0735	351	1	100.0	15
10/12/24	7:30p	76.6	44	53.1	75.9	8.22	.0735	351	1	100.0	15
10/12/24	7:45p	76.3	50	56.3	76.2	9.22	.0734	351	1	100.0	15
10/12/24	8:00p	75.9	48	54.8	75.6	8.93	.0735	351	1	100.0	15
10/12/24	8:15p	76.3	46	54.0	75.8	8.52	.0735	352	1	100.0	15
10/12/24	8:30p	75.8	50	55.8	75.7	9.23	.0735	351	1	100.0	15
10/12/24	8:45p	75.8	47	54.1	75.4	8.73	.0736	351	1	100.0	15
10/12/24	9:00p	76.2	49	55.6	76.0	9.03	.0735	351	1	100.0	15
10/12/24	9:15p	75.5	50	55.6	75.4	9.24	.0736	352	1	100.0	15
10/12/24	9:30p	75.8	44	52.3	75.1	8.23	.0737	351	1	100.0	15
10/12/24	9:45p	75.7	50	55.7	75.6	9.24	.0736	351	1	100.0	15
10/12/24	10:00p	75.4	50	55.5	75.3	9.24	.0736	351	1	100.0	15
10/12/24	10:15p	76.0	46	53.7	75.5	8.53	.0736	351	1	100.0	15
10/12/24	10:30p	75.4	50	55.5	75.3	9.24	.0737	352	1	100.0	15
10/12/24	10:45p	75.5	46	53.3	75.0	8.54	.0737	351	1	100.0	15
10/12/24	11:00p	75.7	50	55.7	75.6	9.24	.0736	351	1	100.0	15
10/12/24	11:15p	75.2	49	54.7	75.0	9.05	.0737	351	1	100.0	15
10/12/24	11:30p	75.8	47	54.1	75.4	8.73	.0737	352	1	100.0	15
10/12/24	11:45p	75.0	49	54.5	74.8	9.05	.0738	351	1	100.0	15
10/13/24	12:00a	75.3	44	51.9	74.6	8.24	.0738	351	1	100.0	15

NKSP 10/13/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/13/24	12:15a	74.9	49	54.4	74.7	9.05	.0739	351	1	100.0	15
10/13/24	12:30a	74.9	46	52.7	74.4	8.55	.0738	351	1	100.0	15
10/13/24	12:45a	74.9	49	54.4	74.7	9.05	.0738	351	1	100.0	15
10/13/24	1:00a	74.8	46	52.6	74.3	8.55	.0738	351	1	100.0	15
10/13/24	1:15a	74.9	48	53.9	74.6	8.95	.0738	351	1	100.0	15
10/13/24	1:30a	74.9	46	52.7	74.4	8.55	.0738	352	1	100.0	15
10/13/24	1:45a	74.8	48	53.8	74.5	8.95	.0738	351	1	100.0	15
10/13/24	2:00a	75.1	44	51.7	74.4	8.25	.0738	351	1	100.0	15
10/13/24	2:15a	74.5	49	54.1	74.3	9.05	.0738	351	1	100.0	15
10/13/24	2:30a	75.1	48	54.1	74.8	8.95	.0737	352	1	100.0	15
10/13/24	2:45a	74.5	48	53.5	74.2	8.94	.0738	351	1	100.0	15
10/13/24	3:00a	74.8	48	53.8	74.5	8.95	.0738	351	1	100.0	15
10/13/24	3:15a	75.1	44	51.7	74.4	8.25	.0738	351	1	100.0	15
10/13/24	3:30a	74.3	49	53.9	74.0	9.05	.0738	351	1	100.0	15
10/13/24	3:45a	74.9	48	53.9	74.6	8.95	.0737	352	1	100.0	15
10/13/24	4:00a	74.6	46	52.4	74.1	8.56	.0738	351	1	100.0	15
10/13/24	4:15a	74.4	49	54.0	74.1	9.05	.0738	351	1	100.0	15
10/13/24	4:30a	75.0	48	54.0	74.7	8.95	.0737	351	1	100.0	15
10/13/24	4:45a	74.4	48	53.4	74.0	8.94	.0738	352	1	100.0	15
10/13/24	5:00a	74.4	49	54.0	74.1	9.05	.0738	351	1	100.0	15
10/13/24	5:15a	75.0	48	54.0	74.7	8.95	.0737	351	1	100.0	15
10/13/24	5:30a	74.6	47	53.0	74.2	8.75	.0738	351	1	100.0	15
10/13/24	5:45a	74.4	49	54.0	74.1	9.05	.0738	352	1	100.0	15
10/13/24	6:00a	75.0	49	54.5	74.8	9.05	.0737	351	1	100.0	15
10/13/24	6:15a	74.1	50	54.3	73.9	9.25	.0739	351	1	100.0	15
10/13/24	6:30a	74.3	50	54.5	74.1	9.25	.0738	351	1	100.0	15
10/13/24	6:45a	74.5	45	51.8	73.9	8.45	.0739	351	1	100.0	15
10/13/24	7:00a	74.1	50	54.3	73.9	9.25	.0739	352	1	100.0	15
10/13/24	7:15a	74.7	49	54.3	74.5	9.05	.0738	351	1	100.0	15
10/13/24	7:30a	74.2	49	53.8	73.9	9.05	.0739	351	1	100.0	15
10/13/24	7:45a	74.5	50	54.6	74.4	9.25	.0738	351	1	100.0	15
10/13/24	8:00a	74.4	47	52.9	73.9	8.75	.0739	352	1	100.0	15
10/13/24	8:15a	74.4	50	54.5	74.2	9.25	.0739	351	1	100.0	15
10/13/24	8:30a	74.7	45	51.9	74.1	8.45	.0739	351	1	100.0	15
10/13/24	8:45a	74.4	51	55.1	74.3	9.36	.0739	351	1	100.0	15
10/13/24	9:00a	75.0	47	53.4	74.6	8.75	.0739	351	1	100.0	15
10/13/24	9:15a	74.6	51	55.3	74.5	9.36	.0738	352	1	100.0	15
10/13/24	9:30a	75.3	48	54.3	75.0	8.94	.0738	351	1	100.0	15
10/13/24	9:45a	75.0	51	55.6	75.0	9.35	.0738	351	1	100.0	15
10/13/24	10:00a	75.5	47	53.9	75.1	8.74	.0738	351	1	100.0	15
10/13/24	10:15a	75.5	52	56.6	75.5	9.54	.0737	352	1	100.0	15
10/13/24	10:30a	75.9	49	55.4	75.7	9.03	.0737	351	1	100.0	15
10/13/24	10:45a	76.3	53	57.9	76.4	9.65	.0735	351	1	100.0	15
10/13/24	11:00a	76.2	51	56.7	76.2	9.35	.0736	351	1	100.0	15
10/13/24	11:15a	77.0	50	56.9	76.9	9.21	.0734	352	1	100.0	15
10/13/24	11:30a	76.7	53	58.3	76.8	9.65	.0734	351	1	100.0	15
10/13/24	11:45a	76.8	48	55.6	76.5	8.91	.0735	351	1	100.0	15
10/13/24	12:00p	77.1	53	58.6	77.2	9.65	.0733	351	1	100.0	15
10/13/24	12:15p	76.5	52	57.6	76.5	9.52	.0734	351	1	100.0	15
10/13/24	12:30p	77.0	50	56.9	76.9	9.21	.0734	352	1	100.0	15

NKSP 10/13/24

Date	Time	In Temp	In Hum	In Dew	In Heat	In EMC	In Air Density	Wind Samp	Wind Tx	ISS Recept	Arc. Int.
10/13/24	12:45p	76.9	54	59.0	77.0	9.81	.0733	351	1	100.0	15
10/13/24	1:00p	76.4	52	57.5	76.4	9.52	.0734	351	1	100.0	15
10/13/24	1:15p	76.6	49	56.0	76.4	9.02	.0734	351	1	100.0	15
10/13/24	1:30p	76.7	53	58.3	76.8	9.65	.0733	352	1	100.0	15
10/13/24	1:45p	76.6	54	58.7	76.7	9.82	.0733	351	1	100.0	15
10/13/24	2:00p	76.4	51	56.9	76.4	9.35	.0733	351	1	100.0	15
10/13/24	2:15p	76.9	49	56.3	76.7	9.01	.0733	351	1	100.0	15
10/13/24	2:30p	77.3	53	58.8	77.4	9.65	.0731	352	1	100.0	15
10/13/24	2:45p	77.1	51	57.6	77.1	9.35	.0732	351	1	100.0	15
10/13/24	3:00p	77.2	47	55.4	76.8	8.71	.0733	351	1	100.0	15
10/13/24	3:15p	77.3	52	58.3	77.3	9.50	.0731	351	1	100.0	15
10/13/24	3:30p	77.3	50	57.2	77.2	9.20	.0731	351	1	100.0	15
10/13/24	3:45p	77.2	46	54.8	76.7	8.51	.0733	352	1	100.0	15
10/13/24	4:00p	77.5	49	56.8	77.3	9.00	.0731	351	1	100.0	15
10/13/24	4:15p	77.1	52	58.1	77.1	9.51	.0731	351	1	100.0	15
10/13/24	4:30p	76.8	48	55.6	76.5	8.91	.0733	351	1	100.0	15
10/13/24	4:45p	77.1	47	55.3	76.7	8.71	.0732	352	1	100.0	15
10/13/24	5:00p	77.5	52	58.5	77.6	9.50	.0730	351	1	100.0	15
10/13/24	5:15p	77.4	49	56.7	77.2	9.00	.0731	351	1	100.0	15
10/13/24	5:30p	77.8	48	56.5	77.5	8.89	.0731	351	1	100.0	15
10/13/24	5:45p	78.1	52	59.0	78.2	9.49	.0729	352	1	100.0	15
10/13/24	6:00p	78.0	49	57.3	77.9	8.99	.0730	351	1	100.0	15
10/13/24	6:15p	77.8	48	56.5	77.5	8.89	.0731	351	1	100.0	15
10/13/24	6:30p	77.8	52	58.8	77.9	9.49	.0730	351	1	100.0	15
10/13/24	6:45p	77.3	51	57.8	77.3	9.35	.0731	351	1	100.0	15
10/13/24	7:00p	76.8	47	55.0	76.4	8.71	.0733	352	1	100.0	15
10/13/24	7:15p	76.7	53	58.3	76.8	9.65	.0732	351	1	100.0	15
10/13/24	7:30p	76.2	53	57.8	76.3	9.65	.0733	351	1	100.0	15
10/13/24	7:45p	76.2	49	55.6	76.0	9.03	.0734	351	1	100.0	15
10/13/24	8:00p	76.5	54	58.6	76.6	9.82	.0732	352	1	100.0	15
10/13/24	8:15p	75.9	55	58.6	76.1	10.01	.0733	351	1	100.0	15
10/13/24	8:30p	75.9	50	55.9	75.8	9.23	.0734	351	1	100.0	15
10/13/24	8:45p	76.0	57	59.7	76.3	10.31	.0733	351	1	100.0	15
10/13/24	9:00p	75.7	54	57.9	75.8	9.84	.0734	352	1	100.0	15
10/13/24	9:15p	76.0	54	58.2	76.1	9.83	.0734	351	1	100.0	15
10/13/24	9:30p	75.7	57	59.4	76.0	10.32	.0733	351	1	100.0	15
10/13/24	9:45p	75.6	52	56.7	75.6	9.54	.0735	351	1	100.0	15
10/13/24	10:00p	75.6	58	59.8	76.0	10.53	.0733	351	1	100.0	15
10/13/24	10:15p	75.4	55	58.1	75.6	10.03	.0735	352	1	100.0	15
10/13/24	10:30p	76.3	58	60.4	76.7	10.50	.0732	351	1	100.0	15
10/13/24	10:45p	76.3	54	58.4	76.4	9.82	.0733	351	1	100.0	15
10/13/24	11:00p	76.4	57	60.0	76.7	10.29	.0732	351	1	100.0	15
10/13/24	11:15p	76.5	52	57.6	76.5	9.52	.0733	352	1	100.0	15
10/13/24	11:30p	76.3	56	59.4	76.6	10.20	.0733	351	1	100.0	15
10/13/24	11:45p	76.6	55	59.2	76.8	9.99	.0733	351	1	100.0	15
10/14/24	12:00a	76.2	55	58.9	76.4	10.00	.0733	351	1	100.0	15