

HOUSING UNIT WATER TEMPURATURE

UNIT: F

MONTH: 5-24

DATE	TANK TEMP	MIXING VALVE TEMP
5/16	144	121
5/15	144	122
5/20	143	119
5/28	140	123

HOUSING UNIT WATER TEMPURATURE

UNIT: F

MONTH: 6 - 24

DATE	TANK TEMP	MIXING VALVE TEMP
6-9	142	122
6-10	141	119
6-11	139	121
6-24	144	119

HOUSING UNIT WATER TEMPURATURE

UNIT: F

MONTH: 7-24

DATE	TANK TEMP	MIXING VALVE TEMP
7-1	140	120
7-8	140	120
7-15	139	119
7-22	142	121
7-29	134	121

HOUSING UNIT WATER TEMPURATURE

UNIT: F

MONTH: 8-24

DATE	TANK TEMP	MIXING VALVE TEMP
8-5	142	121
8-12	144	119
8-19	139	120
8-26	141	119

HOUSING UNIT WATER TEMPURATURE

UNIT: F

MONTH: 9-24

DATE	TANK TEMP	MIXING VALVE TEMP
9-3	144	122
9-9	143	121
9-14	141	119
9-23	39	120
9-30	142	122

HOUSING UNIT WATER TEMPURATURE

UNIT:	F	MONTH:	10-24
DATE	TANK TEMP.	MIXING VALVE TEMP.	
10-1	144	120	
10-5	145	122	
10-21	139	121	
10-26	141	119	

HOUSING UNIT WATER TEMPURATURE

UNIT: F

MONTH: 11-24

DATE	TANK TEMP	MIXING VALVE TEMP
11-7	144	121
11-13	141	119
11-20	143	123
11-27	144	123

HOUSING UNIT WATER TEMPURATURE

UNIT: P

MONTH: 12-24

DATE	TANK TEMP.	MIXING VALVE TEMP.
12-2	142	121
12-11	138	119
12-16	139	120
12-21	141	120

HOUSING UNIT WATER TEMPERATURE

UNIT: P

MONTH: 1-25

DATE	TANK TEMP	MIXING VALVE TEMP
1-2	144	121
1-9	139	119
1-16	141	123
1-23	139	122
1-30	136	121

HOUSING UNIT WATER TEMPURATURE

UNIT: F

MONTH: 2-25

DATE	TANK TEMP	MIXING VALVE TEMP
2-27	142	120
2-11	141	121
2-19	139	119
2-26	141	118