

HOUSING UNIT WATER TEMPERATURE

UNIT:	C	MONTH:	5/24/24
DATE	TANK TEMP	MIXING VALVE TEMP	
5/6/24	139°	120°	
5/13/24	140°	121°	
5/20/24	140°	119°	
5/28/24	142°	121°	

HOUSING UNIT WATER TEMPURATURE

UNIT:	C	MONTH:	6/24
DATE	TANK TEMP	MIXING VALVE TEMP	
6/3/24	140°	120°	
6/10/24	141°	119°	
6/11/24	138°	118°	
6/24/24	140°	121°	

HOUSING UNIT WATER TEMPURATURE

UNIT:	MONTH: 7/24	
DATE	TANK TEMP	
DATE	TANK TEMP	MIXING VALVE TEMP
7/1/24	142°	120°
7/8/24	140°	119°
7/15/24	139°	120°
7/22/24	141°	120°
7/29/24	140°	121°

HOUSING UNIT WATER TEMPERATURE

UNIT: C

MONTH: 8/24

DATE	TANK TEMP	MIXING VALVE TEMP
8/5/24	140°	120°
8/12/24	140	119°
8/19/24	139°	120°
8/26/24	141°	120°

HOUSING UNIT WATER TEMPERATURE

UNIT:	C	MONTH:	9/24
DATE	TANK TEMP	MIXING VALVE TEMP	
9/3/24	142°	122°	
9/9/24	140°	120°	
9/16/24	142°	119°	
9/23/24	138°	119°	
9/30/24	140°	121°	

HOUSING UNIT WATER TEMPURATURE

UNIT:	C	MONTH:	10/24
DATE	TANK TEMP	MIXING VALVE TEMP	
10/1/24	142°	120°	
10/15/24	142°	121°	
10/21/24	138°	119°	
10/28/24	140°	120°	

HOUSING UNIT WATER TEMPURATURE

UNIT:	MONTH:	
DATE	TANK TEMP	MIXING VALVE TEMP
11-24	140	121
11-24-24	141	120
11-15-24	143	122
11-23-24	143	123

HOUSING UNIT WATER TEMPERATURE

UNIT: C

MONTH: Dec 24

DATE	TANK TEMP	MIXING VALVE TEMP
12-22-24	140	119
12-11-24	139	118
11-18-24	133	117
12-21-24	139	119

HOUSING UNIT WATER TEMPURATURE

UNIT: ~~10~~ C

MONTH: Jan 25

DATE	TANK TEMP	MIXING VALVE TEMP
1/2	141	119
1/9	140	117
1/23	139	119
1/30	130	123

HOUSING UNIT WATER TEMPURATURE

UNIT: C

MONTH: Feb 25

DATE	TANK TEMP	MIXING VALVE TEMP
2/4	143	121
2/11	140	120
2/18	141	120
2/25	139	123