

Scanning Online Relay Proteksi Sistem

Asset	: Rele UFR	Lokasi	: GIS Teling
-------	------------	--------	--------------

Merk: SIEMENS Tanggal: 2023-03-30

Type: ARGUS 7SR2203 Bay: BBVT T2

SN : BF1904501503 Ratio VT : 20 kV / 100 V

I Check List

I. CHECK LIST			
Wiring			
Standby Negative Trip di Selektor			
Standby Positive Trip di Selektor			
Tarikan Rangkaian Trip Antar Panel			
Posisi Aux Relay			
Periksa Terminal Rangkaian			
Periksa Rangkaian pada Relay			
II. Catatan			

Mengetahui Koor/SPV GI Pengawas Pelaksana

Moch. Hafid - Maryo Harly Agung Chrisyacandra