

## Scanning Online Relay Proteksi Sistem

Moch. Hafid		A gur	ng Chrisyacandra	Annisa Elm
Mengetahui	Koor/SPV GI		Pengawas	Pelaksana
abc				
II. Catatan			Teriksa Kangkalan pac	ia Relay
Cek Time Relay  Cek Ratio VT			Periksa Terminal Rangkaian Periksa Rangkaian pada Relay	
Cek Measurment Frekuensi			Posisi Aux Relay	
Cek Measurment Tegangan			Tarikan Rangkaian Tr	ip Antar Panel
Cek Value Setting			Standby Positive Trip	di Selektor
Setting UFR Isla	and Enable		Standby Negative Trip	di Selektor
Rele		Wiring		
I. Check List				
SN : test		Ratio VT	: 20 kV / 100 V	
Type: test		Bay	: test	
Merk : test		Tanggal	: 2023-08-25	
Asset: Rele UFR		Lokasi	: GI Tomohon	