

## Scanning Online Relay Proteksi Sistem

Asset : Rele Island Lokasi : GI Boroko

Merk: AREVA Tanggal: 2024-04-22

Type: P14DL Bay: Tanjung Karang 2

SN : 513191Y Ratio VT : 150 kV / 100 V

## I. Check List

Rele Wiring

Setting UFR Island Enable

Standby Negative Trip di Selektor

Cek Value Setting Standby Positive Trip di Selektor

Cek Measurment Tegangan

Tarikan Rangkaian Trip Antar Panel

Cek Measurment Frekuensi

Posisi Aux Relay

Cek Time Relay Periksa Terminal Rangkaian

Cek Ratio VT Periksa Rangkaian pada Relay

## II. Catatan

tahap 1 : 48.50 Hz tahap 2 : 48.30 Hz

Mengetahui Koor/SPV GI Pengawas Pelaksana

Moch. Hafid - Agung Chrisyacandra Annisa Elma