



PT PLN (PERSERO)  
UIKL SULAWESI  
UP2B SISTEM MINAHASA

## FORMULIR SCANNING ONLINE UFR OLS

Merk : Alstom GE  
Type : SR 356  
No : BL1A lg 00783

Tanggal : 11 Mei 2023  
Lokasi : GI Sawangan  
Bay : BB VT TDY  
Ratio VT : -

### I. CHECK LIST

RELAY	WIRING
<input checked="" type="checkbox"/> Setting UFR Tahap 1 - 6 Enable	<input checked="" type="checkbox"/> Standby Negative Trip di Selektor
<input checked="" type="checkbox"/> Cek Value Setting Tahap 1 - 6	<input checked="" type="checkbox"/> Standby Positive Trip di Relay
<input checked="" type="checkbox"/> Cek Measurement Tegangan	<input checked="" type="checkbox"/> Tarikan Rangkaian Trip Antar Panel
<input checked="" type="checkbox"/> Cek Measurement Frekuensi	<input checked="" type="checkbox"/> Posisi Aux Relay
<input checked="" type="checkbox"/> Cek Time Relay	<input checked="" type="checkbox"/> Periksa Terminal Rangkaian
<input checked="" type="checkbox"/> Cek Ratio PT	<input checked="" type="checkbox"/> Periksa Rangkaian Pada Relay
<input type="checkbox"/>	<input type="checkbox"/>

II. CATATAN : Mengcover OLS dan UPLS Kema,

IP 172.17.7.105

Mengetahui

M.B FASOP

Pengawas

SPV/Koord.GI

Pemeriksa

SPV.ProSis

Pelaksana

Agus C