

Scanning Online Relay Proteksi Sistem

Asset: Rele UFR Lokasi: GI Tanjung Merah

Merk: ABB Tanggal: 2023-05-25

Type: REU615 Bay: BBVT TD2

SN : IVHR91395305 Ratio VT : 20 kV / 100 V

I. Check List

Rele Wiring

Setting UFR Island Enable

Standby Negative Trip di Selektor

Cek Value Setting Standby Positive Trip di Selektor

Cek Measurment Tegangan Tarikan Rangkaian Trip Antar Panel

Cek Measurment Frekuensi

Posisi Aux Relay

Cek Time Relay

Periksa Terminal Rangkaian

Cek Ratio VT Periksa Rangkaian pada Relay

II. Catatan

Tahap 1: 49.2 Hz
Tahap 2: 49.05 Hz
Tahap 3: 48.9 Hz
Tahap 4: 48.75 Hz
Tahap 5: 48.65 Hz

Mengetahui Koor/SPV GI Pengawas Pelaksana

Moch. Hafid - Agung Chrisyacandra Annisa Elma