

## Scanning Online Relay Proteksi Sistem

Asset	: Rele UFR	Lokasi	: GI Ranomuut
IDDCL	. IXCIC CI IX	Lokusi	. Of Kunomaut

Merk: ABB Tanggal: 2023-03-27

Type: REU615 Bay: BBVT T3

SN : 1VHR91555763 Ratio VT : 20 kV / 100 V

## I. Check List

Rele	Wiring
Setting UFR Island Enable	Standby Negative Trip di Selektor
Cek Value Setting	Standby Positive Trip di Selektor
Cek Measurment Tegangan	Tarikan Rangkaian Trip Antar Pane
Cek Measurment Frekuensi	Posisi Aux Relay
Cek Time Relay	Periksa Terminal Rangkaian

Periksa Rangkaian pada Relay

## II. Catatan

Cek Ratio VT

SR6, SR4, Spare (Penyulang pada trafo 3)						

Mengetahui Koor/SPV GI Pengawas Pelaksana

Moch. Hafid - Agung Chrisyacandra Annisa Elma