

Scanning Online Relay Proteksi Sistem

Asset : Rel	e UFR	Lokasi	:	GI	Tasikria
-------------	-------	--------	---	----	----------

Merk: ABB Tanggal: 2023-03-28

Type: REU615 Bay: BBVT T1

SN : IVHR91475126 Ratio VT : 20 kV / 100 V

I. Check List

Rele Wiring

- Setting UFR Island Enable

 Standby Negative Trip di Selektor
- Cek Value Setting Standby Positive Trip di Selektor
- Cek Measurment Tegangan

 Tarikan Rangkaian Trip Antar Panel
- Cek Measurment Frekuensi

 Posisi Aux Relay
- Cek Time Relay Periksa Terminal Rangkaian
- Cek Ratio VT Periksa Rangkaian pada Relay

II. Catatan

Trafo 1 : SA1 dan SA2		

Mengetahui Koor/SPV GI Pengawas Pelaksana

Moch. Hafid - Agung Chrisyacandra Annisa Elma