

## Scanning Online Relay Proteksi Sistem

Moch. Hafid	_	Δgur	ng Chrisyacandra	Annisa Elm	
Mengetahui	Koor/SPV GI		Pengawas	Pelaksana	
IP: 172.17.7.10	08				
II. Catatan					
Cek Ratio VT			Periksa Rangkaian pada Relay		
Cek Time Relay			Periksa Terminal Rangkaian		
Cek Measurment Tegangan  Cek Measurment Frekuensi			Tarikan Rangkaian Trip Antar Panel Posisi Aux Relay		
Cek Value Setting			Standby Positive Trip		
Setting UFR Island Enable			Standby Negative Trip	di Selektor	
Rele		Wiring			
I. Check List					
SN . BLIA900	33780	Kano v i			
		•	Ratio VT : -		
Type : MULTIL	IN 350	Bay	: Trafo 2		
Merk : GE		Tanggal	: 2023-03-28		
Asset : Rele OLS		Lokasi	: GI Tasikria		