

Scanning Online Relay Proteksi Sistem

Asset : Rele UPLS Lokasi : GI Kema

Merk: ALSTOM Tanggal: 2023-05-26

Type : MICOM P14DL Bay : Transformer Control

SN : 34933912/11/19/933912X Ratio VT : 150 kV / 100 V

I. Check List

Rele	Wiring
Setting UFR Island Enable	Standby Negative Trip di Selektor
Cek Value Setting	Standby Positive Trip di Selektor
Cek Measurment Tegangan	Tarikan Rangkaian Trip Antar Panel
Cek Measurment Frekuensi	Posisi Aux Relay
Cek Time Relay	Periksa Terminal Rangkaian
Cek Ratio VT	Periksa Rangkaian pada Relay
N. A. I	

Mengetahui Koor/SPV GI Pengawas Pelaksana

Moch. Hafid - Agung Chrisyacandra Annisa Elma