

Scanning Online Relay Proteksi Sistem

Asset	: Rele Island	Lokasi	: GI Likupang 150 kV

Merk : ALSTOM GE Tanggal : 2023-05-23

Type: P14DL Bay: Paniki 1

SN : 35206978/11/20 Ratio VT : 150 kV / 100 V

I. Check List

Rele	Wiring
Setting UFR Island Enable	Standby Negative Trip di Selektor
Cek Value Setting	Standby Positive Trip di Selektor
Cek Measurment Tegangan	Tarikan Rangkaian Trip Antar Panel
Cek Measurment Frekuensi	Posisi Aux Relay
Cek Time Relay	Periksa Terminal Rangkaian
Cek Ratio VT	Periksa Rangkaian pada Relay

II. Catatan

1. Cututun				
tahap 1 : 48.5 Hz				
UV Block: 52 V				
Tidak ada koneksi kabel LAN				

Mengetahui Koor/SPV GI Pengawas Pelaksana

Moch. Hafid - Agung Chrisyacandra Annisa Elma