

CONTRACTOR SUBMITTAL PREFLIGHT

Morrow Correction Packet

A source-cited, contractor-ready example showing what to correct before a formal GC or design-professional review.

PROJECT	Pine Street Community Center (synthetic)	TRADE	HVAC equipment
INPUT 1	Governing specification	INPUT 2	Contractor product submittal

PREFLIGHT DECISION

REVISE BEFORE REVIEW

6	5	3	3
REQUIREMENTS	CONFLICTS	MISSING DOCUMENTS	PRIORITY RISKS

Executive summary

The proposed 3.5-ton R-410A system does not match the 3-ton R-32 basis of design. It also misses minimum efficiency, sound, electrical, accessory, certification, and warranty requirements. The package should be corrected or submitted with a clearly identified deviation request before formal review.

WHY THIS MATTERS	This example turns a likely rejection into a specific worklist. Morrow does not approve products or replace professional judgment; it makes the contractor's next action visible.
------------------	---

Priority risks

SEVERITY	FINDING	CONTRACTOR ACTION
HIGH	Proposed system is not a compliant equivalent.	Select a compliant matched system or submit a design-change request with calculations.
HIGH	Electrical values exceed the specified MCA and MOCP limits.	Recheck feeder and disconnect coordination before submission.
MEDIUM	Required point-by-point deviation comparison is absent.	List every exception and cite the corresponding specification requirement.

SOURCE-CITED COMPARISON

Requirement Matrix

Each row pairs the governing requirement with submitted evidence and a contractor-ready fix.

ID / STATUS	SPECIFICATION REQUIREMENT	SUBMITTED EVIDENCE	RECOMMENDED FIX	SOURCE
R-1 CONFLICT	3 tons; at least 34,000 Btu/h	3.5 tons; 40,200 Btu/h	Select the specified capacity or document an approved design change.	Spec p.1 - Performance
R-2 CONFLICT	Minimum 15.0 SEER2 / 8.0 HSPF2	14.3 SEER2 / 7.5 HSPF2	Provide certified data for a matched system meeting both ratings.	Spec p.1 - Performance
R-3 CONFLICT	Factory-charged R-32 refrigerant	R-410A	Replace with an R-32 system; do not treat an adapter as equivalency.	Spec p.1 - Performance
R-4 CONFLICT	Outdoor sound not greater than 72 dBA	74 dBA	Select quieter equipment or submit a written deviation request.	Spec p.1 - Performance
R-5 CONFLICT	MCA not greater than 24 A; MOCP 35 A max	MCA 26 A; MOCP 40 A	Coordinate feeder and disconnect; submit compliant nameplate data.	Spec p.1 - Electrical
R-6 MISSING	Low ambient, coastal coating, BACnet, warranty	Required options not identified	Add option codes, accessory schedule, and written warranty.	Spec p.2 - Quality

EVIDENCE RULE	Every finding cites the supplied specification or contractor package. If evidence is insufficient, the report says so instead of inventing a requirement.
---------------	---

Missing-document checklist

DOCUMENT	WHY NEEDED	SOURCE
AHRI certificate for exact matched system	Confirms the indoor/outdoor pairing and certified efficiency.	Spec p.2 - Quality
Dimensional drawing and accessory schedule	Supports field coordination and confirms required options.	Spec p.1 - Submittals
Written compressor and parts warranty	Confirms the specified 10-year / 5-year coverage.	Spec p.2 - Quality

CONTRACTOR-READY DELIVERABLE

Correction Action Plan

Use this page as the package worklist before forwarding the revised documents for formal review.

1	Correct product selection Choose a 3-ton R-32 matched system meeting capacity, efficiency, sound, MCA, and MOCP limits.
2	Assemble evidence Add the exact AHRI certificate, dimensional drawing, accessory schedule, option codes, and written warranty.
3	Identify deviations If the specified basis cannot be provided, list each exception and request written design-professional direction.
4	Quality-control the package Mark the selected model and options clearly; remove unselected product variations that create ambiguity.
5	Submit for human review Forward the corrected authentic documents. Do not alter manufacturer product data or represent this preflight as approval.

Draft response for contractor review

SUBJECT: Pine Street Community Center - HVAC submittal revision We reviewed the proposed HVAC package against the governing requirements before formal submission. The current selection does not match the specified capacity, refrigerant, efficiency, sound, or electrical limits. The package also needs the exact AHRI certificate, dimensional drawing, accessory schedule, and written warranty. Please provide a compliant matched system and the missing documents. If the specified basis is unavailable, identify each deviation and include the supporting calculations or written design-change request. The revised package will then be forwarded for the responsible design professional's review.	
IMPORTANT	This synthetic packet demonstrates Morrow's format. It is not an approval, professional opinion, code determination, or substitute for the contractor's and design professional's review.