# PV and Battery Trading in MGP and MI Auctions
# Current Mathematical Model and Execution Workflow

`bess_pv_trading` repository

Implementation updated on 27 October 2026

**Abstract**

This report documents the implemented decision and execution model for a photovoltaic plant with a shared point of interconnection and a hypothetical AC-coupled battery. It specifies the Italian day-ahead and three intraday auction timeline used by the code, the residual mixed-integer optimization, immutable auction commitments, battery degradation, interval-level feedback controller and ex-post imbalance settlement. It distinguishes the general scenario-tree interface from the deterministic actual-price oracle used in the historical studies. The report follows current source code and shared YAML defaults; it is not a market strategy validation or an investment valuation. PV forecasting research is summarized only as an input dependency, with the selected farm bundles identified for reuse by the continuous optimization runner.

## Contents

**1 Scope and implementation map** **3**

**2 Time, units, signs and information** **4**

2.1 Delivery intervals and auction products . . . . . 4

2.2 Notation and electrical basis . . . . . 5

2.3 Forecast vintages and observability . . . . . 5

**3 PV availability supplied to the optimizer** **6**

3.1 Selected farm bundles for continuous optimization . . . . . 6

**4 Optimization at an auction decision** **7**

4.1 Scenario tree and nonanticipativity . . . . . 7

4.2 Physical variables and balances . . . . . 7

4.3 Auction quantities and physical delivery . . . . . 8

4.4 Current objective and sunk cash flows . . . . . 9

4.5 Market transaction fees and operator monthly volume . . . . . 9

4.6 What is free at each of the four decisions . . . . . 10

**5 Battery degradation models** **11**

5.1 Current AC throughput approximation . . . . . 11

5.2 Optional segmented depth-dependent aging . . . . . 11

**6 Submission, publication and reoptimization workflow 12**

**7 Physical feedback with realized PV 13**

7.1 Feasible interval power range . . . . . 13

7.2 Grid-tracking policy . . . . . 13

7.3 PV source allocation for reporting . . . . . 14

**8 Settlement and expected-versus-realized accounting 14**

**9 Value of reoptimization through frozen-plan replay 15**

**10 Perfect-information schedules and the PV-only baseline 16**

10.1 PV+BESS versus the feedback controller . . . . . 16

10.2 PV-only asset counterfactual . . . . . 17

**11 Configurable participation and matched-day profile comparison 17**

11.1 Sequential current-auction-only baseline . . . . . 18

11.2 Operational fallback after an infeasible auction decision . . . . . 18

**12 Continuous operation with daily optimization horizons 20**

12.1 Delivery books and the chronological event sequence . . . . . 20

12.2 Forecast-based projection of the next initial state . . . . . 20

12.3 Daily free decisions, initial condition and final target . . . . . 21

12.4 Independent trajectories, accounting and restart . . . . . 22

**13 Implemented trading experiments and evidence 23**

**14 Price Forecasting Status 23**

**15 Optional optimized-imbalance formulation 24**

**16 Data provenance, outputs and reproducibility 24**

**17 Current limitations and extension boundaries 26**

# 1 Scope and implementation map

One farm has PV generation, an AC-coupled BESS, and a common AC grid connection. There is no local electricity demand. PV can be exported, stored, or curtailed; the battery can charge from PV or grid imports and discharge toward the grid. The market sequence is MGP (called DA in code), MI-A1, MI-A2, and MI-A3 (IDA1, IDA2, IDA3). Every submitted signed quantity is assumed to execute in full at the auction clearing price. Bid prices, acceptance uncertainty, market impact, and continuous intraday trading are outside this formulation.

The implementation has three distinct objects:

1. An optimization plan, which includes the current actionable auction order, future auction recourse, and a battery/PV schedule over the remaining horizon.
2. An immutable commitment ledger, updated at submission and publication.
3. A physical trajectory produced by a feedback/protection policy using realized interval-average PV. Its energy, wear, and deviations are settled separately from the optimization objective.

| Source | Responsibility |
|---|---|
| `src/domain.py` | Validated grids, assets, scenarios, information nodes, states and solver contracts. |
| `src/optimization/model.py` | Physical, trading, product-resolution, optional imbalance constraints and objective. |
| `src/optimization/degradation.py` | Throughput coefficient and segmented cycle-depth model. |
| `src/optimization/validation.py` | Numerical validation independent of the solver constraint objects. |
| `src/transaction_fees.py` | Pure-Python fee integration, dated tariffs and operator monthly state. |
| `src/optimization/transaction_fees.py` | Flat-band LP costs and exact progressive ABS/PWL constraints. |
| `src/simulation/synthetic.py` | Shared event replay and auction submission/publication accounting. |
| `src/simulation/replay.py` | Residual scenario conditioning and bounded physical execution. |
| `src/simulation/gme_oracle.py` | Manual-data historical price oracle, rolling PV and full-information asset comparisons. |
| `src/simulation/continuous.py` | Consecutive delivery-day books, shadow boundary projections and uninterrupted execution. |
| `src/reporting/continuous_outputs.py` | Continuous trajectory accounting, paired comparisons and native solve timing. |
| `src/simulation/settlement.py` | Exact-grid actual settlement and expected/realized KPI reconciliation. |
| `src/forecasting/pv.py` | Weather-to-AC PV conversion. |
| `src/markets.py` | Configurable local auction gates, publication events and DST-aware delivery grids. |

# 2 Time, units, signs and information

## 2.1 Delivery intervals and auction products

A local delivery day is partitioned into physical intervals $\mathcal{T} = \{0, \dots, T-1\}$, with starts $\tau_t$, ends $\tau_{t+1}$ and durations

$$\Delta_t = (\tau_{t+1} - \tau_t)/\text{one hour}. \tag{1}$$

The historical study uses quarter-hours, so $\Delta_t = 0.25$. A local day is constructed between successive midnights in `Europe/Rome`, then stored in UTC: $T$ is 92, 96, or 100 for spring-DST, ordinary, or autumn-DST days. Repeated local hours are distinguished by their actual UTC offset/fold. No equation assumes that every day has exactly 24 elapsed hours.

A physical interval is not necessarily an independent market product. Before 1 October 2025, DA products are hourly; the MI auctions in the current 2025 history are already quarter-hourly. Physical battery controls are quarter-hourly at all four optimization stages. For the four equal-duration quarters of one native DA hour $h$, the implementation enforces

$$q_{\mathrm{DA},n,t} = q_{\mathrm{DA},n,t'} \quad (t, t' \in h). \tag{2}$$

These are equal MWh shares of one hourly order, whose total is $\sum_{t \in h} q_{\mathrm{DA},n,t}$. The hourly clearing price is repeated as an objective coefficient on those shares. The quarters do not become separate DA trades or separate observed prices. There is no corresponding date-based hourly equality on battery charging or discharging. Native product resolution and optional physical-control grouping are separate configuration fields.

The configured auction calendar uses local `Europe/Rome` time. The decision cutoff is five minutes before each gate in the supplied studies.

| Auction | Gate | Decision cutoff | Results clock | Delivery scope |
|---|---|---|---|---|
| MGP/DA | D−1 12:00 | D−1 11:55 | D−1 13:30* | Whole day D |
| MI-A1/IDA1 | D−1 15:00 | D−1 14:55 | by D−1 15:30 | Whole day D |
| MI-A2/IDA2 | D−1 22:00 | D−1 21:55 | by D−1 22:30 | Whole day D |
| MI-A3/IDA3 | D 10:00 | D 09:55 | by D 10:30 | D 12:00–24:00 |

*The configured 13:30 DA publication is a conservative study assumption; GME's technical rule says final MGP results are not published earlier than 13:05. Recorded publication timestamps override the configured clock.

MI-A1/A2/A3 are the three auction sessions; they exclude the separate continuous MI-XBID market. Every submitted quantity is assumed accepted in full and settled at the auction clearing price. The model does not optimize bid prices, acceptance probabilities, market impact or partial fills. DA products were hourly in the studied data through September 2025. GME made 15-minute MGP products available for delivery from 1 October 2025, and also announced 30-minute products. MI auction products in the studied 2025 data were already quarter-hourly. Product-duration groups, rather than a hard-coded number of variables per day, define trade variables and native-product equalities. The delivery grid is always constructed between local midnights and stored in UTC, so DST days can contain 92, 96 or 100 quarter-hours.

An auction $a$ has an eligibility set $\mathcal{T}_a$. A documented/configured cancellation removes that auction from the active set. Missing data alone does not establish a cancellation: unexplained missing or incomplete curves fail validation. Absent auctions create no trade variables and no submission solve.

At DA closure the integrated model may optimize planned DA, IDA1, IDA2 and IDA3 quantities together. At IDA1, DA is fixed and the remaining three markets may be planned; at IDA2, DA and

IDA1 are fixed; at IDA3, the first three are fixed and only IDA3 quantities are free. This integrated planning uses actual future auction curves in the price-oracle experiments, although those prices would not be known at the earlier real-world gates. The sequential baseline removes future-auction trade variables and their expected revenue from each solve. Both modes replan physical operation over the remaining eligible horizon and preserve earlier commitments.

## 2.2 Notation and electrical basis

| Symbol | Unit | Meaning |
|---|---|---|
| $E$ | MWh | Nominal internal stored-energy capacity. |
| $E^{\min}, E^{\max}$ | MWh | Operational energy limits derived from SOC percentages. |
| $\overline{P}$ | MW AC | One symmetric battery charging/discharging rating. |
| $P^{\text{imp}}, P^{\text{exp}}$ | MW AC | Directional shared POI ratings. |
| $\eta_c, \eta_d$ | fraction | Complete AC-bus-to-storage and storage-to-AC efficiencies. |
| $\sigma$ | fraction/hour | Configured hourly self-discharge fraction. |
| $V_{s,t}$ | MW AC | Forecast available PV in scenario $s$. |
| $\widetilde{V}_t$ | MW AC | Effective realized PV used for execution. |
| $c_{n,t}, d_{n,t}$ | MW AC | Battery charge/discharge commands at information node $n$. |
| $u_{n,t}$ | MW AC | PV curtailment. |
| $i_{s,t}$ | MW AC | Uncurtailed PV injection into the common AC bus. |
| $g_{s,t}$ | MW AC | Net grid exchange; positive is export, negative is import. |
| $e_{s,t}$ | MWh | Internal battery energy at an interval boundary. |
| $q_{a,n,t}$ | MWh | Signed auction adjustment; positive sale, negative purchase. |
| $Q_{s,t}$ | MWh | Final cumulative contracted delivery position. |
| $\pi_{a,s,t}$ | EUR/MWh | Auction-price coefficient for interval $t$. |
| $w_s$ | fraction | Scenario probability, summing to one. |

Power variables are AC at the common bus/POI. Battery energy is internal stored energy. Farm nameplate PV capacity is AC. For pvlib, the DC reference rating is derived as $P_{\text{DC,STC}} = P_{\text{AC,rated}}/\eta_{\text{ref}}$, where the reference factor is a separate, fixed configured assumption (currently 0.96). Forecasts receive the DC-to-AC and transformer conversions and are then capped at the farm AC rating. Measured historical `power` is already AC kW and is converted once to MW; no PV or transformer efficiency is applied to it. BESS efficiency is not applied to measured PV or direct PV exports.

## 2.3 Forecast vintages and observability

A weather forecast cycle $v$ has source time $t_v$ and availability time $A_v$. Without explicit source publication times, the configured convention is $A_v = t_v + 6$ hours. At decision cutoff $k$, the rolling policy chooses the latest eligible cycle with $A_v \leq k$ and required remaining-horizon coverage. Weather cycles about six hours apart are successive forecast vintages, not ensemble members. The current dataset supplies one deterministic weather member.

Measured interval-average PV becomes available after interval end plus configured telemetry delay. A forecast for future intervals is not replaced by future realized power in the ordinary auction replay.

If a decision occurs inside an unfinished quarter-hour, the next boundary state is projected through that interval with forecast PV and the same execution policy. Its final realized average cannot yet be observed. The hindsight counterfactuals deliberately have future PV and price information and are labeled as such.

Policy-treated observations carry evidence times. Plateau evidence can require later samples; two-sided interpolation requires its right endpoint and applicable mask evidence. A finalized corrected time series therefore differs from the as-of view available to a past decision. This remains relevant even when a study uses actual-price foresight.

# 3 PV availability supplied to the optimizer

The optimizer receives one nonnegative AC power trajectory $V_t$ per represented weather member. Current farm data contain deterministic forecast vintages keyed by farm, UTC cycle and hourly lead; the successive cycles are not ensemble members. Forecast cycles are selected using publication availability, not just initialization time. The configured availability lag is six hours. Hourly radiation values are aligned to the quarter-hour delivery grid according to their interval-average semantics. PV output is capped at the declared farm AC rating. Historical measured power is already AC and receives no additional conversion loss.

The reference physics path uses configured GHI and horizontal beam irradiance, pvlib solar geometry, fixed-array metadata or the configured single-axis tracker model, plane-of-array irradiance, Faiman module temperature and PVWatts DC output. In symbolic form,

$$G_{\mathrm{DHI}} = G_{\mathrm{GHI}} - G_{\mathrm{BHI}}, \qquad G_{\mathrm{DNI}} \simeq G_{\mathrm{BHI}}/\cos\theta_z, \tag{3}$$

$$G_{\mathrm{POA}} = G_{\mathrm{beam}} + G_{\mathrm{sky}} + G_{\mathrm{ground}}, \qquad T_{\mathrm{mod}} = T_{\mathrm{air}} + \frac{G_{\mathrm{POA}}}{U_0 + U_1 v}, \tag{4}$$

$$P_{\mathrm{DC}} = \max\left(0, \frac{P_{\mathrm{AC,rated}}}{\eta_{\mathrm{ref}}} \frac{G_{\mathrm{POA}}}{1000}[1 + \gamma(T_{\mathrm{mod}} - T_{\mathrm{ref}})]\right). \tag{5}$$

The DC reference ratio $\eta_{\mathrm{ref}} = 0.96$ is distinct from the configured DC-to-AC scale. The final AC forecast uses the selected output coefficient, transformer setting and AC cap. Farm coordinates are a documented proxy, so the physical geometry is an assumption. The optimization does not use satellite GHI as an operational weather forecast; it is retained for retrospective diagnosis.

The modeling-quality mask has one production authority: `configs/data_quality/pv_excluded_episodes_2025_to_2026_08.csv`. Complete feature/target rows identified there are removed from every model split; sequence models do not bridge removed quarters. This quality work defines the AC inputs available to forecasting and the optimizer, but its many model searches and error breakdowns are not the subject of this report.

## 3.1 Selected farm bundles for continuous optimization

The current per-farm pilot is saved as self-contained bundles. These are loaded only when `pv.forecast_replacement.enabled:true`; the default remains the pvlib path. If a bundle is unavailable, the declared fallback is pvlib. All models were trained on 2025 data; pilot choice used a previously inspected 2026 report period, so it is retrospective rather than an as-known-at-the-time benchmark.

| Farm | Selected model | Timing channels | Bundle path |
|---|---|---|---|
| 1 | Direct TCN 02 | none | `models/pv/farm_1/pilot_2025_train/direct_tcn/` |
| 345 | Direct TCN 12 | none | `models/pv/farm_345/pilot_2025_train/direct_tcn/` |
| 901 | Direct TCN timing 05 | lead and cycle hour | `models/pv/farm_901/pilot_2025_train/direct_tcn/` |
| 910 | Direct TCN paired timing | lead and cycle hour | `models/pv/farm_910/pilot_2025_train/direct_tcn/` |

The shared replacement map points to each bundle's `manifest.json`; the continuous runner verifies its farm identity and checksums and preserves the trained feature preprocessing. The default model availability timestamp is 27 October 2026 UTC. The January forecast-pilot configurations explicitly allow retrospective use. `experiment-continuous` consumes these bundles; the historical `experiment-gme-oracle` path currently uses its configured pvlib forecast. Model details and standalone inference instructions are in `models/pv/README.md`.

# 4 Optimization at an auction decision

Each residual solve uses only the remaining suffix of the delivery grid. In the equations below that suffix is reindexed from zero, with $T$ denoting its final boundary; its original UTC product identifiers are retained for commitments.

## 4.1 Scenario tree and nonanticipativity

At decision $k$, let $\mathcal{S}_k$ be represented leaf scenarios and let $\mathcal{A}_k$ be the open active auctions. An information tree assigns an auction bid owner $n_a(s)$ to each auction/leaf and a control owner $n_t(s)$ to each interval/leaf. Curtailment may have a separate owner $m_t(s)$ under the selected execution-information convention.

Decisions are node-owned variables, not independent leaf decisions followed by a penalty for disagreement. For example,

$$c_{s,t} = c_{n_t(s),t}, \quad d_{s,t} = d_{n_t(s),t}, \quad q_{a,s,t} = q_{a,n_a(s),t}, \quad u_{s,t} = u_{m_t(s),t}. \tag{6}$$

Thus two scenarios with the same observable history share actionable decisions. A latent PV-member label is not available information by itself. Constraints apply to every represented leaf, including zero-probability leaves if supplied; probabilities only weight the objective. In the current one-scenario historical price oracle, the tree degenerates to deterministic planning with known future prices and a forecast PV trajectory.

## 4.2 Physical variables and balances

For every scenario and remaining interval:

$$i_{s,t} + u_{s,t} = V_{s,t}, \qquad i_{s,t} \geq 0, \qquad 0 \leq u_{s,t} \leq V_{s,t}, \tag{7}$$

$$g_{s,t} = i_{s,t} + d_{s,t} - c_{s,t}, \tag{8}$$

$$-P^{\text{imp}} \leq g_{s,t} \leq P^{\text{exp}}. \tag{9}$$

Curtailment appears only in the PV balance. It cannot erase bought grid energy or battery charging energy. A negative grid exchange must be absorbed by net battery charging since there is no local

demand. The model does not explicitly assign charging power to its PV/grid source; that partition is an accounting convention used in post-processing.

With $z_{n,t} \in \{0,1\}$ denoting charging mode,

$$0 \le c_{n,t} \le \overline{P} z_{n,t}, \qquad 0 \le d_{n,t} \le \overline{P}(1 - z_{n,t}). \tag{10}$$

This excludes simultaneous charge and discharge, uses one symmetric AC rating, and introduces no separate battery-inverter power limit.

SOC percentage parameters $s_{\min}, s_{\max}$ define

$$E^{\min} = E\frac{s_{\min}}{100}, \qquad E^{\max} = E\frac{s_{\max}}{100}, \qquad E^{\min} \le e_{s,t} \le E^{\max}. \tag{11}$$

For $\rho_t = (1-\sigma)^{\Delta_t}$, the transition is

$$e_{s,t+1} = \rho_t e_{s,t} + \eta_c c_{s,t}\Delta_t - \frac{d_{s,t}\Delta_t}{\eta_d}. \tag{12}$$

One AC MWh charged stores $\eta_c$ MWh. Delivering one AC MWh consumes $1/\eta_d$ internal MWh. In combined mode the two configured efficiencies each cover their entire directional path. In converter-and-cell mode, $\eta_c = \eta_{c,\text{conv}}\eta_{c,\text{cell}}$ and $\eta_d = \eta_{d,\text{conv}}\eta_{d,\text{cell}}$. The alternatives cannot be mixed. The round-trip factor is $\eta_c\eta_d$. Self-discharge acts on stored energy, not on a power variable, and is separate from cycle degradation cost.

The initial boundary is fixed to measured/carried/projected state $e^k$:

$$e_{s,0} = e^k. \tag{13}$$

If the terminal target is configured, also impose

$$e_{s,T} = e^{\text{target}}. \tag{14}$$

In the GME adapter, initial/terminal percentages are converted using nominal capacity. A `null` terminal SOC omits (14). Prepared and synthetic boundary-state contracts use explicitly named MWh values. Neither version adds a terminal energy salvage value to the objective. An independent optional lower target, configured by `state.terminal_soc_min_percent`, imposes

$$e_{s,T} \ge E\, s_{\text{floor}}/100. \tag{15}$$

Its shared default is `null`. When enabled it applies to every planning horizon end, including intermediate delivery days in continuous operation. A non-null final equality and this floor both apply on the final day. The floor constrains planned energy; forecast-error feedback can produce a realized closing SOC below it while still respecting the hard SOC box.

### 4.3 Auction quantities and physical delivery

Let $Q_t^{\text{fix}}$ contain all previously submitted commitments, priced or still pending. The new final position on leaf $s$ is

$$Q_{s,t} = Q_t^{\text{fix}} + \sum_{a \in \mathcal{A}_k :\, t \in \mathcal{T}_a} q_{a,n_a(s),t}. \tag{16}$$

An ineligible auction/interval has no trade variable. The model allows signed sales/purchases; they are adjustments to prior positions, not gross generation. For every eligible trade,

$$-P^{\text{imp}}\Delta_t \le q_{a,n,t} \le P^{\text{exp}}\Delta_t. \tag{17}$$

For every open auction $a$ in chronological order, define the cumulative planned position after that auction as

$$C^a_{s,t} = Q^{\text{fix}}_t + \sum_{b \in \mathcal{A}_k:\, b \le a,\, t \in \mathcal{T}_b} q_{b,n_b(s),t}. \tag{18}$$

It satisfies

$$-P^{\text{imp}}\Delta_t \le C^a_{s,t} \le P^{\text{exp}}\Delta_t, \qquad -P^{\text{imp}}\Delta_t \le Q_{s,t} \le P^{\text{exp}}\Delta_t. \tag{19}$$

There is no independent commercial volume cap. The directional POI ratings apply to individual auction adjustments, cumulative positions after each auction, and physical delivery. An offsetting later trade is allowed, subject to its own POI-derived limit and the resulting position limit. Thus the model permits bounded cross-auction spread trading even without a battery; its revenues can be present in both asset counterfactuals.

With the shared default `trading.optimize_imbalances: false`, planned delivery is exact in every interval:

$$g_{s,t}\Delta_t = Q_{s,t}. \tag{20}$$

No positive/negative imbalance variables or imbalance direction binary are created. Forecast deviations are not an additional dispatch resource. An optional configured product-group delivery equality can additionally impose $\sum_{t \in h}(g_{s,t}\Delta_t - Q_{s,t}) = 0$. It is redundant with (20) and does not replace it in the disabled-imbalance mode.

### 4.4 Current objective and sunk cash flows

For throughput degradation with coefficient $c_{\text{thr}}$ and an optional import fee $f$, the current residual objective is

$$\max J_k = \sum_{s \in \mathcal{S}_k} w_s \left[ \sum_{a \in \mathcal{A}_k} \sum_{t \in \mathcal{T}_a} \pi_{a,s,t} q_{a,n_a(s),t} - c_{\text{thr}} \sum_t (c_{s,t} + d_{s,t})\Delta_t - f \sum_t [-g_{s,t}]_+ \Delta_t - C^{\text{trading}}_s \right]. \tag{21}$$

The implementation uses an exact import-power linearization with a direction binary only when $f$ is nonzero. The shared default sets this additional import fee to zero; market transaction fees are represented separately below.

### 4.5 Market transaction fees and operator monthly volume

The `transaction_fees.mode` is `none`, `flat`, or `gme_real` (the shared YAML default). Legacy programmatic inputs without a fee section remain fee-free. Let $m(a)$ be the calendar month of auction submission in market local time, $V_m$ known already executed operator volume, and $G_{m,s} = \sum_{a:m(a)=m,t} |q_{a,n_a(s),t}|$ new gross MWh. Purchases and sales count separately even when final delivery is zero. Quarter-hour energy shares of an hourly product are summed once, without another duration factor. For a cumulative progressive tariff $F_m$,

$$C^{\text{trading}}_s = \sum_m \left[ F_m(V_m + G_{m,s}) - F_m(V_m) \right]. \tag{22}$$

In flat mode this is the configured EUR/MWh coefficient times gross MWh. The published GME MPE marginal rates are 0 on the first 20,000 MWh/month, 0.04 up to 1,000,000, 0.03 up to 10,000,000, and 0.02 thereafter. These bands are progressive and not a retroactive rate on the monthly total.

Fee-free horizons introduce no auxiliary variables. Positive single-band costs use linear absolute-value epigraphs. Across reachable breakpoints, exact Gurobi ABS general constraints and a PWL

equality represent both gross volume and the nonconvex tariff; a convex epigraph alone is not used for regressive bands. Absolute-value variables retain auction-node ownership and native-product sharing. Costs are evaluated for each leaf and weighted by $w_s$.

The fee state includes pending guaranteed transactions immediately at submission. Publication adds no second fee. Executed gross volume remains in $V_m$ during residual solves, while incurred EUR are sunk. The state carries an availability clock and declared provenance; nonzero future executed monthly volume is rejected. Months use transaction dates, so pre-DA/IDA1/IDA2 and IDA3 for one delivery day may belong to different months. A new month starts at zero. The saved final fee state can initialize a later chronological study. Operator scope must explicitly distinguish a standalone plant from a portfolio with exogenous starting volume. Unknown future external activity is not invented: costs are exact conditional on the supplied initial state, not a complete operator-level monthly forecast.

Tariffs have explicit nonoverlapping complete-month validity windows, version, source, thresholds, marginal rates and an applicability status. The current GME tariff and the 2006 annual report show the same structure, the latter effective in 2007. A dated confirmation of 2025 applicability was not established; the shared December 2024–December 2026 tariff marks this explicitly as `assumed_unchanged`. Unsupported dates fail. The shared initial state assumes a standalone simulated operator at local midnight on 1 December 2024, with zero December volume, zero earlier fees and no external portfolio activity. Subsequent months begin at zero and continuous execution carries actual submitted volume. Known operator-level volume should replace this assumption when the plant belongs to a larger portfolio. Enabling this tariff can still produce zero variable fees below the monthly exemption. Example YAMLs are `configs/full_experiments/synthetic_fees_none.yaml`, `configs/full_experiments/synthetic_fees_flat.yaml`, and `configs/full_experiments/synthetic_fees_gme.yaml`. Membership, taxes, ACER record charges and separate aggregator commissions remain excluded; physical grid fees and degradation remain separate cost components.

Past auction cash flow and already incurred degradation are sunk at residual reoptimization. Priced commitments remain in the external ledger, and pending unpriced submitted quantities enter $Q^{\text{fix}}$ without adding an optimizable cash-flow term. Their future clearing value is constant with respect to all remaining decisions and is excluded from $J_k$. This avoids double counting. The initial pre-DA solve has no prior commitments; its objective spans the modeled whole-day opportunity set. Residual objective values therefore should not be summed across auction solves to compute daily profit.

There is no explicit curtailment penalty, risk measure, capital cost, fixed O&M, tax, brokerage fee, ramp constraint, minimum dwell time, or calendar-aging charge in (21). Curtailment can affect revenue through delivery choices, but is not independently priced. The horizon can exploit inventory when its terminal target is free; this matters when comparing asset value.

### 4.6 What is free at each of the four decisions

| Decision | New free auction quantities | Previously submitted fixed quantities |
|---|---|---|
| DA | DA, IDA1, IDA2, IDA3 plans | None |
| IDA1 | IDA1, IDA2, IDA3 plans | DA |
| IDA2 | IDA2, IDA3 plans | DA and IDA1 |
| IDA3 | IDA3 eligible products | DA, IDA1 and IDA2 |

At each decision, remaining-horizon charge/discharge modes, curtailment, grid powers and energy states are free subject to their balances, boundary state, nonanticipativity, product rules and terminal condition. Executed past intervals are absent from the residual grid. Future-auction quantities are plans until their own submission. Only the current auction order is committed from

that solve. Before noon, IDA3 cannot change orders for the morning; physical control commands from the previous plan also remain in force. All IDA3 decision variables cover only the 48 quarter-hours from 12:00 to midnight: charge, discharge, mode, curtailment, grid power and trades, with 49 SOC boundaries. Gate closure determines the information cutoff, not the delivery horizon.

More generally, let $c_k$ be the submission cutoff and $j_k$ the first grid boundary no earlier than both $c_k$ and the current auction's first eligible delivery. The solver starts at $j_k$. From the latest observed physical state, the replay projects the locked prefix using the previously requested commands $\bar{u}_i$, fixed contracted grid targets $Q_i/\Delta_i$, and the latest cutoff-available PV forecast $\widehat{P}_i^{(c_k)}$ through the same physical controller $\Phi$ used for delivery:

$$\widehat{x}_{i+1|c_k} = \Phi\left(\widehat{x}_{i|c_k}, \bar{u}_i, Q_i/\Delta_i, \widehat{P}_i^{(c_k)}\right), \qquad i < j_k. \tag{23}$$

Here $x$ includes energy and degradation state. The resulting $\widehat{E}_{j_k|c_k}$ is the fixed initial energy of the residual MILP. Forecast publication eligibility is still checked at $c_k$; projecting to noon does not permit a forecast released after the 10:00 gate. No future measured PV is used in this projection. Actual delivery continues with the retained commands and realized PV, so its noon state may differ from the projected state. Grid feedback and protection enforce the actual SOC and power bounds. If IDA3 is the first participating auction, zero-position feedback continues until noon.

# 5 Battery degradation models

## 5.1 Current AC throughput approximation

For one trajectory,

$$H = \sum_t (c_t + d_t)\Delta_t, \qquad D_{\text{thr}} = c_{\text{thr}} H. \tag{24}$$

Both directional AC throughputs are charged once. The YAML can directly supply $c_{\text{thr}}$ or derive it from replacement economics and reference cycle life. Let $p_{\text{USD}}$ be pack USD/kWh, $x$ be USD per EUR, $p_{\text{extra}}$ additional EUR/kWh replacement cost, $s_R$ salvage fraction, $N$ reference cycle life and $d_{\text{ref}}$ reference internal depth of discharge. Then

$$R = 1000E\left(\frac{p_{\text{USD}}}{x} + p_{\text{extra}}\right)(1 - s_R), \tag{25}$$

$$H_{\text{life}} = N d_{\text{ref}} E\left(\frac{1}{\eta_c} + \eta_d\right), \tag{26}$$

$$c_{\text{thr}} = \frac{R}{H_{\text{life}}}. \tag{27}$$

One reference internal cycle charges $d_{\text{ref}}E/\eta_c$ AC MWh and discharges $d_{\text{ref}}E\eta_d$ AC MWh, explaining the normalization. There is no additional factor of two or half applied to (27). The configured end-of-life capacity fraction is descriptive metadata, not an extra multiplier or a dynamic capacity update.

The shared YAML uses a historical generic pack-price proxy, a dated FX conversion, and an illustrative reference cycle life. Those are study inputs with source metadata, not an estimate of a specific installed BESS cost. The resolved $R$ and $c_{\text{thr}}$ are saved. The cost is financial wear; it does not reduce $E$, $\overline{P}$, or efficiencies as the simulation proceeds.

## 5.2 Optional segmented depth-dependent aging

The optional `xu_segmented` mode follows the configured segmented cycle-depth construction described in the repository's Xu notes and the author paper [1]. It is distinct from the current

throughput study. For a configurable convex stress curve $\Phi(d) = \alpha d^{\beta}$, $\beta \geq 1$, partition nominal internal capacity into $J$ equal segments of size $E/J$. The marginal AC discharge cost of segment $j = 1, \ldots, J$ is

$$m_j = \frac{RJ}{\eta_d E} \left[\Phi(j/J) - \Phi((j-1)/J)\right]. \tag{28}$$

It is nondecreasing with depth. The degradation charge is

$$D_{\mathrm{Xu}} = \sum_t \sum_{j=1}^{J} m_j d_{j,t} \Delta_t. \tag{29}$$

Only discharging is charged under this convention. A discharging half-cycle incurs the convention's depth cost, while a charging half-cycle does not; do not add an extra factor of one half. Nonzero throughput cost is rejected in this mode.

Segment flows and energies obey

$$\sum_j c_{j,t} = c_t, \qquad \sum_j d_{j,t} = d_t, \qquad \sum_j h_{j,t} = e_t, \tag{30}$$

$$h_{j,t+1} = h_{j,t} + \Delta_t(\eta_c c_{j,t} - d_{j,t}/\eta_d), \qquad 0 \leq h_{j,t} \leq E/J. \tag{31}$$

Segment energies represent cycle-depth memory, not fixed absolute SOC buckets. Charging and discharging both use shallow available segments first. For each $j < J$, the implementation adds priorities $v^c_{j,t}, v^d_{j,t} \in \{0, 1\}$:

$$\sum_{\ell > j} c_{\ell,t} \leq \overline{P} v^c_{j,t}, \qquad h_{j,t+1} \geq (E/J) v^c_{j,t}, \tag{32}$$

$$\sum_{\ell > j} d_{\ell,t} \leq \overline{P} v^d_{j,t}, \qquad h_{j,t+1} \leq (E/J)(1 - v^d_{j,t}). \tag{33}$$

Using a deeper segment therefore requires the shallower segment to end full when charging or empty when discharging. This chooses a deterministic shallow- first representative, including otherwise indifferent charging allocations. Segment actions have the same information ownership as aggregate battery power.

At a declared fresh study start, initialize

$$h_{j,0} = \mathrm{clip}\left(e_0 - (j-1)E/J,\ 0,\ E/J\right). \tag{34}$$

Afterwards the segment vector must be carried with actual execution; an arbitrary residual solve cannot reconstruct it from aggregate SOC. Previous throughput or aging requires explicit memory. Xu mode currently rejects nonzero self-discharge. It remains a finite-segment approximation and omits calendar, temperature and current-rate aging, capacity-fade feedback and unknown pre-study cycle history.

## 6 Submission, publication and reoptimization workflow

Before each active auction submission, the GME replay refreshes the latest available PV forecast over unexecuted intervals, projects a boundary if necessary, and solves the residual planning problem. Previously submitted quantities, including still-unpriced ones, are fixed. At submission, only the current auction's node-shared action is extracted. Later planned auction quantities are not booked and can change.

At publication, known prices are updated, and actual contractual revenue $\pi^{\mathrm{real}}_{a,t} q^{\mathrm{sub}}_{a,t}$ is entered exactly once in the ledger. Publication does not reopen a market. The current GME experiment

forces `reoptimize_physical_controls=false`; it uses four auction solves for four active auctions, not an extra set of publication solves or 96 physical optimizations. Physical feedback is algebraic. Synthetic replay can separately enable interval-control reoptimization, so its solve count need not be four.

At the next auction, closed commitments are carried, remaining open opportunities are reconsidered, and past executed state/aging remain fixed. In the actual-price oracle all future auction prices are already supplied as a benchmark, so price publication does not remove price uncertainty there. In a forecast-based route, known results condition subsequent price distributions without changing the commitments that produced them.

# 7 Physical feedback with realized PV

## 7.1 Feasible interval power range

The current policy is `track_committed_grid`. For interval $t$ its target is

$$g_t^\star = Q_t^{\text{committed}}/\Delta_t. \tag{35}$$

The controller uses effective realized interval-average PV $\widetilde{V}_t$; this is an idealized interval simulator, not a subsecond telemetry/control model. It does not disclose this final average to the earlier auction optimizer. Given actual initial energy $e_t$ and retained energy $\bar{e}_t = \rho_t e_t$, the feasible charging/discharging maxima are

$$C_t = \min\left\{\overline{P}, \frac{[E^{\max} - \bar{e}_t]_+}{\eta_c \Delta_t}\right\}, \tag{36}$$

$$D_t = \min\left\{\overline{P}, \frac{\eta_d \left[\bar{e}_t - E^{\min}\right]_+}{\Delta_t}\right\}. \tag{37}$$

First clip the planned charge/discharge commands to these maxima, obtaining $c_t^0, d_t^0$. Simultaneous positive requested charging and discharging after protection is rejected. Initially curtail only available PV: $u_t^0 = \min\{\widetilde{V}_t, \left[u_t^{\text{plan}}\right]_+\}$.

## 7.2 Grid-tracking policy

Release scheduled curtailment if it can help meet a deficit:

$$g_t^0 = \widetilde{V}_t - u_t^0 + d_t^0 - c_t^0, \tag{38}$$

$$\bar{u}_t = u_t^0 - \min\{u_t^0, \left[g_t^\star - g_t^0\right]_+\}. \tag{39}$$

The desired net battery dispatch and its feasible projection are

$$b_t^{\text{req}} = g_t^\star - \widetilde{V}_t + \bar{u}_t, \tag{40}$$

$$b_t = \text{clip}(b_t^{\text{req}}, -C_t, D_t), \tag{41}$$

$$c_t = [-b_t]_+, \qquad d_t = [b_t]_+. \tag{42}$$

Finally curtail any remaining surplus that battery adjustment cannot absorb:

$$u_t = \bar{u}_t + \min\{\widetilde{V}_t - \bar{u}_t, \left[\widetilde{V}_t - \bar{u}_t + b_t - g_t^\star\right]_+\}. \tag{43}$$

Thus excess PV first decreases discharge, then increases charging as needed and feasible, then is curtailed. A PV shortfall first releases planned curtailment, then reduces charging or increases discharge within the actual SOC box. The remaining tracking error is preserved if battery power/energy cannot supply it.

POI protection follows. If net import exceeds its rating, charging is reduced. If export exceeds its rating, discharge is reduced first and remaining excess PV is curtailed. Grid power is recomputed consistently with the adjusted actions. Actual energy then advances using (12) with these executed powers, and bounds are checked before accepting the new state. Both throughput/Xu memory and cumulative financial wear are advanced from executed actions, not from the old auction plan. Protection is mandatory under either execution policy; the alternative `follow_battery_plan` skips grid-tracking adjustment.

There is no controller constraint forcing the actual terminal energy to the auction plan's target. Forecast errors and grid tracking can cause an ending-SOC difference even if every optimization imposed (14). This is visible in the current terminal-50% study and is not equivalent to guaranteeing 50% realized SOC. Any hard actual-terminal policy would be an additional controller design and could create different imbalances/cash flows.

### 7.3 PV source allocation for reporting

For the executed trajectory, use the explicit PV-first accounting convention

$$P_t^{\mathrm{PV}\to\mathrm{B}} = \min\{\widetilde{V}_t - u_t, c_t\}, \tag{44}$$

$$P_t^{\mathrm{PV}\to\mathrm{G}} = \widetilde{V}_t - u_t - P_t^{\mathrm{PV}\to\mathrm{B}}, \tag{45}$$

$$P_t^{\mathrm{PV}\to\mathrm{curt}} = u_t. \tag{46}$$

They sum to $\widetilde{V}_t$ in every interval. Grid-supplied charging and battery discharge are not counted as PV production. These are post-processing flows; there are no separate source-attribution decision variables in the MILP.

## 8 Settlement and expected-versus-realized accounting

Actual net deviation is retained at the native quarter-hour:

$$\delta_t^{\mathrm{real}} = g_t^{\mathrm{real}}\Delta_t - Q_t^{\mathrm{committed}}. \tag{47}$$

Positive means more net export than promised. With the selected single Terna NORD settlement price $\lambda_t$, the modeled cash flow is

$$S_t = \lambda_t \delta_t^{\mathrm{real}}. \tag{48}$$

A positive price therefore does not mean every imbalance is penalized: positive excess export is credited and a negative deviation is debited. Negative prices are allowed and reverse these cash-flow signs. The general settlement helper also accepts two directional curves:

$$S_t = \lambda_t^{+}\left[\delta_t^{\mathrm{real}}\right]_+ - \lambda_t^{-}\left[-\delta_t^{\mathrm{real}}\right]_+. \tag{49}$$

This documents the implemented study accounting, not every possible Italian participant-specific settlement item or regulatory regime. The workbook adapter selects the declared NORD macrozone and the imbalance-price column, retaining other imported fields as provenance. Product starts and ends must match the execution grid exactly. Prices are neither hourly-averaged nor filled across gaps; missing enabled settlement prices are an error.

Actual daily auction cash flow and settled operating profit are

$$A^{\mathrm{real}} = \sum_{a,t} \pi_{a,t}^{\mathrm{real}} q_{a,t}^{\mathrm{sub}}, \tag{50}$$

$$J^{\mathrm{real}} = A^{\mathrm{real}} + \sum_t S_t - D^{\mathrm{executed}} - f\sum_t \left[-g_t^{\mathrm{real}}\right]_+ \Delta_t - C^{\mathrm{trading,real}}. \tag{51}$$

A model deterrence penalty is not an actual settlement charge and is not subtracted a second time by actual post-processing. If settlement is unavailable, profit before settlement is reported and fully settled profit remains unknown. Only actually submitted guaranteed transactions enter $C^{\text{trading,real}}$; future plans that are never submitted contribute no realized fees. The ledger retains transaction-month volume, per-trade charges and tariff versions. An independent Python calculation reconciles those charges and the final monthly state. Expected and realized transaction fees are reported separately from gross auction revenue. In `realized_profit_breakdown.png`, trading-fee EUR and gross MWh occupy the former import-fee slot; nonzero physical grid fees appear as their own additional bar.

Let $J^{\text{init}}$ and $A^{\text{init}}$ be the initial auction solve's expected profit and auction revenue. Saved mismatches are

$$\Delta J = J^{\text{real}} - J^{\text{init}}, \qquad \Delta A = A^{\text{real}} - A^{\text{init}}, \qquad r_J = 100\frac{\Delta J}{|J^{\text{init}}|}. \tag{52}$$

The percentage is undefined/`null` when its expectation is zero; unsettled profit comparisons remain unknown. Differences include later replanning and physical execution effects, not only price-forecast error.

The replay also evaluates each stored auction snapshot as an open-loop diagnostic against realized PV and the same settlement prices. Its planned battery commands are protected physically. Deviations are measured against that snapshot's planned grid schedule (which can include assumed future trades) or the final contract, as labeled in the recorded comparisons. It is not another auction optimization. Because IDA3 covers a shorter residual horizon, a common-horizon comparison is also saved; unaligned whole-horizon totals should not be compared as if their delivery intervals were identical.

## 9 Value of reoptimization through frozen-plan replay

The optional frozen-plan comparison asks what would happen if planning stopped after one auction decision but physical feedback continued. This differs from the older open-loop imbalance diagnostic, which follows planned battery commands without grid-tracking feedback and does not reconstruct an alternative complete auction ledger and net profit.

Let $k$ be an active auction other than the final active auction. At its cutoff, retain the entire deterministic future-trade vector from that solve. Define

$$q_{a,t}^{[k]} = \begin{cases} q_{a,t}^{\text{submitted,ref}}, & a \le k, \\ q_{a,t}^{\text{plan},k}, & a > k, \end{cases} \qquad Q_t^{[k]} = \sum_a q_{a,t}^{[k]}. \tag{53}$$

The already submitted trades are fixed even if their prices are unpublished. Future orders are the frozen snapshot's orders, not the later realized orders from the reoptimized strategy. They are submitted at their original gates and priced at actual clearing prices. Their eligibility must ensure submission precedes the relevant delivery interval. Thus their cumulative position is a valid delivery-time tracking target without prematurely revealing new prices or forecasts to the frozen plan.

Executed history before the frozen residual boundary remains identical to the reference trajectory. The suffix starts from the actual carried energy, throughput, incurred wear and, for Xu mode, segment-memory vector. It is not reset to the snapshot's forecast SOC, including when the cutoff projects a not-yet-observed boundary. At physical delivery that boundary's actual state is carried forward without changing the frozen decisions. The same configured execution policy uses the frozen battery/curtailment commands, target $Q_t^{[k]}/\Delta_t$, and the same effective realized PV:

$$(c_t^{[k]}, d_t^{[k]}, u_t^{[k]}, e_{t+1}^{[k]}) = \mathcal{F}(e_t^{[k]}, \widetilde{V}_t, Q_t^{[k]}/\Delta_t, c_t^{\text{plan,k}}, d_t^{\text{plan,k}}, u_t^{\text{plan,k}}). \tag{54}$$

Here $\mathcal{F}$ is the grid-feedback/protection policy described above. The current study uses grid tracking; the alternative execution policy, if selected, is shared with the reference. No later optimization or weather-forecast update is applied. The algebraic replay adds zero optimization solves.

Using the same signed settlement convention and actual dated transaction-fee accounting as the reference, the full-day frozen profit is

$$J^{[k]}_{\text{frozen}} = \sum_{a,t} \pi^{\text{real}}_{a,t} q^{[k]}_{a,t} + \sum_{t} S^{[k]}_{t} - D^{[k]} - C^{[k]}_{\text{import}} - C^{[k]}_{\text{trading}}. \tag{55}$$

Previously executed prefix costs are preserved. Future wear is recomputed from the counterfactual's executed commands; gross fees are recomputed from its own trade ledger and the same initial operator-volume state, including month transitions and tariff bands. Reference future trades or fees are never borrowed after the freeze point.

The value KPI is

$$G_k = J^{\text{real}}_{\text{fully reoptimized}} - J^{[k]}_{\text{frozen}}. \tag{56}$$

Both sides cover the entire delivery day, so differing residual lengths do not create incomparable profit totals. Positive values favor later reoptimization; negative values are retained. Each $G_k$ measures all later replanning after $k$: the values are not additive and need not be monotonic. This comparison includes new forecasts, revised orders and state-aware planning rather than isolating a causal effect of forecast accuracy. Final stored-energy differences are reported; no terminal salvage price is assumed. If actual settlement is unavailable, settled profit and $G_k$ remain unknown.

The independent YAML section is `reoptimization_baseline`. Its options are `enabled`, `freeze_after_auctions`, and `plots`. An absent section disables the feature; the comparison study enables it. A null auction selection evaluates every active pre-final auction, while a list chooses a subset. The last active auction is always excluded, cancelled auctions produce no baseline, and an empty selection produces no comparisons. The plot switch also respects the global plot setting. Snapshot replay requires deterministic plans; it rejects using one selected leaf of a contingent plan as if all of its future branches were already known.

The simulator is `src/simulation/frozen_plans.py`. Saved dispatch-plan rows include every `planned_trade_<auction>_mwh` and their planned net position. Full-day profits, gains and states are saved in the frozen-plan summary CSV/JSON, with separate actual counterfactual dispatch and trade ledgers. Individual gains also enter the scalar KPI table, and `reoptimization_value.png` compares frozen profits with the reference. The isolated January configuration is `configs/full_experiments/gme_oracle_2025-01-01_farm910_reoptimization_value.yaml`.

# 10 Perfect-information schedules and the PV-only baseline

## 10.1 PV+BESS versus the feedback controller

After replay, one additional full-day problem uses $V_t = \widetilde{V}_t$ and all actual auction-price curves, with a single scenario and all auction orders jointly free subject to their native products, eligibility, POI and physical constraints. It retains the BESS ratings, efficiencies, SOC box, degradation, initial energy and configured terminal target. Call its achieved solver objective $J^{\text{PI}}_{\text{PV+BESS}}$.

This is deliberately a hindsight plan rather than a causally executable policy. It is compared with the feedback controller's actual dispatch, curtailment and SOC, and its objective is saved as the solver's `ObjVal`. Four missing measurement intervals, if permitted by the selected run, are handled through that run's explicit fallback; diagnostics record their count and identities. The schedule figure shows both trajectories and their battery-power difference through the final day boundary. It does not assert that feedback should reproduce the hindsight trajectory or terminal energy.

### 10.2 PV-only asset counterfactual

When `experiment_outputs.pv_only_baseline: true`, a second independent solve uses the same optimizer builder with

$$E = 0, \quad \overline{P} = 0, \quad E^{\min} = E^{\max} = 0, \quad e_0 = e_T = 0, \quad D = 0. \tag{57}$$

Battery powers and energy variables are consequently fixed to zero; the code reuses one physical/trading formulation instead of implementing a second, potentially inconsistent PV-only model. Unused variables can be removed by solver presolve. PV injection/curtailment and auction trades remain free subject to the same effective realized PV, native products, active auctions and POI. Call its achieved objective $J^{\mathrm{PI}}_{\mathrm{PV}}$.

The incremental operating-value KPI is

$$\Delta J^{\mathrm{PI}}_{\mathrm{BESS}} = J^{\mathrm{PI}}_{\mathrm{PV+BESS}} - J^{\mathrm{PI}}_{\mathrm{PV}}. \tag{58}$$

The BESS side includes its own modeled degradation; the PV-only side has no battery wear. Both sides retain permitted cross-auction spread trading, so market-trading revenue common to both is not credited to battery ownership. The KPI does not subtract realized feedback wear from a different ideal schedule. Each counterfactual reports its own objective components. Directly subtracting a PV-only hindsight objective from the realized PV+BESS feedback profit would mix information and execution policies and is not the asset-value KPI.

This comparison is one-day operating value before capital expenditure, fixed operating costs, financing and taxes. A free terminal target can also use initial stored energy or leave different inventory; the selected 50% initial/terminal hindsight comparison avoids that particular inventory difference for the BESS model. Realized feedback may still finish at a different SOC. No residual-energy valuation, annualization, payback, NPV or investment optimization is implemented. Those need a representative horizon and additional cost/cash-flow assumptions.

Setting the switch to `false` skips the PV-only solve and its model, JSON, CSV and figure. Incremental-value metrics become `null` and an explicit baseline-enabled KPI is false. The perfect-information PV+BESS-versus-feedback comparison still runs. Four active auctions therefore produce four replay solves plus one PV+BESS hindsight solve and, when enabled, one PV-only solve. Counterfactual solve diagnostics are separate from replay solve counts.

## 11 Configurable participation and matched-day profile comparison

Participation is a choice of a nonempty subset $P$ of the chronologically ordered auction set $\mathcal{A} = \{\mathrm{DA}, \mathrm{IDA1}, \mathrm{IDA2}, \mathrm{IDA3}\}$. The single-study configuration is `gme_oracle_experiment.participating_auctions`. Omission or null selects every configured auction dataset. Gate order remains unchanged; unselected auctions have no price-data requirement, trade variables, submission event/solve or fees. Their orders are absent rather than independent variables fixed after a solve. The active set on day $d$ also removes documented/configured cancellations. If every selected auction is documented/configured as cancelled, the profile retains its full delivery day with zero orders, auction/control solves and auction fees. The zero-position feedback policy stores PV within the SOC box and curtails remaining surplus; executed wear and settlement remain in actual profit. There is no initial auction objective (its expectation KPIs are null), and no auction plan enforces the configured terminal target on that day. Missing or partial price data without cancellation evidence still fail.

Four independently optional auctions produce

$$|\{P \subseteq \mathcal{A} : P \neq \varnothing\}| = 2^4 - 1 = 15. \tag{59}$$

If DA is mandatory and the three IDA auctions remain optional, there are instead

$$|\{\{\text{DA}\} \cup S : S \subseteq \{\text{IDA1}, \text{IDA2}, \text{IDA3}\}\}| = 2^3 = 8. \tag{60}$$

Both families and explicitly listed profiles are supported. For example, $P = \{\text{IDA1}, \text{IDA2}\}$ and $P = \{\text{IDA3}\}$ are valid without DA. All physical, native-product, degradation and settlement constraints continue to apply to the same full delivery day.

If the first selected gate occurs after delivery begins, its prefix uses zero contracted grid delivery and grid feedback with zero planned battery commands. The controller may store PV within the energy box and curtail remaining surplus; it does not earn uncontracted export revenue in this prefix. Actual energy and wear carry to the first selected solve, including the existing unfinished-interval state projection. No extra auction optimization is inserted before the first selected decision. Prefix executed/projected costs are subtracted from the first residual objective when forming an initial whole-day expected profit; the residual model objective is separately retained. Actual whole-day profit already includes all executed prefix costs through the ordinary financial accounting.

### 11.1 Sequential current-auction-only baseline

At the decision for auction $a$, integrated planning includes the open auctions $\mathcal{A}_a$. The configurable sequential baseline replaces this set by $\{a\}$. Let $Q_t^{<a}$ denote all previously submitted, fixed quantities, including unpriced commitments. Its only free market quantity is $q_{a,t}$:

$$Q_t = Q_t^{<a} + q_{a,t}, \qquad \max \sum_t \lambda_{a,t} q_{a,t} - C_{\text{deg}} - C_{\text{import}} - C_{\text{fees}}. \tag{61}$$

The existing physical balances link $Q_t$ to grid delivery. The full remaining delivery horizon retains charge/discharge, curtailment, SOC transitions, native product equalities, POI limits and the configured terminal target. No later auction trade or revenue appears. Sunk earlier cash flow does not affect the choice. Each next gate receives updated PV, actual carried battery state and immutable prior submissions. Under the price-oracle convention, the current auction's actual clearing curve is supplied to that solve.

`gme_oracle_experiment.auction_planning_mode` selects `integrated` (default) or `current_auction_only`. `participation_study.sequential_all_auctions_baseline` optionally adds one all-auction sequential result beside the integrated participation profiles. The January study refresh comprises 465 integrated cases and 31 sequential cases. Matched daily realized profits, their paired differences, model sizes, forecast inputs and fallback decisions are saved. A later infeasible sequential solve retains prior physical commands and submits zero new trades; it has no previously planned future order to submit.

### 11.2 Operational fallback after an infeasible auction decision

Exact planned delivery does not guarantee feasible recourse after forecast updates. Limited remaining energy, power and trading capacity may conflict with the configured terminal state or remaining delivery obligations. The physical controller can continue within SOC/power limits by accepting an imbalance even when the planning model is infeasible. A pre-noon delivery shortfall is executed and settled under the retained policy; those closed intervals are excluded from the IDA3 MILP and cannot make it infeasible.

The configurable policy `execution.infeasible_auction_policy` defaults to `error`. The full-January study uses `previous_plan`. When and only when the solver confirms infeasibility, this policy uses the last feasible deterministic snapshot for the current auction's previously unsubmitted orders and remaining requested physical commands:

$$q_{a,t}^{\text{submit}} = q_{a,t}^{\text{last feasible}}, \qquad u_t^{\text{requested}} = u_t^{\text{last feasible}}. \tag{62}$$

The orders are submitted at their actual gate and priced at actual clearing prices with ordinary fee accounting; existing commitments remain fixed. The same feedback controller executes against actual PV, respects the physical limits, and settles unavoidable deviations ex post. This is a retained plan, not a new feasible optimum under the updated forecast. No recovery optimization or constraint relaxation is introduced. Subsequent selected decisions still attempt their normal reoptimization. Missing prior plans, nondeterministic snapshots and other solver failures remain errors.

Failed decision/forecast diagnostics, reused plan sources, submitted quantities and attempt counts are saved separately from successful solves; optional IIS reports use `execution.save_infeasibility_diagnostics`. Summary tables retain fallback-day and failed-decision counts rather than omitting those dates from the comparison. The physical trajectory can finish away from the terminal SOC target of its retained plan, just as under ordinary forecast-error feedback.

The `experiment-participation` command runs configured profiles on a common set of delivery days $\mathcal{D}$. The ranking metric is

$$\overline{J}(P) = \frac{1}{|\mathcal{D}|} \sum_{d \in \mathcal{D}} J^{\text{real}}(P, d), \qquad P^{\star}_{\mathcal{D}} \in \arg\max_{P} \overline{J}(P). \tag{63}$$

It is an empirical ranking on $\mathcal{D}$, not an established optimum for unseen days. Selecting a different winning profile after each observed day would evaluate $|\mathcal{D}|^{-1} \sum_d \max_P J^{\text{real}}(P, d)$ and would use additional hindsight; the saved daily-winner table is diagnostic and is not the fixed-profile ranking.

Every profile must complete exactly the same requested dates with fully priced actual settlement. Missing or invalid inputs fail the batch; they do not silently change a profile's averaging sample. Battery and operator fee initial state are identical across profiles and reset independently each study day. This is not a continuous multi-day carry of SOC or monthly traded volume. The initialization weather cutoff is common before the earliest candidate gate and delivery start. Later forecast updates occur only at selected auction decisions. Delivery grids, initial PV forecasts, effective realized PV (including configured fallback intervals) and shared actual auction-price curves are fingerprinted and checked for equality across profiles. The market adapter resolves native auction-product durations for each date. Actual price snapshots, model inputs and all daily decisions remain in the per-profile run artifacts.

Summary outputs retain average, total, minimum, maximum and median daily profit, 10th/90th percentiles, daily population standard deviation, negative-profit and zero-active-auction day counts, daily wins including configured tolerance ties, paired differences to the largest selected profile, mean SOC/energy, curtailment, wear, transaction fees and active auction/solve counts. Final stored energy is reported without salvage valuation. The current configured terminal SOC remains a planning constraint rather than a guarantee on feedback's final state, so cash profit and ending inventory must be assessed together. Fee and inventory reset assumptions also matter when extrapolating to a longer investment horizon.

The comparison figure places a separate gold perfect-foresight reference above the ranked profiles. Its mean and daily standard deviation use the full-day perfect-information objective values (Gurobi `ObjVal`) on the identical dates, effective realized PV, assets, costs and configured terminal SOC, with every configured auction that remains available. This reference includes markets outside a restricted candidate/profile family. Existing all-auction benchmark outputs are reused; if that profile is absent, one additional perfect-information solve per day supplies the reference without another auction replay. Its daily objectives and summary are retained separately, along with objective-minus-profit differences in the profile tables. This is a model-objective reference rather than an additional feedback participation rank: actual imbalance settlements and realized terminal inventory can differ between the accounting cases. `participation_study.perfect_foresight_reference` enables this feature by default and can be set to false.

The batch YAML section `participation_study` controls candidate/required auctions, explicit

profile lists, common dates, output paths, per-profile figures/models, summary plotting and profit-tie tolerance. The supplied example is `configs/full_experiments/gme_participation_2025-01-01_03.yaml`. The full-month independent-day configuration is `configs/full_experiments/gme_participation_2025-01.yaml`, with 31 common delivery days and 465 profile/day cases. Fully cancelled IDA3-only cases remain in the averaging sample rather than changing that profile's denominator. The driver is `src/simulation/participation_study.py`, while `src/participation.py` validates/enumerates subsets. Summary CSV/JSON/plots are stored apart from each individual replay under its profile/day directory. Optional `participation_study.resume` verifies the same effective configuration, completed child manifests, input fingerprints and saved profits before reusing checkpoints. Incomplete children are retained separately and rerun; changed configurations are rejected. After independent solution validation, tolerated negative floating-point command roundoff is floored to zero before the physical controller's strict nonnegative-input checks.

# 12 Continuous operation with daily optimization horizons

## 12.1 Delivery books and the chronological event sequence

The separate `experiment-continuous` workflow selects inclusive local delivery dates $d \in \mathcal{D} = \{d_0, \ldots, d_F\}$ through `continuous_optimization.start_date` and `end_date`. Each day has its own physical grid $\mathcal{T}_d$, native auction products, actual price curves and auction calendar. Commitments and revisable plans are keyed by delivery day as well as auction and interval, for example $(d, a, t)$; the same auction name on another delivery day is a different market book. This is continuous chronological execution with daily planning horizons; it is not a single multi-day MILP, and a later-day solve cannot revise an earlier delivery book.

All events are merged into one chronological sequence. On an ordinary operating day $d$, the replay submits IDA3 orders for $d$, then DA, IDA1 and IDA2 orders for $d+1$ while executing delivery $d$. Submissions use the configured decision buffer before the local gate; price publications book already submitted orders without triggering another optimization. IDA3 variables remain restricted to noon–midnight of their delivery day. Native DA-hour equalities and quarter-hour IDA/physical controls are unchanged. Cancelled auctions produce no order, variables or solve, and unexplained missing inputs fail preflight.

This is a chronological sequence of *daily* MILPs, not a simultaneous month-long or two-day trading MILP. An optimization for $d+1$ cannot change current-day dispatch or commitments for $d$. Conversely, current-day IDA3 cannot reopen submitted next-day DA quantities. The current-day commands and book enter next-day planning through the projected boundary state below.

## 12.2 Forecast-based projection of the next initial state

At a decision cutoff $c_k$, let $x_k^{\mathrm{obs}}$ be the most recent observed physical state at boundary $\tau_{i_k} \leq c_k$. This state includes energy, cumulative executed throughput/degradation and, when relevant, depth-model segment history. The current continuous controller requires zero configured telemetry latency, treating an interval's actual state as observable at its end; preflight rejects a nonzero `source.telemetry_latency_minutes`. This restriction is independent of the weather forecast's availability lag. An unfinished interval's already issued command is retained. Let $\bar{u}_i$ be the retained current-day charge, discharge and PV-curtailment commands and $Q_i^{\mathrm{sub}}$ the cumulative submitted grid position. For a pre-delivery DA, IDA1 or IDA2 solve for $d$, the planning boundary $b(d, a)$ is midnight at the start of $d$; for IDA3 it is noon on $d$. Define a shadow state using only the

weather/PV vintage available at $c_k$:

$$\widehat{x}_{i_k|k} = x_k^{\text{obs}}, \tag{64}$$

$$\widehat{x}_{i+1|k} = \Phi\Big(\widehat{x}_{i|k}, \bar{u}_i, Q_i^{\text{sub}}/\Delta_i, \widehat{P}_{i|c_k}\Big), \qquad i_k \le i < b(d,a). \tag{65}$$

$\Phi$ is the same grid-tracking and physical-protection controller used for actual execution. Thus the forecast projection respects SOC, battery power and POI limits while preserving the old commands and submitted grid target. It uses no new optimization for the locked prefix and no future measured PV. Forecast eligibility uses the UTC publication/availability clock at $c_k$, including the configured six-hour lag, independently of the later projected delivery boundary.

The daily MILP fixes its initial state to $x_{d,b} = \widehat{x}_{b(d,a)|k}$. At a later gate this projection is recomputed from the newer actual state and latest eligible forecast. Meanwhile actual execution advances separately:

$$x_{i+1}^{\text{real}} = \Phi\Big(x_i^{\text{real}}, \bar{u}_i, Q_i^{\text{sub}}/\Delta_i, P_i^{\text{real}}\Big). \tag{66}$$

Neither solving nor revising a shadow projection overwrites actual energy or aging state. The realized midnight state may differ from the previously projected state; later solves carry the actual state as it becomes available. Saved boundary records retain prediction, actual state and signed error $E_b^{\text{real}} - \widehat{E}_{b|k}$. Midnight projections are distinguished from IDA3 noon projections in diagnostics and plots.

### 12.3 Daily free decisions, initial condition and final target

For integrated planning, the free trade quantities are those of the current and remaining active auctions *for that delivery day*. For sequential `current_auction_only` planning, only the current auction has free trade variables and expected trading revenue. Previously submitted quantities for the target book, including unpublished pending orders, remain fixed in $Q_{d,t}^{\text{fix}}$ in both modes. Their cash values remain external to the new decision objective. Physical controls and SOC over the target day's remaining eligible delivery horizon remain free under the existing balances, costs and asset constraints. Trades in other delivery books are not decision variables in this MILP. Its objective is the daily residual objective (21); projected costs already locked before its planning boundary are not new trading opportunities.

For the supplied January configuration, $d_0 = 1$ January 2025 and $d_F = 31$ January 2025. The supplied boundary is

$$E_{d_0,0}^{\text{real}} = 0.90\, E^{\text{nominal}}. \tag{67}$$

Trading starts with the 31 December DA/IDA1/IDA2 events for delivery on 1 January. Their initial midnight state is this supplied assumption; it is not inferred from unavailable 31 December physical operation. Eligible 31 December forecasts and the actual 1 January delivery-price curves are still required. After the first midnight, there is no daily SOC reset.

The configured terminal constraint is applied only when planning the final delivery day and only when the target is non-null:

$$e_{d_F,|\mathcal{T}_{d_F}|} = E^{\text{nominal}}\, s_F/100, \qquad s_F = 50 \quad \text{(SOC percentage in the January example)}. \tag{68}$$

Intermediate midnight states have no equality target or energy salvage price. They remain inside their SOC box and, when configured, satisfy the additional planned minimum in (15). The January 2025 template leaves that minimum disabled; the paired January 2026 studies use 40%. Actual terminal energy remains an output of feedback execution and need not equal the planned target. The last delivery interval ends at local midnight on 1 February. No orders for 1 February delivery are submitted by the January study.

### 12.4 Independent trajectories, accounting and restart

The default experiment executes three independent chronologies: integrated planning, sequential current-auction-only planning and an integrated perfect-PV reference with the same daily horizons. All start from the same supplied state and use matched actual price, settlement, effective measured PV and asset inputs, but each carries its own decisions and realized state. The reference replaces forecast PV by effective realized PV, including in shadow projections. It does not introduce future delivery-day trade variables. Its reported performance is continuous settled operating profit, not the sum of overlapping auction objective values. The two trading modes and this reference are independently configurable.

The reference defaults to one optimization per delivery day, at DA (or the first active auction if DA is cancelled). The flag `continuous_optimization.perfect_pv_reoptimize_at_each_auction` defaults to `false`; setting it to `true` restores optimization at every active gate. With the default, all later auction quantities are read from the initial integrated plan and submitted only at their own gates, while its physical commands remain in force throughout delivery. Publication, fees, actual state carryover and settlement follow the same chronological rules. The event trace identifies each retained submission separately from solver attempts. Perfect information preserves the initial plan's attainable value; repeated solves can select different schedules when several optima exist, and finite MIP tolerance can permit small objective improvements.

Monthly operating profit is additive over delivery products:

$$J_{\mathcal{D}}^{\text{real}} = \sum_{d \in \mathcal{D}} \left[ \sum_{a,t} \pi_{d,a,t}^{\text{real}} q_{d,a,t}^{\text{sub}} + \sum_{t \in \mathcal{T}_d} S_t - D_d^{\text{executed}} - C_d^{\text{import}} - C_d^{\text{trading,real}} \right]. \tag{69}$$

The trade ledger preserves submission/publication clocks; daily profit is attributed to delivery date. Fees and auction revenues reconcile both by day and over the complete ledger. Operator fee volume still uses the submission month: the first day's 31 December orders belong to December, even though their revenue appears in 1 January delivery profit. Actual fee mode therefore requires an applicable December tariff and a timestamped initial operator volume state; January volume starts according to the fee calendar, without a daily reset. Wear is charged only on actual executed throughput/history. Per-day initial expectations and realized-minus-expected differences are reported separately; no objective values across overlapping gate solves are added to obtain profit.

With the configured infeasibility policy, a later failed solve can retain the previous physical plan and its already planned current order in integrated mode; the sequential mode retains dispatch and submits zero new trades. No prior plan means the existing failure behavior applies. Actual feedback still enforces physical limits and settles remaining deviations. Failed attempts and fallback choices remain explicit diagnostics.

Resume checks the effective configuration, code/policy and common input fingerprints before restoring an atomic completed-midnight checkpoint. The checkpoint contains actual physical/aging state, outstanding priced and unpriced commitments for both relevant books, retained commands, fee state, publication status and the event cursor. Work after that boundary is replayed without double-booking cash or fees. Business decisions rolled back for resume do not survive as submitted history; every actual Gurobi attempt, including discarded work, survives in a separate attempt log with its rollback marker. Native `Model.Runtime` statistics include these attempts, keep reference solves identifiable, and report totals plus mean/minimum/maximum/population standard deviation by strategy and delivery day. Model-build and Python wall times remain separate. Resolved configurations, common-input provenance, daily/monthly KPIs, state projections and comparisons are saved by file type under `outputs/continuous_optimization/<run_id>/`.

# 13 Implemented trading experiments and evidence

The primary historical runner is `experiment-gme-oracle`. It reads local manual market data, uses the same realized auction price curves for all strategies, forecasts PV using the configured cutoff-available weather, and executes the schedule against measured AC production. Supplying the future realized auction curves at the first decision is an intentional price-oracle assumption: this isolates physical/participation decisions but is not a causal price-forecast backtest and cannot be interpreted as implementable expected profit.

The implemented comparisons are:

- Integrated planning across the currently open auctions versus `current_auction_only`, where only the auction closing now has trade variables. Both carry the same submitted commitments as fixed positions.
- Independent-day participation profiles, comparing all nonempty subsets of DA, IDA1, IDA2 and IDA3 on matched dates, plus a sequential all-auction baseline. Cancellations create neither a solve nor trade variables.
- A frozen-plan replay that measures the value of later forecast updates and replanning while holding previously submitted trades fixed.
- A perfect-PV full-information schedule, and an optional PV-only schedule that removes the battery while preserving the market and farm assumptions. These are operating counterfactuals on the same realized prices and PV data; terminal inventory is reported separately because no terminal energy salvage value is included.
- Continuous daily planning across consecutive delivery days. Each strategy carries actual SOC, degradation history, submitted commitments, transaction-fee volume and cash ledger through local midnight. The daily MILP remains one delivery day at a time; it is not a month-long joint optimization.

The January 2025 participation study uses independent delivery days. The continuous configurations expose inclusive start/end dates and initial SOC; January 2025 starts with DA submission on 31 December, supplied initial SOC 90%, and configured final planned SOC 50%. The January 2026 comparison configs also allow a 40% planned terminal floor. Those are study assumptions, not measured initial conditions or a guarantee on realized terminal energy. The perfect-PV continuous reference solves once at DA (or the first available auction) by default, then retains the plan; a shared flag can request reoptimization at later gates.

Every solve and interval records forecast vintage, position ledger, planned and executed battery flows, SOC, imbalance, throughput/wear, fees and timing. Outputs are grouped by run and file type under `outputs/`. Daily profits are reconciled from submitted trades, actual settlement, executed degradation and fees. The objective values of overlapping auction solves are never summed to represent profit.

# 14 Price Forecasting Status

The active GME and continuous historical experiments use realized auction clearing curves as an oracle input. They do not use predicted prices or model price uncertainty. The former retrospective regression, fundamentals, Gaussian calibration, and prepared stochastic-price input implementations are archived outside the repository in `/home/rghetti/price_prediction_archive`; they are not part of the active optimization pipeline and should not be interpreted as a validated forecasting method. The current work needed is to define price forecasts and uncertainty scenarios from

information demonstrably available by each auction gate, then integrate those causal distributions into the market decisions.

## 15 Optional optimized-imbalance formulation

This section describes supported code that is disabled by the shared default. When `optimize_imbalances=true`, replace (20) by

$$\delta^+_{s,t} - \delta^-_{s,t} = g_{s,t}\Delta_t - Q_{s,t}, \tag{70}$$

$$0 \le \delta^+_{s,t} \le M_t y_{s,t}, \tag{71}$$

$$0 \le \delta^-_{s,t} \le M_t(1 - y_{s,t}), \qquad y_{s,t} \in \{0,1\}. \tag{72}$$

Here $M_t = (P^{\text{imp}}+P^{\text{exp}})\Delta_t$, optionally reduced by a configured imbalance-energy cap. The common $M_t$ is valid because physical and contractual net energy use the same directional POI range. The sign binary prevents simultaneous positive/negative deviations, including with negative prices. Add to each scenario's objective

$$\sum_t \left[\lambda^+_{s,t}\delta^+_{s,t} - \lambda^-_{s,t}\delta^-_{s,t} - \kappa(\delta^+_{s,t} + \delta^-_{s,t})\right]. \tag{73}$$

If this mode has zero settlement price, zero penalty and no useful delivery restriction, an optimized contract need not be backed by delivered energy. That is why the present experiment disables optimized deviations and computes physical mismatches only afterwards. The optional formulation is a mathematical study mode, not an assertion that deliberate imbalance strategies are permitted.

## 16 Data provenance, outputs and reproducibility

Farm inputs are local read-only Zarr/Parquet stores. API and workbook records use `data/api/market.duckdb`. Raw/normalized snapshots, source identities, checksums, revision and retrieval metadata support repeated offline studies. Historical publication remains a separate field/convention. Provider acquisition is an explicit user-run command; neither the MILP builder nor the historical experiment downloads missing inputs. DuckDB writers and analysis processes must be coordinated; complete cached days can be studied before an entire acquisition window is complete.

YAML controls study date, calendar validity, source mappings, PV and data policies, BESS and POI characteristics, state, degradation, solver and outputs. One include is resolved relative to the containing YAML, with recursive mapping overrides. Every shipped entry point imports `configs/standard.yaml` directly; experiment YAMLs contain only their overrides. The standard exposes shared feature flags to existing experiments. Explicit null values and replacement lists survive the merge. The `resolve-config` command prints the effective YAML without running a study or accessing provider data.

A single root `farm_id`, optionally overridden with `-farm-id`, selects forecast and physical plant identifiers through typed references resolved after merging. Each farm uses its own weather and measured-power series and Parquet metadata for PV geometry and tracking. Automatic directional POI ratings use declared AC nameplate capacity divided by 1000 as an illustrative MW proxy; per-farm ratings or explicit plant limits override that rule. Battery size and SOC percentages remain common, while automatic battery dimensions resolve from `farms.<id>.battery` for the selected physical plant. Numeric experiment overrides take precedence over these automatic dimensions. The reusable `configs/full_experiments/gme_day.yaml` exposes this workflow.

The current 50% study is configured by `configs/full_experiments/gme_oracle_2025-01-01_farm910_perfect_pv_comparison_terminal_soc_50.yaml`. Its inherited assumptions include a

5 MWh battery, 2.5 MW symmetric power, a 7–93% SOC box, directional combined efficiencies of $\sqrt{0.90} = 0.9486832981$ and a 6.638 MW directional POI. Their product gives 90% AC-to-AC round-trip efficiency for all farms. These are reproducible study settings, not confirmed anonymous-farm hardware.

The shared per-farm hypothetical BESS dimensions are:

| Farm | PV AC nameplate (MW) | Battery (MWh) | Symmetric power (MW) |
|---|---|---|---|
| 1 | 0.95328 | 0.75 | 0.5 |
| 345 | 1.5246 | 1.0 | 0.5 |
| 901 | 4.1600 | 2.0 | 1.0 |
| 910 | 6.6380 | 5.0 | 2.5 |

The shared 7–93% SOC limits are converted to energy after selecting capacity; replacement cost scales with that capacity. Throughput economics remain the configured historical USD 115/kWh proxy, 1.0389 USD/EUR conversion and 2,500 reference cycles at 80% depth. They have not been updated to a 2026 equipment quote. With the current efficiencies the derived AC-throughput wear cost is 27.635145 EUR/MWh; no dynamic capacity fade is simulated.

Fresh experiment runs default to `experiment_outputs.overwrite_existing:true`: repeating the same ID replaces artifacts within that run's scope under its configured output root. `resume: true` takes precedence and preserves checkpoints, requiring matching configuration and input fingerprints. Continuous output replacement holds the run lock and retains its inode; unrelated run IDs are preserved.

Each historical run is grouped under `outputs/full_experiments/gme_oracle/<run>/farm_<id>/<day>/` with `plots/`, `csv/`, `json/`, and optional `models/`. The effective configuration, input provenance and artifact manifest accompany auction plans, immutable ledger, actual dispatch, used PV vintages, settlement and objective comparisons. The main KPI distinctions are:

- `total_gain_eur`: actual feedback profit after available settlement;
- `perfect_information_objective_eur`: achieved full-information PV+BESS objective;
- `pv_only_perfect_information_objective_eur`: achieved optional PV-only objective;
- `battery_incremental_operating_value_eur`: the difference in (58);
- initial expectation, realized-minus-expected revenue/profit, and separate executed versus counterfactual degradation components.

Figures preserve interval widths and both available boundary points, including next-day local midnight. Held hourly/quarter-hour prices and powers do not create new samples; SOC uses the actual boundary states. Snapshot settlement diagnostics include their different delivery windows and common-horizon comparisons.

Solver settings use relative MIP gap $10^{-4}$ (0.01%) by default, with no absolute MIP gap configured. Configurable `feasibility_tolerance` and `integrality_tolerance` map to Gurobi's numerical feasibility and integer tolerances. The historical YAML sets both to $10^{-8}$ to avoid tiny binary-mode leakage while preserving the independent validator's physical checks. Objective comparisons use achieved `ObjVal`. Status, relative gap, model sizes and timing remain recorded. Before a schedule is used, independent validation recomputes physical balances, limits, native product consistency, information sharing, degradation and objective components. Execution separately checks actual SOC and power/POI protection. Software consistency does not resolve uncertain farm metadata, forecast bias or historical publication vintages.

## 17 Current limitations and extension boundaries

The current empirical workflows use daily perfect-price planning with one weather member, either as independent days or consecutive continuous operation, with approximate geometry and an idealized interval-average controller. Measured AC is effective observed production, not an independently estimated unconstrained irradiance-to-generation potential; hidden plant curtailment/faults in source production are not identified automatically. Configured cleaning and fallback choices remain part of the experiment.

The model currently omits continuous trading, order acceptance, market impact, multiple-farm network coupling, ancillary services, intrainterval dynamics, ramping/startup constraints, dynamic capacity loss, calendar aging, thermal battery dynamics, fixed operating costs and investment cash-flow optimization. The generic `backtest` CLI remains synthetic-only; the separate historical `experiment-gme-oracle`, `experiment-participation` and `experiment-continuous` workflows are the implemented manual-data replays. Future uncertain-price evaluations need their own causal inputs and comparison protocol rather than relabeling the current oracle results.

The original implementation-status report is retired. This source and its PDF are the maintained mathematical description; run manifests and saved solver results are the numerical evidence for particular configurations. Practical commands and configuration examples are in the root `README.md`.

## References


[1] B. Xu, J. Zhao, T. Zheng, E. Litvinov and D. S. Kirschen, *Factoring the Cycle Aging Cost of Batteries Participating in Electricity Markets*. Author preprint and published paper links retained by the repository: https://arxiv.org/abs/1707.04567 and https://doi.org/10.1109/TPWRS.2017.2733339.

[2] pvlib Python documentation. The installed library implements the solar-position, single-axis tracking, isotropic transposition, Faiman and PVWatts functions called by `forecasting/pv.py`. https://pvlib-python.readthedocs.io/.

[3] Gestore dei Mercati Energetici, Technical Rule 03 rev. 13 MPE, valid from 29 September 2025, and rev. 14 MPE, valid from 13 January 2026. The project uses their gate/result timing with explicit local study settings; DA publication at 13:30 is identified as an assumption, while recorded times are preferred. GME's 29 September 2025 notice describes 15-minute MGP products from delivery date 1 October 2025. https://www.mercatoelettrico.org/Portals/0/Documents/en-US/20250930DTF03rev13MPE_En.pdf https://gme.mercatoelettrico.org/Portals/0/Documents/en-US/20260113DTF03rev14MPE_en.pdf https://www.mercatoelettrico.org/en-us/Home/NoticesandAnnouncements/NoticesandAnnouncementsME?id=7101

[4] Repository source files listed in Section 1 and the effective configuration saved with each run are authoritative for implemented behavior. Conceptual references do not replace inspection of those inputs and policies.