

July 31, 2026

Stephen Sze
Archspace - WY Design & Construction Ltd.
2602-7088 18th Avenue
Burnaby, BC V3N 0A2

RE: 1772 Renfrew Street, Vancouver, BC V5M 3H8
Development permit application number DP-2026-00087

On behalf of the Director of Planning, your application has been approved to change the use of existing Retail to a Child Day Care Facility for a maximum of 26 children in this existing building, including the Letter of Operation submitted by Brightlings Early Learning Centre.

Hours of operation: Monday to Friday 7:30am to 5:30pm.

A permit may be issued upon the completion of the revisions and conditions noted below under items 1.0 to 2.2 of this "prior-to permit issuance" letter.

HOW TO RESPOND TO THIS LETTER

1. Write and sign a response letter.

- Explain how you addressed each condition.
- Only changes made pursuant to addressing Prior To conditions are accepted as part of your response. Ensure all changes are clearly identified.
- *Provide a complete response to avoid delays or extra fees.*

2. Ensure relevant documents have digital signatures and seals from registered professionals.

- Review requirements at vancouver.ca/permits-eplan.

3. Upload your response letter and documents.

- Log into your permit account at vancouver.ca/permit-apply.

APPLY FOR BUILDING PERMIT(S)

Apply using the Development and Building Services Centre form at vancouver.ca/contact-dbl

Questions? Contact your Project Coordinator helen.yoon@vancouver.ca

- 1.0 Prior to the issuance of the Development Permit, revised digital drawings shall be submitted, to the satisfaction of the Director of Planning, clearly indicating:

Development Review Branch conditions:

- 1.1 compliance with **Section 6.2.2.6 – Table of Number of Required Off-Street Bicycle Spaces** of the Parking By-Law Section 6;

Note to Applicant: Provide the required five (5) Class B bicycle spaces in accordance with the minimum requirements of Section 6.2.2.6. Ensure all Class B bicycle spaces meet the dimensional and design standards of Section 6.4 of the Parking By-law.

- 1.2 compliance with **Section 7.2.2.3- Table of Number of Required Off-Street Passenger Spaces** of the Parking By-Law Section 7;

Note to Applicant: Provide the required four (4) Class A Passenger Spaces, or three (3) Passenger Spaces together with eight (8) spaces of strollers or bicycle trailer spaces in accordance with Section 7.2.2.3.

Engineering Services conditions:

- 1.3 compliance of parking, loading, bicycle, and passenger loading space quantities must be provided and maintained in accordance with the requirements of the [Parking By-Law](#);

- 1.4 general revisions to the architectural plans:

- i. all types of parking, bicycle and passenger loading spaces individually numbered, dimensioned, and labelled on the drawings;
- ii. design elevations at all four corners of the parking area and entrances;
- iii. remove all bollards from parking spaces;

- 2.0 **Condition(s) to be met prior to the issuance of the Development Permit:**

Development Review Branch conditions:

- 2.1 Written confirmation that Building Review Branch comments under 4.4 have been acknowledged and understood, is required to be submitted as part of the “prior-to” response.
- 2.2 Written confirmation that the notification sign on the site has/have been removed.

- 3.0 **Development Permit Terms:**

- 3.1 All approved off-street vehicle parking, loading, and unloading spaces, and bicycle parking spaces shall be provided in accordance with the relevant requirements of the Parking By-law **prior to the issuance of any required occupancy permit**, or any use or occupancy of the proposed development not

requiring an occupancy permit, and thereafter permanently maintained in good condition.

- 3.2 All landscaping and treatment of the open portions of the site shall be completed in accordance with the approved drawings **prior to the issuance of any required occupancy permit**, or any use or occupancy of the proposed development not requiring an occupancy permit, and thereafter permanently maintained in good condition.

Note to Applicant: In cases where it is not practical, due to adverse weather conditions or other mitigating factors, to complete the landscaping prior to occupancy of a building, the City will accept an Irrevocable Letter of Credit (amount to be determined by the City) as a guarantee for completion of the work by an agreed upon date.

- 3.3 In accordance with Protection of Trees By-law Number 9958, the removal and replacement of trees is permitted only as indicated on the approved Development Permit drawings.
- 3.4 This Development Permit is valid for a period of 12 months from the date of issuance - unless otherwise validated by a Building Permit.
- 3.5 Childcare to be licensed by Vancouver Coastal Health's Community Care Facilities Licensing (CCFL).
- 3.6 The issuance of this permit does not warrant compliance with the relevant provisions of the Provincial Health & Community Care and Assisted Living Acts. The owner is responsible for obtaining any approvals required under the Health Acts. For more information on required approvals and how to obtain these, please contact Vancouver Coastal Health at 604-675-3800 or visit their offices located on the 12th floor of 601 W Broadway. Should compliance with the Health Acts necessitate changes to this permit and/or approved plans the owner is responsible for obtaining approval for the changes prior to commencement of any work under this permit. Additional fees may be required to change the plans.
- 3.7 Detailed drawings of the interior childcare facility and outdoor play space to be submitted for review by the Community Care Facilities Licensing Division for compliance with the Community Care and Assisted Living Act and Child Care Licensing Regulations.
- 3.8 Hours of operation are limited to: Monday to Friday 7:30am to 5:30pm
- 3.9 This permit has been issued for a time limited period and will expire on the date noted unless extended in writing by the Director of Planning. It is the applicant's responsibility to request an extension prior to the expiry date.
- 3.10 Development must meet requirements of the Community Care and Assisted Living Act, Child Care Licensing Regulations and the Adult Care Regulations prior to approval at Building Permit stage.

3.11 Final capacity will be determined at the Child Care Final Inspection.

4.0 Notes to Applicant:

4.1 It should be noted that your Development Permit will be issued when you have complied with all the above conditions. However, if these conditions have not been complied with **on, or before October 16, 2026**, this Development Application may stand refused.


4.2 A new Development Application will be required for any significant changes. This approval is subject to any change in the Zoning and Development By-law or other regulations affecting the development that occurs before the permit is issuable. No permit that contravenes the by-law or regulations can be issued.

4.3 If this application necessitates the demolition of existing residential rental, per Section 10.14.2 and except as set out in section 10.14.3, where development necessitates the demolition of existing residential rental accommodation, no development permit shall be issued for the demolition unless and until a development permit for the new development has been issued.

Note to Applicant: The requirements listed above may be varied subject to the provisions outlined under Section 10.14.4.

4.4 The following comments have been made by the Building Review Branch. The following information should be included at building permit application stage:

- i. As of September 15, 2025, all submissions are to be in accordance with the VBBL 2025.
- ii. Alteration shall not increase the non-conformity of the existing building or create non-conformity with respect to VBBL 2025. All new work shall conform to VBBL 2025.
- iii. ***This project requires the services of a registered architect. Architectural Schedule B and sealed drawings should be submitted.**
- iv. ***The existing 1 storey building is consider a minor renovation and change of major occupancy. The building is required to be upgraded to design levels F4, S4, N4, A4 and E4, as per VBBL 2025 11.5.2.1 Flow Chart No. 1 and No. 2.**
- v. ***Building is to be sprinklered, provide smoke detection and CO alarm and emergency lighting as per VBBL 2025 Table 3.1.2.8**
- vi. Clarify definition of S.A at building permit stage.

a. 

- vii. Provide exit travel distance at building permit stage.

- viii. Provide occupant load and washroom load calculation at building permit stage.
- ix. Indicate accessible path of travel from indoor area to outdoor playground.
- x. Windows and door schedule to be reviewed at building permit stage.
- xi. Building assemblies to be reviewed at building permit stage.
- xii. Suite is to be reference and design in compliance to VBBL 2025 3.8.3 or CSA B561:
 - a. Universal washroom
 - b. Door and doorway
- xiii. All new architectural, mechanical and electrical components are required to comply with the energy and emissions requirements of the Vancouver Building By-law #12511. Please add to your drawings the Energy Statements per the "Energy Statements on Drawings" requirements found within the City of Vancouver energy webpage <http://vancouver.ca/building-energy-requirements>.

*Items marked with an asterisk have been identified as serious non-conforming Building By-law issues.

Written confirmation that the applicant has read and has understood the implications of the above noted comments is required and shall be submitted as part of the "prior to" response.

- 4.5 If this Development Application included a written notification of neighbouring property owners or other interested parties, a copy of this letter will be sent to all respondents advising them of the decision.
- 4.6 The Canadian Electrical Code regulates high voltage overhead conductor clearances from structures and dielectric liquid-filled transformer clearances from combustible building surfaces, doors, windows, and ventilation openings. All structures must have a horizontal distance of at least 3 m from existing BC Hydro high voltage overhead conductors. Combustible building surfaces, windows, doors, and ventilation openings must be located at least 6 m from dielectric liquid-filled, pole-mounted BC Hydro transformers, unless an acceptable non-combustible barrier is constructed between these transformers and combustible building surfaces, doors, windows, or ventilation openings.

Yours truly,



Helen Yoon
Helen.yoon@vancouver.ca
HY/cg