

June 23, 2026

Kevin Yang
110 & 112 East Cordova Street Ltd.
460 Fraserview Place
Delta, BC V3M 6H4

RE: 110 E Cordova Street, Vancouver, BC V6A 1K9
Development permit application number DP-2026-00303

On behalf of the Director of Planning, your application has been approved to perform interior and exterior alterations and to change the use from Office to Hotel on the 1st to 3rd floors of this existing heritage commercial building.

A permit may be issued upon the completion of the revisions and conditions noted below under items 1.0 to 2.3 of this “prior-to permit issuance” letter.

HOW TO RESPOND TO THIS LETTER

1. Write and sign a response letter.

- Explain how you addressed each condition.
- Only changes made pursuant to addressing Prior To conditions are accepted as part of your response. Ensure all changes are clearly identified.
- *Provide a complete response to avoid delays or extra fees.*

2. Ensure relevant documents have digital signatures and seals from registered professionals.

- Review requirements at vancouver.ca/permits-eplan.

3. Upload your response letter and documents.

- Log into your permit account at vancouver.ca/permit-apply.

APPLY FOR BUILDING PERMIT(S)

Apply using the Development and Building Services Centre form at vancouver.ca/contact-dbl.

Questions? Contact your Project Coordinator Stephani.Li@vancouver.ca

1.0 Prior to the issuance of the Development Permit, revised digital drawings shall be submitted, to the satisfaction of the Director of Planning, clearly indicating:

Development Review Branch conditions:

- 1.1 compliance with Section 6 – *Off-street Bicycle Spaces Regulations, of the Parking By-law*, by providing minimum 1 Class A bicycle space;

Heritage conditions:

- 1.2 design development to install a contemporary recessed main entrance door assembly, to reflect or complement the historic character of the heritage building;

Note to Applicant: Refer to Engineering Services condition 1.7.

Landscape Review conditions:

- 1.3 provision of an Arborist Report, Tree Management Plan and Letter of Assurance;

Note to Applicant: Two City trees require an Arborist assessment and tree protection.

- 1.4 provision of updated Architectural/Site Plan with City tree protection method and notations;

Note to Applicant: Tree protection per City of Vancouver standards for trees in hardscape areas, with City staff sign-off. Example methodology: Wrap the tree trunk with the 1/4" foam to 8' in height and 2" x 2" wood sections spaced around the trunk; entire protection to be wrapped in orange safety fencing, secured with long zip-ties.

Engineering Services conditions:

- 1.5 provision of the following details as they relate to the waste collection, loading, and staging:

- i. a solid waste storage amenity located at grade (ground level) and adjacent to the area where collection vehicles are allowed access to the amenity;
- ii. a waste staging area on the architectural drawings;

Note to Applicant: If staging area is required, please indicate staging location on the architectural plan. All staging activities shall occur on private property, not City property.

- 1.6 provision of garbage / recycling containers on the relevant floor plan drawings, in accordance with the Garbage and Recycling Facility Storage Amenity Design Supplement: [Guidelines: Garbage and Recycling Storage Facility Design](#);

- 1.7 removal or relocation of all door swings that currently encroach onto City property;

Note to Applicant: All new emergency exit door swings extending onto City property shall not exceed 0.3 m (1 ft.).

2.0 Condition(s) to be met prior to the issuance of the Development Permit:

Development Review Branch conditions:

- 2.1 Written confirmation is to be submitted that the notification sign on the site has/have been removed.

Heritage conditions:

- 2.2 Provision of digital copies of the approved Statement of Significance and Conservation Plan for the Metropole Livery (110 East Cordova Street) by Luxton.

Note to applicant: Final versions of the documents are to incorporate feedback from Heritage staff, with revisions made to the satisfaction of Director of Planning. The scope of work contained within the Conservation Plan is to be cross-referenced consistently within the development permit documentation.

Engineering Services conditions:

- 2.3 Provision of a waste management plan that includes the following:
- i. A description for how the garbage and recycling bins are to be transported to the designated staging area, including who is responsible for transporting the bins.
 - ii. A description of the following:
 - a. Types of waste streams to be provided: Garbage, Organics, Mixed Papers, Mixed Containers and Glass;
 - b. quantity, stream and capacity of container for each waste stream; and,
 - c. collection frequency of each waste stream.

3.0 Development Permit Terms:

- 3.1 Applicant to contact PBDevelopment.Trees@vancouver.ca and agree at the BP stage to provide a staging plan and identify any required tree pruning.
- 3.2 All conservation work must be consistent with the approved Conservation Plan which forms a part of the development permit. A qualified heritage professional must supervise the implementation of conservation work with the Professional of Record. Once the conservation work is substantially complete, the qualified heritage professional must prepare and submit a *Completion Status Report* upon completion or as condition of the Occupancy Permit.
- 3.3 All impacted utility companies shall be contacted and notified of the following requirements:
- i. All utility services (e.g., BC Hydro, Telus, and Rogers) shall be underground.

- ii. All required electrical equipment (e.g., PMT, LPT, Vista, etc.) provided for entirely within private property.

Note to Applicant: The review of third-party utility service drawings (e.g., BC Hydro, Telus, and Shaw) will not be initiated until all drawings have been received by the Utilities Management Branch (UMB). For questions on this requirement, please contact UMB at umb@vancouver.ca.

- 3.4 A Key Plan shall be submitted by the applicant and approved by the City prior to any third-party utility drawing submissions. It is highly recommended that the applicant submit a Key Plan to the City for review as part of the Building Permit application. Third party utility service drawings will not be reviewed by the City until the Key Plan is defined and achieves the following objectives:

- i. the Key Plan shall follow the specifications in the City of Vancouver Key Plan Process and Requirements Bulletin <https://vancouver.ca/files/cov/Key%20Plan%20Process%20and%20Requirements.pdf>; and
- ii. all third-party service lines to the development are to be shown on the plan (e.g., BC Hydro, Telus, Shaw, etc.) and the applicant is to provide documented acceptance from the third-party utilities prior to submitting to the City.

Note to Applicant: Use of street for temporary power (e.g., temporary pole, pole mounted transformer or ducting) is to be coordinated with the City well in advance of construction. Requests will be reviewed on a case-by-case basis with justification provided substantiating need of street space against other alternatives. If street use for temporary power is not approved, alternate means of providing power will need to be proposed. An electrical permit will be required.

For questions on this requirement, contact the Utilities Management Branch at umb@vancouver.ca.

- 3.5 The owner or representative is advised to contact Engineering to acquire the project's permissible street use. Prepare a mitigation plan to minimize street use during excavation and construction (e.g., consideration to the building design or sourcing adjacent private property to construct from) and be aware that a minimum 60-day lead time is required for any major crane erection / removal or slab pour that requires additional street use beyond the already identified project street use permissions.
- 3.6 All approved off-street vehicle parking, loading, and unloading spaces, and bicycle parking spaces shall be provided in accordance with the relevant requirements of the Parking By-law **prior to the issuance of any required occupancy permit**, or any use or occupancy of the proposed development not requiring an occupancy permit, and thereafter permanently maintained in good condition.
- 3.7 All landscaping and treatment of the open portions of the site shall be completed in accordance with the approved drawings **prior to the issuance of any**

required occupancy permit, or any use or occupancy of the proposed development not requiring an occupancy permit, and thereafter permanently maintained in good condition.

Note to Applicant: In cases where it is not practical, due to adverse weather conditions or other mitigating factors, to complete the landscaping prior to occupancy of a building, the City will accept an Irrevocable Letter of Credit (amount to be determined by the City) as a guarantee for completion of the work by an agreed upon date.

- 3.8 In accordance with Protection of Trees By-law Number 9958, the removal and replacement of trees is permitted only as indicated on the approved Development Permit drawings.
- 3.9 This Development Permit is valid for a period of 12 months from the date of issuance - unless otherwise validated by a Building Permit.

4.0 **Notes to Applicant:**

- 4.1 It should be noted that your Development Permit will be issued when you have complied with all the above conditions. However, if these conditions have not been complied with **on, or before September 23, 2026**, this Development Application may stand refused.
- 4.2 A new Development Application will be required for any significant changes. This approval is subject to any change in the Zoning and Development By-law or other regulations affecting the development that occurs before the permit is issuable. No permit that contravenes the by-law or regulations can be issued.
- 4.3 If this Development Application included a written notification of neighbouring property owners or other interested parties, a copy of this letter will be sent to all respondents advising them of the decision.
- 4.4 The Canadian Electrical Code regulates high voltage overhead conductor clearances from structures and dielectric liquid-filled transformer clearances from combustible building surfaces, doors, windows, and ventilation openings. All structures must have a horizontal distance of at least 3 m from existing BC Hydro high voltage overhead conductors. Combustible building surfaces, windows, doors, and ventilation openings must be located at least 6 m from dielectric liquid-filled, pole-mounted BC Hydro transformers, unless an acceptable non-combustible barrier is constructed between these transformers and combustible building surfaces, doors, windows, or ventilation openings.

Yours truly,



Stephanie Li,
Stephanie.Li@vancouver.ca
(604) 873-7952
SL/cg