

June 22, 2026

Mallen Gowing Berzins Architecture Inc.
MGBA Inc.
#420 - 22 East 5th Avenue
Vancouver, BC
V5T 1G8

RE: 601 Stamp's Landing, Vancouver, BC V5Z 3Z1
Development permit application number DP-2025-00691

On behalf of the Director of Planning, your application has been approved to provide interior and exterior alterations to this existing two-storey Restaurant Class 1 on this site:

A permit may be issued upon the completion of the revisions and conditions noted below under items 1.0 to 2.3 of this "prior-to permit issuance" letter.

HOW TO RESPOND TO THIS LETTER

1. Write and sign a response letter.

- Explain how you addressed each condition.
- Only changes made pursuant to addressing Prior To conditions are accepted as part of your response. Ensure all changes are clearly identified.
- *Provide a complete response to avoid delays or extra fees.*

2. Ensure relevant documents have digital signatures and seals from registered professionals.

- Review requirements at vancouver.ca/permits-eplan.

3. Upload your response letter and documents.

- Log into your permit account at vancouver.ca/permit-apply.

APPLY FOR BUILDING PERMIT(S)

Apply using the Development and Building Services Centre form at vancouver.ca/contact-dbl.

Questions? Contact Samantha Senechal, your Project Coordinator (details at end of letter).

- 1.0 Prior to the issuance of the Development Permit, revised digital drawings shall be submitted, to the satisfaction of the Director of Planning, clearly indicating:

Development Review Branch conditions:

- 1.1 provision of revised site calculations to show computation of additional floor area:

- i. all additions to the building are included in floor area, such as canopy structures, decorative breezeway, covered and enclosed patios, brise-soleil, etc.;

Note to applicant: Additional fees may apply once the additional floor area has been confirmed.

- 1.2 provision of revised Loading and Bicycle Stats to reflect the following:

- i. Loading Class B spaces are not shown on the site plan, update stats to reflect zero spaces proposed; and

Note to applicant: Loading Class B spaces were previously relaxed to zero with the provision that loading will take place in the parking area non-concurrent with operating hours. Refer to Condition 2.3 for requirements.

- ii. remove reference to Class B Bicycle spaces provided.

Note to applicant: The existing Class B Bicycle spaces on City property do not meet the off-street requirements. Director of Planning discretion exercised as existing non-conforming for the Class B Bicycle spaces.

- 2.0 **Condition(s) to be met prior to the issuance of the Development Permit:**

Development Review Branch conditions:

- 2.1 Written confirmation that Building Review Branch comments under 4.4 have been acknowledged and understood, is required to be submitted as part of the "prior-to" response.
- 2.2 Written confirmation that the notification sign has been removed.
- 2.3 Provide an updated letter of operation to confirm that loading will take place in the parking area non-concurrent with operating hours.

- 3.0 **Development Permit Terms:**

- 3.1 All approved off-street vehicle parking, loading, and unloading spaces, and bicycle parking spaces shall be provided in accordance with the relevant requirements of the Parking By-law **prior to the issuance of any required Occupancy Permit**, or any use or occupancy of the proposed development not requiring an Occupancy Permit, and thereafter permanently maintained in good condition.

- 3.2 All landscaping and treatment of the open portions of the site shall be completed in accordance with the approved drawings **prior to the issuance of any required Occupancy Permit**, or any use or occupancy of the proposed development not requiring an Occupancy Permit, and thereafter permanently maintained in good condition.

Note to Applicant: In cases where it is not practical, due to adverse weather conditions or other mitigating factors, to complete the landscaping prior to occupancy of a building, the City will accept an Irrevocable Letter of Credit (amount to be determined by the City) as a guarantee for completion of the work by an agreed upon date.

- 3.3 In accordance with Protection of Trees By-law Number 9958, the removal and replacement of trees is permitted only as indicated on the approved Development Permit drawings.
- 3.4 This Development Permit is valid for a period of 12 months from the date of issuance - unless otherwise validated by a Building Permit.
- 3.5 The outdoor seating area is to be closed and cleared all patrons no later than 10:00 p.m. nightly.
- 3.6 This permit has been issued for a time limited period and will expire one (1) year from the date of issuance unless extended in writing by the Director of Planning. It is the applicant's responsibility to apply for an extension in writing on or before the expiry date or a new Development Permit may be required.
- 3.7 Amplified music or live entertainment are not permitted in and around the patio area at any time.
- 3.8 Operator is responsible for ensuring that patron noise on the patio does not negatively impact neighbours. All applicable requirements of the Noise Control By-law Number 6555 must be adhered to.
- 3.9 Outdoor seating area must comply with applicable provisions of the Health By-law. Smoking in and around the patio area is not permitted.
- 3.10 A Neighbourhood Liaison shall be made available to whom complaints may be directed about any aspects of this operation. The Neighbourhood Liaison is Anoop Parmar, who can be reached at 437-995-6374 or gm@mishreecuisine.com.

4.0 **Notes to Applicant:**

- 4.1 It should be noted that your Development Permit will be issued when you have complied with all the above conditions. However, if these conditions have not been complied with **on, or before December 22, 2026**, this Development Application may stand refused.
- 4.2 A new Development Application will be required for any significant changes. This approval is subject to any change in the Zoning and Development By-law or

other regulations affecting the development that occurs before the permit is issuable. No permit that contravenes the by-law or regulations can be issued.

- 4.3 If this application necessitates the demolition of existing residential rental, per Section 10.14.2 and except as set out in Section 10.14.3, where development necessitates the demolition of existing residential rental accommodation, no Development Permit shall be issued for the demolition unless and until a Development Permit for the new development has been issued.

Note to Applicant: The requirements listed above may be varied subject to the provisions outlined under Section 10.14.4.

- 4.4 The following comments have been made by the Building Review Branch:

- i. The addition of enclosed deck on north side of ground floor will be classified as a Horizontal Addition per Part 11 of VBBL. The enclosed area is required to be sprinklered.
- ii. A separate Building Permit is required after this DP, or a revision to DB-2025-04292 to incorporate this addition on the first floor might be accepted subject to BRB Manager's approval.

- 4.5 If this Development Application included a written notification of neighbouring property owners or other interested parties, a copy of this letter will be sent to all respondents advising them of the decision.

- 4.6 The Canadian Electrical Code regulates high voltage overhead conductor clearances from structures and dielectric liquid-filled transformer clearances from combustible building surfaces, doors, windows, and ventilation openings. All structures must have a horizontal distance of at least 3 m from existing BC Hydro high voltage overhead conductors. Combustible building surfaces, windows, doors, and ventilation openings must be located at least 6 m from dielectric liquid-filled, pole-mounted BC Hydro transformers, unless an acceptable non-combustible barrier is constructed between these transformers and combustible building surfaces, doors, windows, or ventilation openings.

Yours truly,



Samantha Senechal,
samantha.senechal@vancouver.ca
(604) 873-7000

SS/jk