

July 10, 2026

Joe Muego
Hearth Architectural
#1100 - 1200 West 73rd Ave.
Vancouver, BC
V6P 6G5

RE: 3333 Bridgeway, Vancouver, BC V5K 0C7
Development permit application number DP-2026-00130

On behalf of the Director of Planning, your application has been approved to provide interior and exterior alterations and a change of use from existing Wholesale Class A to a 122 capacity Child Day Care Facility (ages 6 months to 5 years) on the 6th floor of this existing building.

A permit may be issued upon the completion of the revisions and conditions noted below under items 1.0 to 2.3 of this “prior-to permit issuance” letter.

HOW TO RESPOND TO THIS LETTER

1. Write and sign a response letter.

- Explain how you addressed each condition.
- Only changes made pursuant to addressing Prior To conditions are accepted as part of your response. Ensure all changes are clearly identified.
- *Provide a complete response to avoid delays or extra fees.*

2. Ensure relevant documents have digital signatures and seals from registered professionals.

- Review requirements at vancouver.ca/permits-eplan.

3. Upload your response letter and documents.

- Log into your permit account at vancouver.ca/permit-apply.

APPLY FOR BUILDING PERMIT(S)

Apply using the Development and Building Services Centre form at vancouver.ca/contact-dbl.

Questions? Contact your Samantha Senechal, your project coordinator (details at end of letter).

- 1.0 Prior to the issuance of the Development Permit, revised digital drawings shall be submitted, to the satisfaction of the Director of Planning, clearly indicating:

Development Review Branch conditions:

- 1.1 compliance with Section 6 Required Off-Street Bicycle Spaces and the Design Supplements of the Parking By-law:
- i. a minimum of twenty (20) Class B off-street bicycle spaces:
 - a. a minimum 0.6 m (2 ft.) width, 1.8 m (6 ft.) length, and 1.9 m (6.2 ft.) vertical clearance for horizontal Class B spaces;
 - ii. a minimum of one (1) Class A off-street bicycle space;

Note to Applicant: Required bicycle spaces are calculated based on each individually approved use on site and should be calculated and labeled accordingly.

- 1.2 compliance with Section 7 Class A Passenger Spaces of the Parking By-law – See Engineering Services Conditions 1.6:
- i. a minimum of fifteen (15) Class A Passenger spaces;

Note to Applicant: Passenger spaces must comply with the minimum size requirements as per the Parking By-law Section 7 and the Design Supplement. Label and dimension the allocated Passenger Spaces on the site plan and update Parking statistics to reflect the changes. Refer to Engineering condition 1.6.

- 1.3 compliance with Section 4 (4.1.4) Required Accessible Parking Spaces:
- i. a minimum of 5 spaces is required and the first accessible parking space provided must be a van-accessible parking space;

Note to Applicant: Parking plan is not representative of parking changes approved under the previously issued Development Permit DP-2025-00197.

- 1.4 provision of revisions and additional information on drawings as follows:
- i. improved technical data table (project statistics) to incorporate the entire site and all approved and proposed uses within the building. Include a breakdown of required, existing and proposed project statistics for each use and subsequent requirements (parking, loading, bicycle, passenger)

Note to Applicant: Support/other spaces throughout' is not an approved use. Relabel this to reflect ancillary office to storage use and wholesale use.

- 1.5 demonstrate compliance with Section 3 Density and Floor area of the I-2 District Schedule:
- i. provide statistical breakdown of Floor Space Ratio for all approved and proposed uses;

Engineering Services conditions:

- 1.6 passenger space(s), per [Parking By-law Section 7](#) and the [Design Supplement](#), including:
 - i. minimum 4.0 m (13.1 ft) width and 5.5 m (18 ft) length for the first Class A space; and
 - ii. minimum 2.9 m (9.5 ft) width and 5.5 m (18 ft) length after the first Class A space.

2.0 Condition(s) to be met prior to the issuance of the Development Permit:

Development Review Branch conditions:

- 2.1 Written confirmation that Building Review Branch comments under 4.4 have been acknowledged and understood, is required to be submitted as part of the “prior-to” response.
- 2.2 Written confirmation that the notification sign on the site has been removed.
- 2.3 Provide updated letter of operation to capture any revisions and applicable relaxation rationale.

3.0 Development Permit Terms:

- 3.1 All approved off-street parking, loading, bicycle, and passenger loading spaces shall be provided in accordance with the relevant requirements of the Parking By-law prior to the issuance of any required Occupancy Permit, or any use or occupancy of the proposed development not requiring an Occupancy Permit, and thereafter permanently maintained in good condition.
- 3.2 All landscaping and treatment of the open portions of the site shall be completed in accordance with the approved drawings **prior to the issuance of any required Occupancy Permit**, or any use or occupancy of the proposed development not requiring an Occupancy Permit, and thereafter permanently maintained in good condition.

Note to Applicant: In cases where it is not practical, due to adverse weather conditions or other mitigating factors, to complete the landscaping prior to occupancy of a building, the City will accept an Irrevocable Letter of Credit (amount to be determined by the City) as a guarantee for completion of the work by an agreed upon date.

- 3.3 In accordance with Protection of Trees By-law Number 9958, the removal and replacement of trees is permitted only as indicated on the approved Development Permit drawings.
- 3.4 This Development Permit is valid for a period of 12 months from the date of issuance - unless otherwise validated by a Building Permit.

- 3.5 This permit has been issued for a time limited period and will expire on the date noted unless extended in writing by the Director of Planning. It is the applicant's responsibility to request an extension prior to the expiry date.
- 3.6 Development must meet requirements of the Community Care and Assisted Living Act, Child Care Licensing Regulations and the Adult Care Regulations prior to approval at Building Permit stage.
- 3.7 Childcare to be licensed by Vancouver Coastal Health's Community Care.
- 3.8 Final capacity will be determined at the Child Care Final Inspection.

4.0 **Notes to Applicant:**

- 4.1 It should be noted that your Development Permit will be issued when you have complied with all the above conditions. However, if these conditions have not been complied with **on, or before January 10, 2027**, this Development Application may stand refused.
- 4.2 A new Development Application will be required for any significant changes. This approval is subject to any change in the Zoning and Development By-law or other regulations affecting the development that occurs before the permit is issuable. No permit that contravenes the by-law or regulations can be issued.
- 4.3 If this application necessitates the demolition of existing residential rental, per Section 10.14.2 and except as set out in Section 10.14.3, where development necessitates the demolition of existing residential rental accommodation, no Development Permit shall be issued for the demolition unless and until a Development Permit for the new development has been issued.

Note to Applicant: The requirements listed above may be varied subject to the provisions outlined under Section 10.14.4.

- 4.4 The following comments have been made by the Building Review Branch:

This is a preliminary courtesy review to identify issues that do not comply with the Vancouver Building By-law #14343 as amended (VBBL) and includes a review of Subsection 3.2.5. "Provisions for Fire Fighting".

The following information should be included at Building Permit Application Stage:

- i. All new work must comply with the current VBBL, and the rest of the upgrade to the existing is required in Part 11, VBBL 2025.
- ii. In Part 11, this is a Minor Renovation, and a Change of Major Occupancy (Cumulative 5-year limit). *Please check to make sure the 5-year limit is not exceeded; otherwise, it will be a Full Upgrade.
- iii. 3.2.2. must comply with the number of storeys, occupancies, and sprinklers. (non-comb construction)
- iv. ***Means of egress must meet Article 3.3.1.3.**

- v. ***Travel distance shall comply with Article 3.4.2.5.**
- vi. ***The public corridor must comply with Article 3.3.1.4 and Sentence 3.3.1.3 (12).**
- vii. ***Dead-end corridors must comply with Article 3.3.1.9.**
- viii. A designated egress path is required for exit stair #2. The playground can present a tripping hazard in an emergency evacuation.
- ix. Additional fire bell or strobe lights may be required at the play area and patio.

*** Items marked with an asterisk have been identified as serious non-conforming Building Bylaw issues.**

Further reviews are required at the Building Permit application stage.

The applicant may wish to retain the services of a qualified Building Code consultant in case of difficulty in comprehending the comments and their potential impact on the proposal. Failure to address these issues may jeopardize the ability to obtain a Building Permit or delay the issuance of a Building Permit for the proposed.

- 4.5 If this Development Application included a written notification of neighbouring property owners or other interested parties, a copy of this letter will be sent to all respondents advising them of the decision.
- 4.6 The Canadian Electrical Code regulates high voltage overhead conductor clearances from structures and dielectric liquid-filled transformer clearances from combustible building surfaces, doors, windows, and ventilation openings. All structures must have a horizontal distance of at least 3 m from existing BC Hydro high voltage overhead conductors. Combustible building surfaces, windows, doors, and ventilation openings must be located at least 6 m from dielectric liquid-filled, pole-mounted BC Hydro transformers, unless an acceptable non-combustible barrier is constructed between these transformers and combustible building surfaces, doors, windows, or ventilation openings.

Yours truly,



Samantha Senechal,
samantha.senechal@vancouver.ca
(604) 873-7000

SS/jk