

April 13, 2026

Firouzeh Sourì  
Cornerstone Architecture  
611 Alexander Street  
Unit 307  
Vancouver, BC V6A 1E1

**RE 4666 MAIN STREET, Vancouver, BC**  
**Development permit application number DP-2025-00984**

On behalf of the Director of Planning, your application has been approved to develop a new five-storey mixed-use building, consisting of 12 rental dwelling units, and one commercial rental unit (CRU) at grade with one level of underground parking, having vehicular access from the lane.

A permit may be issued upon the completion of the revisions and conditions noted below under items 1.0 to 2.4 of this “prior-to permit issuance” letter.

**HOW TO RESPOND TO THIS LETTER**

**1. Write and sign a response letter.**

- Explain how you addressed each condition.
- Only changes made pursuant to addressing Prior To conditions are accepted as part of your response. Ensure all changes are clearly identified.
- *Provide a complete response to avoid delays or extra fees.*

**2. Ensure relevant documents have digital signatures and seals from registered professionals.**

- Review requirements at [vancouver.ca/permits-eplan](https://vancouver.ca/permits-eplan).

**3. Upload your response letter and documents.**

- Log into your permit account at [vancouver.ca/permit-apply](https://vancouver.ca/permit-apply).

**APPLY FOR BUILDING PERMIT(S)**

**Apply using the Development and Building Services Centre form at**  
[vancouver.ca/contact-dbl](https://vancouver.ca/contact-dbl).

**Questions?** Contact your Project Coordinator [stephanie.li@vancouver.ca](mailto:stephanie.li@vancouver.ca)

- 1.0 Prior to the issuance of the Development Permit, revised digital drawings shall be submitted, to the satisfaction of the Director of Planning, clearly indicating:

**Development Review Branch conditions:**

- 1.1 compliance with Section 3.1.(d) Family Unit Mix requirement of the C-2 District Schedule;

**Note to Applicant:** Minimum 35% of the total dwelling units to have 2 or more bedrooms.

- 1.2 provision of a complete FSR overlay sheet;

**Landscape Review conditions:**

- 1.3 design development to enhance privacy and better align with the C-2 Landscape Design Guidelines;

- i. provide a continuous planter at the outer edge of the second level approximately 1.5 M wide and deep enough for soil volumes needed for planting trees. Refer to Guideline C-2, Section 7 b ii;
- ii. consideration to provide climbing vines to grow up the exposed south and east facing walls and support with cable system. Refer to Guideline C-2, Section 7 b;

- 1.4 design development to enhance the performance of the outdoor rooftop amenity;

**Note to Applicant:** Explore providing additional elements to support urban agriculture additional raised planters with shade trees, and extensive green-roof. Refer to Guideline C-2, Section 7.

- 1.5 provision of updated Architectural and Landscape plans;

- i. provide a complete Plant List that includes all trees and plants;
- ii. include arborist construction notes and indicate areas requiring arborist supervision, to be outlined in the Arborist Report, LOA and Tree Management Plan (TMP);
- iii. provide soil depths that meet or exceed the minimums as set out in the CSLA latest version. Labels to match actual depths in plan and section drawings;

- 1.6 provision of an updated Tree Management Plan (TMP);

**Note to Applicant:** Overlay the TMP onto the most current Architectural Site Plan. Exiting canopy of trees to be drawn to scale. Park Board Urban Forestry tree retention for City trees to be clearly described in a note.

**Urban Forestry conditions:**

- 1.7 provision of an updated Tree Management Plan and architectural drawing:

**Note to Applicant:** Include the following instructions for tree protection in hardscape boulevard on the tree management plan and architectural drawing:

- i. Wrap the tree trunk with the ¼" foam to 8' in height.
- ii. Then erect 2X2" x 8's wood sections (or height of main stem if less than 8') spaced around the trunk wrapped in orange safety fencing secured with long zip-ties.
- iii. Send [PBDevelopment.trees@vancouver.ca](mailto:PBDevelopment.trees@vancouver.ca) pictures to confirm alternative tree protection have been installed correctly.

- 1.8 provision of updated arborist documents:

**Note to Applicant:**

- i. As per Engineering condition for street improvements including but not limited to the proposed broom finish saw-cut concrete sidewalk, ensure the Project Arborist is conducting on-site supervision during the removal and replacement of the concrete panels. Contact [PBDevelopment.trees@vancouver.ca](mailto:PBDevelopment.trees@vancouver.ca) if roots 5 cm or larger are conflicting with the upgrade.
- ii. Any front boulevard upgrades that may impact the boulevard trees require project arborist supervision.

**Engineering Services conditions:**

- 1.9 street improvements, and appropriate transitions, along Main St. adjacent to the site, including:

- i. minimum 3.0 m wide broom finish saw-cut concrete sidewalk;
- ii. 1.2 m wide front boulevard with a street tree;

- 1.10 provision of new or replacement duct bank that meets current City standards;

**Note to Applicant:** Duct banks are to consist of electrical and communication ducts and cables and connect to existing electrical and communication infrastructure.

- 1.11 provision of City issued Building Grades to be shown on A1.1 the site plan & A2.1 Ground Level:

- i. Building Grade elevations are incorrect; refer to Building Grade Plan BG-2024-00078 for correct elevations (see markup for location/details);

- 1.12 provision of Design Elevations to be shown on A1.1 the site plan & A2.1 Ground Level:

- i. Design Elevations are missing from the plan at middle of entrances along the lane (see markup for location/details);
  - ii. one Design Elevation is incorrect along Main Street. Design Elevations must be directly interpolated between adjacent building grades (see markup for location/details);
- 1.13 provision of City issued Building Grades survey benchmark Monument V-1799 to be used on A1.1 the site plan & A2.1 Ground Level, or, provide written confirmation specifying the benchmark denoted on any topographic survey used for design purposes is consistent with the benchmark elevation established on the Building Grade plan issued by the City.

**Note to Applicant:** Please see building grade letter and attached markup for more details.

- 1.14 landscape and site plans to reflect required off-site improvements, including:
- i. dimensions for the front boulevard and sidewalk;
  - ii. show and note required 2.5 m Statutory Right of Way from P/L to building face;
- 1.15 updated Parking By-law statistics table(s) noting the following:
- i. *“Parking, loading, bicycle, and passenger loading shall be provided and designed in compliance with the Parking By-law and the Parking and Loading Design Supplement.”;*
  - ii. *“End of Trip Facilities layout shall be in compliance with the Vancouver Parking By-law and the Vancouver Building By-law.”;*
- 1.16 vehicle space(s), per Parking By-law Section 4 and the Design Supplement, including:
- i. minimum 2.6 m (8.5 ft.) width for small spaces adjacent one wall or if column located more than 1.2 m (4 ft.) from either end of the stall;
  - ii. provision minimum 1 ft. column setback for small car space 4;
- Note to Applicant:** Move stall 4 in line with neighbouring standard space 3 to achieve this.
- iii. minimum 2.0 m (6.6 ft.) vertical clearance for all standard and small spaces;
  - iv. minimum 2.3 m (7.5 ft.) of vertical clearance for access and maneuvering to all accessible spaces;
- 1.17 bicycle space(s), per [Parking By-law Section 6](#), including:

- i. minimum 1.5 m (5 ft.) wide access route(s) in front of oversized Class A spaces;
- ii. stair-free access route to bicycle spaces / removal of stair runnel wheel ramp(s);
- iii. provision of retail Class A bicycle spaces separate from the residential Class A bicycle room;

1.18 general revisions to the architectural plans:

- i. dimension of columns and column encroachments into parking spaces;
- ii. section drawings showing elevations and minimum vertical clearances for parking levels, loading bays, ramps, and to the underside of raised security gates considering mechanical projections and built obstructions;
- iii. design elevations at all breakpoints on both sides of ramps, drive aisles, loading and passenger loading spaces, accessible spaces, and entrances;

2.0 **Condition(s) to be met prior to the issuance of the Development Permit:**

**Development Review Branch conditions:**

- 2.1 Written confirmation is to be submitted that the notification sign on the site has/have been removed.
- 2.2 Submission of a letter clarifying if there have been any changes proposed since previous submission which was not caused by addressing the remaining conditions.

**Note to Applicant:** Provide details clarifying the proposed changes.

**Engineering Services conditions:**

- 2.3 Entry into (a) legal agreement(s) to the satisfaction of the General Manager of Engineering Services and the Director of Legal Services for statutory right of way (SRW) for public pedestrian use adjacent to Main St, to achieve a 2.5 m offset distance from the property line. The SRW will be free of any encumbrance such as walls, stairs, and vents at-grade and the agreement will accommodate the underground parking structure.

**Note to Applicant:** The preparation of this legal agreement includes statutory rights-of-way and the requirement for [collection of a fee for service](#) and will be due prior to issuance of the Development Permit.

**Housing Regulation conditions:**

- 2.4 Make arrangements to the satisfaction of the General Manager of Planning, Urban Design and Sustainability and the Director of Legal Services to enter into a

Housing Agreement and a Section 219 Covenant securing 12 residential units, as secured market rental housing, excluding Seniors Supportive or Independent Living Housing, for a term equal to the longer of 60 years and the life of the building, subject to the following additional conditions:

- i. A no separate-sales covenant.
- ii. A no stratification covenant.
- iii. That none of the units are to be rented for less than 90 consecutive days at a time.
- iv. Such other terms and conditions as the General Manager of Planning, Urban Design and Sustainability and the Director of Legal Services may in their sole discretion require.

**Note to Applicant:** This condition will be secured by a Housing Agreement to be entered into by the City By-law enacted pursuant to section 565.2 of the Vancouver Charter.

### 3.0 Development Permit Terms:

- 3.1 All approved off-street vehicle parking, loading, and unloading spaces, and bicycle parking spaces shall be provided in accordance with the relevant requirements of the Parking By-law **prior to the issuance of any required occupancy permit**, or any use or occupancy of the proposed development not requiring an occupancy permit, and thereafter permanently maintained in good condition.
- 3.2 Parking, loading, bicycle, and passenger loading space quantities must be provided and maintained in accordance with the requirements of the Parking By-Law.
- 3.3 Construction dewatering is a Water Use Purpose under the Water Sustainability Act requiring a provincial Approval or License.

**Note to Applicant:** Applications for provincial Approvals or Licenses can be completed online. The application will be received and accepted into the province's online system, and the provincial authorizations team strives for 140 days to get the approval to the applicant. The approval holder must be able to produce their approval on site so that it may be shown to a government official upon request. Dewatering before this approval is granted is not in compliance with the provincial Water Sustainability Act.

- 3.4 A Key Plan shall be submitted by the applicant and approved by the City prior to any third-party utility drawing submissions. It is highly recommended that the applicant submit a Key Plan to the City for review as part of the Building Permit application. Third party utility service drawings will not be reviewed by the City until the Key Plan is defined and achieves the following objectives:

- i. the Key Plan shall follow the specifications in the City of Vancouver Key Plan Process and Requirements Bulletin <https://vancouver.ca/files/cov/Key%20Plan%20Process%20and%20Requirements.pdf>; and
- ii. all third-party service lines to the development are to be shown on the plan (e.g., BC Hydro, Telus, Shaw, etc.) and the applicant is to provide documented acceptance from the third-party utilities prior to submitting to the City.

**Note to Applicant:** Use of street for temporary power (e.g., temporary pole, pole mounted transformer or ducting) is to be coordinated with the city well in advanced of construction. Requests will be reviewed on a case-by-case basis with justification provided substantiating need of street space against other alternatives. If street use for temporary power is not approved, alternate means of providing power will need to be proposed. An electrical permit will be required.

For questions on this requirement, contact the Utilities Management Branch at [umb@vancouver.ca](mailto:umb@vancouver.ca).

- 3.5 All impacted utility companies shall be contacted and notified of the following requirements:
- i. all utility services (e.g., BC Hydro, Telus, and Rogers) shall be underground.
  - ii. all required electrical equipment (e.g., BC Hydro, Telus, and Rogers) shall be underground.

**Note to Applicant:** The review of third-party utility service drawings (e.g. BC Hydro, Telus, and Shaw) will not be initiated until all drawings have been received by the Utilities Management Branch (UMB). For questions on this requirement, please contact UMB at [umb@vancouver.ca](mailto:umb@vancouver.ca).

- 3.6 Provision of construction details to determine ability to meet municipal design standards for shotcrete removal (street restoration manual section 02596 and Encroachment By-law (#4243 section 3A) and access around existing and future utilities adjacent to your site.

**Note to Applicant:** Detailed confirmations of these commitments will be sought at the building permit stage with final design achievements certified and confirmed with survey and photographic evidence of removals and protection of adjacent utilities prior to building occupancy.

- 3.7 The owner or representative is advised to contact Engineering to acquire the project's permissible street use. Prepare a mitigation plan to minimize street use during excavation and construction (e.g., consideration to the building design or sourcing adjacent private property to construct from) and be aware that a minimum 60-day lead time is required for any major crane erection / removal or slab pour that requires additional street use beyond the already identified project street use permissions.

- 3.8 Please note that as the City of Vancouver prepares for the FIFA World Cup 26™, street use for public and private construction during and around the event period will be limited so additional consideration should be given to planning for and requesting street use where required. To help you plan, Vancouver's match dates for 2026 are:

- Saturday, June 13
- Thursday, June 18
- Sunday, June 21
- Wednesday, June 24
- Friday, June 26
- Thursday, July 2
- Tuesday, July 7

For questions, please contact the City at [streetusereview@vancouver.ca](mailto:streetusereview@vancouver.ca). To learn more about FIFA World Cup 26 Vancouver™ and stay updated, visit [www.vancouverfwc26.ca](http://www.vancouverfwc26.ca).

- 3.9 All landscaping and treatment of the open portions of the site shall be completed in accordance with the approved drawings **prior to the issuance of any required occupancy permit**, or any use or occupancy of the proposed development not requiring an occupancy permit, and thereafter permanently maintained in good condition.

**Note to Applicant:** In cases where it is not practical, due to adverse weather conditions or other mitigating factors, to complete the landscaping prior to occupancy of a building, the City will accept an Irrevocable Letter of Credit (amount to be determined by the City) as a guarantee for completion of the work by an agreed upon date.

- 3.10 In accordance with Protection of Trees By-law Number 9958, the removal and replacement of trees is permitted only as indicated on the approved Development Permit drawings.
- 3.11 This Development Permit is valid for a period of 12 months from the date of issuance - unless otherwise validated by a Building Permit.

#### 4.0 **Notes to Applicant:**

- 4.1 Provide the Class B DCL waiver request form confirming the DCL waiver prior to issuance of a building permit.
- 4.2 Provide a final Class B DCL waiver request form with rent roll prior to issuance of an Occupancy Permit.
- 4.3 The proposed unit mix, including 4 studio units (33%), 4 one-bedroom units (33%), 4 two-bedroom units (33%) is to be revised to achieve at least 35% dwelling units with two or more bedrooms.

**Note to Applicant:** Any changes in the unit mix from the development permit application may be varied under the discretion of the Director of Planning or

Development Permit Board provided that it does not go lower than 35% of the dwelling units with two or more bedrooms

- 4.4 It should be noted that your Development Permit will be issued when you have complied with all the above conditions. However, if these conditions have not been complied with **on, or before July 13, 2026**, this Development Application may stand refused.
- 4.5 A new Development Application will be required for any significant changes. This approval is subject to any change in the Zoning and Development By-law or other regulations affecting the development that occurs before the permit is issuable. No permit that contravenes the by-law or regulations can be issued.
- 4.6 If this Development Application included a written notification of neighbouring property owners or other interested parties, a copy of this letter will be sent to all respondents advising them of the decision.
- 4.7 The Canadian Electrical Code regulates high voltage overhead conductor clearances from structures and dielectric liquid-filled transformer clearances from combustible building surfaces, doors, windows, and ventilation openings. All structures must have a horizontal distance of at least 3 m from existing BC Hydro high voltage overhead conductors. Combustible building surfaces, windows, doors, and ventilation openings must be located at least 6 m from dielectric liquid-filled, pole-mounted BC Hydro transformers, unless an acceptable non-combustible barrier is constructed between these transformers and combustible building surfaces, doors, windows, or ventilation openings.

Yours truly,



Stephanie Li,  
Stephanie.Li@vancouver.ca  
(604) 873-7952  
SL/cg