

June 18, 2026

Dilpreet Parmar
65 East 61st Avenue
Vancouver, BC
V5X 2B3

RE: 2421 E 41st Avenue, Vancouver, BC V5R 2W2
Development permit application number DP-2025-01047

On behalf of the Director of Planning, your application has been approved to develop a Duplex with two Secondary Suites in the front building, along with a Duplex in the rear, providing zero parking spaces.

A permit may be issued upon the completion of the revisions and conditions noted below under items 1.0 to 2.1 of this “prior-to permit issuance” letter.

HOW TO RESPOND TO THIS LETTER

1. Write and sign a response letter.

- Explain how you addressed each condition.
- Only changes made pursuant to addressing Prior To conditions are accepted as part of your response. Ensure all changes are clearly identified.
- *Provide a complete response to avoid delays or extra fees.*

2. Ensure relevant documents have digital signatures and seals from registered professionals.

- Review requirements at vancouver.ca/permits-eplan.

3. Upload your response letter and documents.

- Log into your permit account at vancouver.ca/permit-apply.

APPLY FOR BUILDING PERMIT(S)

Apply using the Development and Building Services Centre form at vancouver.ca/contact-dbl.

Questions? Contact your kiana.alizadeh@vancouver.ca (details at end of letter).

- 1.0 Prior to the issuance of the Development Permit, revised digital drawings shall be submitted, to the satisfaction of the Director of Planning, clearly indicating:

Urban Design conditions:

- 1.1 design development to improve the overall site functionality and the provision of enhanced usable outdoor space for family-oriented units;

Note to Applicant: Refer to Section 2.2.2(b) – Use Specific Regulations, and 3.1.1.4 – Density and Floor Area, of the RT-11 District Schedule and respond to the intent of the RT-11 By-law. This may be achieved by:

- i. replacing at least one of the outdoor spaces at the lane interface to accommodate on-site parking;
- ii. reducing the rear building massing and revising unit layout; and
- iii. providing 2 shared open spaces within the courtyard in accordance with Section 6.2 - Semi-private or shared open space, of the RT-11 Guidelines with enhanced landscaping and appropriate screening for all usable open areas. Refer to Landscape Review condition 1.8.

- 1.2 design development to encourage pedestrian activity and transition between public and private space adjacent to the lane while proposing outdoor space suitable for children to accommodate families where parking is not proposed;

Note to Applicant: Refer to Section 5.3.4(f)– Doors and Entrances and Section 6.1 – Private Open Space of the RT-11 Guidelines. Remove asphalt apron where parking is not proposed; and propose landscaping between rear building and rear property line. The landscape should be visually interesting as the lane will become a focus of development, and in effect, an exposure that is as important as the streetscape. Refer to Landscape Review condition 1.8.

- 1.3 design development to improve livability at secondary suites located in the basement at the front building;

Note to Applicant: This can be achieved by:

- i. revising the internal layout of the secondary suite by reducing the bedroom width from 11 ft. 5 in. to approximately 9 ft., and shifting the laundry and cooking appliances southward to optimize and expand the usable living area;
- ii. enhancing the size of side-facing kitchen and living room windows for better access to natural light and ventilation, particularly for the living space; and
- iii. reducing the depth of the rear deck and reorienting the stair configuration to provide a compliant and functional landing at the base, while also

improving solar access and daylight penetration to the secondary suite via the north-facing windows beneath the deck.

- 1.4 design development to improve wayfinding for each unit including the secondary suites;

Note to Applicant: Refer to Sec 5.3.4(c) and (e) – Doors and Entrances, of the RT-11 Guideline. The presence and location of unit entries should be announced through architectural or landscape gateway elements or by providing contrasting colours at the entry doors where entries to units are not clearly visible from the street. Refer to Landscape Review condition 1.8.

- 1.5 consideration to improve the expression of both buildings side elevation composition;

Note to Applicant: Refer to Section 5.6 – Exterior Walls and Finishing, of the RT-11 Guideline. This can be achieved by breaking down the two-storey massing as seen from the side while avoiding large blank walls while carrying materials around the corners and terminate at a logical point to avoid appearing as a thin veneer or ‘false front’.

Development Review Branch conditions:

- 1.6 compliance with Section 3.1.2.3(ii) of the RT-11 District schedule;

Note to Applicant: Maximum permitted height for the rear building is 25.26 ft (7.7 m). Calculation shows the 2.2 ft overage on the rear building height.

- 1.7 provision of updated Architectural drawing:

- i. locate all Heat pumps/pads within the maximum permitted projection area (4 ft [1.22 m] from the building) and provide the Landscape screening in accordance with the Landscape Condition 1.8;

Refer to the Heat pump Bulletin:

<https://guidelines.vancouver.ca/bulletins/bulletin-heat-pumps-for-ground-oriented-dwellings.pdf>

- ii. correct site coverage proposed on statistic chart as it shows two different number for site coverage;
- iii. correct the rear building label on north elevation on page 9;
- iv. ensure the Site plan, Floor plan and Elevations are match. Ex: the number of stairs and the landing dimensions at the rear of the front building is not match with site plan;

Landscape Review conditions:

- 1.8 design development to improve the overall landscape design strategy and site biodiversity by enhancing landscape elements, providing diverse planting, and integrating bird-friendly features;

Note to Applicant: Refer to s. 7 – Landscaping - RT-11 Guidelines, Bird-Friendly Design Guidelines, Urban Design condition(s) 1.1, 1.2 and 1.4, and DRB condition(s) 1.7.

This can be achieved by:

- i. A well-designed landscape that enhances private open space, outdoor space, and the lane and street interfaces with diverse coniferous and deciduous trees, and seasonal variation of understory planting with shrubs, larger perennials, and groundcovers.
- ii. Front yard and City boulevard landscaped as a green visual amenity for the street while limiting the use of sod. Layered landscape screening from streetscape to private patios and landscape elements such as arbours or trellis to assist unit wayfinding and fences combined with soft landscaping are also supported.
- iii. Rear yard landscape design that provides adequate layered planting, larger caliper trees and landscape elements balanced with hardscaped areas and circulation.
- iv. Lanescape with continuous and varied planting and vertical greening on landscape elements to support privacy.
- v. Locating Heat Pump/Pads (HPPs) within maximum building setbacks and providing landscape screening.

<https://guidelines.vancouver.ca/guidelines-rt-11.pdf>

<https://guidelines.vancouver.ca/B021.pdf>

<https://bylaws.vancouver.ca/tree/schedd.pdf>

- 1.9 provision of information and details that demonstrate safe retention and protection of off-site neighbour trees #OS1 through #OS6, as follows:

Note to Applicant: Proposed hardscape demolition and site development conflicts with tree protection and critical root zones for off-site neighbour trees. Clearly defined and illustrated site-specific mitigation such as, alternative construction methods, modified foundation, shoring, tunnelling versus trenching of site services, relocation of site services, low impact permeable paving, arboricultural care throughout site excavation and construction, and interim or phased tree protection are supported. Provide updated LOA, Tree Management, Architectural/Site and Landscape Plans as required.

- i. confirmation on plan that the existing concrete retaining wall and fence along the west property line within tree protection zones (TPZ) will be retained;
- ii. confirmation of tunnelling or trenching locations for utility connections, avoiding conflict with neighbour trees Critical Root Zones (CRZs), coordinated with utility providers;
- iii. as per the Arborist's trigger points and supervision, the use of L-shaped footings for the rear building west foundation is recommended to minimize excavation requirements into CRZs of neighbour's Trees #OS4 and #OS5;

L-shaped footings details and notations should be provided and indicated on the Architectural/Site or structural drawing to confirm.

1.10 provision of updated Landscape, Architectural, and Site Plans, Arborist Report, Arborist Letter of Assurance, and Tree Management Plans including:

- i. scaled longitudinal and cross sections with grades between front and rear buildings and front buildings to front and side property lines;
- ii. scaled details of building-to-grade and sub-grade relationships within retained neighbour trees critical root zones and building foundation, including modified building foundation method within #OS4, #OS5, #OS6, as recommended by project Arborist;
- iii. arborist trigger point comments for west access path and garbage enclosure coordinated with Architectural/Site and Landscape plan notations and locations;
- iv. additional notations coordinated with Architectural/Site, Landscape and TMP plans as follows:
 - a) existing fence and retaining wall to be retained, adjacent to west property line
 - b) no grade changes allowed within tree protection zones
 - c) new planting within tree protection zones to be no greater than #1 container size and amended or new soil depth is three inches or less
 - d) phased tree protection barriers, as applicable
- v. tree protection barriers to be squared to the full dimensions;
- vi. confirmation of site services connections, locations and installation methods;
- vii. confirmation of landscape irrigation methods and locations;

Note to Applicant: Hose bibs and automatic irrigation methods in all landscape areas, outside of tree protection zones are supported.

- viii. a detailed plant list with deciduous and coniferous trees and diverse seasonal variation of shrubs, perennials and groundcovers;
- ix. Letter of Assurance for arborist supervision signed and dated by three parties: arborist, owner and contractor;

Urban Forestry Review conditions:

- 1.11 provision of updated architectural drawing.

Note to Applicant:

- i. provide sewer service location on site plan; and
- ii. provide the water service location on site plan.

2.0 Condition(s) to be met prior to the issuance of the Development Permit:

Development Review Branch conditions:

- 2.1 Written confirmation that site sign removed.

3.0 Development Permit Terms:

- 3.1 Provision of a Construction Management Plan directly to Translink (MRN@translink.ca) with a copy of the correspondence provided to the City of Vancouver a minimum 8 weeks prior to the start of any construction activity.

Note to Applicant: The City of Vancouver and Translink have authority over construction works carried out on a City Street that is designated as part of the Major Road Network (MRN). This development site has been identified as being adjacent the MRN, as defined under the South Coast British Columbia Transportation Authority Act (<https://www.translink.ca/plans-and-projects/projects/roads-bridges-and-goods-movement> [[translink.ca](https://www.translink.ca)]) on one or more frontages. Potential impacts to the road network due to site specific construction activity must be reviewed and approved for all sites proposing street use outside of currently regulated zone limitations.

- 3.2 All approved off-street vehicle parking, loading, and unloading spaces, and bicycle parking spaces shall be provided in accordance with the relevant requirements of the Parking By-law **prior to the issuance of any required Occupancy Permit**, or any use or occupancy of the proposed development not requiring an Occupancy Permit, and thereafter permanently maintained in good condition.
- 3.3 All landscaping and treatment of the open portions of the site shall be completed in accordance with the approved drawings **prior to the issuance of any required Occupancy Permit**, or any use or occupancy of the proposed

development not requiring an Occupancy Permit, and thereafter permanently maintained in good condition.

Note to Applicant: In cases where it is not practical, due to adverse weather conditions or other mitigating factors, to complete the landscaping prior to occupancy of a building, the City will accept an Irrevocable Letter of Credit (amount to be determined by the City) as a guarantee for completion of the work by an agreed upon date.

- 3.4 In accordance with Protection of Trees By-law Number 9958, the removal and replacement of trees is permitted only as indicated on the approved Development Permit drawings.
- 3.5 This Development Permit is valid for a period of 12 months from the date of issuance - unless otherwise validated by a Building Permit.

4.0 **Notes to Applicant:**

- 4.1 It should be noted that your Development Permit will be issued when you have complied with all the above conditions. However, if these conditions have not been complied with **on, or before August 15, 2026**, this Development Application may stand refused.
- 4.2 A new Development Application will be required for any significant changes. This approval is subject to any change in the Zoning and Development By-law or other regulations affecting the development that occurs before the permit is issuable. No permit that contravenes the by-law or regulations can be issued.
- 4.3 If this application necessitates the demolition of existing residential rental, per Section 10.14.2 and except as set out in Section 10.14.3, where development necessitates the demolition of existing residential rental accommodation, no Development Permit shall be issued for the demolition unless and until a Development Permit for the new development has been issued.

Note to Applicant: The requirements listed above may be varied subject to the provisions outlined under Section 10.14.4.

- 4.4 If this Development Application included a written notification of neighbouring property owners or other interested parties, a copy of this letter will be sent to all respondents advising them of the decision.
- 4.5 The Canadian Electrical Code regulates high voltage overhead conductor clearances from structures and dielectric liquid-filled transformer clearances from combustible building surfaces, doors, windows, and ventilation openings. All structures must have a horizontal distance of at least 3 m from existing BC Hydro high voltage overhead conductors. Combustible building surfaces, windows, doors, and ventilation openings must be located at least 6 m from dielectric liquid-filled, pole-mounted BC Hydro transformers, unless an acceptable non-combustible barrier is constructed between these transformers and combustible building surfaces, doors, windows, or ventilation openings.

Yours truly,

A handwritten signature consisting of the letters "K.A." inside a hand-drawn oval. A short horizontal line extends from the bottom of the oval.

Kiana Alizadeh
Kiana.Alizadeh@vancouver.ca
604-673-8266

KA/jk