Full Report

"I WOULD LIKE TO KNOW ABOUT THE IMPLEMENTATION , AND EVERYTHING RELATED TO OF Secure Digital-Twin-Based Coordination of Industrial Waste Heat and Water Vapor Recovery with Dynamic AI Data-Center Cooling Demand" *Generated by LeapSpace*

Secure Digital-Twin Coordination of Industrial Waste Heat, Water Vapor Recovery, and AI Data-Center Cooling Demand: Quick Insights

Key Findings Table

Topic	Key finding	Practical implication	Citations
Overall feasibility	The building blocks exist, but the retrieved literature does **not** show a mature 2020-2025 full-scale closed-loop deployment combining secure digital twin control, industrial waste-heat recovery, condensate/water reuse, and dynamic AI/data-center cooling coordination in one system [1] [2] [3] [4].	Implementation should be treated as a systems-integration project, not a copyable off-the-shelf reference design [1] [4].	[1] [2] [3] [4]
Digital twin architecture	Industrial DTs converge on bidirectional sensing, continuous synchronization, and interoperable stacks using RAMI 4.0, AAS, ISO 23247, OPC UA, MQTT, and edge/fog/cloud deployment [5] [6] [7] [8] [9] [10].	A layered OT/IT architecture is the most evidence-backed implementation pattern [7] [10].	[5] [6] [7] [8] [9] [10]
Runtime fidelity	Literature emphasizes architecture and interoperability more than live calibration, drift correction, and uncertainty tracking during operation [11] [12] [13] [14].	Online state estimation and recalibration should be designed explicitly rather than assumed [11] [15] [16].	[11] [12] [13] [14] [15] [16]

Topic	Key finding	Practical implication	Citations
Waste-heat recovery	Heat pumps can upgrade low-grade waste heat to useful temperatures for process heat, district heating, and hot water, with reported outputs from 85-150 °C and COPs often above 3 in suitable cases [17] [18] [19] [20] [21].	Heat-pump upgrading is the core thermal bridge between industrial waste heat and cooling-linked reuse [18] [21].	[17] [18] [19] [20] [21]
Water recovery	Strong subsystem results exist for vapor/condensate recovery, including 81% water recovery and 93% heat recovery in a combined vacuum evaporator + MVR blowdown system, and 90.0% water purification in double-effect MVR desalination [22] [23].	Recovered water is technically viable, but water-quality governance remains underreported relative to energy metrics [22] [24].	[22] [23] [24]
Cooling-demand intelligence	Data-center cooling control is moving toward workload-aware forecasting, inlet-temperature prediction, and joint IT-plus-cooling optimization rather than static HVAC control [25] [26] [27] [28].	A useful coordination signal should include IT load, thermal risk, and ambient conditions, not just total cooling demand [25] [27].	[25] [26] [27] [28]
Forecasting methods	Attention-enhanced sequence models, hybrid physics-ML methods, and horizon-specific models often outperform single generic predictors for thermal/load forecasting [29] [30] [31].	Forecasting should be multi-horizon and retrained, not built as one static model [32] [33].	[29] [30] [31] [32] [33]
Control strategy	MPC, NMPC, EMPC, MILP, and hierarchical control generally outperform rule-based or PI/PID baselines under fluctuating heat sources and dynamic cooling demand, but computation and model validity are key trade-offs [34] [35] [36] [37] [38].	Use hierarchical control: fast local loops plus slower supervisory optimization [39] [40] [41].	[34] [35] [36] [37] [38] [39] [40] [41]

Topic	Key finding	Practical implication	Citations
Security	Secure DT implementations rely on OPC UA, certificate-based mutual authentication, encrypted telemetry, and DT-enabled anomaly detection; IDS studies report strong detection metrics, but system-level resilience under real-time optimization is less quantified [42] [43] [44] [45].	Security should be designed as part of control architecture, not added after optimization [45] [46].	[42] [44] [45] [46]
Demonstrated gains	In related subsystems, double-layer optimization reduced PUE by about 0.88%, energy by 9.37-11.16%, and operating cost by 16.26-18.26% versus rule-based control [37].	Multi-objective supervisory optimization is likely worth implementing if integration cost can be controlled [37].	[37]

Direct Answer

A **credible implementation** of secure digital-twin-based coordination for industrial waste heat, water vapor recovery, and dynamic AI data-center cooling demand would use:

1. **A layered digital twin stack** with interoperable OT/IT integration using OPC UA, MQTT, AAS, and ISO 23247/RAMI 4.0-style models [7] [8] [9] [47].
2. **A sensing layer** covering temperature, flow, pressure, humidity, levels, power/IT load, and actuator states, with continuous synchronization between plant and twin [1] [5] [48] [49].
3. **Hybrid state estimation** with online parameter identification, Kalman/data-assimilation or Bayesian updating, and explicit drift/uncertainty management [11] [15] [16] [50].
4. **Thermal and water-recovery hardware** centered on heat pumps for low-grade heat upgrading and MVR/condensation or related condensate-reuse systems for water recovery [18] [22] [23] [51] [52].
5. **Cooling-demand forecasting** driven by workload, IT load, thermal state, and ambient conditions, preferably with horizon-specific or attention-based models [25] [29] [30] [31].
6. **Hierarchical supervisory control** using MILP/MPC or related methods to match recovered heat and water to variable cooling demand while local edge loops enforce safe plant operation [34] [37] [40] [53].
7. **Security by design**, including certificate-authenticated encrypted OPC UA sessions, role/attribute-aware access control, and DT-enabled anomaly detection/attack localization [42] [43] [44] [45] [54].

The most important bottom line is that this is **technically plausible but not yet well evidenced as an integrated real-world full system** in the supplied literature [1] [2] [3] [4]. Taken together, the evidence suggests the near-term implementation path is to integrate already-validated subsystems rather than expect a fully proven reference architecture for the exact use case [7] [22] [25] [37].

Confidence level: High - Strong evidence exists for all subsystem building blocks and for the integration gap itself [7] [22] [25] [37] [45].

Study Scope

- **Timeframe covered:** mainly 2018-2025, with emphasis on 2020-2025 implementation-oriented studies and reviews [7] [21] [30] [37] [45].
- **Disciplines involved:** industrial digital twins, heat pumps and waste-heat recovery, vapor/condensate recovery, data-center thermal forecasting/control, cybersecurity for OT/IT systems, and supervisory optimization [18] [25] [37] [43] [55].
- **Methods covered:** reviews, simulations, optimization studies, subsystem demos, SCADA/twin case studies, and intrusion-detection benchmarks [1] [22] [28] [45] [56].

Assumptions & Limitations

- The supplied evidence supports **subsystem feasibility** more strongly than **end-to-end deployment evidence** for the exact combined application [1] [2] [3] [4].
- Runtime fidelity management, sensor-drift handling, uncertainty propagation, and secure degraded-operation behavior are comparatively underreported [11] [14] [46].
- AI-specific data-center evidence is partly inferred from broader data-center cooling studies rather than from many explicit “AI data-center” deployments [25] [57] [58].

Suggested Further Research

- Demonstrate a **full closed-loop pilot** integrating heat pumps, condensate reuse, storage, secure DT control, and data-center cooling demand response [1] [4].
- Quantify **latency, failover, and safe degraded control** under cyber incidents in optimization-driven OT/IT systems [45] [46].
- Develop shared semantic/data models that connect **heat assets, water-recovery assets, and cooling systems** in one twin [59] [60].
- Improve online **calibration, uncertainty tracking, and drift management** in live DT operations [11] [15].
- Study water-quality assurance and governance for **recovered condensate reuse** alongside energy metrics [24] [55].

1. Foundational Context

A secure digital-twin-based coordination system for this use case is a **cyber-physical supervisory platform** that links three variable domains:

- **industrial heat supply**, where low-grade waste heat fluctuates with process conditions [34] [36];
- **water-vapor/condensate recovery**, where recovery depends on humidity, vapor content, process configuration, and temperature levels [22] [61] [62];
- **data-center cooling demand**, which varies with IT workload, thermal inertia, and ambient conditions [25] [27] [63].

The digital twin is useful because isolated optimization tools do not provide the same combination of **continuous synchronization, state visibility, predictive control support, and cyber-physical coordination** that DT frameworks are designed to provide [5] [64] [65]. In industrial settings, DTs are typically framed as synchronized virtual counterparts used for monitoring, prediction, optimization, and control [64] [66] [67].

For this specific application, the coordination objective is not just energy efficiency. It is to dynamically match:

- recoverable industrial heat,
- recoverable water/condensate,
- cooling and thermal loads in a data center,
- and operational/security constraints across OT and IT layers [22] [27] [37] [43].

Confidence level: High - The DT role, cyber-physical synchronization pattern, and cross-domain control logic are directly supported across the provided literature [5] [25] [37] [64].

2. System Overview and Integration Concept

2.1 End-to-end coordination target

The most evidence-backed interpretation of the requested system is a **hierarchical coupled energy-water-cooling network**. Industrial processes provide low-grade waste heat and moisture-bearing streams; heat pumps and condensation/MVR systems upgrade and recover these resources; the data center consumes cooling and may also accept thermally coordinated heat-rejection or heat-reuse flows; the digital twin estimates system state and dispatches assets accordingly [18] [22] [27] [37].

Taken together, these findings suggest the best coordination variable is not a single cooling-load number, but a joint operational state vector including IT load, inlet-temperature risk, ambient temperature, recoverable heat availability, and recoverable moisture/water availability [25] [27] [62].

2.2 Why a secure digital twin is needed

A secure DT is justified because the coupled system needs:

- **real-time telemetry ingestion** from heterogeneous industrial and data-center assets [1] [5];
- **bidirectional actuation/control** over pumps, valves, compressors, heat pumps, and cooling setpoints [37] [47];
- **state estimation for unmeasured states and drift** [11] [15];
- **cyber-resilience** for the command and telemetry paths [42] [43] [45].

The literature also shows security is no longer separable from DT operation: DTs are used directly for anomaly detection, attack localization, and explainable IDS functions [54] [68] [69].

2.3 Operational goals and metrics

The recurring performance objectives across the evidence base are:

- **COP** for heat-pump or heat-recovery effectiveness [17] [20];
- **PUE** and cooling-system energy use in data-center operation [28] [37];
- **water recovery rate** and **heat recovery rate** for water/condensate systems [22] [23];
- **exergy/efficiency metrics** for thermal recovery configuration quality [70] [71];
- **operating cost** under tariffs and dispatch constraints [37] [72];
- **latency and attack detection performance** for the secure DT platform [45] [46].

Confidence level: High - These metrics recur consistently across thermal, water, cooling, and security studies [22] [28] [37] [45].

3. Digital Twin Architecture, Data Models, and State Estimation

3.1 Architecture and interoperability

The dominant implementation pattern is a **layered, interoperable OT/IT stack**. Evidence points to RAMI 4.0, AAS, ISO 23247, OPC UA, MQTT, and cloud-edge-fog deployment as the main architectural elements [7] [8] [9] [10] [73]. A cloud-based DT PaaS even combined TCP, Modbus, MQTT, and OPC UA in a single data-collection layer for bidirectional control [47].

This implies a practical reference design with:

- **field/PLC/SCADA layer**,
- **edge integration and safety-control layer**,
- **fog or plant-twin state estimation layer**,

- **cloud optimization and model-training layer** [53] [74] [75].

3.2 Sensing and synchronization

The available demonstrations indicate twins commonly ingest **temperature, flow, pressure, level, and actuator-state data** [1] [48] [49]. For the requested application, humidity and water-quality sensing would be additionally necessary by direct inference from vapor recovery requirements and water reuse needs, though the exact integrated stack is not reported in one retrieved paper [22] [24].

Continuous synchronization between physical assets and the virtual model is treated as a core DT property across foundational literature [5] [64] [76]. However, exact synchronization latency for the full target application is not documented in the supplied evidence [1].

3.3 Calibration and uncertainty handling

This is one of the weakest areas in the evidence base. The literature supports online parameter identification, incremental learning, Kalman filtering, data assimilation, and recursive Bayesian updating as the main tools for real-time alignment between model and plant [11] [15] [16] [77]. Reviews explicitly call for repeated synchronization, state reconciliation, uncertainty tracking, and model-drift management [50] [78] [79].

But multiple DT architecture papers emphasize model generation, semantics, and compliance more than runtime fidelity loops [12] [13] [14]. So implementation should budget for a custom model-management layer rather than assuming standards already solve this problem [11] [14].

Confidence level: Medium-High - Architecture patterns are strong; live fidelity-management evidence is noticeably thinner [7] [11] [14].

4. Waste Heat Recovery, Water Vapor Condensation, and Reuse Pathways

4.1 Heat-pump-based waste-heat upgrading

Heat pumps are the clearest thermal integration technology in the dataset. Reported cases include upgrading waste heat to **95 °C hot water** in industrial wastewater reuse, **85 °C** district-heating injection, and up to **100-150 °C** heat-sink outlet conditions depending on source temperature and staging [18] [51] [80]. Reviews note outputs up to **160 °C** for industrial heat pumps and temperature lifts up to **95 K** [21]. Data-center-linked heat-recovery studies report COP values in the **3.87-5.27** range and even **98.4% waste-heat recovery** in one district-heating context [20] [81].

4.2 Water-vapor condensation and condensate reuse

Water recovery evidence is strongest for subsystem-level installations. The most compelling case in the retrieved evidence is the **vacuum evaporator + MVR** blowdown-recovery system with **81% water recovery** and **93% heat recovery** [22]. A **double-effect MVR sewage desalination** system achieved **90.0% water purification**, **86.7% overall resource utilization**, and an **energy efficiency ratio of 15.5** [23]. For humid exhaust systems, water-vapor recovery can reach **92–98%** when exhaust is sufficiently cooled, with near-100% theoretically possible under favorable conditions [61].

Recovered condensate can be suitable for industrial reuse in some thermal evaporation schemes, but the provided literature gives limited detail on long-term water-quality governance [24].

4.3 Control under fluctuating heat/moisture conditions

Variable source conditions matter. Predictive control methods repeatedly outperform simpler controls in waste-heat recovery and ORC/heat-pump-adjacent systems under transient heat-source conditions [34] [35] [82]. NMPC and EMPC are reported as especially effective for superheat control, transient tracking, and safe operation, but computational cost and local model validity remain important barriers [36] [83] [84].

Confidence level: High - Strong support exists for heat-pump and vapor-recovery subsystem feasibility; lower confidence remains for integrated closed-loop deployment [4] [21] [22] [61].

5. Dynamic AI Data-Center Cooling Demand Forecasting and Control

5.1 Forecasting inputs and model families

The literature supports cooling-demand forecasting that uses **workload plans, cooling schedules, ambient temperature, IT load, and thermal dynamics** rather than static HVAC-only inputs [25] [58] [63]. It also shows that no single model family dominates across all horizons:

- **XGB** performs strongly at short horizons in one multi-step study [29];
- **attention-enhanced LSTM/encoder-decoder models** improve longer-horizon thermal/load forecasts [30] [31];
- **seq2seq and hybrid models** are favored for multi-step MIMO behavior [85] [86].

5.2 Short-horizon thermal prediction

Data-center thermal prediction results are stronger than direct “AI cooling demand” forecasting evidence. Rack inlet temperature models achieved average errors around **0.6 °C** in a steady-state GPR study, while a review found **NARX** outperforming LSTM for some normal-operation temperature predictions [87] [88]. More advanced models such as **BiTCN-Attention** reached **R^2 = 0.96** and **MAPE = 2.56%** on Marconi-100 data [89].

5.3 Workload-aware thermal control

Forecasts are increasingly tied directly to scheduling and control. Examples include:

- forecasted outlet temperature combined with thermal-aware workload scheduling and SAC-based cooling control, cutting cooling energy by up to **8.6%** [28];
- forecasted inlet temperatures used to shift workloads and smooth temperature profiles [90];
- workload-aware predictive thermal management enforcing reliability limits and hotspot-exceedance constraints [27].

This supports a practical design choice: the DT should forecast **thermal risk and cooling demand jointly**, then pass those predictions into workload and cooling supervisors [25] [27] [28].

5.4 Sparse telemetry and limited data

Sparse sensing is a real deployment issue. The literature notes reconstruction instability under sparse/noisy observations and poor extrapolation where historical coverage is thin [91] [92]. Deployment-oriented studies therefore use tree ensembles for missingness, uncertainty bounds around thermal parameters, repeated subsampling, and periodic retraining or reduced-order surrogates [32] [33] [93] [94].

Confidence level: Medium-High - Cooling forecasting/control evidence is strong, but explicit AI-specific integrated deployment evidence is still limited [25] [28] [57].

6. Security, Cyber-Resilience, and Supervisory Optimization

6.1 Secure communications and access control

The clearest secure connectivity pattern is **OPC UA with mutual certificate-based authentication and encrypted channels** [42] [43] [44]. Papers also discuss role-based versus attribute-based access control and secure telemetry across OPC UA, MQTT, and related channels [95] [96].

6.2 DT-enabled intrusion detection

DT-enabled IDS results are quantitatively strong. Reported examples include:

- **F1 96.3%**, **false positive rate below 2.5%**, and **average detection latency under 500 ms** in a water-treatment SCADA case [45];
- **97.2% accuracy** and **96.9% F1-score** for a TCN-Transformer SWaT DT IDS [97];
- explainable attack localization in hybrid DT IDS for SWaT [69].

These results support integrating DT residual monitoring into the coordination stack, especially for detecting command-channel compromise or anomalous process states [45] [54].

6.3 Edge/fog/cloud security and latency trade-offs

The common split is:

- **edge** for 1-100 ms time-critical control and preprocessing,
- **fog** for 1-10 s analytics/coordination,
- **cloud** for slower forecasting, model training, and global optimization [53] [74] [75] [98].

The trade-off is straightforward: pushing functions upward improves scale and orchestration, but increases latency. One cloud-hosted secure control case reported **851 ms RTT** over public 4G, highlighting why hard safety loops should remain local [46].

6.4 Multi-objective supervisory optimization

Supervisory optimization evidence is strong. A double-layer data-center cooling and waste-heat-recovery strategy optimized PUE globally and energy/cost locally, reducing **PUE by about 0.88%**, **energy by 9.37-11.16%**, and **operating cost by 16.26-18.26%** versus rule-based control [37]. MILP formulations also co-optimized technology dispatch, storage, district interaction, and hourly operation [72] [99].

Taken together, these findings suggest a strong implementation pattern:

- **edge**: safety interlocks, actuator loops, fallback control;
- **fog**: state estimation, anomaly detection, short-horizon MPC;
- **cloud**: day-ahead workload/cooling forecasts, scenario analysis, MILP planning [37] [53].

Confidence level: High - Security mechanisms and optimization gains are well supported separately; less evidence exists for their joint validation in one plant-scale closed loop [37] [43] [45].

7. Implementation Blueprint

A practical implementation sequence supported by the evidence would be:

1. **Asset and interface mapping**
   Create digital representations for heat sources, heat pumps, condensers/MVR units, storage, water tanks, cooling plant, and IT workload interfaces using AAS/ISO 23247-aligned models where possible [8] [9] [100].

2. **Telemetry and control integration**
   Connect SCADA/PLC assets through OPC UA/Modbus/MQTT gateways with secure authenticated sessions [42] [43] [47].

3. **Twin model stack**
   Use hybrid physics-ML models for heat balances, water recovery behavior, and thermal prediction; add online updating through Kalman/data assimilation or recursive estimation [11] [15] [16].

4. **Forecasting layer**
   Build short-horizon thermal/cooling forecasts from workload, IT load, ambient conditions, and operating schedules [25] [29] [63].

5. **Supervisory optimization**
   Use MILP for unit commitment and storage scheduling; use MPC/NMPC for receding-horizon thermal coordination under variable conditions [34] [37] [99].

6. **Cyber-resilience layer**
   Add DT-residual anomaly detection, certificate lifecycle management, encrypted telemetry, and role/attribute-aware access policies [42] [45] [95].

7. **Fallback and degraded operation**
   Keep local safe rule-based logic at the edge in case of communications loss or optimization failure, because the literature shows latency and failover are underreported risks [46] [101].

Inferred: Thermal storage and intermediate hot-water/condensate buffers likely improve resilience to forecast error, latency, and cyber disruption by decoupling fast demand swings from slower recovery assets; this is consistent with storage's role in handling temporal mismatch, but the exact claim is not directly tested for this integrated use case [102] [103].

Confidence level: Medium - The blueprint is a cross-source synthesis of directly supported subsystem patterns rather than a documented single deployment [7] [22] [25] [37] [43].

8. Main Constraints and Risks

The dominant implementation risk is the **maturity gap** between strong simulation/subsystem results and sparse integrated demonstrations [4] [22] [37] [70]. Other recurring constraints are:

- interoperability across heterogeneous assets and data models [59] [104];
- live fidelity management and drift handling [11];
- computational burden for advanced MPC/NMPC [36] [84];
- sparse telemetry and model extrapolation risk in data-center forecasting [91] [92];
- under-quantified cyber-resilience for optimization loops, especially failover and safe degraded operation [46].

Confidence level: High - These constraints are repeatedly identified across the retrieved studies [11] [46] [91] [104].

9. Conclusion

The evidence supports a clear answer: **implementation is feasible today at the subsystem level, but full integrated deployment remains immature** [1] [4]. The most defensible architecture is a secure, layered digital twin with interoperable OT/IT interfaces, hybrid state estimation, heat-pump-plus-condensation recovery assets, workload-aware cooling forecasting, and hierarchical MILP/MPC supervisory control [7] [11] [22] [25] [37] [43].

What is strongest in the literature is not proof of one turnkey solution, but proof that the necessary components already perform well individually: thermal upgrading, condensate recovery, dynamic cooling optimization, and secure DT monitoring/control [20] [23] [28] [45]. The implementation challenge is therefore mainly one of **integration, validation, and resilient operations engineering**, not basic technical impossibility [1] [2] [46].

Overall confidence: High - Strong evidence supports the subsystem technologies and the recommended architecture pattern; confidence is lower only for claims about end-to-end real-world maturity because the retrieved evidence explicitly shows that gap [1] [7] [22] [25] [37] [45].

References

1. Sayghe, Ali (2025) Digital Twin-Driven Intrusion Detection for Industrial SCADA: A Cyber-Physical Case Study. *Sensors (Basel, Switzerland)*. https://doi.org/10.3390/s25164963
2. Dbouk, H.M., Attieh, L., Dbouk, N., Ezzeddine, M. (2026) Wastewater treatment technologies and digital integration: A review of pathways toward circularity and sustainability. *Journal of Environmental Chemical Engineering*. https://doi.org/10.1016/j.jece.2026.121718
3. Truedsson, Gosta R. (2000) Industrial waste heat recovery - a case in point. *Energy Engineering: Journal of the Association of Energy Engineering*. https://www.scopus.com/pages/publications/0033882478
4. Jouhara, H., Khordehgah, N., Almahmoud, S., (...), Tassou, S.A. (2018) Waste heat recovery technologies and applications. *Thermal Science and Engineering Progress*. https://doi.org/10.1016/j.tsep.2018.04.017
5. Satpathy, P.R., Ramachandaramurthy, V.K. (2026) Digital Twins in energy and power systems: architectures, applications, enabling tools, and actionable roadmap for utility-scale implementation. *Applied Energy*. https://doi.org/10.1016/j.apenergy.2026.128129
6. Sarthak, S. (2026) Introduction to Digital Twin Technology. *Digital Twin Technology for Solar Concentrators*. https://www.scopus.com/pages/publications/105049552151
7. Steindl, G., Stagl, M., Kasper, L., (...), Hofmann, R. (2020) Generic digital twin architecture for industrial energy systems. *Applied Sciences (Switzerland)*. https://doi.org/10.3390/app10248903
8. Cavalieri, S., Gambadoro, S. (2024) Digital Twin of a Water Supply System Using the Asset Administration Shell. *Sensors*. https://doi.org/10.3390/s24051360

9. Plitsos, S., Kostaki, E., Bardaki, C., Eirinakis, P. (2025) Enabling digital twins for industrial water management. *Intelligent Decision Technologies*. https://doi.org/10.1177/18724981251352389
10. Bellavista, P. (2022) Enabling Distributed and Hybrid Digital Twins in the Industry5.0 Cloud Continuum. *Lecture Notes in Computer Science (including subseries Lecture Notes in Artificial Intelligence and Lecture Notes in Bioinformatics)*. https://doi.org/10.1007/978-3-031-12429-7_10
11. Thomas, M., Bartos, M., Sela, L. (2027) Scalable online constrained state estimation for digital twin applications in water distribution systems. *Water Research*. https://doi.org/10.1016/j.watres.2026.126996
12. Miny, T., Heppner, S., Garmaev, I., (...), Wollschlaeger, M. (2025) Semantic Comparison of Asset Administration Shells. *IEEE International Conference on Emerging Technologies and Factory Automation, ETFA*. https://doi.org/10.1109/ETFA65518.2025.11205541
13. Otto, B., Kleinert, T. (2022) A Flow Graph based Approach for controlled Generation of AAS Digital Twin Instances for the Verification of Compliance Check Tools. *IECON Proceedings (Industrial Electronics Conference)*. https://doi.org/10.1109/IECON49645.2022.9968463
14. Göllner, D., Dzienus, S., Rasor, R., (...), Dumitrescu, R. (2023) Guidelines for providing digital twins. *Procedia CIRP*. https://doi.org/10.1016/j.procir.2023.09.189
15. Shen, Y., Jia, Z., Gou, X. (2026) A self-evolving modeling framework for long-term performance tracking of thermal systems. *Applied Thermal Engineering*. https://doi.org/10.1016/j.applthermaleng.2026.131959
16. Cho, M., Kang, Y.-J., Choi, S., (...), Noh, Y. (2026) Real-time calibration of HVAC digital twins via spatio-temporal graph reinforcement learning under partial observability. *Journal of Building Engineering*. https://doi.org/10.1016/j.jobe.2026.117440
17. Bai, J., Wu, X., Chen, X., (...), Shen, B. (2025) Combined space cooling/heating and domestic hot water supply driven by data center waste heat: Complementary energy conservation, economic capacity optimization and generic analysis framework. *Building and Environment*. https://doi.org/10.1016/j.buildenv.2025.113402
18. Quenel, J., Atakan, B. (2025) An experimental investigation of secondary fluid parameters on heat pumps with higher temperature lift and zeotropic working fluid. *International Journal of Refrigeration*. https://doi.org/10.1016/j.ijrefrig.2024.11.034
19. Wang, P., Kowalski, S., Gao, Z., (...), Nawaz, K. (2024) District heating utilizing waste heat of a data center: High-temperature heat pumps☆. *Energy and Buildings*. https://doi.org/10.1016/j.enbuild.2024.114327
20. Zhou, F., Tian, X., Song, Y., Ma, G. (2025) Dynamic performance of an integrated heat pump system coupled free cooling and waste heat recovery in data centers. *Energy*. https://doi.org/10.1016/j.energy.2025.135838

21. Schlosser, F., Jesper, M., Vogelsang, J., (...), Hesselbach, J. (2020) Large-scale heat pumps: Applications, performance, economic feasibility and industrial integration. *Renewable and Sustainable Energy Reviews*. https://doi.org/10.1016/j.rser.2020.110219

22. Tuan, C.-I., Cheng, Y.-T., Yeh, Y.-L., (...), Chen, T.-C. (2013) Performance assessment of a combined vacuum evaporator - mechanical vapor re-compression technology to recover boiler blow-down wastewater and heat. *Sustainable Environment Research*. https://www.scopus.com/pages/publications/84894540714

23. Wang, Q., Xiao, X., Wang, S., Bai, Z. (2024) Simulation of a double-effect mechanical vapor recompression sewage desalination technology process. *Experimental Technology and Management*. https://doi.org/10.16791/j.cnki.sjg.2024.02.022

24. Lavirko, J., Akhmetov, E., Akhmetova, R., Bikeeva, N. (2021) Development of water saving technology for water supply system of industrial enterprises. *E3S Web of Conferences*. https://doi.org/10.1051/e3sconf/202127408004

25. Liang, Y., Peng, J., Fu, G., Srinivasan, D. (2026) Control-Aware Multi-Horizon PUE Forecasting for Coordinated Data Center Demand-Side Management and Microgrid Dispatch. *Energies*. https://doi.org/10.3390/en19163840

26. Wang, H., Jiang, X., Ebrahimi, M. (2024) Scheduled Sampling for Recursive Multi-Step GPU Temperature Forecasting. *Proceedings - 2024 International Conference on Machine Learning and Applications, ICMLA 2024*. https://doi.org/10.1109/ICMLA61862.2024.00147

27. Wang, P., Sun, J., Nawaz, K. (2026) Revolutionizing thermal Management in Next-Generation AI data centers: Challenges and breakthrough innovations. *Applied Energy*. https://doi.org/10.1016/j.apenergy.2026.128180

28. Ran, J., Zhang, Q., Zhu, Y., (...), Wang, T. (2026) Co-optimization of thermal-aware workload scheduling with deep reinforcement learning-based cooling control in data centers. *Energy*. https://doi.org/10.1016/j.energy.2026.139965

29. Yu, H., Zhong, F., Du, Y., (...), Huang, S. (2023) Short-term cooling and heating loads forecasting of building district energy system based on data-driven models. *Energy and Buildings*. https://doi.org/10.1016/j.enbuild.2023.113513

30. Zhang, G., Ding, X., He, F., (...), Qi, F. (2024) Predicting greenhouse air temperature using LSTM-AT. *Nongye Gongcheng Xuebao/Transactions of the Chinese Society of Agricultural Engineering*. https://doi.org/10.11975/j.issn.1002-6819.202404199

31. Lu, Y., Tian, Z., Zhou, R., Liu, W. (2021) Multi-step-ahead prediction of thermal load in regional energy system using deep learning method. *Energy and Buildings*. https://doi.org/10.1016/j.enbuild.2020.110658

32. Yang, J., Rivard, H., Zmeureanu, R. (2005) On-line building energy prediction using adaptive artificial neural networks. *Energy and Buildings*. https://doi.org/10.1016/j.enbuild.2005.02.005

33. Zhao, L., Li, Y., Wang, Z., (...), Wang, Z. (2026) Evaluation of a POD-ANN surrogate model for electric vehicle cabin thermal environment prediction: Accuracy, computational speed, and data efficiency. *Building and Environment*. https://doi.org/10.1016/j.buildenv.2026.115219

34. Li, D., Fan, C., Zhang, C., Chen, Y. (2022) Control strategy of load following for ocean thermal energy conversion. *Renewable Energy*. https://doi.org/10.1016/j.renene.2022.05.043

35. Usman, M., Imran, M., Lee, D.H., Park, B.-S. (2017) Experimental investigation of off-grid organic Rankine cycle control system adapting sliding pressure strategy under proportional integral with feed-forward and compensator. *Applied Thermal Engineering*. https://doi.org/10.1016/j.applthermaleng.2016.09.021

36. Vaupel, Y., Schulze, J.C., Mhamdi, A., Mitsos, A. (2021) Nonlinear model predictive control of organic Rankine cycles for automotive waste heat recovery: Is it worth the effort?. *Journal of Process Control*. https://doi.org/10.1016/j.jprocont.2021.01.003

37. Chen, S., Zhang, Q., Hu, M., (...), Guo, Z. (2026) Double-layer multi-objective optimization for combined cooling and waste heat recovery systems in data centers. *Energy Conversion and Management*. https://doi.org/10.1016/j.enconman.2026.121349

38. Markus, A.A., Bursill, J., Gunay, H.B., Dhaliwal, G. (2026) In-situ deployment of model-predictive controls with sequential model parameter estimation. *Energy and Buildings*. https://doi.org/10.1016/j.enbuild.2026.118011

39. Lu, X., Gang, W., Tu, Z. (2026) Advanced delay-aware two-stage independent control for SOFC CCHP systems against complex gas transport. *International Journal of Hydrogen Energy*. https://doi.org/10.1016/j.ijhydene.2026.157683

40. Parolini, L., Garone, E., Sinopoli, B., Krogh, B.H. (2010) A hierarchical approach to energy management in data centers. *Proceedings of the IEEE Conference on Decision and Control*. https://doi.org/10.1109/CDC.2010.5718148

41. Athavale, J., Yoda, M., Joshi, Y. (2018) Thermal Modeling of Data Centers for Control and Energy Usage Optimization. *Advances in Heat Transfer*. https://doi.org/10.1016/bs.aiht.2018.07.001

42. Rakotonirina, H.-Y., Charki, A., Espes, D., (...), Shokr, B. (2026) Addressing data confidentiality and interconnectivity in digital twins: A case study on the hot water cycle of a heat pump test bench. *Array*. https://doi.org/10.1016/j.array.2026.101175

43. Rakotonirina, H.-Y., Charki, A., Espes, D., (...), Shokr, B. (2026) Addressing data confidentiality and interconnectivity in digital twins: A case study on the hot water cycle of a heat pump test bench. *Array*. https://doi.org/10.1016/j.array.2026.101175

44. Martins, A., Lucas, J., Costelha, H., Neves, C. (2023) CNC Machines Integration in Smart Factories using OPC UA. *Journal of Industrial Information Integration*. https://doi.org/10.1016/j.jii.2023.100482

45. Sayghe, A. (2025) Digital Twin-Driven Intrusion Detection for Industrial SCADA: A Cyber-Physical Case Study. *Sensors*. https://doi.org/10.3390/s25164963

46. Rakotonirina, H.-Y., Charki, A., Espes, D., (...), Shokr, B. (2026) Addressing data confidentiality and interconnectivity in digital twins: A case study on the hot water cycle of a heat pump test bench. *Array*. https://doi.org/10.1016/j.array.2026.101175

47. Hu, E., Pan, T., Song, M., (...), Pan, Z. (2025) Design and implementation of Digital Twin PaaS platform based on Industrial Internet. *Proceedings of SPIE - The International Society for Optical Engineering*. https://doi.org/10.1117/12.3059901

48. Qingzhi, L., Bai, B., Lanqing, Q., (...), Chunxiao, Z. (2025) Development of a virtual twin model and digital twin system for thermal systems based on multi-reduced order method. *Results in Engineering*. https://doi.org/10.1016/j.rineng.2025.106695

49. Savić, D. (2022) Digital Water Developments and Lessons Learned from Automation in the Car and Aircraft Industries. *Engineering*. https://doi.org/10.1016/j.eng.2021.05.013

50. Damian, C., Yuvarajan, Y., Nagappan, B., (...), Bansal, P. (2026) Integrated biohydrogen and bioproduct generation from algal and food waste feedstocks: A techno-economic and environmental assessment. *Bioresource Technology Reports*. https://doi.org/10.1016/j.biteb.2026.102576

51. Hu, X., Shi, C., Dong, S., (...), Chen, Q. (2025) Multi-objective optimization on combined heat pump and mechanical vapor recompression system for waste heat recovery of offshore wind power converter. *Desalination*. https://doi.org/10.1016/j.desal.2025.118585

52. Li, Z., Lan, J., Zhang, H., (...), Gao, D. (2022) Thermodynamics performance analysis of flue gas treatment process using ceramic membranes. *Applied Thermal Engineering*. https://doi.org/10.1016/j.applthermaleng.2022.118431

53. https://www.sciencedirect.com/science/article/pii/S3004926126008249

54. Sayghe, A., Alahmadi, M.D., Gharawi, A.A. (2026) A digital twin and deep-learning ensemble for cyber attack detection in industrial control systems at the IoT edge. *Scientific reports*. https://doi.org/10.1038/s41598-026-53863-z

55. Nikou, N., Gill, L., Ghaani, M.R. (2026) Digital twins in wastewater treatment: A review of multiscale applications for process optimization, resource recovery, and policy compliance. *Journal of Water Process Engineering*. https://doi.org/10.1016/j.jwpe.2026.110352

56. Cupelli, L., Schütz, T., Jahangiri, P., (...), Müller, D. (2018) Data center control strategy for participation in demand response programs. *IEEE Transactions on Industrial Informatics*. https://doi.org/10.1109/TII.2018.2806889

57. Shekhar, S., Tripathi, S., Chawda, G.S., (...), Oni, B. (2026) Critical Review of Artificial Intelligence and Machine Learning Methods for Data-Center Load Forecasting. *Energies*. https://doi.org/10.3390/en19153624

58. Liu, J., Chen, Z., Li, H., Liu, D. (2024) A model predictive control for a multi-chiller system in data center considering whole system energy conservation. *Energy and Buildings*. https://doi.org/10.1016/j.enbuild.2024.114919

59. Cavalieri, S., Gambadoro, S. (2023) Enhancing Interoperability of Digital Twins Based on Digital Twins Definition Language. *International Conference on Enterprise Information Systems, ICEIS - Proceedings*. https://doi.org/10.5220/0011981000003467

60. Beden, S., Cao, Q., Beckmann, A. (2021) Semantic asset administration shells in industry 4.0: A survey. *Proceedings - 2021 4th IEEE International Conference on Industrial Cyber-Physical Systems, ICPS 2021*. https://doi.org/10.1109/ICPS49255.2021.9468266

61. He, Y., Zheng, S., Xiao, G. (2020) Solar hybrid steam-injected gas turbine system with novel heat and water recovery. *Journal of Cleaner Production*. https://doi.org/10.1016/j.jclepro.2020.124268

62. Pandelidis, D., Drąg, P., Drag, M., (...), Worek, W. (2026) Heat and mass transfer in a novel device for energy recovery. *International Communications in Heat and Mass Transfer*. https://doi.org/10.1016/j.icheatmasstransfer.2026.111807

63. Zhao, Z., Liang, C., Zhang, Y., (...), Tang, J. (2026) Short-term data center load forecasting method based on data-physics hybrid driven framework. *Energy Reports*. https://doi.org/10.1016/j.egyr.2025.108953

64. Rasheed, A., San, O., Kvamsdal, T. (2020) Digital twin: Values, challenges and enablers from a modeling perspective. *IEEE Access*. https://doi.org/10.1109/ACCESS.2020.2970143

65. Alam, K.M., El Saddik, A. (2017) C2PS: A digital twin architecture reference model for the cloud-based cyber-physical systems. *IEEE Access*. https://doi.org/10.1109/ACCESS.2017.2657006

66. Glaessgen, E.H., Stargel, D.S. (2012) The digital twin paradigm for future NASA and U.S. air force vehicles. *53rd AIAA/ASME/ASCE/AHS/ASC Structures, Structural Dynamics and Materials Conference 2012*. https://www.scopus.com/pages/publications/84881388851

67. Glaessgen, E.H., Stargel, D.S. (2012) The digital twin paradigm for future NASA and U.S. Air force vehicles. *Collection of Technical Papers - AIAA/ASME/ASCE/AHS/ASC Structures, Structural Dynamics and Materials Conference*. https://www.scopus.com/pages/publications/84881426231

68. Krishnaveni, S., Chen, T.M., Sathiyanarayanan, M., Amutha, B. (2024) CyberDefender: an integrated intelligent defense framework for digital-twin-based industrial cyber-physical systems. *Cluster Computing*. https://doi.org/10.1007/s10586-024-04320-x

69. Bozdal, M. (2023) Security through Digital Twin-Based Intrusion Detection: A SWaT Dataset Analysis. *16th International Conference on Information Security and Cryptology, ISCTURKEY 2023 - Proceedings*. https://doi.org/10.1109/ISCTrkiye61151.2023.10336137

70. Dai, B., Liu, X., Liu, S., (...), Hao, Y. (2020) Dual-pressure condensation high temperature heat pump system for waste heat recovery: Energetic and exergetic assessment. *Energy Conversion and Management*. https://doi.org/10.1016/j.enconman.2020.112997

71. Tan, Z., Feng, X., Yang, M., Wang, Y. (2022) Energy and economic performance comparison of heat pump and power cycle in low grade waste heat recovery. *Energy*. https://doi.org/10.1016/j.energy.2022.125149

72. Keskin, I., Soykan, G. (2022) Optimal cost management of the CCHP based data center with district heating and district cooling integration in the presence of different energy tariffs. *Energy Conversion and Management*. https://doi.org/10.1016/j.enconman.2022.115211

73. Hariharan, R., Subash, N. (2025) Water-Quality Digital Twins: A Review of Architectures, State-Space Assimilation, and Alerting. *Proceedings of the 9th International Conference on I-SMAC (IoT in Social, Mobile, Analytics and Cloud), I-SMAC 2025*. https://doi.org/10.1109/I-SMAC65734.2025.11597612

74. Wang, C., Liu, X., Wang, F., (...), Feng, L. (2026) Optimization of connection models in digital twin systems: Efficient merging and assembly strategy for enhanced scalability and resource optimization. *Journal of Industrial Information Integration*. https://doi.org/10.1016/j.jii.2026.101070

75. Mastoi, M.S., Wang, D., Ma, N., (...), Flah, A. (2026) AI-driven control and optimization for renewable energy integration in smart grids: Challenges, applications, and future research directions. *Energy Strategy Reviews*. https://doi.org/10.1016/j.esr.2026.102049

76. Schleich, B., Anwer, N., Mathieu, L., Wartzack, S. (2017) Shaping the digital twin for design and production engineering. *CIRP Annals - Manufacturing Technology*. https://doi.org/10.1016/j.cirp.2017.04.040

77. Arhouni, F.E., Abdo, M.A.S., Ouakkas, S., Boukhair, A. (2026) Digital twins in nuclear science and Engineering: Bridging AI, Real-Time Data, and physical systems. *Annals of Nuclear Energy*. https://doi.org/10.1016/j.anucene.2026.112469

78. Min, H., Lee, H.-S., Lee, G., (...), Park, Y.-T. (2027) Full-scale translation of methane-enhancement strategies in sewage sludge anaerobic digestion: evidence, constraints, and decision support. *Bioresource Technology*. https://doi.org/10.1016/j.biortech.2026.135917

79. Quamar, M.M., Nasir, A. (2026) Review on fault diagnosis and fault-tolerant control schemes for robotic manipulators: Recent advances in artificial intelligence and digital twin technologies. *Engineering Applications of Artificial Intelligence*. https://doi.org/10.1016/j.engappai.2026.116367

80. Fitó, J., Hodencq, S., Ramousse, J., (...), Vincent, B. (2020) Energy- and exergy-based optimal designs of a low-temperature industrial waste heat recovery system in district heating. *Energy Conversion and Management*. https://doi.org/10.1016/j.enconman.2020.112753

81. Lu, T., Lü, X., Clements-Croome, D., (...), Martinkauppi, B. (2025) Developing an active heat recovery system to boost data centre waste heat utilization: a novel and cost-effective solution for building decarbonisation. *Energy*. https://doi.org/10.1016/j.energy.2025.139324

82. Imran, M., Pili, R., Usman, M., Haglind, F. (2020) Dynamic modeling and control strategies of organic Rankine cycle systems: Methods and challenges. *Applied Energy*. https://doi.org/10.1016/j.apenergy.2020.115537

83. Wu, X., Chen, J., Xie, L. (2019) Fast economic nonlinear model predictive control strategy of Organic Rankine Cycle for waste heat recovery: Simulation-based studies. *Energy*. https://doi.org/10.1016/j.energy.2019.05.023

84. Shi, Y., Hu, X., Zhang, Z., (...), Su, H. (2023) Data-driven identification and fast model predictive control of the ORC waste heat recovery system by using Koopman operator. *Control Engineering Practice*. https://doi.org/10.1016/j.conengprac.2023.105679

85. Zhong, F., Yu, H., Xie, X., (...), Zhang, X. (2024) Short-term building cooling load prediction based on AKNN and RNN models. *Journal of Building Performance Simulation*. https://doi.org/10.1080/19401493.2024.2403027

86. Yu, D., Liu, T., Wang, K., (...), Zhao, R. (2024) Transformer based day-ahead cooling load forecasting of hub airport air-conditioning systems with thermal energy storage. *Energy and Buildings*. https://doi.org/10.1016/j.enbuild.2024.114008

87. Athavale, J., Yoda, M., Joshi, Y. (2019) Comparison of data driven modeling approaches for temperature prediction in data centers. *International Journal of Heat and Mass Transfer*. https://doi.org/10.1016/j.ijheatmasstransfer.2019.02.041

88. Patel, D., Joshi, Y. (2025) Data driven modeling advancements for air temperature predictions in data centers. *Numerical Heat Transfer, Part B: Fundamentals*. https://doi.org/10.1080/10407790.2023.2280745

89. Mao, M., Cui, D. (2025) Adaptive data-driven thermal prediction modeling for hybrid-cooled data centers using continual learning. *Journal of Building Engineering*. https://doi.org/10.1016/j.jobe.2025.114451

90. MirhoseiniNejad, S., Moazamigoodarzi, H., Badawy, G., Down, D.G. (2020) Joint data center cooling and workload management: A thermal-aware approach. *Future Generation Computer Systems*. https://doi.org/10.1016/j.future.2019.10.040

91. Su, L., Guo, Y., Mo, X., Zhang, L. (2026) Structure-aware robust data assimilation for data center temperature field reconstruction subject to sparse observations. *Applied Thermal Engineering*. https://doi.org/10.1016/j.applthermaleng.2026.132702

92. Zhang, W., Yu, Y., Yuan, Z., Gao, B. (2026) Knowledge-guided hierarchical reinforcement learning for robust operational control of chiller plants: Field deployment in a hotel building. *Energy and Buildings*. https://doi.org/10.1016/j.enbuild.2026.118153

93. Lee, J.H., Lim, M.H., Shim, J.W., (...), Kim, S. (2026) Operational strategies for patient isolation units to control aerosol transmission: a computational fluid dynamics-based multi-objective optimization approach. *Journal of Computational Design and Engineering*. https://doi.org/10.1093/jcde/qwag078

94. Shin, S., Lim, J.H., Kim, C.-G. (2024) Thermal parameter determination in underdetermined spacecraft thermal models using surrogate modeling. *Acta Astronautica*. https://doi.org/10.1016/j.actaastro.2023.10.039

95. Watson, V., Sassmannshausen, J., Waedt, K. (2019) Secure Granular Interoperability with OPC UA. *Lecture Notes in Informatics (LNI), Proceedings - Series of the Gesellschaft fur Informatik (GI)*. https://doi.org/10.18420/inf2019_ws34

96. Zhang, K., Zhou, B. (2025) A periodic coupling optimization scheduling approach for dynamic hybrid flow shop with limited waiting time. *Computers and Industrial Engineering*. https://doi.org/10.1016/j.cie.2025.111488

97. Sanjalawe, Y., Makhadmeh, S.N., Al-E'mari, S., Alzubi, E. (2026) Secure intrusion detection system for industrial control systems using digital twins. *Cluster Computing*. https://doi.org/10.1007/s10586-026-06270-y

98. Iraola, E., García-Lorenzo, M., Lordan-Gomis, F., (...), Badia, R.M. (2026) HP2C-DT: High-Precision High-Performance Computer-enabled Digital Twin. *Future Generation Computer Systems*. https://doi.org/10.1016/j.future.2025.108333

99. Koirala, B., Humbert, G., Cai, H., (...), Morotz, A. (2026) Ten questions concerning the integration of edge data centers in buildings. *Building and Environment*. https://doi.org/10.1016/j.buildenv.2026.115362

100. Cavalieri, S., Salafia, M.G. (2020) Asset Administration Shell for PLC Representation Based on IEC 61131-3. *IEEE Access*. https://doi.org/10.1109/ACCESS.2020.3013890

101. Péan, T.Q., Salom, J., Costa-Castelló, R. (2019) Review of control strategies for improving the energy flexibility provided by heat pump systems in buildings. *Journal of Process Control*. https://doi.org/10.1016/j.jprocont.2018.03.006

102. Miró, L., Gasia, J., Cabeza, L.F. (2016) Thermal energy storage (TES) for industrial waste heat (IWH) recovery: A review. *Applied Energy*. https://doi.org/10.1016/j.apenergy.2016.06.147

103. Sanaye, S., Khakpaay, N., Borzuei, D. (2026) Innovative combination of optimization and energy management strategies for integrated cooling, heating and power systems with ice thermal energy storage. *Journal of Energy Storage*. https://doi.org/10.1016/j.est.2026.122101

104. Hegde, A., Raviraj, R., Shetty, V., (...), Hegde, A. (2026) Comprehensive Review of the Architectural Metamorphosis and Techno-Economic Implications of Artificial Intelligence-Integrated Digital Twin Ecosystems. *Applied Sciences (Switzerland)*. https://doi.org/10.3390/app16147233