Mock Drill Report

1. General Information

- **Date of Drill:**
- **Time of Drill:**
- **Location/Unit:**
- **Type of Drill:**
- **Conducted By:**
- **Participants:**

2. Objective of the Drill

- **Purpose:** To evaluate the preparedness of employees during a fire emergency.
- **Specific Goals:**
  - Evacuate all personnel from the assembly line area within 3 minutes.
  - Ensure the proper use of PPE during evacuation.
  - Test the functionality of fire alarms and extinguishers.

3. Scenario Description

- **Incident Simulated:** Fire outbreak in the assembly line caused by an electrical short circuit.
- **Trigger Point:** Fire alarm activated at 10:00 AM.
- **Conditions Simulated:** Smoke machine used to simulate reduced visibility, one mock injury (minor burn).

4. Steps Followed During the Drill

Step	Time Initiated	Time Completed	Responsible Team/Person	Remarks
Alarm Activation	10:00 AM	10:00 AM	Maintenance Team	Alarm functioned properly.
Evacuation Initiated	10:00 AM	10:03 AM	Supervisors	Evacuation completed in 3 minutes.
Emergency Response Team Activated	10:01 AM	10:04 AM	Safety Team	Team reached the site promptly.
First Aid Provided	10:05 AM	10:07 AM	First Aid Officer	Mock injury treated successfully.
Area Secured	10:04 AM	10:08 AM	Safety Team	Assembly area declared safe.

5. Observations

Parameter	Observation	Compliance (Yes/No)	Remarks/Issues
Response Time	Alarm triggered promptly; evacuation completed in 3 minutes	Yes	Timely response observed.
Evacuation Time	Completed within 3 minutes	Yes	Target achieved.
Assembly Point Utilization	All personnel reached assembly point	Yes	Smooth assembly process.
Use of PPE	Some employees forgot helmets	No	Need refresher training on PPE use.
Communication Effectiveness	Clear instructions given by supervisors	Yes	Effective communication observed.
Equipment Functionality	Fire alarms and extinguishers worked properly	Yes	No issues noted.
Coordination Among Teams	Teams coordinated well during the drill	Yes	Good teamwork observed.

6. Post-Drill Feedback

- **Strengths Observed:**
  - Quick response to the alarm.
  - Effective evacuation within the target time.
  - Emergency response team acted promptly.
- **Areas for Improvement:**
  - Some employees did not wear helmets during the evacuation.
  - A few employees were unsure about the assembly point location.

7. Corrective Actions

Issue Identified	Corrective Action	Responsible Person	Target Date	Status
Improper Use of PPE	Conduct refresher training on PPE usage.	Safety Officer	January 15, 2026	Pending
Uncertainty About Assembly Point	Conduct awareness sessions about assembly point locations.	Supervisors	January 20, 2026	Pending

DEVBHOOMI TEMPLE FLOWERS REPROCCSSING PROJECT

Doc. No. DTFRPL\OWS	**Issue No**. - 01	**Revision No**. - 00	**Date** -