

Permit Punch List

55 Loring Avenue, Mill Valley CA

2021-02-08 15:46

Electrical, Plumbing, Gas - Under floor

1. _____ Additional ABS DWV (Drain, Waste; Vent) Pipe Hangars
2. _____ Strengthen some DWV Hangars
3. _____ Replace Missing Floor Insulation
4. _____ Add missing hot water pipe insulation absent.
5. _____ Add missing cable staples
6. _____ Repair Plumbing affected Structural Framing
7. _____ Seal foundation pipe entries
8. _____ DWV pressure tests

Kitchen

1. _____ Construction Photos
2. _____ Replace 2 GFCI outlets with tamper resistance

Master Bathroom, Bedroom

1. _____ Construction Photos
2. _____ Rodent proofing under sink around 2" DWV through wall
3. _____ Fireplace specifications

Main Bathroom

1. _____ Construction Photos
2. _____ Mechanical Vent required

Living Room, Bedrooms

1. _____ Construction Photos
2. _____ Fireplace specifications
3. _____ Additional Smoke, CO detectors

Mechanical, Electrical

1. _____ Subpanel inspection
2. _____ AFCI circuit breakers may be required
3. _____ Verify grounding paths

Car Port, Laundry, Seismic

1. _____ Construction Photos
2. _____ Additional water heater strapping

Site Work

1. _____ Construction Photos