

Test Certificate

Testing Date RangeFrom:10/05/2023 To:10/05/2024

*Note - Items were not function tested

Client: Bamboo Music Management Ltd	Site: 60 Colson Road	Location: GARAGE
Asset ID: 157251	Description: SPEAKER	Make: BEHRINGER
User: GIOVANNI	Test Instrument: Seaward Apollo 600 11H-0277	Model: B212
Comments:		

Test Type	Date	Result	Unit	Status
Plug	10/05/2023			Pass
Flex	10/05/2023			Pass
Enclosure	10/05/2023			Pass
Environment	10/05/2023			Pass
Socket	10/05/2023			Pass
Switch	10/05/2023			Pass
Voltage	10/05/2023	230	V	Information
Earth Continuity	10/05/2023	0.06	ohm	Pass
Insulation Voltage	10/05/2023	250	V	Information
Insulation	10/05/2023	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 157252	Description: SPEAKER	Make: BEHRINGER	Model: B212
User: GIOVANNI	Test Instrument: Seaward Apollo 600 11H-0277	Comments:	

Test Type	Date	Result	Unit	Status
Plug	10/05/2023			Pass
Flex	10/05/2023			Pass
Enclosure	10/05/2023			Pass
Environment	10/05/2023			Pass
Socket	10/05/2023			Pass
Switch	10/05/2023			Pass
Voltage	10/05/2023	230	V	Information
Earth Continuity	10/05/2023	0.08	ohm	Pass
Insulation Voltage	10/05/2023	250	V	Information
Insulation	10/05/2023	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 157253	Description: SPEAKER	Make: ELECTRO VOICE	Model: ZLX
User: GIOVANNI	Test Instrument: Seaward Apollo 600 11H-0277	Comments:	

Test Type	Date	Result	Unit	Status
Plug	10/05/2023			Pass
Flex	10/05/2023			Pass
Enclosure	10/05/2023			Pass
Environment	10/05/2023			Pass
Socket	10/05/2023			Pass
Switch	10/05/2023			Pass
Voltage	10/05/2023	230	V	Information
Earth Continuity	10/05/2023	0.01	ohm	Pass
Insulation Voltage	10/05/2023	250	V	Information
Insulation	10/05/2023	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 157254	Description: SPEAKER	Make: ELECTRO VOICE	Model: ZLX
User: GIOVANNI	Test Instrument: Seaward Apollo 600 11H-0277	Comments:	

Test Type	Date	Result	Unit	Status
Plug	10/05/2023			Pass
Flex	10/05/2023			Pass
Enclosure	10/05/2023			Pass
Environment	10/05/2023			Pass
Socket	10/05/2023			Pass
Switch	10/05/2023			Pass
Voltage	10/05/2023	230	V	Information
Earth Continuity	10/05/2023	< 0.010	ohm	Pass
Insulation Voltage	10/05/2023	250	V	Information
Insulation	10/05/2023	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 157255	Description: LIGHT	Make: ADJ	Model: STARBURST
User: GIOVANNI	Test Instrument: Seaward Apollo 600 11H-0277	Comments:	

Test Type	Date	Result	Unit	Status
Plug	10/05/2023			Pass
Flex	10/05/2023			Pass
Enclosure	10/05/2023			Pass
Environment	10/05/2023			Pass
Socket	10/05/2023			Pass
Switch	10/05/2023			Pass
Voltage	10/05/2023	230	V	Information

Signed By: 

Test Certificate

Testing Date RangeFrom:10/05/2023 To:10/05/2024

*Note - Items were not function tested

Earth Continuity	10/05/2023	0.05	ohm	Pass
Insulation Voltage	10/05/2023	250	V	Information
Insulation	10/05/2023	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 157256	Description: MIXER	Make: PRESONUS	Model: STUDIOLIVE 2442
User: GIOVANNI	Test Instrument: Seaward Apollo 600 11H-0277	Comments:	

Test Type	Date	Result	Unit	Status
Plug	10/05/2023			Pass
Flex	10/05/2023			Pass
Enclosure	10/05/2023			Pass
Environment	10/05/2023			Pass
Socket	10/05/2023			Pass
Switch	10/05/2023			Pass
Voltage	10/05/2023	230	V	Information
Earth Continuity	10/05/2023	0.05	ohm	Pass
Insulation Voltage	10/05/2023	250	V	Information
Insulation	10/05/2023	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 157257	Description: LIGHT	Make:	Model:
User: GIOVANNI	Test Instrument: Seaward Apollo 600 11H-0277	Comments:	

Test Type	Date	Result	Unit	Status
Plug	10/05/2023			Pass
Flex	10/05/2023			Pass
Enclosure	10/05/2023			Pass
Environment	10/05/2023			Pass
Socket	10/05/2023			Pass
Switch	10/05/2023			Pass
Voltage	10/05/2023	230	V	Information
Earth Continuity	10/05/2023	0.16	ohm	Pass
Insulation Voltage	10/05/2023	250	V	Information
Insulation	10/05/2023	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 157258	Description: LIGHT	Make:	Model:
User: GIOVANNI	Test Instrument: Seaward Apollo 600 11H-0277	Comments:	

Test Type	Date	Result	Unit	Status
Plug	10/05/2023			Pass
Flex	10/05/2023			Pass
Enclosure	10/05/2023			Pass
Environment	10/05/2023			Pass
Socket	10/05/2023			Pass
Switch	10/05/2023			Pass
Voltage	10/05/2023	230	V	Information
Earth Continuity	10/05/2023	< 0.010	ohm	Pass
Insulation Voltage	10/05/2023	250	V	Information
Insulation	10/05/2023	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 157259	Description: LIGHT	Make:	Model:
User: GIOVANNI	Test Instrument: Seaward Apollo 600 11H-0277	Comments:	

Test Type	Date	Result	Unit	Status
Plug	10/05/2023			Pass
Flex	10/05/2023			Pass
Enclosure	10/05/2023			Pass
Environment	10/05/2023			Pass
Socket	10/05/2023			Pass
Switch	10/05/2023			Pass
Voltage	10/05/2023	230	V	Information
Earth Continuity	10/05/2023	< 0.010	ohm	Pass
Insulation Voltage	10/05/2023	250	V	Information
Insulation	10/05/2023	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 157260	Description: LIGHT	Make:	Model:
User: GIOVANNI	Test Instrument: Seaward Apollo 600 11H-0277	Comments:	

Test Type	Date	Result	Unit	Status
Plug	10/05/2023			Pass
Flex	10/05/2023			Pass
Enclosure	10/05/2023			Pass

Signed By: 

Test Certificate

Testing Date RangeFrom:10/05/2023 To:10/05/2024

*Note - Items were not function tested

Environment	10/05/2023			Pass
Socket	10/05/2023			Pass
Switch	10/05/2023			Pass
Voltage	10/05/2023	230	V	Information
Earth Continuity	10/05/2023	< 0.010	ohm	Pass
Insulation Voltage	10/05/2023	250	V	Information
Insulation	10/05/2023	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 157261	Description: LIGHT	Make:	Model:
User: GIOVANNI	Test Instrument: Seaward Apollo 600 11H-0277	Comments:	

Test Type	Date	Result	Unit	Status
Plug	10/05/2023			Pass
Flex	10/05/2023			Pass
Enclosure	10/05/2023			Pass
Environment	10/05/2023			Pass
Socket	10/05/2023			Pass
Switch	10/05/2023			Pass
Voltage	10/05/2023	230	V	Information
Insulation Voltage	10/05/2023	250	V	Information
Insulation	10/05/2023	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 157262	Description: LIGHT	Make:	Model:
User: GIOVANNI	Test Instrument: Seaward Apollo 600 11H-0277	Comments:	

Test Type	Date	Result	Unit	Status
Plug	10/05/2023			Pass
Flex	10/05/2023			Pass
Enclosure	10/05/2023			Pass
Environment	10/05/2023			Pass
Socket	10/05/2023			Pass
Switch	10/05/2023			Pass
Voltage	10/05/2023	230	V	Information
Insulation Voltage	10/05/2023	250	V	Information
Insulation	10/05/2023	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 157263	Description: LIGHT	Make:	Model:
User: GIOVANNI	Test Instrument: Seaward Apollo 600 11H-0277	Comments:	

Test Type	Date	Result	Unit	Status
Plug	10/05/2023			Pass
Flex	10/05/2023			Pass
Enclosure	10/05/2023			Pass
Environment	10/05/2023			Pass
Socket	10/05/2023			Pass
Switch	10/05/2023			Pass
Voltage	10/05/2023	230	V	Information
Insulation Voltage	10/05/2023	250	V	Information
Insulation	10/05/2023	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 157264	Description: LIGHT	Make:	Model:
User: GIOVANNI	Test Instrument: Seaward Apollo 600 11H-0277	Comments:	

Test Type	Date	Result	Unit	Status
Plug	10/05/2023			Pass
Flex	10/05/2023			Pass
Enclosure	10/05/2023			Pass
Environment	10/05/2023			Pass
Socket	10/05/2023			Pass
Switch	10/05/2023			Pass
Voltage	10/05/2023	230	V	Information
Insulation Voltage	10/05/2023	250	V	Information
Insulation	10/05/2023	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 157265	Description: LIGHT	Make:	Model:
User: GIOVANNI	Test Instrument: Seaward Apollo 600 11H-0277	Comments:	

Test Type	Date	Result	Unit	Status
Plug	10/05/2023			Pass
Flex	10/05/2023			Pass
Enclosure	10/05/2023			Pass

Signed By: 

Test Certificate

Testing Date RangeFrom:10/05/2023 To:10/05/2024

*Note - Items were not function tested

Environment	10/05/2023			Pass
Socket	10/05/2023			Pass
Switch	10/05/2023			Pass
Voltage	10/05/2023	230	V	Information
Earth Continuity	10/05/2023	< 0.010	ohm	Pass
Insulation Voltage	10/05/2023	250	V	Information
Insulation	10/05/2023	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 157266	Description: LIGHT	Make:	Model:
User: GIOVANNI	Test Instrument: Seaward Apollo 600 11H-0277	Comments:	

Test Type	Date	Result	Unit	Status
Plug	10/05/2023			Pass
Flex	10/05/2023			Pass
Enclosure	10/05/2023			Pass
Environment	10/05/2023			Pass
Socket	10/05/2023			Pass
Switch	10/05/2023			Pass
Voltage	10/05/2023	230	V	Information
Earth Continuity	10/05/2023	< 0.010	ohm	Pass
Insulation Voltage	10/05/2023	250	V	Information
Insulation	10/05/2023	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 157267	Description: LIGHT	Make:	Model:
User: GIOVANNI	Test Instrument: Seaward Apollo 600 11H-0277	Comments:	

Test Type	Date	Result	Unit	Status
Plug	10/05/2023			Pass
Flex	10/05/2023			Pass
Enclosure	10/05/2023			Pass
Environment	10/05/2023			Pass
Socket	10/05/2023			Pass
Switch	10/05/2023			Pass
Voltage	10/05/2023	230	V	Information
Earth Continuity	10/05/2023	< 0.010	ohm	Pass
Insulation Voltage	10/05/2023	250	V	Information
Insulation	10/05/2023	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 157268	Description: LIGHT	Make:	Model:
User: GIOVANNI	Test Instrument: Seaward Apollo 600 11H-0277	Comments:	

Test Type	Date	Result	Unit	Status
Plug	10/05/2023			Pass
Flex	10/05/2023			Pass
Enclosure	10/05/2023			Pass
Environment	10/05/2023			Pass
Socket	10/05/2023			Pass
Switch	10/05/2023			Pass
Voltage	10/05/2023	230	V	Information
Earth Continuity	10/05/2023	< 0.010	ohm	Pass
Insulation Voltage	10/05/2023	250	V	Information
Insulation	10/05/2023	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 157269	Description: LIGHT	Make:	Model:
User: GIOVANNI	Test Instrument: Seaward Apollo 600 11H-0277	Comments:	

Test Type	Date	Result	Unit	Status
Plug	10/05/2023			Pass
Flex	10/05/2023			Pass
Enclosure	10/05/2023			Pass
Environment	10/05/2023			Pass
Socket	10/05/2023			Pass
Switch	10/05/2023			Pass
Voltage	10/05/2023	230	V	Information
Insulation Voltage	10/05/2023	250	V	Information
Insulation	10/05/2023	> 19.99	MOhm	Pass

Overall: Pass

Signed By: 

Test Certificate



Testing Date RangeFrom:10/05/2023 To:10/05/2024
*Note - Items were not function tested

Asset ID: 157270		Description: LIGHT		Make:		Model:	
User: GIOVANNI		Test Instrument: Seaward Apollo 600 11H-0277		Comments:			
Test Type		Date	Result	Unit	Status		
Plug		10/05/2023			Pass		
Flex		10/05/2023			Pass		
Enclosure		10/05/2023			Pass		
Environment		10/05/2023			Pass		
Socket		10/05/2023			Pass		
Switch		10/05/2023			Pass		
Voltage		10/05/2023	230	V	Information		
Insulation Voltage		10/05/2023	250	V	Information		
Insulation		10/05/2023	> 19.99	MOhm	Pass		
					Overall: Pass		
User: GIOVANNI		Test Instrument: Seaward Apollo 600 11H-0277		Comments:			
Total Tests: 20							

Signed By:

