



服务单 Service Sheet

编号 No: _____

客户 Customer: PT. hakbarindo Bahatitama 地址 Address: medan

联系人 Contact: Mr. David 电话 Phone: 0812 598 1343

服务目的 Main tasks: Genset Commissioning

基本资料/ Basic information	机组型号 Genset Model:	<u>PCP540Y</u>	编号 No:	<u>G5090218314</u>
	发动机型号 Engine Model:	<u>G5X15</u>	编号 No:	<u>80113329</u>
	发电机型号 Alternator Model:	<u>HCI544D1</u>	编号 No:	<u>A1BD144060</u>
	控制器型号 Controller Model:		运行时间 Running Time:	<u>H</u>

服务记录 Service Record:

1. Replace the Genset on site.
2. Commissioning the Genset on site. normal operation.

Load Test Record:

voltage 500V, frequency 60 HZ

Speed 1800 RPM,

Oil pressure 362 KPA

Water temperature 80 °C

Battery voltage 26.8 V

Charging voltage 26.9 V

Generator running state: ☒ Normal ☐ Anomaly

负载测试记录:

电压 _____ V 频率 _____ HZ

转速 _____ RPM, 油压 _____ KPA

水温 _____ °C

电池电压 _____ V, 功率 _____ KW 电流 _____ A

发电机组运行状态: ☐ 正常 ☐ 异常

对客户关于保养和使用的建议/Suggestions for maintenance to the customer:

1. Maintenance of the Genset every 250 hours. replacement of the Fuel Filter. oil Filter. oil. Air Filter.

服务人员签名/Service signature:



David

日期/Day: 27-12-2018

意见或建议/Comments or Suggestions:

顾客签名 (盖章) / Customer signature(Seal):

日期/Day: