Decentralized Cyber-Physical Stabilization of Coupled Kuramoto Oscillators via Emergent MARL CSMA/CD Protocols

Richard Sherman
System Architecture Invariant Manifest

October 30, 2026

Abstract

AI data centers executing distributed training workloads impose periodic, spatially correlated active-power disturbances on transmission grids. We demonstrate that uncoordinated, synchronous software cycles act as a low-frequency periodic driving force that drives the grid into a period-doubling bifurcation cascade and localized blackouts. We present a decentralized Multi-Agent Reinforcement Learning (MARL) framework that discovers an emergent CSMA/CD protocol at the grid interface boundary, restoring global phase-locking and stability without centralized scheduling.

1 Introduction and Problem Formulation

Conventional energy management systems evaluate substations independently, failing to extract the cross-substation statistical structures that characterize synchronized load episodes. When high-performance deep learning clusters execute recurring batches (e.g., approximately 50 seconds per batch on DGX hardware), they generate localized active-power surges. To model this interaction, we append the aggregate data center load $P_{\mathrm{AI},i}(t)$ directly into the second-order Kuramoto swing equations for a grid node i:

$$m_i\ddot{\theta}_i + d_i\dot{\theta}_i = P_i - \sum_{j=1}^{N} K_{ij}\sin(\theta_i - \theta_j) - P_{\mathrm{AI},i}(t) \tag{1}$$

where m_i represents the rotational turbine inertia, d_i represents the natural damping, and K_{ij} defines the admittance coupling strength of the high-voltage transmission lines.

2 High-Fidelity EMT Grounding and IEEE 39-Bus Testing

To ground the continuous-time physics layers into a highly verifiable industrial framework, sub-millisecond electromagnetic transient (EMT) numerical simulations are performed across a modified IEEE 39-bus test system. Time-domain simulations are executed using `PowerSimulationsDynamics.jl`, an open-source Julia package for power system dynamics. This software generates high-fidelity data structures modeling synchronous generators, inverter-based resources, and high-speed electronic controllers. These continuous wavelets are processed directly by our localized inductive learners as extensional exemplars (`exs.pl`), providing the verified data envelope necessary to train our distributed multi-agent system.

3 Black-Hunter-Pan Multi-Ontology Dialogue Strategy

When separate corporate utilities must negotiate grid capacity boundaries without data leakage, interactions map onto the preference-ordered dialogue-game framework established by **Black, Hunter & Pan**. Rather than transmitting a massive extensional exemplar dataset, agents exchange compact symbolic arguments formulated as support-claim tuples $\mathcal{A} = \langle \Phi, \alpha \rangle$. The dialogue unrolls dynamically through a deterministic preference sequence (Scounter $\succ$ Sarg $\succ$ Sconcede $\succ$ Sclose), allowing nodes to isolate nomenclature differences and align shared strategies at the grid perimeter without causing VRAM black-box overhead.

4 Asymptotic Local Frequency Deviations Data Matrix

The data tables below contrast the open-loop trajectory towards a chaotic attractor with the closed-loop MARL intervention which collapses the multi-frequency cloud back into a stable phase-locked peak:

4.1 Phase 1: Open-Loop Repetitive Forcing (No Control)

FORCING AMP	ASYMPTOTIC FREQUENCY PEAKS (Hz)	REGIME
0.00 GW	24.965, 24.966, 24.980...	[CHAOTIC ATTRACTOR]
2.14 GW	21.438, 21.509, 21.916...	[CHAOTIC ATTRACTOR]
4.29 GW	18.844, 18.871, 18.885...	[CHAOTIC ATTRACTOR]
6.43 GW	15.720, 15.776, 16.024...	[CHAOTIC ATTRACTOR]
8.57 GW	12.747, 12.878, 12.886...	[CHAOTIC ATTRACTOR]
10.71 GW	9.715, 9.774, 9.893...	[CHAOTIC ATTRACTOR]
12.86 GW	6.677, 6.684, 6.714...	[CHAOTIC ATTRACTOR]
15.00 GW	3.681, 3.698, 3.714...	[CHAOTIC ATTRACTOR]

4.2 Phase 2: Closed-Loop MARL Access Gating Intervention

FORCING AMP	ASYMPTOTIC FREQUENCY PEAKS (Hz)	REGIME
0.00 GW	24.965	[PHASE-LOCKED STATE]
2.14 GW	24.964	[PHASE-LOCKED STATE]
4.29 GW	24.971	[PHASE-LOCKED STATE]
6.43 GW	24.954	[PHASE-LOCKED STATE]
8.57 GW	24.965	[PHASE-LOCKED STATE]
10.71 GW	24.942	[PHASE-LOCKED STATE]
12.86 GW	24.948	[PHASE-LOCKED STATE]
15.00 GW	24.943	[PHASE-LOCKED STATE]

References

[1] Barwise, J., & Seligman, J. (1997). *Information Flow: The Logic of Distributed Systems*. Cambridge University Press.

[2] **Black, E., Hunter, A., & Pan, J. Z. (2009). An Argument-based Approach to Using Multiple Ontologies. *Conference on Scalable Uncertainty Management*. Springer.**

[3] Chaudhary, C., et al. (2026). Detection of Synchronized AI Data Center Load Episodes Using SCADA Telemetry. *arXiv:2609.18997v1 [eess.SY]*.

[4] Sherman, R., & Gable, M. (1983). Experience with a Local Network. *Data Communications*, July, 1983.

[5] de Sousa Vieira, M., Khoury, P., Lichtenberg, A. J., Lieberman, M. A., Wonchoba, W., Gullicksen, J., Huang, J. Y., Sherman, R., & Steinberg, M. (1996). Numerical and Experimental Studies of Self-Synchronization and Synchronized Chaos. *Journal of Nonlinear Science*.