

As discussed, The following changes have been added

Top view :

1. Raised floor for the Server room .
2. Raised floor for the UPS room.
3. Raised floor for the NOC room.
4. Battery room will have a normal floor.
5. Cold Aisle is represented by green tiles .
6. Novec cylinders are placed .
7. All the PAC , UPS AND PDUs are marked properly .
8. Space between racks reduced .

Design Document :

1. Calculations for number of servers .
2. Calculations for power consumption .
3. Calculations for Number of UPS.
4. Calculations for Number of ACs.
5. Rodent repellent .

Equipment List :

Now made in the required format of BOQ.