

P-102 Inspection Report — 2024

Document ID: APEL-INS-P102-2024 | Owner: Inspection & Integrity | Revision: 1.4

This dated record evaluates P-102 crude-transfer service.

Identity

Field	Value
Asset	P-102
Unit	CDU-4
Date	2024-06-18
Criticality	HIGH
WO	WO-4102

2024 measurements

The recorded measurements support later trend analysis.

Measured values

Parameter	Value	Unit
Pressure	34.0	bar
Corrosion	1.2	mm
Vibration	4.1	mm/s
Seal temperature	74	°C

2024 condition findings

The inspector records condition without extending the evidence.

Findings

- Early vibration increase; no active leakage.
- External observation does not establish internal structural condition.
- Record is linked to the work order.

2024 historical context

Baseline point.

Series

- Pressure: 34 → 37 → 42 bar.
- Corrosion: 1.2 → 2.4 → 3.8 mm.
- Vibration: 4.1 → 5.3 → 7.2 mm/s.

2024 recommendation

The recommendation states the next action supported at that date.

Disposition

- Continue routine monitoring and scheduled maintenance.
- This report is not a final fitness-for-service decision.
- Owner: Inspection & Integrity.